

BEFORE THE PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Order Instituting Rulemaking on the Commission's Own Motion to Revise General Order 58A to Comply with Decision 14-01-034.

FILED
PUBLIC UTILITIES COMMISSION
JULY 14, 2016
SAN FRANCISCO, CALIFORNIA
RULEMAKING 16-07-006

**ORDER INSTITUTING RULEMAKING ON THE COMMISSION'S
OWN MOTION TO REVISE GENERAL ORDER 58A TO
COMPLY WITH DECISION 15-01-034**

Summary

General Order (GO) 58A sets forth the Commission's rules governing gas service. It applies to all public utilities furnishing gas and operating under the jurisdiction of the Commission. This Order Instituting Rulemaking is being issued to revise GO 58A *STANDARDS FOR GAS SERVICE IN THE STATE OF CALIFORNIA* to adopt standards for constituents of concern found in biomethane as directed by Decision 14-01-034 and California Health and Safety Code Section 25421.

1. Background

California Health and Safety Code Section 25421 requires, in part, that the Commission adopt standards reasonably necessary to ensure the protection of human health and pipeline facility integrity and safety for constituents of concern that may be found in biomethane.

Decision (D.) 14-01-034 was issued to implement California Health and Safety Code Section 25421. D.14-01-034, Finding of Fact 30, states:

The vinyl chloride provision in section 7.e of General Order 58A needs to be revised in light of the repeal and replacement of former Health and Safety Code Section 25421 by AB 1900, and the adoption of a trigger level of 0.33 ppm.

D.14-01-034 concluded, in part:

After consulting with the different divisions, the Commission should draft a new rulemaking to revise General Order 58A. (Conclusion of Law 18.)

Therefore, D.14-01-034, Ordering Paragraph 15, provides:

After consulting with the Energy Division, the Gas Safety and Reliability Branch of the Safety and Enforcement Division, and the Administrative Law Judge Division, the Commission shall draft a new rulemaking to revise General Order 58A.

2. Procedure

We are issuing the proposed changes to General Order (GO) 58A based on the joint recommendations of the Commission's Safety and Enforcement Division (SED) and Energy Division (ED). This order solicits public review and comment on the proposed changes.

All gas corporations subject to the Commission's jurisdiction are made respondents to this proceeding. All respondents are directed, and any interested parties are invited, to comment on the proposed changes by August 15, 2016.

The schedule for this proceeding will depend on the input we receive from the parties.

3. Proposed Changes to GO 58A

The suggested revisions to GO 58A, attached to this order as proposed General Order 58A, Amended are set forth below.

3.1. Section 2. Definitions

3.1.1. Subsection 2.a

We propose adding a new subsection 2.a, as follows:

a. Biogas

Biogas is created when organic waste decomposes anaerobically (without oxygen). Biogas may be obtained from landfills, dairies, sewage treatment plants, and other organic sources.

3.1.2. Subsection 2.b

We propose adding a new subsection 2.b, as follows:

b. Biomethane

Biomethane is interchangeable with natural gas and is produced by processing or upgrading biogas to increase the percentage of methane in the gas by removing carbon dioxide and other trace components to meet the standards for injection into a common carrier pipeline. Biomethane does not include biogas collected from a hazardous waste landfill, as defined in Health and Safety Code Section 25117.1.

3.1.3. Subsections 2.a-k

We propose re-lettering existing subsections 2.a-k, as follows:

- c. British Thermal Unit (Btu)
- d. Commission
- e. Customer
- f. Gas (Fuel Gas)
- g. LPG (Liquefied Petroleum Gas)
- h. Pressure Recording Device
- i. Standard Pressure
- j. Standard Cubic Foot of Gas
- k. Standard Temperature
- l. Heating Value
- m. Utility

3.1.4. Subsection 2.d

We propose amending subsection 2.f (former subsection 2.d) as follows:

f. Gas (Fuel Gas)

Gas or Fuel Gas, as used in these rules, shall mean any combustible gas or vapor, or combustible mixture of gaseous constituents, used to produce heat by burning. It shall include, but shall not be limited to, natural gas, gas manufactured from coal or oil, ~~gas obtained from biomass or from a land fill,~~ biomethane, or a mixture of any or all of the above.

3.2. Section 7. Purity of Gas

The proposed changes in this section revise GO 58A to reference current measurements, to conform biomethane concentration standards for constituents of concern to standards adopted by D.14-01-034, and to eliminate references to former California Health and Safety Code Section 25421 (repealed by Assembly Bill 1900 enacted into law by Chapter 602 of the Statutes of 2012).

We propose amending Section 7, as follows (amendments underlined):

7. Purity of Gas

a. Hydrogen Sulfide

No gas supplied by any gas utility for domestic, commercial or industrial purposes in this state shall contain more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet (4 parts per million of hydrogen sulfide).

b. Total Sulfur

No gas supplied by any gas utility for domestic, commercial or industrial purposes shall contain more than five (5) grains of total sulfur per one hundred (100) standard cubic feet (80 parts per million of total sulfur).

- c. Test procedures used to determine the amounts of hydrogen sulfide and total sulfur shall be in accordance with accepted gas industry standards and practices.
- d. When hydrogen sulfide, or total sulfur, exceeds the limits set forth in Section 7.a and Section 7.b, the gas utility shall notify the Commission and commence remedial action immediately. The Commission shall be notified when the level of hydrogen sulfide, or total sulfur, has been reduced to allowable limits.
- e. [former section “e- Vinyl Chloride” deleted.]
Operators shall monitor, as set forth by this Section 7 and the following table, the levels of the constituents of concern above the trigger levels to verify that the total potential cancer and non-cancer risks for the constituents of concern continue to stay within the trigger level and the lower and upper action levels. To the extent this section or existing gas quality requirements of the utility’s tariff specify stricter concentrations for a constituent of concern the stricter concentration limit will apply.

Constituent of Concern ¹	Trigger Level mg/m ³ (ppmv)	Lower Action Level mg/m ³ (ppmv)	Upper Action Level mg/m ³ (ppmv)
Arsenic	0.019 (0.006)	0.19 (0.06)	0.48 (0.15)
p-Dichlorobenzene	5.7 (0.95)	57 (9.5)	140 (24)
Ethylbenzene	26 (6.0)	260 (60)	650 (150)
n-Nitroso-di-n-propylamine	0.033 (0.006)	0.33 (0.06)	0.81 (0.15)
Vinyl Chloride	0.84 (0.33)	8.4 (3.3)	21 (8.3)
Antimony	0.60 (0.12)	6.0 (1.2)	30 (6.1)
Copper	0.060 (0.02)	0.60 (0.23)	3.0 (1.2)
Hydrogen Sulfide	30 (22)	300 (216)	1,500 (1,080)

¹ The constituents listed from “arsenic” to “vinyl chloride” are carcinogenic constituents of concern. The constituents listed from “antimony” to “toluene” are non-carcinogenic constituents of concern.

Lead	0.075 (0.009)	0.75 (0.09)	3.8 (0.44)
Methacrolein	1.1 (0.37)	11 (3.7)	53 (18)
Alkyl Thiols (Mercaptans)	n/a (12)	n/a (120)	n/a (610)
Toluene	904 (240)	9,000 (2,400)	45,000 (12,000)
Ammonia	0.001%	--	--
Biologicals	4x10 ⁴ /scf (qPCR per group) and free of <0.2 micron filter	--	--
Hydrogen	0.1%	--	--
Mercury	0.08 mg/m ³	--	--
Siloxanes	0.01 mg Si/m ³	0.1 mg Si/m ³	--

The action levels set by the foregoing table act as a warning or alarm. The lower action level is used to screen gas suppliers during the initial gas quality review and as an ongoing screening level during the periodic testing. The upper action level results in an immediate shutoff, and the gas supplier is denied access to the utilities' pipeline systems until the supplier can demonstrate compliance with the gas quality and constituent requirements.

- f. Pacific Gas and Electric Company, San Diego Gas & Electric Company, Southern California Gas Company, and Southwest Gas Corporation, either individually or collectively, shall file an application every five years, or earlier if new information becomes available, or as directed by the Commission in the future, commencing no later than January 22, 2019, for the Commission to review and update the standards for the protection of human health and pipeline integrity and safety, including considering proposals to amend the list of constituents of concern and concentration limits found in biomethane.
- g. If the Office of Environmental Health Hazard Assessment (OEHHA) or the California Air Resources Board (CARB)

believes that an update proceeding should occur before the five-year period, OEHHA or the CARB may notify the Commission's Executive Director and the Energy Division Director that an update proceeding should be conducted.

4. No Further Amendments Will Be Considered

This rulemaking is limited to conforming GO 58A to the requirements of D.14-01-034 by amendments to Section 2 and Section 7, only, of GO 58A. A broader scope is not considered at this time due to the burden on Commission staff and reallocation of Commission resources.

5. Preliminary Scoping Memo

5.1. Category

Rule 7.1(d) of the Commission's Rules of Practice and Procedure requires that an Order Instituting Rulemaking preliminarily determine the category and need for hearing, and contain a preliminary scoping memo. This OIR is preliminarily categorized as a quasi-legislative proceeding, as that term is defined in Rule 1.3(d).

5.2. Scope and Issues

The scope of this proceeding is to amend Section 2 and Section 7, only, of GO 58A to conform to the requirements of D.14-01-034 and to address any safety issues which may be identified due to these amendments. Therefore, the proposed issues for this proceeding are:

- a) Do the proposed amendments to section 2 and section 7 of General Order 58A conform to the requirements of Decision 14-01-034?
- b) Are there any additional amendments which should be made to conform General Order 58A to the requirements of D.14-01-034 at this time, and if so, why?
- c) Are there any safety issues implicated by the proposed amendments to General Order 58A?

5.3. Hearings

At this time, we do not anticipate holding formal hearings. Any party that believes a hearing is required to receive testimony regarding adjudicative facts must make an explicit request in its filed comments. The request must (1) identify the material disputed facts, (2) explain why a hearing must be held, and (3) describe the general nature of the evidence that would be introduced at a hearing.

5.4. Workshops

The timetable for this proceeding will depend on the input received from the parties. Based on our review of written comments, if any, ED or the Gas Safety and Reliability Branch of SED may schedule a workshop to further discuss issues. If there are any workshops in this proceeding, formal notice will be issued by the assigned Administrative Law Judge (ALJ) and notices of such workshops will be posted on the Commission's Daily Calendar to inform the public that a decisionmaker or an advisor may be present at those meetings or workshops. Parties shall check the Daily Calendar regularly for such notices.

5.5. Final Decision

We anticipate issuing a final decision in this proceeding within one year of issuing this OIR. It is the Commission's intent to complete this proceeding within 18 months of the date this Scoping Memo is filed. (Public Utilities Code Section 1701.5(a).)

5.6. Schedule

The following schedule is subject to change by the assigned Commissioner or the assigned ALJ after review of the comments received.²

Day	Action
0	Order Instituting Rulemaking
30	Comments on Proposed GO 58A, Amended attached at Appendix A
60	Final Scoping Memo Issued
TBD if required by Final Scoping Memo	Workshop, Workshop Report, and Comments
TBD	Proposed Decision mailed for comment
TBD	Final Commission Decision issued

6. Service of OIR, Filing Requirements, and Service List

The rules developed in this proceeding will affect all gas utilities regulated by the Commission. The subject matter and issues are also of interest to ratepayers. We will therefore name as Respondents Pacific Gas and Electric Company, San Diego Gas & Electric Company, Southern California Gas Company, and Southwest Gas Corporation and serve this rulemaking and its attachment on all gas utilities regulated by the Commission - including the named Respondents, all gas storage facilities regulated by the Commission, all

² Any changes to the schedule will be by written ruling. Pursuant to Rule 7.3(b), the assigned Commissioner has the discretion not to issue a scoping memo if no timely request for hearing is filed.

persons and entities on the official service lists for Rulemaking (R.) 11-02-019 and R.13-02-008, and the Office of Ratepayer Advocates.³

Service of this OIR does not confer party status or place a person who has received service of this OIR on the Official Service List for this proceeding, except for the named respondents.

Persons who file responsive comments will become parties to the proceeding (*See* Rule 1.4(a)(2)) and will be added to the “Parties” category of the official service list upon comments. While we will serve this order on all gas utilities and storage facilities regulated by the Commission and the service lists for R.11-02-019 and R.13-02-008, service of this order does not confer party status or placement on the Official Service List for this rulemaking unless they are named as Respondents by this rulemaking or they respond to this order or otherwise become parties pursuant to Rule 1.4.

In order to assure service of comments and other documents and correspondence in advance of obtaining party status, persons should promptly request addition to the “Information Only” category as described below. They will be removed from the “Information Only” category upon obtaining party status.

Article 1 of the Commission’s Rules of Practice and Procedure contains the Commission’s filing requirements. Parties are encouraged to file electronically whenever possible as it speeds processing of the filings and allows them to be posted on the Commission’s website. More information about electronic filing is available at the Commission’s website, www.cpuc.ca.gov.

³ The names and addresses of all Commission-regulated gas utilities are maintained by the Energy Division.

We will follow the electronic service protocols adopted by the Commission in Rule 1.10 for all documents. This rule provides for electronic service of documents, in a searchable format, unless the party did not provide an e-mail address. If no e-mail address is provided, service should be made by first-class mail. Parties are expected to provide paper copies of served documents upon request. Paper format copies, in addition to electronic copies, shall be served on the assigned Commissioner and the assigned ALJ.

The official service list for this proceeding is available on the Commission's web page. Parties should confirm that their information on the service list is correct, and serve notice of any errors on the Commission's Process office, the service list, and the assigned ALJ. Prior to serving any document, each party must ensure that it is using the most up-to-date service list. The list on the Commission's website meets this definition.

Non-parties who wish to receive electronic service of documents in this rulemaking may request to be added to the Official Service List by completing the Request for Addition or Change to Service List (http://www.cpuc.ca.gov/forms/service_list_addition_change.pdf.) and providing it to the Commission's Process Office (process_office@cpuc.ca.gov).

7. Subscription Service

Persons may monitor the proceeding by subscribing to receive electronic copies of documents in this proceeding that are published on the Commission's website. There is no need to be on the official service list in order to use the subscription service. Instructions for enrolling in the subscription service are available on the Commission's website at <http://subscribecpuc.cpuc.ca.gov/>.

8. Ex Parte Communications

Communications with decisionmakers and advisors in this rulemaking are governed by Article 8 of the Rules of Practice and Procedure. (Rule 8.1, *et seq.*) *Ex parte* communications are allowed without restriction or reporting requirement in a quasi-legislative proceeding. (Rule 8.3(a).) No *ex parte* restrictions or reporting requirements apply in this proceeding.

9. Public Advisor

Any person or entity interested in participating in this rulemaking who is unfamiliar with the Commission's procedures should contact the Commission's Public Advisor's Office in San Francisco by telephone at (415) 703-2074 or (866) 849-8390, or by e-mail at public.advisor@cpuc.ca.gov. The TTY number is (866) 836-7825. Written communication may be sent to Public Advisor, California Public Utilities Commission, 505 Van Ness Avenue, San Francisco, CA, 94102.

10. Intervenor Compensation

Any party that expects to claim intervenor compensation for its participation in this Rulemaking must file its notice of intent to claim intervenor compensation within 30 days of the filing of reply comments, except that notice may be filed within 30 days of a prehearing conference in the event that one is held. (*See* Rule 17.1(a)(2).)

O R D E R

IT IS ORDERED that:

1. A Rulemaking on the Commission's own motion is instituted to solicit comments and recommendations on proposed revisions to the Commission's General Order 58A to comply with Decision 14-01-034.

2. This rulemaking is preliminarily determined to be a quasi-legislative proceeding as that term is defined in the Commission's Rules of Practice and Procedure, Rule 1.3(d).

3. This proceeding is preliminarily determined not to need a formal hearing.

4. The scope of issues and expected timetable for this proceeding are set forth in the body of this order in Section 5.

5. Proposed changes to General Order 58A are set forth in the body of this order in Section 3 and contained within General Order 58A, Amended appended to this decision as Attachment 1.

6. The Executive Director shall serve this Order Instituting Rulemaking on all Commission-regulated gas utilities and gas storage facilities, the service lists for Rulemaking (R.) 11-02-019, R.13-02-008, and the Office of Ratepayer Advocates. Service of this order does not confer party status or placement on the Official Service List for this rulemaking unless named as Respondents by this rulemaking or a response to this order is filed or one otherwise become a party pursuant to Rule 1.4.

7. Pacific Gas and Electric Company, San Diego Gas & Electric Company, Southern California Gas Company, and Southwest Gas Corporation shall be Respondents to this proceeding and therefore Parties. All Respondents are directed, and all other interested parties are invited, to comment on the proposed changes to General Order 58A by August 15, 2016. We urge the Office of Ratepayers Advocates to file and serve comments and to participate fully in this proceeding, in order to ensure that ratepayers are represented. In addition to the named Respondents, persons who file responsive comments will become parties to the proceeding and will be added to the "Parties" category of the official service list.

8. Any person may file opening comments on the proposed revised general order by August 15, 2016, and reply comments by August 30, 2016. Pursuant to Rule 6.2, parties shall include with their comments any objections to the preliminary scoping memo regarding the category, need for hearing, issues to be considered, or schedule.

9. The preliminary service list to this proceeding is appended as Attachment 2 and the rules applicable to filing, service, and the service list are set forth in the body of this order. In order to receive service of comments, persons other than respondents should request addition to the Official Service List as "Information Only" or "State Service." Any person interested in participating in this proceeding who is unfamiliar with the Commission's procedures or who has questions about the electronic filing procedures should contact the Commission's Public Advisor at (866) 849-8390.

10. Any party that expects to claim intervenor compensation for its participation in this Rulemaking must file its notice of intent to claim intervenor compensation within 30 days of the filing of reply comments, except that notice may be filed within 30 days of a prehearing conference in the event that one is held. (*See* Rule 17.1(a)(2).)

11. The dates and tentative schedule specified herein may be modified by the assigned Commissioner or the assigned Administrative Law Judge.

This order is effective today.

Dated July 14, 2016, at San Francisco, California.

MICHAEL PICKER
President
MICHEL PETER FLORIO
CATHERINE J.K. SANDOVAL
CARLA J. PETERMAN
LIANE M. RANDOLPH
Commissioners

ATTACHMENT 1

STATE OF CALIFORNIA

**STANDARDS FOR GAS SERVICE
IN THE STATE OF CALIFORNIA**



Prescribed by the
PUBLIC UTILITIES COMMISSION

OF THE

STATE OF CALIFORNIA

GENERAL ORDER No. 58A

Month xx, 2016

GENERAL ORDER 58-A
PUBLIC UTILITIES COMMISSION OF THE
STATE OF CALIFORNIA
STANDARDS FOR GAS SERVICE IN THE STATE OF
CALIFORNIA

(37 C.R.C. 589)
(Original Order Approved August 1, 1919
Effective September 1, 1919) (Revised
Order Approved March 1, 1923
Effective April 1, 1923)
(Revised Order Approved May 31, 1932
Effective July 1, 1932) (Decision No.
24827, Case No. 3181) [Revised April 12,
1989 Effective April 12, 1989] [Resolution G-
2870]
Revised December 16, 1992, Effective December 16, 1992
Decision No. 92-12-062
Revised Month xx, 2016, Effective Month xx, 2016
Decision No. xx-yy-zzzz

Formatted: Font: (Default) Arial, 7 pt

Formatted: Font: (Default) Arial, 7 pt

|

TABLE OF CONTENTS

<i>Title</i>	<i>Page No.</i>
1. Application of Rules	1
2. Definitions	1
3. System Maps and Records	2
4. Station and Other Records	2
5. Testing Equipment and Facilities	3
6. Heating Value of Fuel Gas	4
7. Purity of Gas	5
8. Standard Gas Delivery Pressure	6
9. Pressure Testing Equipment and Tests	6
10. Meters and Regulators	7
11. Service and Meter Installations	8
12. Gas Meter Accuracy	8
13. Periodic and Other Required Tests of Gas Meters	8
14. Standard Methods of Testing Gas Meters	9
15. Meter Testing Equipment	9
16. Records of Meters and Meter Tests	10
17. Meter Testing at Request of A Customer	10
18. Calculation of Gas Volumes	11
19. Meter Reading and Bill Forms	11
20. Information for Customers	12
21. Customers' Deposits	12
22. Maintenance and Operation of Facilities	12
23. Complaints	13
24. Reports to the Commission	13
25. General Provisions	13
26. Modification of Rules	13

1. Application of Rules

The following rules shall apply to any person, firm or corporation now or hereafter engaged as a public utility in the business of furnishing gas (fuel gas) for domestic, commercial, industrial or other purposes within the State of California where gas service is subject to the jurisdiction of the Public Utilities Commission of the State of California. In no case shall any public utility deviate from these rules except with specific written authorization from the Commission.

2. Definitions

~~e.~~

a. Biogas

Biogas is created when organic waste decomposes anaerobically (without oxygen). Biogas may be obtained from landfills, dairies, sewage treatment plants, and other organic sources.

b. Biomethane

Biomethane is interchangeable with natural gas and is produced by processing or upgrading biogas to increase the percentage of methane in the gas by removing carbon dioxide and other trace components to meet the standards for injection into a common carrier pipeline. Biomethane does not include biogas collected from a hazardous waste landfill, as defined in Health & Safety Code § 25117.1.

c. British Thermal Unit (Btu)

The quantity of heat that must be added to one avoirdupois pound of pure water to raise its temperature from 58.5°F. to 59.5°F. under standard pressure.

d. ~~b.~~ Commission

The word "Commission" as used in these rules shall mean the Public Utilities Commission of the State of California.

e. ~~e.~~ Customer

The word "customer" as used in these rules shall mean any person, group of persons, firm, corporation, institution, municipality, or other civic body supplied directly with gas by any gas utility, or which may be entitled or permitted to use for compensation any of the facilities of any gas utility.

f. ~~d.~~ Gas (Fuel Gas)

Gas or Fuel Gas, as used in these rules, shall mean any combustible gas or vapor, or combustible mixture of gaseous constituents, used to produce heat by burning. It shall include, but shall not be limited to, natural gas, gas manufactured from coal or oil, ~~gas obtained from biomass or from a landfill, biomethane,~~ or a mixture of any or all of the above.

g. ~~e.~~ LPG (Liquefied Petroleum Gas)

A gas containing certain specific hydrocarbons which are gaseous under ambient atmospheric conditions, but can be liquefied under moderate pressure at normal temperatures. Propane and butane are the principal examples.

h. ~~f.~~ Pressure Recording Device

Formatted: Indent: Left: 0.91"

Formatted: Indent: Left: 1.11", Right: 0.93"

Formatted: Indent: Left: 0.91"

Formatted: Indent: Left: 1.11", Right: 0.93"

Formatted: Left, Indent: Left: 0.91", Right: 2.62", Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 0.7" + Indent at: 0.95", Tab stops: 3.5", Left

Formatted: Left, Indent: Left: 0.91", Right: 2.62", Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 0.7" + Indent at: 0.95", Tab stops: 3.5", Left

Formatted: Font: (Default) Bookman Old Style, 9 pt

Formatted: Justified, Indent: Left: 1.11", First line: 0", Right: 0.93"

Formatted: Font: (Default) Bookman Old Style, 9 pt

Formatted: Left, Indent: Left: 0.91", Right: 2.62", Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 0.7" + Indent at: 0.95", Tab stops: 3.5", Left

Formatted: Not Expanded by / Condensed by

Formatted: Left, Indent: Left: 0.91", Right: 2.62", Space Before: 0 pt, Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 0.7" + Indent at: 0.95", Tab stops: 3.5", Left

Formatted: Left, Indent: Left: 0.91", Right: 2.62", Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 0.7" + Indent at: 0.95", Tab stops: 3.5", Left


As used in these rules, pressure recording device shall mean a mechanical or electronic device that automatically records gas pressure on an analog chart, or an electronic device which provides a printed log of the pressure or records it on storage media.

i. ~~g.~~ Standard Pressure

A pressure of 14.73 psia.

j. ~~h.~~ Standard Cubic Foot of Gas

The amount of gas that occupies one cubic foot at standard temperature under standard pressure and saturated with water vapor, or free of water vapor (dry) as specified.



Formatted: Left, Indent: Left: 0.91", Right: 2.62", Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 0.7" + Indent at: 0.95", Tab stops: 3.5", Left

Formatted: Left, Indent: Left: 0.91", Right: 2.62", Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 0.7" + Indent at: 0.95", Tab stops: 3.5", Left

~~k.~~ ~~i.~~ Standard Temperature
60°F., based on the international temperature scale.

~~l.~~ ~~j.~~ Heating Value
The term "heating value" as used in these rules shall mean the total heating value of the gas measured on a dry basis, which is defined as the number of British thermal units evolved by the complete combustion, at constant pressure, of one standard cubic foot of gas with air, the temperature of the gas, air and products of combustion being 60°F. and all of the water formed by the combustion reaction being condensed to the liquid state.

~~m.~~ ~~k.~~ Utility
The word "utility" and the term "gas utility" as used in these rules shall mean any person, firm or corporation engaged as a public utility in producing, transmitting, distributing or furnishing fuel gas for domestic, commercial, industrial or other purposes.

3. System Maps and Records

- a. Each gas utility shall keep on file with the Commission up-to-date maps of the general territory, which it holds itself in readiness to serve, outlining operating districts and showing major transmission lines.
- b. A suitable map or maps shall be kept on file in the principal office of each division or district. Maps shall at all times show the size, character and location of each street main, district regulator, operating valve and drip, and when practicable, each service connection in the corresponding territory served. In lieu of showing service locations on maps, a card record, a computerized system, or other suitable means may be used.
- c. In each division or district office there shall be available such information relative to the distribution system which will enable the local representatives at all times, to furnish necessary information regarding the rendering of service to existing and prospective customers.
- d. Each major gas control station and each compressor and holder station shall have available an accurate ground plan drawn to a suitable scale, showing the entire layout of the plant or station, the location, size and character of plant equipment, major pipelines, connections, valves and other facilities used for the control and delivery of gas, all properly identified.

4. Station and Other Records

- a. Each gas utility shall keep and preserve, for a period of at least three years, transmission line pressures from each compressor station and receiving station.
- b. Each gas utility shall keep and preserve for a period of three years, an accurate record of the operation of each compressor station, as follows:

Formatted: Indent: Left: 0.91", Right: 2.62", Line spacing: single, Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 0.7" + Indent at: 0.95", Tab stops: 3.5", Left

Formatted: Indent: Left: 0.91", Right: 2.62", Line spacing: single, Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 0.7" + Indent at: 0.95", Tab stops: 3.5", Left

Formatted: Indent: Left: 0.91", Right: 2.62", Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 0.7" + Indent at: 0.95", Tab stops: 3.5", Left + Not at 2.91"

1. The amount of fuel gas used each month for compression purposes.
2. The amount of electricity or any other energy used each month for compression purposes.
- c. Each gas utility serving liquefied petroleum gas, or a liquefied petroleum gas—air mix, shall keep and preserve, for a period of at least three (3) years, an accurate record of the operation of each vaporizing plant, as follows:
 1. The quantity of liquefied petroleum gas vaporized each month, recorded in Mcf.
 2. The quantity of liquefied petroleum gas, or liquefied petroleum gas—air mix, sent out each month, recorded in Mcf.
 3. The amount of liquefied petroleum gas used each month, recorded in gallons.
 4. The amount of fuel used each month for plant operations, in Mcf.
 5. The amount of electricity used each month.
 6. The heating value per gallon of each new supply of liquefied petroleum gas received.
- d. Each gas utility serving fuel gas shall keep and preserve for a period of at least three years an accurate record of the volume of gas handled in Mcf as follows:

System

 - (1) Receipts (Daily)

Total volume of fuel gas purchased or received from major producers and at major supply points:

 - a. From producers (charts or flow computer readouts).
 - b. From transporting companies or utilities.
 - c. From owned supplies or sources.
 - d. From underground storage.
 - e. Holder variations.
 - (2) Disbursements (Monthly)

Total Volume of gas sent to:

 - a. Resale sales.
 - b. Storage.
 - c. Domestic and commercial use.
 - d. Industrial use.
 - e. Company use.
 - f. Transport for others.
 - g. Losses and unaccounted for.

5. Testing Equipment and Facilities

- a. Each gas utility shall provide, or make arrangements for, meter testing equipment and facilities and other testing equipment and facilities as needed to perform the tests required by these rules or other orders of the Commission. The apparatus and equipment used shall be state-of-the-art, meeting industry standards, and shall be available at all times for inspection by any

-5-

authorized representative of the Commission. The equipment shall be of a type and form approved by the Commission.

- b. Each gas utility shall make such tests as are prescribed under these rules with such frequency and in such manner, and at such places as herein provided, or as may be approved or ordered by the Commission.
- c. Each gas utility shall file with the Commission a detailed statement showing the location of each meter testing shop and testing station owned, controlled or operated by the utility, and used to make the tests required by these rules, together with a full and complete description of each major testing or standardizing instrument or apparatus maintained therein. Any major change or addition to these facilities, or abandonment of facilities, shall be reported to the Commission within 10 days after the change has become effective.
- d. Where gas utilities do not maintain their own testing and meter repair facilities, they shall provide the Commission with a statement indicating the location and organization by whom such testing and meter repair work is performed. The proof settings and tolerances of new and repaired meters shall also be stated.

6. Heating Value of Fuel Gas

- a. Each gas utility supplying fuel gas for domestic, commercial or industrial purposes shall develop and maintain a plan establishing the heating value of the gas being supplied. This plan shall provide for the following requirements:
 - 1. Establish distinct distribution system areas in which a uniform quality of gas will be supplied.
 - 2. Identify a heating value range for each such area. Provide for verification of the average heating value of the gas supplied to each area, at intervals frequent enough to assure that the heating value is being maintained within the heating value range established for the area, and to assure adequate accuracy for customer billing.
 - 3. Provide for establishing, and maintaining for three years, records of the heating value of the gas provided in each area.
- b. Each gas utility shall establish and maintain, as outlined in General Order 58-B, Heating Value Measurement Standard For Gaseous Fuels, heating value measurement stations, and shall develop and implement the procedures necessary to determine the heating value of the fuel gas being supplied in each area, to meet the requirements of Section 6.a. If heating value determination of the same gas is satisfactorily made by another utility, supplier or qualified laboratory, it may be used for the purpose of the above record upon written approval of the Commission.

Such utility, supplier, or qualified laboratory shall use a heating value measurement device of a type that has been approved by the Commission.

- c. Each gas utility supplying a liquefied petroleum gas—air mix, shall establish and maintain, with the approval of the Commission, a standard heating value for its product. The maximum daily variation shall not exceed twenty-five (25) Btu per standard cubic foot above or below the standard heating value.
- d. Each gas utility supplying fuel gas, including liquefied petroleum gas and a liquefied petroleum gas—air mix, shall file with the Commission as a part of its schedule of rates, rules and regulations, the average total heating value of such gas together with the maximum fluctuation above and below the average total heating value which may be expected.
- e. The monthly average total heating value at any given test station shall be the average of all total heating value tests made during each month.
- f. As an alternative to establishing a heating value measurement station, samples may be taken near the center of a distribution system area. Where this is done, at least one determination per week shall be made of the total heating value of gas delivered to customers in distribution system areas identified as in Section 6.a.1. which have annual sales in excess of one hundred million (100,000,000) cubic feet of gas. Where a number of distribution system areas are so interconnected as to be certain of receiving gas from the same source, there may be established a testing or sampling station at a location where the gas tested will be representative of that served in all such distribution system areas.

7. Purity of Gas

a. Hydrogen Sulfide

No gas supplied by any gas utility for domestic, commercial or industrial purposes in this state shall contain more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet 4 parts per million of hydrogen sulfide.

b. Total Sulfur

No gas supplied by any gas utility for domestic, commercial or industrial purposes shall contain more than five (5) grains of total sulfur per one hundred (100) standard cubic feet 80 parts per million of total sulfur.

c. Test procedures used to determine the amounts of hydrogen sulfide and total sulfur shall be in accordance with accepted gas industry standards and practices.

d. When hydrogen sulfide, or total sulfur, exceeds the limits set forth in Section 7.a. and Section 7.b., the gas utility shall notify the Commission and commence remedial action immediately. The Commission shall be notified when the level of hydrogen sulfide, or total sulfur, has been reduced to allowable limits.

~~e. Vinyl Chloride~~

~~No regulated gas utility shall knowingly purchase landfill gas if that landfill gas, when supplied to any existing gas customer, contains vinyl chloride in a concentration greater than 1,170 parts~~

~~per billion by volume. This value is adopted as instructed by Section 25421(b) of the California Health and Safety Code as the maximum amount of vinyl chloride that may be found in landfill gas supplied to a gas utility customer pursuant to Section 25421(a). Testing for vinyl chloride shall be performed as specified by Section 25421(d) of the Health and Safety Code. When vinyl chloride exceeds the limits set forth herein, the gas utility shall notify the Commission and commence remedial action immediately. The gas utility shall notify the Commission when the level of vinyl chloride is reduced to allowable limits. Direct delivery for industrial use of landfill gas is exempted from these requirements as provided by Section 25421(e). A gas utility desiring to purchase landfill gas with a vinyl chloride content that exceeds the Commission adopted standard shall file an application with the commission. The application shall demonstrate that dilution of landfill gas exceeding the Commission's standard with other natural gas in the utility's system shall not result in any customer receiving gas with a vinyl chloride concentration level exceeding the Commission's standard.~~

e. Operators shall monitor, as set forth by this Section 7 and the following table, the levels of the constituents of concern above the trigger levels to verify that the total potential cancer and non-cancer risks for the constituents of concern continue to stay within the trigger level and the lower and upper action levels. To the extent this section or existing gas quality requirements of the utility's tariff specify stricter concentrations for a constituent of concern the stricter concentration limit will apply.

Formatted: Font: Bookman Old Style, 9 pt
Formatted: Justified, Indent: Left: 0.89", Hanging: 0.17", Right: 1.03", Space Before: 0 pt

<u>Constituent of Concern¹</u>	<u>Trigger Level mg/m³ (ppmv)</u>	<u>Lower Action Level mg/m³ (ppmv)</u>	<u>Upper Action Level mg/m³ (ppmv)</u>
<u>Arsenic</u>	<u>0.019 (0.006)</u>	<u>0.19 (0.06)</u>	<u>0.48 (0.15)</u>
<u>p-Dichlorobenzene</u>	<u>5.7 (0.95)</u>	<u>57 (9.5)</u>	<u>140 (24)</u>
<u>Ethylbenzene</u>	<u>26 (6.0)</u>	<u>260 (60)</u>	<u>650 (150)</u>
<u>n-Nitroso-di-n-propylamine</u>	<u>0.033 (0.006)</u>	<u>0.33 (0.06)</u>	<u>0.81 (0.15)</u>
<u>Vinyl Chloride</u>	<u>0.84 (0.33)</u>	<u>8.4 (3.3)</u>	<u>21 (8.3)</u>
<u>Antimony</u>	<u>0.60 (0.12)</u>	<u>6.0 (1.2)</u>	<u>30 (6.1)</u>
<u>Copper</u>	<u>0.060 (0.02)</u>	<u>0.60 (0.23)</u>	<u>3.0 (1.2)</u>
<u>Hydrogen Sulfide</u>	<u>30 (22)</u>	<u>300 (216)</u>	<u>1,500 (1,080)</u>
<u>Lead</u>	<u>0.075 (0.009)</u>	<u>0.75 (0.09)</u>	<u>3.8 (0.44)</u>
<u>Methacrolein</u>	<u>1.1 (0.37)</u>	<u>11 (3.7)</u>	<u>53 (18)</u>
<u>Alkyl Thiols (Mercaptans)</u>	<u>n/a (12)</u>	<u>n/a (120)</u>	<u>n/a (610)</u>
<u>Toluene</u>	<u>904 (240)</u>	<u>9,000 (2,400)</u>	<u>45,000 (12,000)</u>
<u>Ammonia</u>	<u>0.001%</u>	<u>--</u>	<u>--</u>
<u>Biologicals</u>	<u>4 x 10⁴/scf (qPCR per group) and free of <0.2 micron filter</u>	<u>--</u>	<u>--</u>
<u>Hydrogen</u>	<u>0.1%</u>	<u>--</u>	<u>--</u>
<u>Mercury</u>	<u>0.08 mg/m³</u>	<u>--</u>	<u>--</u>
<u>Siloxanes</u>	<u>0.01 mg Si/m³</u>	<u>0.1 mg Si/m³</u>	<u>--</u>

¹ The constituents listed from "arsenic" to "vinyl chloride" are carcinogenic constituents of concern. The constituents listed from "antimony" to "toluene" are non-carcinogenic constituents of concern.

Formatted: Font: Bookman Old Style, 9 pt

The action levels by the foregoing table act as a warning or alarm. The lower action level is used to screen gas suppliers during the initial gas quality review and as an ongoing screening level during the periodic testing. The upper action level results in an immediate shut-off, and the gas supplier is denied access to the utilities' pipeline systems until the supplier can demonstrate compliance with the gas quality and constituent requirements.

Formatted: Font: Bookman Old Style, 9 pt

Formatted: Justified

f. Pacific Gas and Electric Company, San Diego Gas & Electric Company, Southern California Gas Company, and Southwest Gas Corporation, either individually or collectively, shall file an application every five years, or earlier if new information becomes available, or as directed by the Commission in the future, commencing no later than January 22, 2019, for the Commission to review and update the standards for the protection of human health and pipeline integrity and safety, including considering proposals to amend the list of constituents of concern and concentration limits found in biomethane.

Formatted: Justified, Indent: Left: 0.89", Hanging: 0.17", Right: 1.03"

g. If the Office of Environmental Health Hazard Assessment (OEHHA) or the California Air Resources Board (CARB) believes that an update proceeding should occur before the five year period, OEHHA or the CARB may notify the Commission's Executive Director and the Energy Division Director that an update proceeding should be conducted.

8. Standard Gas Delivery Pressure

- a. Each gas utility supplying gas for domestic, commercial or industrial purposes shall, subject to the approval of the Commission, adopt and maintain a standard gas delivery pressure measured at the outlet of any customer's meter. In adopting such a standard gas delivery pressure, each utility may divide its distribution system into sections and establish a separate standard gas delivery pressure for each section, or the utility may establish a single standard gas delivery pressure for its distribution system as a whole.
- b. The standard gas delivery pressure supplied by any gas utility to domestic, commercial, or industrial customers, as measured at the outlet of any such customer meter, shall not be less than two inches nor more than twelve inches of water column pressure.
- c. The standard gas delivery pressure adopted shall be filed with the Commission as a part of each gas utility's tariff schedules. These tariff schedules shall be open to public inspection at each office or location where applications for gas service are received.
- d. No change shall be made by any gas utility in the standard gas delivery pressure adopted by it for any section or system without the approval of the Commission.
- e. In the case of customers who require higher pressure than the standard established for domestic, commercial, or industrial service, the gas utility may supply gas at the desired pressure, and the volume of such gas shall be adjusted to standard pressure for accounting and billing purposes.
- f. The pressure of gas supplied at low pressure to domestic and commercial customers shall not vary more than fifty percent (50%) above or below the standard pressure which the utility has

-9-

adopted for a section or system and no such variation in pressure shall be more than that equivalent to four inches of water column above or below the standard. No variation in pressure from the

standard pressure of two inches or more of water column shall occur in a time less than fifteen (15) minutes, excepting momentary fluctuations on individual services caused by the operations of customer's appliances or fluctuations caused by reasonable regulator buildups.

9. Pressure Testing Equipment and Tests

- a. Each gas utility shall own and maintain at least one recording pressure device on each principal distribution main leaving each major control facility such as a compressor station, holder station or transmission terminal. No utility shall maintain less than two such devices unless specifically relieved in writing by the Commission. Official pressure data taken from such devices shall be preserved as a continuous record for a period of at least one (1) year.
- b. Each gas utility shall own and maintain at least one low pressure, portable pressure recording device for each one hundred (100) miles or fraction thereof of low pressure main in any separate distribution system.
- c. On low pressure distribution systems each gas utility shall during the six months of the peak season of the year make at least one 24-hour record of pressure each week at the outlet of customer's meters for each one hundred (100) miles or less of distribution main in each district or separate distribution system. Such record shall bear the address of the customer where the pressure is taken and the dates, together with such other information as the Commission may from time to time direct and shall be filed and retained for a period of at least two calendar years in the principal office of each district or division. In lieu of fifty percent (50%) of the above required number of records from portable pressure recording devices at customer's premises there may be substituted an equal number of twenty-four (24) hour records from recording pressure devices permanently located at critical points on the distribution system.
- d. On high pressure distribution systems, gas utilities shall maintain permanently located pressure recording devices at critical points and shall preserve in the district or division offices the data from these devices for a period of at least one (1) year.
- e. Pressure conditions on a customer's premises served from a high pressure distribution system shall be determined by a test made with a water column manometer or other suitable test device, during service calls in answer to pressure complaints. A report on such tests shall be made on the complaint order, which report shall state the pressure observed when appliances were on and when all appliances (excepting pilot lights) were off. It shall state whether the test was made at the outlet of the meter or at the customer's appliance. A test shall be made for each pressure complaint received.

10. Meters and Regulators

- a. In the service of gas to domestic, commercial and industrial customers, each gas utility shall provide, and, unless otherwise specified, install at its own expense and shall continue to own, maintain and operate all equipment for the regulation and measurement of gas to the outlet of the meter set. Temperature correction is required where the average monthly use of gas is greater than one million (1,000,000) cubic feet per active month.
- b. Where an applicant for gas service requests installation of special facilities and the utility agrees to make such installation, the additional cost of the special facilities shall conform to

the special facilities provisions set forth in the utilities' filed tariffs.

11. Service and Meter Installations

- a. Each utility shall install service lines and meters of adequate capacity to provide satisfactory service and to assure accurate meter registration under the load conditions imposed.
- b. Rules governing specific locations of service and meter installations, and relocations or replacements of service pipe, shall conform to the applicable provisions of the latest revision of General Order 112-D, and revisions thereto, and the utilities' applicable currently effective filed gas tariff rules.

12. Gas Meter Accuracy

- a. All tests to determine the accuracy of registration of any diaphragm gas meter shall be made with a suitable meter prover.
- b. Every diaphragm gas meter, when installed for the use of any customer, shall be in good order and shall have been adjusted to register within one percent (1%) over or two percent (2%) under the prover registration when passing gas at a rate which will cause a pressure drop across the meter not to exceed one-half inch of water column (1/2" W.C.). The meter shall be adjusted so that the open flow test agrees with the check flow test within one percent (1%), provided, however, that no meter shall be put in service which on any test registers in excess of one percent (1%) over the prover registration.
- c. All gas meters other than diaphragm meters shall be tested for accuracy in accordance with accepted industry standards and practices. Any such test results shall not register less than minus two percent (2%) error or more than plus one percent (1%) error. In order to obtain the accuracy range set forth in this section, orifice meters shall be manufactured and installed in accordance with all guidelines specified in the current edition of ANSI/API 2530 (AGA Report No. 3), Orifice Metering of Natural Gas.

13. Periodic and Other Required Tests of Gas Meters

- a. No gas meters hereafter installed shall be allowed to remain in service more than ten (10) years from the time when last tested without being retested in the manner herein provided, and if found inaccurate, each such meter shall, at the time of each test, be readjusted to be correct within the prescribed limits before being installed.
- b. If during an inspection or the servicing of appliances or equipment on a customer's premises, a residential or small commercial meter is observed or is suspected to be out of calibration, it should be removed promptly, transported to a meter testing facility without alteration of its condition, and tested. If the meter is a large commercial or industrial meter, and suitable transfer prover equipment is available, the meter may be tested in place.

-12-

- c. Under certain conditions utilities may be authorized to deviate from Section 13.a. and use a statistical meter control program based on meter performance as demonstrated by sample testing in lieu of periodic testing of each meter. Applications to deviate shall be based on accepted principles of statistical sampling.

14. Standard Methods of Testing Gas Meters

Each gas utility shall adopt and maintain standard methods of testing gas meters. These methods and the facilities used shall be reported to the Commission for approval.

15. Meter Testing Equipment

- a. Unless otherwise specifically authorized by the Commission, each gas utility shall own at least one meter prover for diaphragm type meters, of a type approved by the Commission and shall maintain such equipment in proper adjustment and so calibrated that the error of indication shall not exceed one-half percent ($1/2\%$). No meter prover not having temperature compensation, shall be so placed as to be subject to excessive temperature variation and each meter prover shall be equipped with suitable thermometers and other necessary accessories.
- b. Each utility using orifice meters or other large volume meters shall determine meter accuracy in accordance with accepted industry standards and practices.
- c. The accuracy of all provers and methods of operation will be established from time to time by a representative of the Commission. Any alterations, accidents, or repairs which might affect the accuracy of any meter prover, or the method of operating same, shall be promptly reported in writing to the Commission.
- d. Proving and calibration devices used for the requirements specified in these rules shall be traceable to the National Institute of Standards and Technology.
- e. This section is applicable to those utilities authorized to use recognized meter test and repair shops, other than their own, for testing and/or repairing all or a portion of meters removed from service. Results of such tests, together with relevant data, shall be furnished the Commission with the utility's statement including:
 - 1. The name of the organization making such meter tests and/or repairs.
 - 2. The type and characteristics of meters used by the utility and showing the number of meters by types.
 - 3. Certification of meter testing equipment by a recognized governing agency.

4. A copy of the sheet titled "Gas Meter Performance Record During the Year" as furnished in the utilities' annual report to the Commission.

16. Records of Meters and Meter Tests

- a. A complete record of the tests made under these rules shall be kept by each gas utility. The record so kept shall contain complete information concerning each test, including the date when, and the place where the test was made, the name of the inspector conducting the test, the result of the test, and such other information as may be required by these rules, or as the Commission may from time to time direct, and such additional information as the utility making the test may deem desirable.
- b. Whenever any meter is tested, the test information shall be retained including the information necessary for identifying the meter, the reason for the test, the reading of the meter upon removal from service, together with all data taken at the time of the test in sufficiently complete form to permit the convenient checking of the methods employed and the results obtained. These records shall be retained for a period of not less than two (2) years.
- c. A record shall be kept, numerically arranged by meter number, indicating for each meter owned or used by a gas utility, its type, size and date purchased, together with the dates and locations of each installation, the date and result of each test, and the date and character of all repairs made. Where, because of the large number of meters involved, or for other valid operating reasons, the utility desires to adopt other methods for meter records, it shall present such proposal in detail to this Commission for approval. When the utility adopts a different method for meter records, no duplicate system need be maintained. These records shall be retained for a period of one year after the meter is sold, dismantled or destroyed.

17. Meter Testing at Request of A Customer

- a. Each gas utility shall at any time when requested by a customer upon not less than five (5) working days' notice, test the accuracy of any meter used to serve that customer. Conditions under which a gas utility will make meter tests at the request of its customers, charges for, and bill adjustments resulting from such requests shall be set forth by each utility in its filed tariff schedules. However, no charge will be made to the customer where a meter test is requested by this Commission. When a meter has been tested at the request of a customer, a retest for a meter at the same location within six months will not be made unless specifically requested by the Commission.
- b. A customer shall have the right to require the utility to conduct the test on the meter in his or her presence, if the customer so

-14-

desires. The test may be observed by a representative, other than from the utility or the Commission, appointed by the customer.

- c. A report giving the name of the customer requesting the test, the date of the request, the location of the premises where the meter was installed, the meter statement at time of removal, the date tested, and the result of the test at the check flow rate, the type, make, size and identification number of the meter, the date of removal and deductions drawn therefrom shall be supplied to such customer within a reasonable time after completion of the test.

18. Calculation of Gas Volumes

The procedures used by each utility to determine gas volumes used for billing purposes shall be in accordance with accepted industry standards and practices. Each utility shall include the procedures and gas measurement standards used in its applicable currently effective filed gas tariff rules.

19. Meter Readings and Bill Forms

- a. Each meter shall indicate clearly the cubic feet or other unit of gas registered by such meter. In cases where the dial readings of a meter must be multiplied by a constant to obtain the cubic feet or other unit consumed, the proper constant to be applied shall be clearly marked on the consumer's bill. Where gas is metered under high pressure or where the quantity is determined by calculations from recording devices, the company shall, upon application from the customer, supply the customer with such information as will cover the conditions under which the quantity is determined.
- b. Bills rendered to customers shall show the reading of the meters at the beginning and end of a period for which the bill is rendered, the number of cubic feet or other units of gas supplied and the date of the meter readings. Each bill shall bear upon its face the date when the bill was mailed to or left upon the premises of the customer. On all bills which are computed on any other basis than a definite charge per unit of service, the other factors used in computing the bill shall be clearly stated thereon or submitted to the customer upon request so that the amount of the bill may be readily recomputed.
- c. Copies of all forms of bills, bill stubs and notices appertaining to the payment of bills shall be filed with the Commission as a part of the schedule of rates, rules and regulations then in force. No change shall be made in any such bill, bill stub or notice, without the approval of the Commission.

20. Information for Customers

- a. Each gas utility, upon request, shall give its customers such information and assistance as is reasonable in order that customers may secure service at the most economical rate.
- b. Each gas utility shall inform its customers of any change made, or proposed to be made, in the character of the service supplied as would affect the safety of operation of the appliances or equipment which may be in use by said customer.
- c. Each gas utility shall adopt some means of informing its customers as to the methods of reading meters, either by printing on its bills a description of the method of reading meters, or by a notice to the effect that the method will be explained upon request at any office where requests for service are received.

21. Customers' Deposits

Each utility receiving deposits from customers for the establishment of credit shall keep a record showing the name of the customer making the deposit, the premises occupied by the customer, the date deposit was made, the amount of the deposit and the interest accrued, paid or credited. The record shall be kept for one year after the deposit has been refunded.

22. Maintenance and Operation of Facilities

- a. Each gas utility, unless specifically relieved in any case by the Commission from such obligation, shall operate and maintain in safe, efficient and proper condition all of the facilities and instrumentalities used in connection with the furnishing, regulation, measurement and delivery of gas to any customer up to and including the point of delivery, which point, for the purpose of these rules, shall be deemed to be the outlet fitting of the meter installed by the utility, or the point where the pipe owned and installed by the utility connects to the customer owned piping, whichever is further downstream.
- b. The gas utility may refuse to serve or may discontinue service to a customer:
 1. If any part of the facilities, appliances or other equipment for receiving or using service, or the use of that service, shall be determined by the utility to be unsafe, or
 2. If any condition existing upon the customer's premises shall be determined by the utility to endanger the utility's service facilities.Service shall not be connected or restored until the utility determines that the customer's facilities, appliances or other gas equipment have been made safe, or; the utility has written notice from an appropriate governmental agency that the premises meet applicable laws, ordinances or regulations.
- c. Each gas utility, unless specifically relieved in any case by the Commission from such obligation, upon request of any cus-

tomer and without extra charge, shall make an inspection of appliances in use by that customer, in accordance with the rules and regulations of such utility filed with the Commission. Inspection of appliances does not include making repairs, without charge, other than those commonly referred to as adjustments to insure safe and efficient use of the gas service. Where it is recognized that unsafe or hazardous conditions exist, service shall be discontinued and the customer notified. Service shall not be restored until hazardous conditions have been corrected as provided by Section 22.b.

23. Complaints

- a. Each gas utility shall make a full and prompt investigation of all complaints made to it by its customers, either directly or through the Commission.
- b. Each gas utility shall keep a record of all complaints received which shall show in each case the name and address of the complainant, the date of receiving a complaint, its general nature, the date and method of disposal, and the name of service person responding to the complaint. The record shall be kept for a period of at least two (2) calendar years after the complaint has been resolved.

24. Reports to the Commission

Each gas utility shall at such time and in such form as the Commission shall prescribe, report to the Commission the result of all tests required to be made or the information contained in any record required to be kept by the utility.

25. General Provisions

- a. The adoption of these rules shall in no way preclude the Commission from altering or amending the same in whole or in part, or from requiring any other or additional service, equipment, facilities, standard or practice, either upon complaint or upon its own motion, or upon the application of any utility or customer.
- b. In any case where any gas utility is supplying gas to customers under conditions more favorable or advantageous to such customers than are provided in these rules, either as to quality or character of service, no change shall be made in such service conditions without further approval of the Commission.

26. Modification of Rules

- a. Any gas utility may of its own accord establish uniform, nondiscriminatory rules more favorable to its customers than the rules herein established. The rules herein established shall take precedence over all orders, general or special heretofore made by the Commission, insofar as said orders may be inconsistent with these rules.

- b. The rules herein established shall take precedence over all rules filed or to be filed by gas utilities insofar as inconsistent therewith. Rules now on file and inconsistent with the rules herein established shall be properly revised and refiled within thirty (30) days from the effective date of this order.
- c. If hardship would occur from the application of any rule herein prescribed because of special facts, application may be made to the Commission for a modification of such rule provided that no utility shall submit any rule or regulation for the approval of the Commission which is contrary to any section of this order without submitting therewith a full and complete justification of such rule.

Approved and dated at San Francisco, ~~April 12, 1989~~ Month XX, 2016.

PUBLIC UTILITIES COMMISSION
STATE OF CALIFORNIA

By ~~VICTOR WEISSER~~ *Executive Director*

(End of Attachment 1)

ATTACHMENT 2

CALIFORNIA PUBLIC UTILITIES COMMISSION

Service Lists

Proceeding: R1302008 - CPUC - OIR TO ADOPT

Filer: CPUC

List Name: LIST

Last changed: January 15, 2016

[Download the Comma-delimited File](#)
[About Comma-delimited Files](#)

[Back to Service Lists Index](#)

Parties

DAVID COX
DIRECTOR - OPERATIONS
COALITION FOR RENEWABLE NATURAL GAS
EMAIL ONLY
EMAIL ONLY, CA 00000
FOR: COALITION FOR RENEWABLE NATURAL
GAS, INC.

GREG KESTER
CALIF. ASSN. OF SANITATION AGENCIES
EMAIL ONLY
EMAIL ONLY, CA 00000
FOR: CALIFORNIA ASSOCIATION OF
SANITATION AGENCIES (CASA)

JOHN BOEHME
MANAGER-REGULATORY AFFAIRS
AGL RESOURCES
INC
EMAIL ONLY
EMAIL ONLY, IL 00000
FOR: CENTRAL VALLEY GAS STORAGE, LLC
CONSULTANTS,

WILLIAM HELD
VICE PRESIDENT
CIVIL & ENVIRONMENTAL CONSULTANTS,
EMAIL ONLY
EMAIL ONLY, OH 00000
FOR: CIVIL & ENVIRONMENTAL
INC.

LAURA WISLAND
UNION OF CONCERNED SCIENTISTS
EMAIL ONLY
EMAIL ONLY, CA 00000-0000

RANDY FINKEN
SR. V.P.
FIRSTSOUTHWEST COMPANY
250 W. 57TH STREET, SUITE 1420

FOR: UNION OF CONCERNED SCIENTISTS

NEW YORK, NY 10107
FOR: FIRSTSOUTHWEST COMPANY

CHRISTOPHER SCHINDLER
HOGAN LOVELLS US, LLP
COLUMBIA SQUARE
555 THIRTEENTH STREET, N.W.
WASHINGTON, DC 20004
FOR: CENTRAL VALLEY STORAGE

RANDALL LACK
CHIEF MARKETING OFFICER
ELEMENT MARKETING, LLC
3555 TIMMONS LANE, SUITE 900
HOUSTON, TX 77027
FOR: ELEMENT MARKETING, LLC

RHONDA BENTON
REGULATORY ADVISOR
BP ENERGY COMPANY
21 HELIOS WAY
HOUSTON, TX 77079
FOR: BP ENERGY COMPANY

RHONDA DENTON
BP ENERGY COMPANY
201 HELIOS WAY
HOUSTON, TX 77079
FOR: BP ENERGY COMPANY

CATHERINE M. MAZZEO
ASSISTANT GENERAL COUNSEL
SOUTHWEST GAS CORPORATION
5241 SPRING MOUNTAIN ROAD
GT14E7
LAS VEGAS, NV 89150
FOR: SOUTHWEST GAS CORPORATION

JASON W. EGAN
COUNSEL
SOUTHERN CALIFORNIA GAS COMPANY
555 W. FIFTH STREET, STE. 1400.
LOS ANGELES, CA 90013
FOR: SOUTHERN CALIFORNIA GAS
COMPANY/SAN DIEGO GAS & ELECTRIC

COMPANY

EVAN G. WILLIAMS
CAMBRIAN ENERGY MANAGEMENT LLC
AFFAIRS
624 SO. GRAND AVE., NO. 2425
LOS ANGELES, CA 90017-3335
FOR: CAMBRIAN ENERGY MANAGEMENT LLC

JOHN ATKINSON
DIR. OF REGULATORY & GOV'T.
VNG.CO
1458 ECHO PARK AVENUE
LOS ANGELES, CA 90026
FOR: VNG.CO

NORMAN A. PEDERSEN
HANNA AND MORTON LLP
AFFAIRS
444 SOUTH FLOWER STREET, SUITE 1500
LOS ANGELES, CA 90071-2916
FOR: SOUTHERN CALIFORNIA GENERATION
COALITION

TODD CAMPBELL
VP - PUBLIC POLICY & REGULATORY
CLEAN ENERGY FUELS CORPORATION
3020 OLD RANCH PARKWAY, STE. 400
SEAL BEACH, CA 90740
FOR: CLEAN ENERGY FUELS CORPORATION

DANIEL W. DOUGLASS
ATTORNEY
DOUGLASS & LIDDELL
4766 PARK GRANADA, SUITE 209
CALABASAS, CA 91302
FOR: ALLIANCE FOR RETAIL ENERGY MARKETS
(AREM)/DIRECT ACCESS CUSTOMER COALITION
(DACC)

GREGORY S.G. KLATT
DOUGLASS & LIDDELL
4766 PARK GRANADA, STE. 209
CALABASAS, CA 91302
FOR: EDF RENEWABLE ENERGY

MATTHEW W. DWYER
ATTORNEY, LAW DEPT.
SOUTHERN CALIFORNIA EDISON COMPANY
2244 WALNUT GROVE AVE. / PO BOX 800
ROSEMEAD, CA 91770
FOR: SOUTHERN CALIFORNIA EDISON COMPANY

MIKE MOHAJER, PE
PO BOX 3334
SAN DIMAS, CA 91773-7334
FOR: MIKE MOHAJER

DAVID SCHNEIDER
DIRECTOR OF BUSINESS DEVELOPMENT
ANAERGIA SERVICES
5780 FLEET STREET, STE. 310
CARLSBAD, CA 92008
FOR: ANAERGIA SERVICES

NEIL MOHR
GENERAL MANAGER
REPUBLIC SERVICES, INC
8514 MAST BLVD.
SNTTE, CA 92071
FOR: REPUBLIC SERVICES, INC

JOHN W. LESLIE, ESQ
ATTORNEY
DENTONS US LLP
600 WEST BROADWAY, STE. 2600
SAN DIEGO, CA 92101
FOR: SHELL ENERGY NORTH AMERICA

RICHARD PROSSER
MEMBER
BENA POWER PRODUCERS, LLC
1230 N. JEFFERSON ST., STE. J
ANAHEIM, CA 92807
FOR: BENA POWER PRODUCERS, LLC

JONATHAN BROMSON
CALIF PUBLIC UTILITIES COMMISSION
LEGAL DIVISION
ROOM 4107
505 VAN NESS AVENUE
SAN FRANCISCO, CA 94102-3214
FOR: ORA

MARCEL HAWIGER
ENERGY ATTY
THE UTILITY REFORM NETWORK
785 MARKET ST., STE. 1400
SAN FRANCISCO, CA 94103
FOR: TURN

JONATHAN D. PENDLETON
COUNSEL
PACIFIC GAS AND ELECTRIC COMPANY
77 BEALE STREET, MC B30A
SAN FRANCISCO, CA 94105
CALIFORNIA
FOR: PACIFIC GAS & ELECTRIC COMPANY

NICOLE JOHNSON
CONSUMER FEDERATION OF CALIFORNIA
150 POST ST., STE. 442
SAN FRANCISCO, CA 94108
FOR: CONSUMER FEDERATION OF

JEANNE B. ARMSTRONG
ATTORNEY
GOODIN MACBRIDE SQUERI & DAY LLP
505 SANSOME STREET, SUITE 900
SAN FRANCISCO, CA 94111
AND
FOR: WILD GOOSE STORAGE, LLC

SARA STECK MYERS
ATTORNEY AT LAW
122 28TH AVENUE
SAN FRANCISCO, CA 94121
FOR: CENTER FOR ENERGY EFFICIENCY
RENEWABLE TECHNOLOGIES (CEERT)

KATERINA ROBINSON
LEGISLATIVE AID TO ASSEMBLYMEMBER
MIKE GATTO
PO BOX 94249

DENNIS FENN
WESTERN SALES MANAGER
BIOCNG, LLC
7600 DUBLIN BOULEVARD, SUITE 200

R.16-07-006 ALJ/EW2/ar9

SACRAMENTO, CA 94249
FOR: ASSEMBLYMAN MIKE GATTO

DUBLIN, CA 94568
FOR: BIOCNG, LLC

MARK HOLMSTEDT
WESTHOFF, CONE & HOLMSTEDT
500 YGNACIO VALLLEY ROAD, STE. 380
WALNUT CREEK, CA 94596
FOR: WESTHOFF, CONE & HOLMSTEDT

JODY S. LONDON
PO BOX 3629
OAKLAND, CA 94609
FOR: SUSTAINABLE CONSERVATION

GREGORY MORRIS
DIRECTOR
GREEN POWER INSTITUTE
2039 SHATTUCK AVENUE, STE 402
BERKELEY, CA 94704
FOR: GREEN POWER INSTITUTE
CALIFORNIA

JULIA LEVIN
EXECUTIVE DIRECTOR
BIOENERGY ASSOCIATION OF CALIFORNIA
PO BOX 6184
ALBANY, CA 94706
FOR: BIOENERGY ASSOCIATION OF

SHAWN GARVEY
VICE PRESIDENT, COMMUNICATIONS
CLEANWORLD
2330 GOLD MEADOW WAY
GOLD RIVER, CA 95670
FOR: CLEANWORLD

TROND ASCHEHOUG
PARTNER
ENERGY POWER PARTNERS
7467 DAPHNE DRIVE
GRANITE BAY, CA 95746
FOR: ENERGY POWER PARTNERS

CHARLES HELGET
PRESIDENT
SECTOR STRATEGIES
980 9TH STREET, 16TH FL.
SACRAMENTO, CA 95814
FOR: SECTOR STRATEGIES

CHUCK WHITE
DIRECTOR - REGULATORY AFFAIRS/WEST
WASTE MANAGEMENT
915 L STREET, STE. 1430
SACRAMENTO, CA 95814
FOR: WASTE MANAGEMENT

DAN L. CARROLL
ATTORNEY AT LAW
DOWNEY BRAND, LLP
DISTRICT
621 CAPITOL MALL, 18TH FLOOR
SACRAMENTO, CA 95814
FOR: LODI GAS STORAGE

WILLIAM W. WESTERFIELD
SR ATTORNEY
SACRAMENTO MUNICIPAL UTILITY

6201 S STREET, MS B406
SACRAMENTO, CA 95817
FOR: SACRAMENTO MUNICIPAL UTILITY
DISTRICT (SMUD)

ANN L. TROWBRIDGE
ATTORNEY AT LAW
DAY CARTER & MURPHY LLP
3620 AMERICAN RIVER DRIVE, SUITE 205
SACRAMENTO, CA 95864
FOR: GILL RANCH STORAGE

Information Only

R.16-07-006 ALJ/EW2/ar9

ADAM D. LINK
CALIF. ASSN. OF SANITATION AGENCIES
EMAIL ONLY
EMAIL ONLY, CA 00000

AICHI NGUYEN
PACIFIC GAS AND ELECTRIC COMPANY
EMAIL ONLY
EMAIL ONLY, CA 00000

ALICIA AGUILAR
LEGAL SECRETARY/PARALEGAL
HANNA AND MORTON LLP
EMAIL ONLY
EMAIL ONLY, CA 00000
FOR: SOUTHERN CALIFORNIA GENERATION
COALITION

ANDREW G. SALMON
SR. TOXICOLOGIST
STATE OF CALIFORNIA - OEHHA
EMAIL ONLY
EMAIL ONLY, CA 00000
FOR: OFFICE OF ENVIRONMENTAL HEALTH
HAZARD ASSESSMENT (CALIFORNIA EPA)

BARBARA BARKOVICH
CONSULTANT
POLICY
BARKOVICH & YAP
EMAIL ONLY
EMAIL ONLY, CA 00000

DIANE I. FELLMAN
SR. DIR. - REGULATORY STRATEGY &
NRG WEST
EMAIL ONLY
EMAIL ONLY, CA 00000

DOUG DAVIE
WELLHEAD ELECTRIC
EMAIL ONLY
EMAIL ONLY, CA 00000

ERIN GRIZARD
BLOOM ENERGY
EMAIL ONLY
EMAIL ONLY, CA 00000

EVELYN KAHL
COUNSEL
ALCANTAR & KAHL LLP
EMAIL ONLY
EMAIL ONLY, CA 00000

HARRISON CLAY
CLEAN ENERGY FUELS CORPORATION
EMAIL ONLY
EMAIL ONLY, CA 00000

JASMIN ANES
PACIFIC GAS & ELECTRIC COMPANY
EMAIL ONLY
EMAIL ONLY, CA 00000

KATIE HOPKEN
CASE COORDINATOR
PACIFIC GAS AND ELECTRIC COMPANY
EMAIL ONLY
EMAIL ONLY, CA 00000

KATY MORSONY
ALCANTAR & KAHL
EMAIL ONLY
EMAIL ONLY, CA 00000

KEVIN D. BEST
REAL ENERGY, LLC
EMAIL ONLY
EMAIL ONLY, CA 00000

MARCIE A. MILNER
VP & REGULATORY AFFAIRS
SHELL ENERGY NORTH AMERICA (US), L.P.
EMAIL ONLY
EMAIL ONLY, CA 00000

MATTHEW FREEDMAN
THE UTILITY REFORM NETWORK
EMAIL ONLY
EMAIL ONLY, CA 00000

NOAH LONG

PETER MILLER

R.16-07-006 ALJ/EW2/ar9

NATURAL RESOURCES DEFENSE COUNCIL
EMAIL ONLY
EMAIL ONLY, CA 00000

NATURAL RESOURCES DEFENSE COUNCIL
EMAIL ONLY
EMAIL ONLY, CA 00000

SPENCER RICHLEY
CLEAN ENERGY FUELS CORPORATION
EMAIL ONLY
EMAIL ONLY, CA 00000

VALERIE PUFFER
POWER CONTRACTS MANAGER
GLENDALE WATER & POWER
EMAIL ONLY
EMAIL ONLY, CA 00000

MRW & ASSOCIATES, LLC
EMAIL ONLY
EMAIL ONLY, CA 00000

KAREN TERRANOVA
ALCANTAR & KAHL
EMAIL ONLY
EMAIL ONLY, CA 00000-0000

MARTIN L. RYAN
MONTAUK ENERGY
680 ANDERSEN DR., FOSTER PLZA 10, 5TH FL
PITTSBURGH, PA 15220

KATHRYN MCCOY
ASSOCIATE GENERAL COUNSEL
AGL RESOURCES
1200 SMITH STREET, SUITE 900
HOUSTON, TX 77002

JASON LAWHORN
ASSISTANT GENERAL COUNSEL
BUCKEYE PARTNERS L.P.
ONE GREENWAY PLAZA, STE. 600
HOUSTON, TX 77046

FRANCISCO TARIN
DIRECTOR, REGULATORY AFFAIRS
EL PASO NATURAL GAS COMPANY, LLC
2 NORTH NEVADA AVENUE
COLORADO SPRINGS, CO 80944

PETER G. ESPOSITO
PRINCIPAL
CRESTED BUTTE CATALYSTS LLC
PO BOX 668/1181 GOTHIC CORRIDOR (CR 317)
CRESTED BUTTE, CO 81224

MARIA ZANNES
THE ZANNES FIRM
928 AVENIDA MANANA NE
ALBUQUERQUE, NM 87110

VALERIE J. ONTIVEROZ
REGULATORY MANAGER/CA
SOUTHWEST GAS CORPORATION
5241 SPRING MOUNTAIN ROAD
LAS VEGAS, NV 89150

PRISCILA C. KASHA
DEPUTY CITY ATTORNEY
LOS ANGELES DEPT. OF WATER & POWER
111 N. HOPE STREET, RM. 340
LOS ANGELES, CA 90012

ROBERT PETTINATO
LOS ANGELES DEPARTMENT OF WATER & POWER
111 NORTH HOPE STREET, SUITE 1150
LOS ANGELES, CA 90012

RODNEY A. LUCK
LOS ANGELES DEPT. OF WATER & POWER
111 NORTH HOPE STREET, ROOM 1150
LOS ANGELES, CA 90012

JEFFERY L. SALAZAR
REGULATORY BUSINESS MGR.
SOUTHERN CALIFORNIA GAS COMPANY
555 W. FIFTH STREET, GT14D6
LOS ANGELES, CA 90013

MIKE FRANCO
SOUTHERN CALIFORNIA GAS COMPANY
555 W. FIFTH STREET, GT14D6
LOS ANGELES, CA 90013

RONALD VAN DER LEEDEN
DIR.-GENERAL RATE CASE & REVENUE REQ.
SOUTHERN CALIFORNIA GAS COMPANY
555 W. FIFTH STREET, GT14D6
LOS ANGELES, CA 90013

STEVEN HRUBY
SOUTHERN CALIFORNIA GAS COMPANY
555 W. FIFTH ST., GT14D6
LOS ANGELES, CA 90013

VINCENT M. GONZALES, ESQ.
SR. ENVIRONMENTAL COUNSEL - LAW DEPT
SOUTHERN CALIFORNIA GAS COMPANY
555 W. FIFTH STREET, GT14G1
LOS ANGELES, CA 90013

YVONNE MEJIA
SOUTHERN CALIFORNIA GAS COMPANY
555 W. FIFTH STREET, GT14D6
LOS ANGELES, CA 90013

TOM ROTH
ROTH ENERGY COMPANY
545 S. FIGUEROA STREET, SUITE 1235
LOS ANGELES, CA 90071

ERIC B. NELSON
ENERGY CONSULTANT
4025 VIA LARGAVISTA
PALOS VERDES EST., CA 90274

PATRICK GRIFFITH, P.E., BCEE
SR ENGINEER
LA COUNTY SANITATION DISTRICTS
1955 WORKMAN MILL ROAD
WHITTIER, CA 90601

MICHAEL ALEXANDER
LEPRECHAUN CONSULTING GROUP
45 EAST RODELL PLACE
ARCADIA, CA 91006

LINCOLN E. BLEVEANS
POWER RESOURCES MANAGER
BURBANK WATER AND POWER
AUTH
PO BOX 631
BURBANK, CA 91503-0631

RICHARD J. MORILLO
GENERAL COUNSEL
SOUTHERN CALIFORNIA PUBLIC POWER
1160 NICOLE COURT
GLENORA, CA 91740

CASE ADMINISTRATION
SOUTHERN CALIFORNIA EDISON COMPANY
LAW DEPT.
2244 WALNUT GROVE AVE., RM 370
ROSEMEAD, CA 91770

DON C. LIDDELL
ATTORNEY
DOUGLASS & LIDDELL
2928 2ND AVENUE
SAN DIEGO, CA 92103

CARRIE ANNE DOWNEY
LAW OFFICES OF CARRIE ANNE DOWNEY
1313 YNEZ PLACE
CORONADO, CA 92118

CENTRAL FILES
SAN DIEGO GAS & ELECTRIC COMPANY
8330 CENTURY PARK CT, CP31-E
SAN DIEGO, CA 92123-1530

LISA MUSICK
SOUTHERN CALIFORNIA TELEPHONE & ENERGY
27515 ENTERPRISE CIRCLE WEST
TEMECULA, CA 92590

BILL HANCK
MANAGING DIR.
DIRECTED BIOGAS, LLC
3991 MAC ARTHUR BLVD., NO. 400
NEWPORT BEACH, CA 92660

R.16-07-006 ALJ/EW2/ar9

VLADIMIR KOGAN
SR. SCIENTIST - ENVIRONMENTAL COMPLIANCE
ORANGE COUNTY SANITATION DISTRICT
10844 ELLIS AVENUE
FOUNTAIN VALLEY, CA 92708

FARIDEH KIA
MEMBER
BENA POWER PRODUCERS, LLC
1230 N. JEFFERSON ST., STE. J
ANAHEIM, CA 92807

PAUL KERKORIAN
ATTORNEY AT LAW
1100 W. SHAW AVENUE., STE. 126
FRESNO, CA 93711

SUE MARA
CONSULTANT
RTO ADVISORS, LLC
164 SPRINGDALE WAY
REDWOOD CITY, CA 94062

JAMIE L. MAULDIN
ADAMS BROADWELL JOSEPH & CARDOZO
601 GATEWAY BLVD., STE. 1000
SO. SAN FRANCISCO, CA 94080
FOR: COALITION OF CALIFORNIA UTILITY
EMPLOYEES

EILEEN COTRONEO
REGULATORY MGR.
PACIFIC GAS AND ELECTRIC COMPANY
77 BEALE STREET, MC B9A, RM. 969
SAN FRANCISCO, CA 94105

ERIC STEINHOFER
PACIFIC GAS & ELECTRIC COMPANY
245 MARKET STREET, ROOM 347
SAN FRANCISCO, CA 94105

M. GRADY MATHAI-JACKSON
ATTORNEY
PACIFIC GAS AND ELECTRIC COMPANY
77 BEALE STREET, B30A
SAN FRANCISCO, CA 94105

MOONZAREEN AHSAM
PACIFIC GAS & ELECTRIC COMPANY
77 BEALE ST., MC B9A
SAN FRANCISCO, CA 94105
3300

SHERIDAN J. PAUKER, ESQ.
REGULATORY COUNSEL
WILSON SONSINI GOODRICH & ROSATI
ONE MARKET PLAZA, SPEAR TOWER, STE
SAN FRANCISCO, CA 94105

TODD O. MAIDEN, ESQ.
ATTORNEY
REED SMITH LLP
101 SECOND STREET, STE. 1800
SAN FRANCISCO, CA 94105

JILL N. JAFFE
NOSSAMAN LLP
50 CALIFORNIA STREET, 34TH FLOOR
SAN FRNACISCO, CA 94111

MARTIN A. MATTES
ATTORNEY AT LAW
NOSSAMAN GUTHNER KNOX & ELLIOTT, LLP
50 CALIFORNIA STREET, 34TH FLOOR
SAN FRANCISCO, CA 94111-4799

HILARY CORRIGAN
CALIFORNIA ENERGY MARKETS
425 DIVISADERO ST. SUITE 303
SAN FRANCISCO, CA 94117-2242

CASE COORDINATION
PACIFIC GAS AND ELECTRIC COMPANY
PO BOX 770000; MC B9A
SAN FRANCISCO, CA 94177

KAREN KHAMOU
PACIFIC GAS AND ELECTRIC COMPANY
245 MARKET ST., RM. 1255C
SAN FRANCISCO, CA 94177-0001

R.16-07-006 ALJ/EW2/ar9

BEVIN HONG
TRANS CANADA CORPORATION
P.C.
43 WOODLAND CT.
620
SAN RAMON, CA 94582

PHILLIP MULLER
PRESIDENT
SCD ENERGY SOLUTIONS
436 NOVA ALBION WAY
SAN RAFAEL, CA 94903

ROBERT RUSSELL
LODI GAS STORAGE, LLC
POL.
PO BOX 230
ACAMPO, CA 95220

ANTHONY ANDREONI
DIRECTOR, REGULATORY AFFAIRS
CALIFORNIA MUNICIPAL UTILITIES ASSN
915 L STREET, STE. 1460
SACRAMENTO, CA 95814

JOHANNES ESCUDERO
EXECUTIVE DIRECTOR
COALITION FOR RENEWABLE NATURAL GAS
1017 L STREET, STE. 513
SACRAMENTO, CA 95814

ANDREW B. BROWN
ELLISON SCHNEIDER & HARRIS L.L.P.
2600 CAPITOL AVENUE, STE. 400
SACRAMENTO, CA 95816

CHASE B. KAPPEL
ELLISON SCHNEIDER & HARRIS LLP
2600 CAPITOL AVENUE, SUITE 400
SACRAMENTO, CA 95816-5905

LYNN HAUG
ELLISON, SCHNEIDER & HARRIS L.L.P.
2600 CAPITOL AVENUE, SUITE 400
SACRAMENTO, CA 95816-5931

TIMOTHY TUTT

THOMAS M. BRUEN
LAW OFFICES OF THOMAS M. BRUEN,

1990 NORTH CALIFORNIA BLVD., STE.

WALNUT CREEK, CA 94596

C. SUSIE BERLIN
LAW OFFICES OF C. SUSIE BERLIN
1346 THE ALAMEDA, SUITE 7, NO. 141
SAN JOSE, CA 95126

DOUGLAS M. GRANDY, PE
CALIF. ONSITE GENERATION - REG. &

1220 MACAULAY CIRCLE
CARMICHAEL, CA 95608

CURT BARRY
SENIOR WRITER
CLEAN ENERGY REPORT
717 K STREET, SUITE 503
SACRAMENTO, CA 95814

JOHN SHEARS
CEERT
1100 11TH STREET, SUITE 311
SACRAMENTO, CA 95814

RONALD LIEBERT
ATTORNEY AT LAW
ELLISON SCHNEIDER & HARRIS LLP
2600 CAPITOL AVENUE, STE. 400
SACRAMENTO, CA 95816

JEDEDIAH J. GIBSON
ATTORNEY AT LAW
ELLISON SCHNEIDER & HARRIS LLP
2600 CAPITOL AVENUE, SUITE 400
SACRAMENTO, CA 95816-5905

CHAD ADAIR
SMUD
6301 S STREET, MS A404
SACRAMENTO, CA 95817

RACHEL GOLD

R.16-07-006 ALJ/EW2/ar9

SACRAMENTO MUNICIPAL UTILITY DISTRICT
6201 S STREET, MS B404
SACRAMENTO, CA 95817

POLICY DIRECTOR
CONSCIOUS VENTURES GROUP
2501 PORTOLA WAY
SACRAMENTO, CA 95818

MIKE CADE
INDUSTRY SPECIALIST
AFFAIRS
ALCANTAR & KAHL
121 SW SALMON STREET, SUITE 1100
PORTLAND, OR 97204

VIRINDER SINGH
DIR - REGULATORY & LEGISLATIVE
EDF RENEWABLE ENERGY
1000 SW BROADWAY, STE. 1880
PORTLAND, OR 97205-3060

DAVE WEBER
PRESIDENT & CEO
NW NATURAL GAS STORAGE
220 NW 2ND AVENUE
PORTLAND, OR 97209

ROGER HALEY
NW NATURAL GAS STORAGE
220 NW 2ND AVENUE
PORTLAND, OR 97209

TODD THOMAS
NW NATURAL GAS STORAGE
220 NW 2ND AVENUE
PORTLAND, OR 97209

State Service

DAVID PECK
CALIFORNIA PUBLIC UTILITIES COMMISSION
EMAIL ONLY
EMAIL ONLY, CA 00000

LE-HUY NGUYEN
CALIFORNIA ENERGY COMMISSION
EMAIL ONLY
EMAIL ONLY, CA 00000

MARK WONG
CALIFORNIA ENERGY COMMISSION
COMMISSION
EMAIL ONLY
EMAIL ONLY, CA 00000

MATTHEW KARLE
CALIFORNIA PUBLIC UTILITIES
EMAIL ONLY
EMAIL ONLY, CA 00000

BURTON MATTSON
CALIF PUBLIC UTILITIES COMMISSION
DIVISION OF ADMINISTRATIVE LAW JUDGES
BRANC
ROOM 2106
505 VAN NESS AVENUE
SAN FRANCISCO, CA 94102-3214

CHERYL LEE
CALIF PUBLIC UTILITIES COMMISSION
PROCUREMENT STRATEGY AND OVERSIGHT
AREA 4-A
505 VAN NESS AVENUE
SAN FRANCISCO, CA 94102-3214

FRANZ CHENG
CALIF PUBLIC UTILITIES COMMISSION
MARKET STRUCTURE, COSTS AND NATURAL GAS

JENNIFER KALAFUT
CALIF PUBLIC UTILITIES COMMISSION
COMMISSIONER PETERMAN

AREA 4-A
505 VAN NESS AVENUE
SAN FRANCISCO, CA 94102-3214

ROOM 5303
505 VAN NESS AVENUE
SAN FRANCISCO, CA 94102-3214

JOHN S. WONG
CALIF PUBLIC UTILITIES COMMISSION
DIVISION OF ADMINISTRATIVE LAW JUDGES
BRANCH
ROOM 5106
505 VAN NESS AVENUE
SAN FRANCISCO, CA 94102-3214

KELLY C. LEE
CALIF PUBLIC UTILITIES COMMISSION
ENERGY SAFETY & INFRASTRUCTURE
ROOM 4108
505 VAN NESS AVENUE
SAN FRANCISCO, CA 94102-3214

RICHARD A. MYERS
CALIF PUBLIC UTILITIES COMMISSION
MARKET STRUCTURE, COSTS AND NATURAL GAS
AREA 4-A
505 VAN NESS AVENUE
SAN FRANCISCO, CA 94102-3214

CARL WILLIAMS
CALRECYCLE
1001 I STREET
SACRAMENTO, CA 95812

CLARK WILLIAMS
CALRECYCLE
1001 I STREET
SACRAMENTO, CA 95812

PEGGY TARICCO
CALIFORNIA AIR RESOURCES BOARD
1001 I STREET
SACRAMENTO, CA 95812

SCOTT BECKNER
CALRECYCLE
1001 I STREET
SACRAMENTO, CA 95812

GARRY O'NEILL MARISCAL
RENEWABLE ENERGY SPECIALIST
CALIFORNIA ENERGY COMMISSION
1516 9TH STREET
SACRAMENTO, CA 95814

(END OF ATTACHMENT 2)

[Top of Page](#)

[Back to INDEX OF SERVICE LISTS](#)