

June 30, 2000

Wesley Franklin - Executive Director
California Public Utilities Commission
505 Van Ness Avenue, Room 5222
San Francisco, California 94102-3298

RE: PacifiCorp's (U901-E) Plan for Inspections, Record Keeping, and Reporting
D.97-03-070
I.95-02-015/R.96-11-004

As required by California D.97-03-070, Appendix A, dated March 31, 1997, PacifiCorp provides an original and five copies of the attached Plan for Inspections, Record Keeping, and Reporting. This report is also being served on the attached service list of I.95-02-015. In addition an electronic version has been sent via e-mail to Wade McCartney @ WSM@cpuc.ca.gov.

Should you have any questions regarding this report, please contact Steve Henderson at (503) 813-6157 or Carole Rockney at (503) 813-7408.

Respectfully submitted on behalf of PacifiCorp.

By: Matthew Wright, Vice President
Regulation, PacifiCorp
825 N.E. Multnomah, Suite 800
Portland, Oregon 97232
Telephone: (503) 813-6015
Facsimile: (503) 813-6060

Enclosure

c: Wade McCartney, Energy Division w/diskette
Brian Schumacher, Energy Division

bc: Wright - 800 LCT, Henderson - 1000 PSB, Hellebuyck - 800 LCT,
A. Nelson - Portland Business Center, Mammenga - 1700 LCT

BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA

Commission Order Instituting Investigation) into the rates, charges, services, and) practices of Pacific Gas and Electric) Company. (U 39 M))	I.95-02-015 (Filed February 22, 1995)
<hr/> Order Instituting Rulemaking for electric) distribution facility standard setting.)	R.96-11-004 (Filed November 8, 1996)

PACIFICORP'S (U901-E) IMPLEMENTATION PLAN FOR INSPECTIONS

USING INDICES SET FORTH IN APPENDIX A OF D.97-03-070

FOR CALENDAR YEAR 1999

June 30, 2000

PacifiCorp
Inspection and Maintenance Programs
California 1999

The attached sheets demonstrate the status of 1999 Inspections, Conditions found and Corrections in the state of California for PacifiCorp owned facilities. PacifiCorp has four districts in California: Tulelake, Alturas, Crescent City and Yreka/Mt. Shasta.

Inspections

All inspections were completed in 1999 for Urban & Rural Patrol, Detail and Intrusive inspection types. The attached Inspection sheets break down the inspections into three categories: Poles, Street Lights and Equipment. The information includes the type of equipment, the plan for each inspection category and the actuals of the inspection plan.

Conditions

Conditions found by the inspections were rated as either A or B priority, A priority requiring more immediate action. All A priority conditions found by the inspections have been corrected, with the exception of 95 in the Yreka/Mt. Shasta district. The A priority conditions will be corrected by the end of 2000. The remaining B priority conditions will be corrected by the end of 2000 or 2001, depending on the date found. The attached Condition workpapers breakdown the conditions into four categories: number of conditions found in 1999; 1999 conditions corrected as of June 20, 2000; conditions currently outstanding, and the final date outstanding conditions will be corrected by.

Dated in Portland, Oregon this 30th day of June 2000.

Respectfully Submitted,

Matthew Wright, Vice President
Regulation
PacifiCorp
825 N.E. Multnomah, Suite 800
Portland, Oregon 97232
Telephone: (503) 813-6015
Facsimile: (503) 813-6060

PACIFICORP
CERTIFICATE OF SERVICE

I hereby certify that on this 30th day of June, 2000, I served true copies of PacifiCorp's (U901-E) Plan for Inspections, Record Keeping, and Reporting - California I.95-02-015 on the following service list by first -class postage paid mail.

Dated: June 30, 2000

Kathleen M. Sauer
Tariff Policy
PacifiCorp