

APPENDIX A

Deficiencies and Conditions

BVES-1	Focus on grid hardening
Class	B
Deficiency	<p>BVES is focused almost entirely on grid hardening without much analysis of whether this is the most cost effective and efficacious approach. Without a stated long-term vision, it is not possible to assess why BVES has this singular focus.</p> <p>BVES does provide RSE estimates for a significant number of initiatives and provides a high-level comparative analysis in Figures 3-4 and 3-5 of its WMP. However, BVES reports that “Underground of the Ute line” has a wildfire RSE of 0.13 in Figure 3-4 and that the same initiative has a PSPS RSE of 0.3. It is not clear how BVES calculated these or what assumptions it made. Therefore, it is unclear specifically how BVES applies these estimates to inform its allocation of resources across initiatives and whether the spend allocated to undergrounding is the most effective use of BVES’ limited resources.</p>
Condition	<p>In a first quarterly report, BVES shall:</p> <ul style="list-style-type: none"> i. explain why it is focused heavily on system hardening, including giving information on how other mitigations compare in terms of cost and efficacy; ii. articulate a vision for where it plans to go over the next 3 and 10 years; iii. provide an explanation for the RSE estimates in Figures 3-4 and 3-5 of the BVES WMP, including the assumptions made and how wildfire RSE and PSPS RSE were calculated; and iv. outline in detail how BVES’ RSE estimates were used to determine which initiatives it is pursuing, including the level of spend allocated to its undergrounding program.

BVES-2	Wildfire cameras do not provide good coverage of service territory.
Class	B
Deficiency	BVES has four existing cameras on the mountain top ridge southwest of BVES' service territory. In viewing them on alertwildfire.org they are clustered near each other and do not appear to provide good coverage from different angles. The WMP says BVES plans to work with partners to install more but no number or details are given. In remote rugged terrain with limited cell coverage such as BVES, cameras provide high situational awareness value.
Condition	In its first quarterly report, BVES shall detail: <ol style="list-style-type: none"> whether it has sufficient cameras, including the observations from alertwildfire.org, and plans, including a timeline to improve its camera coverage moving forward.

BVES-3	High spend per circuit mile
Class	B
Deficiency	BVES plans to spend more than three times as much per circuit mile as the large electrical corporations. While BVES has lower economies of scale given its small size, the expense of its program may cause significant impact to ratepayers.
Condition	In its first quarterly report, BVES shall provide: <p>further quantitative justification and explanation that from a total cost of ownership perspective, the amount of ignition risk that its initiatives will reduce warrants the extra expense, including whether alternatives could enable BVES to achieve the same level of risk reduction using fewer resources.</p>

BVES-4	LiDAR patrol targets not met.
Class	B
Deficiency	BVES reports that it did not meet 2019 targets for LiDAR inspections. BVES' target for 2019 was 211 circuit miles of LiDAR patrols, but BVES shows zero circuit miles actually surveyed.
Condition	In a first quarterly report, BVES shall: i) explain its LiDAR inspection plan and results including the targets that it has set for this program and how these it expects to actually achieve this performance.

BVES-5	Compliance focus rather than proactive wildfire risk mitigation
Class	C
Deficiency	<p>BVES' vegetation management practice is based around following minimum regulations and requirements, and any additional analysis and initiatives are not discussed. Further, the plan is very general in its description of the vegetation management program and not clear on how often inspections occur. It simply states a contractor completes work under company direction to meet minimum required regulatory requirements.</p> <p>BVES needs to focus on relying less on contractor opinion, and work to set up internal procedures to ensure consistency across work and allow for evaluation of effectiveness for future improvement. Additionally, to allow for maximum effectiveness and minimize oversight, BVES should perform or adopt "at-risk" species analysis similar to other utilities, based on tree growth rate and failure likelihood.</p>
Condition	<p>In its 2021 WMP, BVES shall:</p> <ul style="list-style-type: none"> i. explain whether focusing simply on compliance with GO 95 achieves adequate wildfire mitigation in light of the requirements of SB 901 and AB 1054, and ii. whether it needs to go beyond rules that predate the WMP statute in order to achieve wildfire mitigation that addresses current risks in its service territory.

BVES-6	Community Outreach.
Class	C
Deficiency	BVES provides no discussion of community outreach or public education in its vegetation management section. It acknowledges the importance of such measures but provides no solution moving forward to set up a program.
Condition	In its 2021 WMP, BVES shall: <ol style="list-style-type: none"> i. supply the missing information on its community outreach and public education related to vegetation management.

BVES-7	Fuels management.
Class	C
Deficiency	BVES provides discussion on slash treatment or fuels reduction around facilities, and just states that practices are incorporated into vegetation management practices with no details on how.
Condition	In its 2021 WMP, BVES shall: <ol style="list-style-type: none"> ii. provide detailed information on its fuels management and slash reduction practices.

BVES-8	Patrols for asset and vegetation inspections combined.
Class	B
Deficiency	BVES conducts two patrols a year but these are not specific to vegetation management; asset and vegetation patrols are conducted together.
Condition	In its first quarterly report, BVES shall detail: <ol style="list-style-type: none"> why it combines its asset and vegetation inspections, how it verifies and ensures effectiveness of these inspections, whether it plans to establish two distinct inspection processes for assets and vegetation, in order to more thoroughly inspect vegetation, and how it complies with the Public Resources Code 4291 et seq. and associated regulations to conduct inspections on annual basis.

BVES-9	Tracking of tree status.
Class	C
Deficiency	BVES does not discuss whether it has a tracking system for trees, other than one to ensure its contractor is completing required work.
Condition	In its 2021 WMP BVES shall detail: <ol style="list-style-type: none"> how it tracks its trees or groups of trees to ensure they are treated according to an appropriate schedule and appropriate specifications that ensure they do not pose a risk of wildfire, and whether this tracking documents the condition of trees to ensure they are maintained in proper condition over time.

BVES-10	PSPS
Class	B
Deficiency	<p>Because BVES' PSPS activity is governed at least in part by what SCE does, BVES should have better plans in place in the event a PSPS event occurs in its service territory. It is not adequate simply to state that BVES has not had a PSPS event. In combination with BVES' failure to have information on its access and functional needs population, BVES lacks overall preparedness.</p> <p>BVES' statement that "Customer Service staff and/or additional staff may be called out to assist with notification procedures as needed" shows a lack of understanding of the information and notification demands required during and in advance of a PSPS. Short of the effort to work closely with stakeholders, no information is provided on the strategy to minimize public safety risk. In terms of customer communications and mitigating the public safety impact of PSPS on first responders, health care facilities, operations of telecommunications infrastructure and water utilities/agencies, BVES' only statement is that it has worked and will continue to work with the named entities. Finally, Bear Valley lacks a communication strategy for providing in-language material, and material for customers with AFN. Several Commission decisions already impose these requirements, but it is unclear whether BVES is currently in compliance with any of them.</p>
Condition	<p>In its first quarterly report, BVES shall detail:</p> <ul style="list-style-type: none"> i. its strategy to minimize public safety risk during high wildfire risk conditions (including the list and description of community assistance locations and services provided during a de-energization event and a communication strategy) sufficient to address the needs of the population in those areas, including Limited English Proficiency and Access and Functional Needs (AFN) populations ii. a plan for customer communications and mitigating the public safety impact of PSPS on first responders, health care facilities, operations of telecommunications infrastructure and water utilities/agencies iii. how it would restore power after a PSPS event.

BVES-11	BVES did not report an ability to identify and support customers with access and functional needs (AFN).
Class	B
Deficiency	BVES is required both in the context of PSPS and for disaster preparedness purposes generally to know which of its customers have access and functional needs so that they can receive assistance in preparation for and during an emergency.
Condition	In a first quarterly report, BVES shall describe: <ol style="list-style-type: none"> how it will identify and support customers with access and functional needs during PSPS, emergencies or other disasters.

BVES-12	Undergrounding (Related to BVES-1).
Class	B
Deficiency	BVES plans to underground most of its assets even though it has had no ignitions, fires or PSPS events and has seen a decreasing trend in near miss incidents in recent years.
Condition	In its first quarterly report, BVES shall describe: <ol style="list-style-type: none"> all reasonable alternatives it has considered in addition to undergrounding, whether an option other than undergrounding will achieve comparable reduction in outage and ignition frequency and probability, how the capital and maintenance cost for undergrounding and alternatives compare, and the expected life of undergrounded vs. overhead assets.

BVES-13	Overall lack of an emergency preparedness plan.
Class	C
Deficiency	BVES must have an emergency plan in place, both for wildfire and PSPS events, as discussed in the section on Grid Operations and Protocols. Lack of ignition in the past does not mean the utility will not have events in the future, and we are concerned it is generally unprepared to meet this challenge.
Condition	In its 2021 WMP, BVES shall: <ol style="list-style-type: none"> i. set forth its emergency planning and preparedness for wildfire, including customer support before, during and after a wildfire, including support for low income customers, billing adjustments, deposit waivers, extended payment plan, suspension of disconnection and nonpayment fees, and repairs, ii. describe emergency communications before, during, and after a wildfire in English, Spanish, and other languages required by the Commission, and iii. address plans for coordination with first responders and other public safety organizations, plans to prepare for and restore service, including workforce mobilization and prepositioning of equipment and employees, and a showing that it has an adequate and trained workforce to promptly restore service after a major event.

BVES-14	"As needed" community engagement insufficient.
Class	C
Deficiency	It is not sufficient for BVES simply to state that it will engage with its community "as needed." It must plan now in the event of wildfire or PSPS emergencies later. No established program is in place for community engagement, which is conducted on an "as-needed" basis. BVES needs to take the initiative to better work with the community, with areas of focus such as PSPS, vegetation management, and inspections.
Condition	In its 2021 WMP, BVES shall: <ol style="list-style-type: none"> establish and describe its program regarding customer outreach and engagement, including community meetings with proper input from the community, such as surveys, with a process to change procedures and the WMP based off such input.

BVES-15	Collaboration.
Class	B
Deficiency	In terms of collaboration with outside agencies and entities in order to make use of best practices and lessons learned, in table 30, BVES states there is existing cooperation but gives no details.
Condition	In its first quarterly report, BVES shall describe how: <ol style="list-style-type: none"> it collaborates with outside agencies, it uses best practices, and it acts on lessons learned from this collaboration.

(End of Appendix A)

APPENDIX B

Detailed Figures & Charts

0. Description of Data Sources

All figures reference the latest submitted versions of 2020 WMPs as of April 10th, 2020. Data is pulled from Tables 1-31 of Utility WMPs unless stated otherwise.

By utility, the WMPs referenced in this document are:

PG&E	Update to WMP submitted March 17 th , 2020
SCE	Revision 02 to WMP
SDG&E	Update to WMP submitted March 10 th , 2020
Liberty CalPeco	Update to WMP submitted February 28 th , 2020
PacifiCorp	Update to WMP submitted February 26 th , 2020
Bear Valley Electric Service	Update to WMP submitted February 26 th , 2020
Horizon West Transmission	Update to WMP submitted February 28 th , 2020
Trans Bay Cable	Update to WMP submitted February 28 th , 2020

All are available at cpuc.ca.gov/wildfiremitigationplans.

All the analysis and corresponding figures presented in this appendix rely upon data that is self-reported by the utilities. By utilizing and presenting this self-reported data in this appendix, the WSD is not independently validating that all data elements submitted by utilities are accurate. The WSD will continue to evaluate utility data, conduct data requests, and conduct additional compliance activities to ensure that data provided is accurate.

1. Figures

CONTENTS


1.1 WILDFIRE RISK EXPOSURE	B6
FIGURE 1.1A: COMPARISON OF DATA SOURCES FOR CIRCUIT TYPOLOGIES.....	B6
FIGURE 1.1B: CIRCUIT TOPOLOGY BREAKDOWN BY OVERHEAD AND UNDERGROUND CIRCUIT MILES	B7
FIGURE 1.2A: OVERHEAD CIRCUIT MILES BY HFTD TIER (LARGE UTILITIES)	B8
FIGURE 1.2B: OVERHEAD CIRCUIT MILES BY HFTD TIER (SMALL UTILITIES).....	B9
FIGURE 1.3A: BREAKDOWN OF OVERHEAD TRANSMISSION AND DISTRIBUTION CIRCUIT MILES BY HFTD AND WUI LOCATION (LARGE UTILITIES).....	B10
FIGURE 1.3B: BREAKDOWN OF OVERHEAD TRANSMISSION AND DISTRIBUTION CIRCUIT MILES BY HFTD AND WUI LOCATION (SMALL UTILITIES).....	B11
FIGURE 1.4A: BREAKDOWN OF OVERHEAD TRANSMISSION AND DISTRIBUTION CIRCUIT MILES BY HFTD AND POPULATION DENSITY (LARGE UTILITIES)	B12
FIGURE 1.4B: BREAKDOWN OF OVERHEAD TRANSMISSION AND DISTRIBUTION CIRCUIT MILES BY HFTD AND POPULATION DENSITY (SMALL UTILITIES)	B13
FIGURE 1.5A: RED FLAG WARNING CIRCUIT MILE DAYS PER YEAR BY UTILITY (LARGE UTILITIES)	B14
FIGURE 1.5B: RED FLAG WARNING CIRCUIT MILE DAYS PER YEAR BY UTILITY (SMALL UTILITIES).....	B15
FIGURE 1.5C: 95 TH AND 99 TH PERCENTILE WIND CONDITIONS (LARGE UTILITIES)	B16
FIGURE 1.5D: 95 TH AND 99 TH PERCENTILE WIND CONDITIONS (SMALL UTILITIES).....	B17
1.2 OUTCOME METRICS.....	B18
FIGURE 2.1A: ASSET INSPECTION FINDINGS NORMALIZED BY TOTAL CIRCUIT MILEAGE (LARGE UTILITIES)	B18
FIGURE 2.1B: ASSET INSPECTION FINDINGS NORMALIZED BY TOTAL CIRCUIT MILEAGE (SMALL UTILITIES)	B19
FIGURE 2.2A: NEAR MISS INCIDENTS NORMALIZED BY OVERHEAD CIRCUIT MILEAGE (LARGE UTILITIES)	B20
FIGURE 2.2B: NEAR MISS INCIDENTS NORMALIZED BY OVERHEAD CIRCUIT MILEAGE (SMALL UTILITIES).....	B21
FIGURE 2.3A: NUMBER OF IGNITIONS, NORMALIZED BY OVERHEAD CIRCUIT MILEAGE (LARGE UTILITIES)	B22
FIGURE 2.3B: NUMBER OF IGNITIONS, NORMALIZED BY OVERHEAD CIRCUIT MILEAGE (SMALL UTILITIES).....	B23

FIGURE 2.4A: TOTAL IGNITIONS BY HFTD LOCATION (LARGE UTILITIES).....	B24
FIGURE 2.4B: TOTAL IGNITIONS BY HFTD LOCATION (SMALL UTILITIES)	B25
FIGURE 2.5A: IGNITIONS BY IGNITION PROBABILITY DRIVER TYPE (LARGE UTILITIES)	B26
FIGURE 2.5B: IGNITIONS BY IGNITION PROBABILITY DRIVER TYPE (SMALL UTILITIES)	B27
FIGURE 2.6A: DETAIL: SHARE OF IGNITIONS DUE TO EACH IGNITION PROBABILITY DRIVER (LARGE UTILITIES)	B28
FIGURE 2.6B: DETAIL: SHARE OF IGNITIONS DUE TO EACH IGNITION PROBABILITY DRIVER (SMALL UTILITIES)	B29
FIGURE 2.7A: ACTUAL AND PROJECTED IGNITIONS FOR TOP IGNITION DRIVERS, 2019 AND 2022	B30
FIGURE 2.7B: PG&E DETAIL: ACTUAL AND PROJECTED IGNITIONS FOR TOP IGNITION DRIVERS, 2019 AND 2022.....	B31
FIGURE 2.7C: SCE DETAIL: ACTUAL AND PROJECTED IGNITIONS FOR TOP IGNITION DRIVERS, 2019 AND 2022	B32
FIGURE 2.8A: NORMALIZED PSPS DURATION IN CUSTOMER HOURS (LARGE UTILITIES).....	B33
FIGURE 2.8B: NORMALIZED PSPS DURATION IN CUSTOMER HOURS (SMALL UTILITIES)	B34
FIGURE 2.8C: PSPS IMPACTS ON CRITICAL INFRASTRUCTURE	B35
FIGURE 2.9A: NORMALIZED AREA BURNED BY UTILITY IGNITED WILDFIRE (LARGE UTILITIES)	B36
FIGURE 2.9B: NORMALIZED AREA BURNED BY UTILITY IGNITED WILDFIRE (SMALL UTILITIES)	B37
FIGURE 2.10: NUMBER OF STRUCTURES DAMAGED BY UTILITY IGNITED WILDFIRE	B38
FIGURE 2.11: FATALITIES DUE TO UTILITY IGNITED WILDFIRE	B39
1.3 RESOURCE ALLOCATION.....	B40
FIGURE 3.1A: OVERVIEW OF TOTAL PLAN SPEND ACROSS UTILITIES (LARGE UTILITIES)	B40
FIGURE 3.1B: OVERVIEW OF TOTAL PLAN SPEND ACROSS UTILITIES (SMALL UTILITIES)	B41
FIGURE 3.2A: OVERVIEW OF TOTAL PLAN SPEND ACROSS UTILITIES (LARGE UTILITIES)	B42
FIGURE 3.2B: OVERVIEW OF TOTAL PLAN SPEND ACROSS UTILITIES (SMALL UTILITIES)	B43
FIGURE 3.3A: BREAKDOWN OF PLANNED SPEND BY CATEGORY (LARGE UTILITIES)	B44
FIGURE 3.3B: BREAKDOWN OF PLANNED SPEND BY CATEGORY (SMALL UTILITIES)	B45
FIGURE 3.4A: PG&E RESOURCE ALLOCATION DETAIL FOR TOP 5 INITIATIVES BY PLANNED SPEND	B46
FIGURE 3.4B: PG&E RESOURCE ALLOCATION DETAIL FOR TOP 4 CATEGORIES BY PLANNED SPEND.....	B47
FIGURE 3.5A: SCE RESOURCE ALLOCATION DETAIL FOR TOP 5 INITIATIVES BY PLANNED SPEND	B48
FIGURE 3.5B: SCE RESOURCE ALLOCATION DETAIL FOR TOP 4 CATEGORIES BY PLANNED SPEND	B49
FIGURE 3.6A: SDG&E RESOURCE ALLOCATION DETAIL FOR TOP 5 INITIATIVES BY PLANNED SPEND.....	B50

FIGURE 3.6B: SDG&E RESOURCE ALLOCATION DETAIL FOR TOP 4 CATEGORIES BY PLANNED SPEND	B51
FIGURE 3.7: LIBERTY RESOURCE ALLOCATION DETAIL FOR TOP 5 INITIATIVES BY PLANNED SPEND	B52
FIGURE 3.8: PACIFICORP RESOURCE ALLOCATION DETAIL FOR TOP 5 INITIATIVES BY PLANNED SPEND	B53
FIGURE 3.9: BEAR VALLEY RESOURCE ALLOCATION DETAIL FOR TOP 5 INITIATIVES BY PLANNED SPEND.....	B54
FIGURE 3.10: HORIZON WEST TRANSMISSION ALLOCATION DETAIL FOR ALL PLANNED INITIATIVES	B55

1.1 Wildfire Risk Exposure


Figure 1.1a: Comparison of data sources for circuit typologies



Note: In their 2020 WMPs, PG&E and SCE only reported circuit mileage data for overhead facilities. Based on the best available historical data on circuit mileage and grid topology in the Commission's possession, PG&E is reported to have 84% of its total line miles overhead, and SCE is reported to have 62% of its total line miles overhead. While the 2020 WMP Guidelines directed the utilities to report their grid topology breakdown by circuit miles, rather than line miles, the percentages overhead and underground are expected to be similar. The WSD will issue a data request to confirm accurate underground circuit mileage numbers.

Source: SED standard data requests for annual grid data (reflect values as of December 2018), WMP Table 13


Figure 1.1b: Circuit topology breakdown by overhead and underground circuit miles



1. Trans Bay Cable did not report underground circuit miles in Table 13 of the WMP, but mentioned on page 8 of its WMP that it had 53 circuit miles of underground submarine cable, which is reflected in this chart.

Source: WMP Table 13


Figure 1.2a: Overhead circuit miles by HFTD Tier (Large Utilities)
Broken out by distribution (dist.) and transmission (transm.)



Note: Zone 1 not shown as subtotal.

Source: WMP Table 13


Figure 1.2b: Overhead circuit miles by HFTD Tier (Small Utilities)
Broken out by distribution (dist.) and transmission (transm.)



Note: Zone 1 not shown as subtotal.


Source: WMP Table 13

Figure 1.3a: Breakdown of overhead transmission and distribution circuit miles by HFTD and WUI location (Large utilities)



Source: WMP Table 13


Figure 1.3b: Breakdown of overhead transmission and distribution circuit miles by HFTD and WUI location (Small utilities)



Note: Trans Bay Cable and Horizon West Transmission are not shown. Trans Bay Cable is almost entirely underground and submarine, and Horizon West Transmission did not yet have operational facilities at the time it submitted its 2020 WMP.

Source: WMP Table 13


Figure 1.4a: Breakdown of overhead transmission and distribution circuit miles by HFTD and population density (Large utilities)



Note: SDG&E did not report breakdown of circuit mileage between areas of different population densities.


Source: WMP Table 13

Figure 1.4b: Breakdown of overhead transmission and distribution circuit miles by HFTD and population density (Small utilities)



Source: WMP Table 13


Figure 1.5a: Red flag warning circuit mile days per year by utility (Large utilities)



Note: A “Red Flag Warning (RFW) Circuit Mile Day” is intended to capture the duration and scope of the fire weather that year. It is defined on page 5 of the 2020 WMP Guidelines to be calculated as the number of circuit miles that were under a RFW multiplied by the number of days those miles were under said RFW. For example, if 100 circuit miles were under a RFW for 1 day, and 10 of those miles were under RFW for an additional day, then the total RFW circuit mile days would be 110.

Source: WMP Table 10


Figure 1.5b: Red flag warning circuit mile days per year by utility (Small utilities)



Note: A “Red Flag Warning (RFW) Circuit Mile Day” is intended to capture the duration and scope of the fire weather that year. It is defined on page 5 of the 2020 WMP Guidelines to be calculated as the number of circuit miles that were under a RFW multiplied by the number of days those miles were under said RFW. For example, if 100 circuit miles were under a RFW for 1 day, and 10 of those miles were under RFW for an additional day, then the total RFW circuit mile days would be 110.

Source: WMP Table 10


Figure 1.5c: 95th and 99th percentile wind conditions (Large utilities)



Note: Utilities were directed to report historical conditions as conditions over 10 prior years, 2005-2014. SCE appears to have instead reported historical conditions over the 5 prior years, 2009-2014, thus using a different baseline to calculate 95th and 99th percentile wind speeds. More information is needed to fully address potential inconsistencies between utilities. PG&E stated that 2019 data would not be available until late Q2 2020.

Source: WMP Table 10

Figure 1.5d: 95th and 99th percentile wind conditions (Small utilities)




Note: Historical conditions refer to conditions over 10 prior years, 2005-2014.

Source: WMP Table 10

1.2 Outcome Metrics


Figure 2.1a: Asset inspection findings normalized by total circuit mileage (Large utilities)



Note: Utilities reported their inspection findings as normalized by total circuit miles in Table 1 of their WMPs.

Source: WMP Table 1


Figure 2.1b: Asset inspection findings normalized by total circuit mileage (Small utilities)



Note: Utilities reported their inspection findings as normalized by total circuit miles in Table 1 of their WMPs. In Table 1, Liberty reported inspection findings in miles between findings rather than in findings per circuit mile as the 2020 WMP Guidelines directed. To represent inspection findings in a way consistent with the reporting of other utilities, the WSD inverted the metric reported by Liberty to show inspection findings in findings per circuit mile in this chart. Bear Valley reported inspecton findings normalized per overhead cirucit mile rather than per total cirucit mile as instructed. For consistency, the WSD re-normalized these findings per total circuit mile using data from Table 13.

Source: WMP Table 1


Figure 2.2a: Near miss incidents normalized by overhead circuit mileage (Large utilities)



Note: The measurement of each 'near miss' is not yet perfectly standardized across utilities. The WSD will work toward a more standardized approach for tracking and classifying near miss data for 2021 WMPs. A near miss was defined in the 2020 WMP Guidelines as "An event with significant probability of ignition, including wires down, contacts with objects, line slap, events with evidence of significant heat generation, and other events that cause sparking or have the potential to cause ignition."

Source: Tables 11a and 11b from utility WMPs and data requests, normalized by data from Table 13 of utility WMPs; SDG&E equipment failure numbers adjusted to address inconsistencies in subtotal calculations provided by SDG&E.

Figure 2.2b: Near miss incidents normalized by overhead circuit mileage (Small utilities)




Note: The measurement of each 'near miss' is not yet perfectly standardized across utilities. The WSD will work toward a more standardized approach for tracking and classifying near miss data for 2021 WMPs. A near miss was defined in the 2020 WMP Guidelines as "An event with significant probability of ignition, including wires down, contacts with objects, line slap, events with evidence of significant heat generation, and other events that cause sparking or have the potential to cause ignition."

For PacifiCorp, the largest drivers of "Other" near misses were "Other" (50% on average over the 5 year period) and "Unknown" (42% on average over the 5 year period).


Source: Tables 11a and 11b from utility WMPs and data requests, normalized by data from Table 13 of utility WMPs; BVES numbers adjusted to address inconsistencies in subtotal calculations provided.

Figure 2.3a: Number of ignitions, normalized by overhead circuit mileage (Large utilities)



Source: Tables 11a and 11b from utility WMPs and data requests normalized by data from Table 13 of utility WMPs; SDG&E equipment failure numbers adjusted to address inconsistencies in subtotal calculations provided.


Figure 2.3b: Number of ignitions, normalized by overhead circuit mileage (Small utilities)



Note: Total number of ignitions only shown for utilities and years where ignitions were greater than zero.

Source: Tables 11a and 11b from utility WMPs and data requests normalized by data from Table 13 of utility WMPs; PacifiCorp numbers adjusted to account for Tables 11c and 11d.


Figure 2.4a: Total ignitions by HFTD location (Large utilities)



Note: Ignitions in Zone 1 HFTD areas make up less than 1% of total ignitions.

Source: Table 2 from utility WMPs


Figure 2.4b: Total ignitions by HFTD location (Small utilities)



Note: Ignitions in Zone 1 HFTD areas make up less than 1% of total ignitions.


Source: Table 2 from utility WMPs

Figure 2.5a: Ignitions by ignition probability driver type (Large utilities)



Source: Tables 11a and 11b from utility WMPs and data requests normalized by data from Table 13 of utility WMPs; SDG&E equipment failure numbers adjusted to address inconsistencies in subtotal calculations provided.


Figure 2.5b: Ignitions by ignition probability driver type (Small utilities)



Note: Since Liberty and PacifiCorp have less than 10,000 overhead circuit miles, their average number of total annual ignitions per 10,000 circuit miles is greater than their average number of total annual ignitions.

Source: Tables 11a and 11b from utility WMPs and data requests, normalized by data from Table 13 of utility WMPs; PacifiCorp numbers adjusted to account for Tables 11c and 11d.


Figure 2.6a: Detail: Share of ignitions due to each ignition probability driver (Large utilities)



Note: Conductor failure includes conductor failure (as reported), splice, clamp and connector. Other includes wire to wire contact / contamination.

Source: Tables 11a and 11b from utility WMPs and data request normalized by data from Table 13 of utility WMPs; SDG&E equipment failure numbers adjusted to address inconsistencies in subtotal calculations provided. Since SDG&E has less than 10,000 overhead circuit miles, its average number of total annual ignitions per 10,000 circuit miles is greater than its average number of total annual ignitions.


Figure 2.6b: Detail: Share of ignitions due to each ignition probability driver (Small utilities)



Note: Conductor failure includes conductor failure (as reported), splice, clamp and connector. Other includes wire-to-wire contact / contamination. Since Liberty and PacifiCorp have less than 10,000 overhead circuit miles, their average number of total annual ignitions per 10,000 circuit miles is greater than their average number of total annual ignitions.

Source: Tables 11a and 11b from utility WMPs and data requests, normalized by data from Table 13 of utility WMPs; PacifiCorp numbers adjusted to account for Tables 11c and 11d.

Figure 2.7a: Actual and projected ignitions for top ignition drivers, 2019 and 2022




Note: Projections assume WMP implementation according to plan and weather patterns consistent with 5 year historical average. See the 2020 WMP Guidelines for further detail.

Small utilities populated Table 31 either not at all or with all zeroes. Specifically: Horizon West Transmission left it blank as it did not yet have operational facilities when it submitted its 2020 WMP; Trans Bay Cable and Bear Valley Electric Service reported anticipating no ignitions (having seen no ignitions in the past 5 years); Liberty did not populate Table 31; PacifiCorp reported only a general reducing trend anticipated with no discrete data available.

Source: Tables 11a, 11b, 31a, and 31b from utility WMPs and data requests; SDG&E equipment failure numbers adjusted to address inconsistencies in subtotal calculations provided by SDG&E.


Figure 2.7b: PG&E Detail: Actual and projected ignitions for top ignition drivers, 2019 and 2022
Figure shows reported 2019 ignitions and projected future ignitions by driver category, for transmission and distribution



Note: Projections assume WMP implementation according to plan and weather patterns consistent with 5 year historical average. See the 2020 WMP Guidelines for more information on assumptions made.

Source: Tables 11a, 11b, 31a, and 31b from PG&E WMP and data requests


Figure 2.7c: SCE Detail: Actual and projected ignitions for top ignition drivers, 2019 and 2022
Figure shows reported 2019 ignitions and projected future ignitions by driver category, for transmission and distribution



Source: Tables 11a, 11b, 31a, and 31b from SCE WMP and data requests

Note: Projections assume WMP implementation according to plan and weather patterns consistent with 5 year historical average. See the 2020 WMP Guidelines for more information on assumptions made.

Figure 2.8a: Normalized PSPS duration in customer hours (Large utilities)




Note: Normalization using RFW circuit mile days helps take into account fire weather conditions based on a commonly used metric; more detail is necessary to address potential inconsistencies in how each utility calculates this figure. A “Red Flag Warning (RFW) Circuit Mile Day” is intended to capture the duration and scope of the fire weather that year and is calculated as the number of circuit miles that were under a RFW multiplied by the number of days those miles were under said RFW (per page 5 of the 2020 WMP Guidelines). For example, if 100 circuit miles were under a RFW for 1 day, and 10 of those miles were under RFW for an additional day, then the total RFW circuit mile days would be 110.

Utilities' ability to implement PSPS (including accurate predictions and customer communication) is captured in the Utility Wildfire Mitigation Maturity Model's "PSPS operating model and consequence mitigation" capability.

Source: Table 12 of utility WMPs.

Figure 2.8b: Normalized PSPS duration in customer hours (Small utilities)

Customer hours of PSPS, normalized per Red Flag Warning (RFW) circuit mile day




Note: Normalization using RFW circuit mile days helps take into account fire weather conditions based on a commonly used metric; more detail is necessary to address potential inconsistencies in how each utility calculates this figure. A “Red Flag Warning (RFW) Circuit Mile Day” is intended to capture the duration and scope of the fire weather that year and is calculated as the number of circuit miles that were under a RFW multiplied by the number of days those miles were under said RFW (per page 5 of the 2020 WMP Guidelines). For example, if 100 circuit miles were under a RFW for 1 day, and 10 of those miles were under RFW for an additional day, then the total RFW circuit mile days would be 110.

Utilities' ability to implement PSPS (including accurate predictions and customer communication) is captured in the Utility Wildfire Mitigation Maturity Model's "PSPS operating model and consequence mitigation" capability.

Source: Table 12 of utility WMPs.

Figure 2.8c: PSPS impacts on critical infrastructure




Note: Count is based on number of critical infrastructure locations impacted per hour multiplied by hours offline per year

Source: Table 2 of utility WMPs

Figure 2.9a: Normalized area burned by utility ignited wildfire (Large utilities)


Acres burned, per 1,000 Red Flag Warning (RFW) circuit mile days



Note: Normalization using RFW circuit mile days helps take into account fire weather conditions based on a commonly used metric. A “Red Flag Warning (RFW) Circuit Mile Day” is intended to capture the duration and scope of the fire weather that year. It is defined on page 5 of the 2020 WMP Guidelines to be calculated as the number of circuit miles that were under a RFW multiplied by the number of days those miles were under said RFW. For example, if 100 circuit miles were under a RFW for 1 day, and 10 of those miles were under RFW for an additional day, then the total RFW circuit mile days would be 110. To address inconsistencies in how utilities normalized this metric in Table 2 of their WMPs, this table shows number of acres burned as reported in Table 2 normalized by RFW Circuit Mile Days as reported in Table 10.

Source: Table 2 and Table 10 of utility WMPs.


Figure 2.9b: Normalized area burned by utility ignited wildfire (Small utilities)



Note: Normalization using RFW circuit mile days helps take into account fire weather conditions based on a commonly used metric. A “Red Flag Warning (RFW) Circuit Mile Day” is intended to capture the duration and scope of the fire weather that year. It is defined on page 5 of the 2020 WMP Guidelines to be calculated as the number of circuit miles that were under a RFW multiplied by the number of days those miles were under said RFW. For example, if 100 circuit miles were under a RFW for 1 day, and 10 of those miles were under RFW for an additional day, then the total RFW circuit mile days would be 110. To address inconsistencies in how utilities normalized this metric in Table 2 of their WMPs, this table shows number of acres burned as reported in Table 2 normalized by RFW Circuit Mile Days as reported in Table 10.

Source: Table 2 and Table 10 of utility WMPs.

Figure 2.10: Number of structures damaged by utility ignited wildfire




No SMJUs or ITOs reported number of structures damaged over the past 5 years

Note: Normalization using RFW circuit mile days helps take into account fire weather conditions based on a commonly used metric. A “Red Flag Warning (RFW) Circuit Mile Day” is intended to capture the duration and scope of the fire weather that year. It is defined on page 5 of the 2020 WMP Guidelines to be calculated as the number of circuit miles that were under a RFW multiplied by the number of days those miles were under said RFW. For example, if 100 circuit miles were under a RFW for 1 day, and 10 of those miles were under RFW for an additional day, then the total RFW circuit mile days would be 110.

This figure is shown for IOUs only because the smaller utilities did not report structures damaged in a comparable way. PacifiCorp reported the value of assets destroyed, rather than number of structures damaged; Liberty reported no homes destroyed, only 18 utility poles; and no other SMJUs or ITOs reported any structures damaged.

Source: Table 2 of utility WMPs.

Figure 2.11: Fatalities due to utility ignited wildfire



No SMJUs or ITOs reported fatalities due to utility ignited wildfire over the past 5 years

Note: Normalization using RFW circuit mile days helps take into account fire weather conditions based on a commonly used metric. A “Red Flag Warning (RFW) Circuit Mile Day” is intended to capture the duration and scope of the fire weather that year. It is defined on page 5 of the 2020 WMP Guidelines to be calculated as the number of circuit miles that were under a RFW multiplied by the number of days those miles were under said RFW. For example, if 100 circuit miles were under a RFW for 1 day, and 10 of those miles were under RFW for an additional day, then the total RFW circuit mile days would be 110.

Source: Table 2 of utility WMPs.

1.3 Resource Allocation

Figure 3.1a: Overview of total plan spend across utilities (Large utilities)

	PG&E	SCE	SDG&E
Total spend	2019 planned spend	\$2,296M	\$671M
	2019 actual spend	\$2,999M	\$307M
	2020 planned spend	\$3,171M	\$1,606M
	2021 planned spend	\$3,130M	\$444M
	2022 planned spend	\$3,247M	\$445M
	Total planned spend as for 2020, 2021 and 2022, as reported by utility	\$9,548M	\$4,511M
Normalized spend	\$1,336M ¹		
	Total planned spend for 2020, 2021 and 2022 per overhead HFTD circuit mile	\$307K	\$318K
			\$291K

1. Totals for SDG&E include a calculation error on the part of SDG&E in which the sum of the reported spend for 2020, 2021, and 2022 is not equal to the reported total 2020-2022 planned spend. This error has not been corrected by the WSD in this table.

Note: "M" stands for millions, "K" stands for thousands.

Source: Tables 21-30 from utility WMPs and data requests, normalized by data from Table 13 of utility WMPs

Figure 3.1b: Overview of total plan spend across utilities (Small utilities)


	Liberty	PacifiCorp	Bear Valley	Horizon West	Trans Bay Cable
Total spend	2019 planned spend	\$4M	\$1M	\$12M	\$0M
	2019 actual spend	\$7M	\$13M	\$12M	\$0M
	2020 planned spend	\$30M	\$26M	\$84M	\$4M
	2021 planned spend	\$32M	\$38M	\$79M	\$4M
	2022 planned spend	\$27M	\$37M	\$79M	\$0M
	Total planned spend as for 2020, 2021 and 2022, as reported by utility	\$88K¹	\$101M¹	\$247M¹	\$8M
Normalized spend	Total planned spend for 2020, 2021 and 2022 per overhead HFTD circuit mile	\$63K	\$86K	\$1,168K	NA – no operational facilities as of WMP submission
					\$0K

1. Totals for Liberty, PacifiCorp, and Bear Valley include calculation errors on the part of utilities in which the reported sum of the spend for 2020, 2021, and 2022 is not equal to the total reported 2020-2022 planned spend. This error has not been corrected by the WSD in this table.

Note: "M" stands for millions, "K" stands for thousands.

Source: Tables 21-30 from utility WMPs and data requests, normalized by data from Table 13 of utility WMPs


Figure 3.2a: Overview of total plan spend across utilities (Large utilities)



1. Totals for SDG&E include a calculation error on the part of SDG&E which has not been corrected by the WSD in this chart. Specifically, the sum of the reported spend for 2020, 2021, and 2022 is not equal to the reported total 2020-2022 spend as reported by SDG&E.

Source: Tables 21-30 from utility WMPs and data requests, normalized by data from Table 13 of utility WMPs

Figure 3.2b: Overview of total plan spend across utilities (Small utilities)



1. Totals for Liberty, PacifiCorp and Bear Valley include calculation errors on the part of those utilities which have not been corrected by the WSD in this chart. Specifically, the sum of the spend for 2020, 2021, and 2022 is not equal to the total 2020-2022 spend as reported by those utilities.

Note: Spending for ITOs not shown here. Trans Bay Cable reports no planned spend. Horizon West Transmission (HWT) does not yet have operational facilities but reports up to \$8M in planned spending, shown in HWT detailed appendix.

Source: Tables 21-30 from utility WMPs and data requests, normalized by data from Table 13 of utility WMPs

Figure 3.3a: Breakdown of planned spend by category (Large utilities)

Total plan spend is shown for 2020-2022 plan period as calculated by utility

Category	PG&E		SCE		SDG&E	
	Total plan spend, \$M	% of total	Total plan spend, \$M	% of total	Total plan spend, \$M	% of total
Grid design / system hardening	5,102	53%	3,162	70%	853	64%
Vegetation mgt. and inspections	2,645	28%	583	13%	187	14%
Asset mgt. and inspections	499	5%	232	5%	146	11%
Grid operations and protocols	788	8%	198	4%	68 ¹	5%
Data governance	177	2%	39	1%	1	0%
Situational awareness and forecasting	140	2%	90	2%	24	2%
Emergency planning and preparedness	114	1%	72	2%	18	1%
Stakeholder cooperation & community engagement	84	1%	0	0%	0	0%
Resource allocation methodology	0	0%	133	3%	26	2%
Risk assessment and mapping	0	0%	0	0%	14	1%
Total plan, 2020-2022	9,548	100%	4,511	100%	1,336	100%

1. SDG&E has reported an incorrect total (reported 2020-2022 total plan spend is not equal to the sum of planned 2020, 2021, and 2022 spend). This error has not been corrected by the WSD in this table.

Source: Tables 21-30 of utility WMPs

Figure 3.3b: Breakdown of planned spend by category (Small utilities)

Total plan spend is shown for 2020-2022 plan period as calculated by utility

Category	Liberty		PacifiCorp		Bear Valley	
	Total plan spend, \$M	% of total	Total plan spend, \$M	% of total	Total plan spend, \$M	% of total
Grid design / system hardening	45	51%	68	68%	222 ¹	90%
Vegetation mgt. and inspections	28	31%	22	22%	10	4%
Asset mgt. and inspections	11 ¹	13%	4 ¹	4%	10	4%
Grid operations and protocols	0	0%	6	6%	1	0%
Data governance	1	2%		0%	0	0%
Situational awareness and forecasting	2	2%	1	1%	4	2%
Emergency planning and preparedness	1	1%	0	0%	0	0%
Stakeholder cooperation & community engagement	0	0%	0	0%	0	0%
Resource allocation methodology	0	0%	0	0%	0	0%
Risk assessment and mapping	0	0%	0	0%	0	0%
Total plan, 2020-2022	88	100%	101	100%	247	100%

1. Totals for Liberty, PacifiCorp, and BVES include calculation errors on the part of utilities where reported 2020-2022 plan total spend is different from the sum of reported spend for 2020, 2021 and 2022. These errors have not been corrected by the WSD in this table.

Source: Tables 21-30 of utility WMPs

Figure 3.4a: PG&E resource allocation detail for top 5 initiatives by planned spend

Total plan spend is shown for 2020-2022 plan period as calculated by utility

Initiative	Category	Planned spend, \$M					2020-2022 plan total	Initiative spend as percent of total planned spend
		2019 plan	2019 actual	2020 plan	2021 plan	2022 plan		
1 17-1. Updates to grid topology to minimize risk of ignition in HFTDs - System Hardening, Distribution	Grid design and system hardening	229	287	367	566	698	1,631	17%
2 15. Remediation of at-risk species - Enhanced Vegetation Management	Vegetation management and inspections	295	424	449	463	477	1,388	15%
3 15. Transmission tower maintenance and replacement	Grid design and system hardening	444	750	297	305	312	914	10%
4 6. Distribution pole replacement and reinforcement, including with composite poles	Grid design and system hardening	255	109	212	218	223	654	7%
5 12-4. Other corrective action - Distribution	Grid design and system hardening	322	167	200	205	210	614	6%
Total spend for top 5 initiatives by planned spend		1,545	1,738	1,525	1,756	1,920	5,201	54%

Source: Tables 21-30 of utility WMP

Figure 3.4b: PG&E resource allocation detail for top 4 categories by planned spend

Total plan spend is shown for 2020-2022 plan period as calculated by utility

Category	Total Category Planned Spend	Category spend as percent of total planned spend	Top 3 initiatives by planned spend in category Initiative names as reported in WMP	Initiative spend as percent of total planned spend
Grid design and system hardening	\$5.1B	53%	17-1. System Hardening, Distribution 15. Transmission tower maintenance and replacement 6. Distribution pole replacement and reinforcement, including with composite poles	17% 10% 7%
Vegetation management and inspections	\$2.6B	28%	15. Remediation of at-risk species-Enhanced Veg Mgt. 2. Detailed inspections of vegetation-Distribution 9. Other discretionary inspection of veg. around distribution lines and equipment, beyond those required by regulations	15% 6% 3%
Asset management of inspections	\$499M	5%	1. Detailed inspections of distribution electric lines/equip. 2. Detailed inspections of transmission electric lines/equip. 15-1 Substation inspections - Transmission Substation	3% 2% 0%
Grid operations and protocols	\$788M	8%	5-1. PSPS events and mitigation of PSPS impacts-Distribution 5-3. PSPS events and mitigation of PSPS impacts - Additional PSPS Mitigation Initiatives, Distribution 2. Crew-accompanying ignition prevention and suppression resources and services	4% 2% 1%

Note: "M" stands for millions, "B" stands for billions.

Source: Tables 21-30 of utility WMP

Figure 3.5a: SCE resource allocation detail for top 5 initiatives by planned spend

Total plan spend is shown for 2020-2022 plan period as calculated by utility

Initiative	Category	Planned spend, \$M					2020-2022 plan total	Initiative spend as percent of total planned spend
		2019 plan	2019 actual	2020 plan	2021 plan	2022 plan		
1 3.1. Covered conductor installation: covered conductor (SH-1)	Grid design and system hardening	42	240	454	656	772	1,883	42%
2 12.1. Other corrective action: distribution remediation (SH-12.1)	Grid design and system hardening	192	395	328	125	85	538	12%
3 20. Vegetation management to achieve clearances around electric lines and equipment	Vegetation management and inspections	76	247	76	64	61	201	4%
4 6.1. Distribution pole replacement and reinforcement, including with composite poles: composite poles and crossarms (SH-3)	Grid design and system hardening	5	Reported as "NA" - part of 3.1	57	64	74	194	4%
5 16.1. Removal and remediation of trees with strike potential to electric lines and equipment: hazard tree (VM-1)	Vegetation management and inspections	57	15	54	59	72	186	4%
Total spend for top 5 initiatives by planned spend		372	897	969	969	1063	3002	67%

Source: Tables 21-30 of utility WMP

Figure 3.5b: SCE resource allocation detail for top 4 categories by planned spend
Total plan spend is shown for 2020-2022 plan period as calculated by utility

Category	Total Category Planned Spend	Category spend as percent of total planned spend	Top 3 initiatives by planned spend Initiative names in some cases abbreviated to fit in this table	Initiative spend as percent of total plan spend
Grid design and system hardening	\$3.1B	70%	3.1. Covered conductor installation: covered conductor 12.1. Other corrective action: Distribution remediation 6.1. Distribution pole replacement and reinforcement, including with composite poles: Composite poles and crossarms	42% 12% 4%
Vegetation management and inspections	\$583M	13%	20. Vegetation management to achieve clearances around electric lines and equipment 16.1. Removal and remediation of trees with strike potential to electric lines and equipment: Hazard tree 16.2. Removal and remediation of trees with strike potential to electric lines and equipment: DRI quarterly inspections and tree removals	4% 4% 2%
Asset management of inspections	\$232M	5%	9.2. Distribution aerial inspections 15. Substation inspections 10.2. Transmission aerial inspections	2% 1% 1%
Grid operations and protocols	\$198M	4%	5.8. PSPS events and mitigation of PSPS impacts: SGIP resiliency 5. PSPS events and mitigation of PSPS impacts 5.3. PSPS events and mitigation of PSPS impacts: income qualified critical care (IQCC) customer battery backup incentive program	3% 0% 0%

Source: Tables 21-30 of utility WMP

Figure 3.6a: SDG&E resource allocation detail for top 5 initiatives by planned spend
Total plan spend is shown for 2020-2022 plan period as calculated by utility

Initiative	Category	Planned spend, \$M					2020-2022 plan total	Initiative spend as percent of total plan spend
		2019 plan	2019 actual	2020 plan	2021 plan	2022 plan		
1 Undergrounding of Electric Lines and/or Equipment	Grid design and system hardening	2	5	31	157	188	376	28%
2 Distribution Overhead Fire Hardening (OH)	Grid design and system hardening	75	121	87	12	7	106	8%
3 LTE Communication Network	Grid design and system hardening	11	7	32	32	42	105	8%
4 Tree Trimming	Vegetation management and inspections	Not provided ¹	34	28	28	28	83	6%
5 Drone Inspections (O&M) – Engr and construction	Asset management and inspections	Listed "NA"	Listed "NA"	27	24	20	71	5%
Total spend for top 5 initiatives by planned spend		88	166	204	253	284	741	55%

1. Incorporated into 2019 base costs.

Source: Tables 21-30 of utility WMP

Figure 3.6b: SDG&E resource allocation detail for top 4 categories by planned spend

Total plan spend is shown for 2020-2022 plan period as calculated by utility

Category	Total Category Planned Spend	Category spend as percent of total planned spend	Top 3 initiatives by planned spend	Initiative spend as percent of total planned spend
			Initiative names as reported in WMP	
Grid design and system hardening	\$853M	64%	Undergrounding of Electric Lines and/or Equipment	28%
			Distribution Overhead Fire Hardening (OH)	8%
			LTE Communication Network	8%
Vegetation management and inspections	\$187M	14%	Tree Trimming	6%
			Enhanced Inspections Patrols and Trimming	5%
			Pole Brushing	1%
Asset management of inspections	\$146M	11%	Drone Inspections (O&M) *Engineering & Construction	5%
			Drone Inspections (O&M) *Flights & Assessments	4%
			Drone Inspections (capital)	1%
Grid operations and protocols	\$68M	5%	Aviation Firefighting Program (O&M)	2%
			Aviation Firefighting Program (Capital)	2%
			Communication Practices (O&M) ¹	1%

1. Totals for SDG&E include a calculation error on the part of SDG&E in which the sum of the reported spend for 2020, 2021, and 2022 is not equal to the reported total 2020-2022 planned spend. This error has not been corrected by the WSD in this table.

Note: "M" stands for millions

Source: Tables 21-30 of utility WMP

Figure 3.7: Liberty resource allocation detail for top 5 initiatives by planned spend

Total plan spend is shown for 2020-2022 plan period as calculated by utility

Initiative	Category	Planned spend, \$M					2020-2022 plan total	Initiative spend as percent of total plan spend
		2019 plan	2019 actual	2020 plan	2021 plan	2022 plan		
1 Covered Conductor Installation	Grid design and system hardening	1	1	3	8	10	21	24%
2 Remediation of at-risk-species	Vegetation management and inspections	0	5	5	5	5	14	16%
3 13. Pole loading infrastructure hardening and replacement program based on pole loading assessment program	Grid design and system hardening	1	1	2	3	4	8	9%
4 Undergrounding electric lines and/or equipment	Grid design and system hardening	0	0	2	6	0	8	9%
5 Fuel management and reduction of "slash" from vegetation management activities	Vegetation management and inspections	0	0	2	3	3	7	8%
Total spend for top 5 initiatives by planned spend		2	6	13	24	21	58	66%

Note: "M" stands for millions.

Source: Tables 21-30 of utility WMP

Figure 3.8: PacifiCorp resource allocation detail for top 5 initiatives by planned spend

Total plan spend is shown for 2020-2022 plan period as calculated by utility

Initiative	Category	Planned spend, \$M					2020-2022 plan total	Initiative spend as percent of total plan spend
		2019 plan	2019 actual	2020 plan	2021 plan	2022 plan		
1 3b. Covered conductor installation - distribution	Grid design and system hardening	0	0	8	11	12	31	31%
2 6b. Transmission pole replacement and reinforcement, including with composite poles	Grid design and system hardening	0	0	4	4	4	12	12%
3 3. Covered conductor installation - transmission	Grid design and system hardening	0	0	0	6	6	12	12%
4 20. Vegetation management to achieve clearances around electric lines and equipment	Vegetation management and inspections	0	4	3	3	3	10	10%
5 6. Distribution pole replacement and reinforcement, including with composite poles	Grid design and system hardening	0	0	0	3	3	5	5%
Total spend for top 5 initiatives by planned spend		0	4	15	27	28	70	70%

Note: "M" stands for millions.

Source: Tables 21-30 of utility WMP

Figure 3.9: Bear Valley resource allocation detail for top 5 initiatives by planned spend

Total plan spend is shown for 2020-2022 plan period as calculated by utility

Initiative	Category	Planned spend, \$M					2020-2022 plan total	Initiative spend as percent of total plan spend
		2019 plan	2019 actual	2020 plan	2021 plan	2022 plan		
1 16. Undergrounding of electric lines and/or equipment (35 kV system)	Grid design and system hardening	0	0	39	39	39	118	27%
2 16. Undergrounding of electric lines and/or equipment (4 kV system)	Grid design and system hardening	0	0	13	13	13	40	9%
3 18. Other / not listed (Covering overhead conductor)	Grid design and system hardening	0	0	4	4	4	11	2%
4 2. Detailed inspections of vegetation around distribution electric lines and equipment	Vegetation management and inspections	3	3	3	3	3	10	2%
5 20. Other / not listed (energy storage facility)	Grid design and system hardening	0	0	0	5	5	9	2%
Total spend for top 5 initiatives by planned spend		3	3	59	64	64	187	43%

Note: "M" stands for millions.

Source: Tables 21-30 of utility WMP

Figure 3.10: Horizon West Transmission allocation detail for all planned initiatives

Total plan spend is shown for 2020-2022 plan period as calculated by utility. Horizon West reported only four initiatives with allocated spend

Initiative	Upper range ¹ of planned spend, \$M						Initiative spend as percent of total plan spend
	2019 plan	2019 actual	2020 plan	2021 plan	2022 plan	2020-2022 plan total	
SVC Site Hardening	0.00	0.00	2.20	4.30	0.00	6.50	77%
Underground of 115 feet of overhead line	0.00	0.00	1.70	0.00	0.00	1.70	20%
Advanced weather monitoring, weather stations and OH line/pole cameras	0.00	0.00	0.15	0.00	0.00	0.15	2%
Inspections (Training, facility, vegetation, and fuel modification)	0.00	0.00	0.04	0.04	0.04	0.11	1%
Total 2020-2022 planned spend	0.00	0.00	4.09	4.34	0.04	8.46	100%

1. For some initiatives, Horizon West reported a range of possible future spend. The higher number in that reported range is displayed in this table.

Note: "M" stands for millions.

Source: Tables 21-30 of utility WMP

(End of Appendix B)

APPENDIX C

Bear Valley Maturity Model Summary

0. Bear Valley: Description of Data Sources

Data related to the Maturity Model is based on the latest submitted versions of 2020 Utility Wildfire Mitigation Maturity Survey (“Survey”) as of April 10th, 2020. Data for the Maturity Model is pulled from Survey responses unless stated otherwise.

All source data (the WMP and the Survey responses) are available at cpuc.ca.gov/wildfiremitigationplans

All the analysis and corresponding tables presented in this appendix rely upon data that is self-reported by the utilities. By utilizing and presenting this self-reported data in this appendix, the WSD is not independently validating that all data elements submitted by utilities are accurate. The WSD will continue to evaluate utility data, conduct data requests, and conduct additional compliance activities to ensure that data provided is accurate.

1. Bear Valley: Maturity Model Summary

Contents

1.1 BEAR VALLEY: MATURITY SUMMARY BY CATEGORY.....	C3
1.2 BEAR VALLEY: MATURITY DETAIL BY CAPABILITY.....	C10
1.2.1 A. RISK ASSESSMENT AND MAPPING	C10
1.2.2 B. SITUATIONAL AWARENESS AND FORECASTING.....	C15
1.2.3 C. GRID DESIGN AND SYSTEM HARDENING.....	C20
1.2.4 D. ASSET MANAGEMENT AND INSPECTIONS.....	C25
1.2.5 VEGETATION MANAGEMENT AND INSPECTIONS	C31
1.2.6 F. GRID OPERATIONS AND PROTOCOLS	C38
1.2.7 G. DATA GOVERNANCE	C45
1.2.8 H. RESOURCE ALLOCATION METHODOLOGY	C49
1.2.9 I. EMERGENCY PLANNING AND PREPAREDNESS	C55
1.2.10 J. STAKEHOLDER COOPERATION AND COMMUNITY ENGAGEMENT.....	C60
1.3 BEAR VALLEY: NUMERICAL MATURITY SUMMARY	C65

1.1 Bear Valley: Maturity Summary by Category

Maturity Model Category	Summary of Maturity Assessment Focused on areas where utility plans to grow over the 2020-2022 WMP period
A. Risk assessment and mapping Median automated maturity levels: 2020: 1 2023: 1	<ul style="list-style-type: none"> Bear Valley plans to increase its maturity level by 2023 in two of five capabilities. Specifically, by capability: <ul style="list-style-type: none"> 1. Climate Scenario Modeling: Bear Valley's survey responses do not indicate an increased maturity level in 2023. However, Bear Valley projects some growth within the capability: currently wildfire risk from weather is estimated broadly, but by 2023 Bear Valley plans to reliably categorize weather scenarios by level of risk. 2. Ignition Risk Estimation: Bear Valley's survey responses do not indicate an increased maturity level in 2023. However, Bear Valley projects some growth within the capability: Currently, ignition risk is categorized into at least two risk categories (e.g., high, low), but by 2023, Bear Valley plans to quantitatively assess ignition risk. 3. Estimation of Wildfire Consequences for Communities: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, ignition events are categorized as low or high risk. By 2023, Bear Valley plans to categorize estimates with five or more levels of risk to communities. 4. Estimation of wildfire and PSPS risk-reduction impact: Bear Valley's survey responses do not indicate an increased maturity level in 2023. However, Bear Valley projects some growth within the capability: Currently, risk reduction is estimated on an interval scale (e.g., specific quantitative units) without a confidence interval, but by 2023 Bear Valley will make these estimations on an interval scale using a quantitative confidence interval. 5. Risk maps and simulation algorithms: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, there is no defined process for updating risk mapping algorithms. By 2023, Bear Valley plans to update risk mapping algorithms based on detected deviations of risk model to ignitions and propagation.
B. Situational awareness and forecasting Median automated maturity levels: 2020: 1 2023: 2	<ul style="list-style-type: none"> Bear Valley plans to increase its maturity level by 2023 in three of five capabilities. Specifically, by capability: <ul style="list-style-type: none"> 6. Weather variables collected: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, a range of accurate weather variables is collected. By 2023, Bear Valley plans to also measure the physical impact of weather on the grid (e.g. sway in lines, sway in vegetation). 7. Weather data resolution: Bear Valley's survey responses do not indicate an increased maturity level in 2023. However, Bear Valley projects some growth within the capability: currently, weather data is collected at least four times per hour, but by 2023 Bear Valley plans to collect this data at least six times per hour.

Maturity Model Category	Summary of Maturity Assessment Focused on areas where utility plans to grow over the 2020-2022 WMP period
	<ul style="list-style-type: none"> • 8. Weather forecasting ability: Bear Valley's survey responses do not indicate an increased maturity level in 2023. However, Bear Valley projects some growth within the capability: currently weather forecasting is only sufficiently accurate to fulfill PSPS requirements, but by 2023 Bear Valley plans to combine accurate weather stations and external weather data to make accurate forecasts. • 9. External sources used in weather forecasting: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, a mostly manual process is used for error checking weather stations with external data. By 2023, Bear Valley plans to do this through a mostly automated process. • 10. Wildfire detection processes and capabilities: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, there is no consistent set of equipment for detecting ignitions along the grid. By 2023, Bear Valley plans to have well-defined equipment for detecting ignitions along the grid, including software in installed cameras.
C. Grid design and system hardening Median automated maturity levels: 2020: 2 2023: 3	<ul style="list-style-type: none"> • Bear Valley plans to increase its maturity level by 2023 in five of five capabilities. Specifically, by capability: <ul style="list-style-type: none"> • 11. Approach to prioritizing initiatives across territory: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley prioritizes risk reduction initiatives using risk modeling and wildfire / PSPS risk simulation. By 2023, Bear Valley plans to additionally take delivery power uptime into account when prioritizing initiatives. • 12. Grid design for minimizing ignition risk: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, the grid design meets minimum G095 requirements and loading standards in HFTD areas. By 2023, Bear Valley plans to exceed design requirements and have the grid designed based on an accurate understanding of drivers of risk. • 13. Grid design for resiliency and minimizing PSPS: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, distribution architecture has (n-1) redundancy covering at least 70% of customers in HFTD. By 2023, Bear Valley plans to increase this number to at least 85%. • 14. Risk based hardening and cost efficiency: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley has an accurate understanding of the relative cost and effectiveness of initiatives. By 2023, Bear Valley plans to understand the relative cost and effectiveness of initiatives, tailored to the circumstances of different locations on its grid. • 15. Grid design and asset innovation: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, grid hardening initiatives are evaluated based on installation into the grid and measuring direct reduction in ignition events. By 2023, Bear Valley plans to also evaluate initiatives by measuring reduction impact on near-miss metrics.

Maturity Model Category	Summary of Maturity Assessment Focused on areas where utility plans to grow over the 2020-2022 WMP period
D. Asset management and inspections Median automated maturity levels: 2020: 1 2023: 2	<ul style="list-style-type: none"> Bear Valley plans to increase its maturity level by 2023 in four of five capabilities. Specifically, by capability: <ul style="list-style-type: none"> 16. Asset inventory and condition assessments: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently the asset inventory includes information on age, state of wear and expected lifecycle, including records of all inspections and repairs, of equipment. By 2023, Bear Valley plans for this inventory to also include up-to-date work plans on expected future repairs and replacements. 17. Asset inspection cycle: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, inspections are based on annual or periodic schedules. By 2023, Bear Valley plans to schedule inspections based on risk, as determined by predictive modeling of equipment failure probability and risk-causing ignition. 18. Asset inspection effectiveness: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently inspection procedures and checklists include all items required by statute and regulations. By 2023, Bear Valley plans to also include the lines and equipment typically responsible for ignitions and near misses. 19. Asset maintenance and repair: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, service intervals are set based on the wildfire risk in relevant circuit. By 2023, Bear Valley plans to also set service intervals based on real-time monitoring from sensors. 20. QA/QC for asset management: Bear Valley's survey responses do not indicate an increased maturity level in 2023. However, Bear Valley projects some growth within the capability. Currently QA/QC information is used to identify deficiencies in work and recommend trainings. By 2023 Bear Valley plans to use QA/QC information to identify deficiencies in work and trainings, grade individuals, and recommend trainings based on weaknesses.
E. Vegetation management and inspections Median automated maturity levels: 2020: 1.5 2023: 3	<ul style="list-style-type: none"> Bear Valley plans to increase its maturity level by 2023 in five of six capabilities. Specifically, by capability: <ul style="list-style-type: none"> 21. Vegetation inventory and condition assessments: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, vegetation inventory is updated within 1 week of collection. By 2023, Bear Valley plans to update inventory within 1 day of collection. 22. Vegetation inspection cycle: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, inspections are scheduled based on maps of predominant vegetation species and environment. By 2023, Bear Valley plans to base inspections on predictive modeling of vegetation growth and growing conditions. 23. Vegetation inspection effectiveness: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, inspection procedures and checklists include all items required by statute and regulations. By 2023, Bear Valley plans to also include vegetation types typically responsible for ignitions and near misses.

Maturity Model Category	Summary of Maturity Assessment Focused on areas where utility plans to grow over the 2020-2022 WMP period
	<ul style="list-style-type: none"> • 24. Vegetation grow-in mitigation: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, ignition risk modelling is used to guide clearances around lines and equipment. By 2023, Bear Valley plans to also use propagation risk modeling. • 25. Vegetation fall-in mitigation: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley removes vegetation outside of its right of way. By 2023, Bear Valley plans to remove vegetation outside of its right of way and to inform relevant communities of this removal. • 26. QA/QC for vegetation management: Bear Valley's survey responses do not indicate an increased maturity level in 2023. However, Bear Valley projects some growth within the capability. Currently QA/QC information is used to identify deficiencies in work and recommend trainings. By 2023 Bear Valley plans to use QA/QC information to identify deficiencies in work and trainings, grade individuals, and recommend trainings based on weaknesses.
F. Grid operations and protocols Median automated maturity levels: 2020: 1.5 2023: 4	<ul style="list-style-type: none"> • Bear Valley plans to increase its maturity level by 2023 in six of six capabilities. Specifically, by capability: • 27. Protective equipment and device settings: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley increases sensitivity of risk reduction elements during high threat weather conditions and monitors near misses. By 2023, Bear Valley plans to increase the sensitivity of risk reduction elements during high threat weather conditions based on risk mapping. • 28. Incorporating ignition risk factors in grid control: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley does not use predictive modeling to estimate expected life or make equipment decisions. By 2023, Bear Valley plans to use predicitve modeling to estimate expected life and make equipment decisions. • 29. PSPS op. model and consequence mitigation: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, PSPS events are communicated to >99% of affected customers and >99.9% of medical baseline customers prior to the event. By 2023, Bear Valley plans to increase these numbers to >99.9% and 100% respectively. • 30. Protocols for PSPS initiation: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley only takes into account SME opinions when making PSPS decisions. By 2023, Bear Valley plans to also take into account a partially automated system that makes PSPS recommendations. • 31. Protocols for PSPS re-energization: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently there is a process for inspecting de-energized sections of the grid prior to re-energization. By 2023, Bear Valley plans to also include sensors and aerial tools in this process.

Maturity Model Category	Summary of Maturity Assessment Focused on areas where utility plans to grow over the 2020-2022 WMP period
	<ul style="list-style-type: none"> 32. Ignition prevention and suppression: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, ignition prevention and suppression policies only include employees. By 2023, Bear Valley plans to also include contractors and subcontractors in these policies.
G. Data Governance Median automated maturity levels: 2020: 0.5 2023: 2.5	<ul style="list-style-type: none"> Bear Valley plans to increase its maturity level by 2023 in four of four capabilities. Specifically, by capability: <ul style="list-style-type: none"> 33. Data collection and curation: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley does not have a centralized database of situational, operational, and risk data. By 2023, Bear Valley plans to have one of these databases. 34. Data transparency and analytics: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley does not have a single document cataloguing all fire-related data and algorithms, analyses, and data processes. By 2023, Bear Valley plans to have all this information kept in one document. 35. Near-miss tracking: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley is not able to simulate wildfire potential given an ignition based on event characteristics. By 2023, Bear Valley plans to simulate wildfire potential given an ignition based on event characteristics. 36. Data sharing with research community: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley discloses only data as required. By 2023, Bear Valley plans to make data disclosures beyond what is required.
H. Resource allocation methodology Median automated maturity levels: 2020: 1 2023: 2	<ul style="list-style-type: none"> Bear Valley plans to increase its maturity level by 2023 in six of six capabilities. Specifically, by capability: <ul style="list-style-type: none"> 37. Scenario analysis across different risk levels: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley provides projections for each scenario with region-level granularity. By 2023, Bear Valley plans to provide projections for each scenario with circuit-level granularity. 38. Presentation of relative risk spend efficiency (RSE) for portfolio of initiatives: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley includes the expected overall reduction in risk in explanations of investments. By 2023, Bear Valley plans to also include estimates of impact on reliability factors in explanations of investments as well. 39. Process for determining risk spend efficiency of vegetation management initiatives: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley understands the cost and effectiveness of producing an RSE estimate of vegetation management initiatives. By 2023, Bear Valley plans to also understand the cost sensitivities of producing an RSE estimate. 40. Process for determining risk spend efficiency of system hardening initiatives: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley understands the cost and

Maturity Model Category	Summary of Maturity Assessment Focused on areas where utility plans to grow over the 2020-2022 WMP period
	<p>effectiveness of producing an RSE estimate of grid hardening initiatives. By 2023, Bear Valley plans to also understand the cost sensitivities of producing an RSE estimate.</p> <ul style="list-style-type: none"> • 41. Portfolio-wide initiative allocation methodology: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley verifies RSE estimates with only historical or experimental pilot data. By 2023, Bear Valley plans to also use independent experts to verify its RSE estimates. • 42. Portfolio-wide innovation in new wildfire initiatives: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, reviews of innovative initiatives are not audited by independent parties. By 2023 Bear Valley plans to have these reviews audited by independent parties.
I. Emergency planning and preparedness Median automated maturity levels: 2020: 4 2023: 4	<ul style="list-style-type: none"> • Bear Valley plans to increase its maturity level by 2023 in one of five capabilities. Specifically, by capability: • 43. Wildfire plan integrated with overall disaster/emergency plan: Bear Valley's survey responses project no growth in this capability. Bear Valley's wildfire plan is an integrated component of overall disaster and emergency plans • 44. Plan to restore service after wildfire related outages: Bear Valley's survey responses project no growth in this capability. Bear Valley has detailed and actionable procedures in place to restore service after a wildfire related outage. • 45. Emergency community engagement during and after wildfire: Bear Valley's survey responses project no growth in this capability. Bear Valley provides clear and substantially complete communications of available information relevant to affected customers. • 46. Protocols in place to learn from wildfire events: Bear Valley's survey responses project no growth in this capability. There is a protocol in place to record the outcome of emergency events and integrate learnings into existing process. • 47. Processes for continuous improvement after wildfire and PSPS: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley engages in public listening sessions and debriefs with partners. By 2023, Bear Valley plans to also have debriefs with other groups.
J. Stakeholder cooperation and community engagement Median automated maturity levels:	<ul style="list-style-type: none"> • Bear Valley plans to increase its maturity level by 2023 in one of five capabilities. Specifically, by capability: • 48. Cooperation and best practice sharing with other utilities: Bear Valley's survey responses project no growth in this capability. Bear Valley works to identify and implement best practices from utilities around the globe. • 49. Engagement with communities on utility wildfire mitigation initiatives: Bear Valley's survey responses project no growth in this capability. Bear Valley has a clear and actionable plan to develop / maintain a collaborative relationship with local communities.

Maturity Model Category	Summary of Maturity Assessment Focused on areas where utility plans to grow over the 2020-2022 WMP period
2020: 4 2023: 4	<ul style="list-style-type: none"> • 50. Engagement with LEP¹ and AFN² populations: Bear Valley's survey responses project no growth in this capability. Bear Valley does not have a plan to partner with LEP and AFN communities. • 51. Collaboration with emergency response agencies: Bear Valley's survey responses project no growth in this capability. Bear Valley cooperates with emergency response agencies. • 52. Collaboration on wildfire mitigation plan with stakeholders: Bear Valley's survey responses indicate an increased maturity level in 2023. Currently, Bear Valley shares fuel management plans with other stakeholders and coordinates fuel management activities to focus on areas that will have the biggest impact in reducing wildfire risk. By 2023, Bear Valley plans to undertake this effort proactively. <p>1. Limited English Proficiency 2. Access and Functional Needs</p>

1.2 Bear Valley: Maturity Detail by Capability

1.2.1 A. Risk assessment and mapping

1.2.1.1 Capability 1: Climate scenario modeling

Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020	Bold responses have planned growth between 2020 and 2023
2020	2023	Both			
4	a. Wildfire risk can be reliably determined based on weather and its impacts		b. Scenarios are assessed by independent experts	c. Climate scenario modeling is done with regional granularity	d. Climate scenario modeling tool is partially (<=50%) automated
3	e. Climate scenario tool also accounts for weather and how weather effects failure modes and propagation		f. Future risk estimates take into account generally higher risk across the entire service territory due to changing climate		a. Weather scenarios are planned to be reliably categorized by level of risk
2					b. Scenarios are planned to be assessed by independent experts, and supported by historical data of incidents and near misses
1					c. Climate scenario modeling is planned to be done with regional granularity
0					d. Climate scenario modeling tool is planned to be mostly (>=50%) automated
	Criteria missing to reach a maturity level of 1 or more:			Criteria missing to reach a maturity level of 1 or more:	
	<ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric			<ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric	

1.2.1.2 Capability 2: Ignition risk estimation

Capability 2: Ignition risk estimation		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. Tools and processes can reliably categorize the risk of ignition across the grid into at least two categories based on characteristics and condition of lines, equipment, surrounding vegetation, and localized weather patterns	a. Tools and processes are planned to be able to quantitatively and accurately assess the risk of ignition across the grid based on characteristics and condition of lines, equipment, surrounding vegetation, and localized weather patterns
3	b. Ignition risk estimation tool is partially (<=50%) automated	b. Ignition risk estimation tool is planned to be mostly (>=50%) automated
2	c. Ignition risk estimation tool has regional granularity	c. Ignition risk estimation tool is planned to have regional granularity
1	d. Ignition risk estimation is confirmed by historical data	d. Ignition risk estimation is planned to be confirmed by historical data and through real-time learning
0	e. Ignition risk estimation uses >80% or no quantified confidence interval	e. Ignition risk estimation is planned to use >90% confidence interval
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.1.3 Capability 3: Estimation of wildfire consequences for communities

Capability 3: Estimation of wildfire consequences for communities		
Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend 2020 2023 Both		
4	a. Ignition events are categorized as low or high risk to communities b. Consequence of ignition risk is estimated as a function of at least potential fatalities, and one or both of structures burned, or area burned c. Ignition risk impact analysis is not available for all seasons d. Ignition risk estimation process is not automated e. Ignition risk estimation process is done with regional granularity f. Outputs of consequence estimation are independently assessed by experts g. Estimation of wildfire consequences uses level and conditions of vegetation and weather, including the vegetation specifics immediately surrounding the ignition site	a. Ignition events are planned to be categorized with five or more levels of risk to communities b. Consequence of ignition risk is planned to be estimated as a function of at least potential fatalities, structures burned, area burned, monetary damages, impact on air quality, and impact on GHG reduction goals c. Ignition risk impact analysis is planned to be available for all seasons d. Ignition risk estimation process is planned to be partially (<=50%) automated e. Ignition risk estimation process is planned to be done with regional granularity f. Outputs of consequence estimation is planned to be independently assessed by experts and confirmed by historical data g. Estimation of wildfire consequences plans to use level and conditions of vegetation and weather, including the vegetation specifics immediately surrounding the ignition site and up-to-date moisture content, local weather patterns
3		
2		
1		
0		
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.1.4 Capability 4. Estimation of wildfire and PSPS reduction impact

Capability 4. Estimation of wildfire and PSPS reduction impact		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. Approach reliably estimates risk reduction potential of initiatives on an interval scale (e.g., specific quantitative units)	a. Approach is planned to reliably estimate risk reduction potential of initiatives on an interval scale (e.g., specific quantitative units) with a quantitative confidence interval
3	b. Estimation of wildfire and PSPS reduction impact is not automated	b. Estimation of wildfire and PSPS reduction impact is planned to be partially (<=50%) automated
2	c. Estimation of wildfire and PSPS reduction impact has regional granularity	c. Estimation of wildfire and PSPS reduction impact is planned to have regional granularity
1	d. Ignition risk reduction assessment tool estimates are assessed with evidence and logical reasoning	d. Ignition risk reduction assessment tool estimates are planned to be assessed by independent experts
0	e. Estimation of wildfire and PSPS reduction impact accounts for existing hardware type and condition, including operating history; level and condition of vegetation; weather; and combination of initiatives already deployed	e. Estimation of wildfire and PSPS reduction impact plans to account for existing hardware type and condition, including operating history; level and condition of vegetation; weather; and combination of initiatives already deployed
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.1.5 Capability 5. Risk maps and simulation algorithms

Capability 5. Risk maps and simulation algorithms		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. There is no defined process for updating risk mapping algorithms b. Decision to update algorithms based on deviations is not automated c. Deviations from risk model to ignitions and propagations are calculated manually d. Decisions to update algorithms are independently evaluated by experts e. Current/historic ignition and propagation data is used to decide whether to update algorithms	a. Risk mapping algorithms are planned to be updated based on detected deviations of risk model to ignitions and propagation b. Decision to update algorithms based on deviations is planned to be partially (<=50%) automated c. Deviations from risk model to ignitions and propagations are planned to be calculated with a semi-automated process d. Decisions to update algorithms are planned to be independently evaluated by experts and historical data e. Current/historic ignition and propagation data, as well as near-miss data, is planned to be used to decide whether to update algorithms
3		
2		
1		
0		
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• Risk mapping algorithms are updated at least bi-annually	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.2 B. Situational awareness and forecasting

1.2.2.1 Capability 6: Weather variables collected

			Capability 6: Weather variables collected		
Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020	
2020	2023	Both			Bold responses have planned growth between 2020 and 2023
4			a. A range of accurate weather variables (e.g., humidity, precipitation, surface and atmospheric wind conditions) that impact probability of ignition and propagation from utility assets are collected	a. A range of accurate weather variables (e.g., humidity, precipitation, surface and atmospheric wind conditions) that impact probability of ignition and propagation from utility assets are planned to be collected; additional data to measure physical impact of weather on grid (e.g., sway in lines, sway in vegetation) is also planned to be collected	
3			b. Measurements are validated through manual field calibration	b. Measurements are planned to be validated through automatic field calibration measurements	
2			c. Elements that cannot be reliably measured in real time (e.g., fuel moisture content) are being predicted	c. Elements that cannot be reliably measured in real time (e.g., fuel moisture content) are planned to be predicted	
1			d. More than one data source used for each weather metric collected	d. More than one data source is planned to be used for each weather metric collected	
0					
Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 				Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.2.2 Capability 7: Weather data resolution

Capability 7: Weather data resolution		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. Weather data collected has sufficient granularity to reliably measure weather conditions in HFTD areas, and along the entire grid and in all areas needed to predict weather on the grid	a. Weather data collected is planned to have sufficient granularity to reliably measure weather conditions in HFTD areas, and along the entire grid and in all areas needed to predict weather on the grid. Bear Valley also plans to include wind estimations at various atmospheric altitudes relevant to ignition risk
3	b. Weather data collected at least four times per hour	b. Weather data is planned to be collected at least six times per hour
2	c. Weather data resolution with regional granularity	c. Weather data resolution is planned to be done with regional granularity
1	d. Measurement of weather conditions is partially (<=50%) automated	d. Measurement of weather conditions is planned to be mostly (>=50%) automated
0	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• Weather data is gathered with sufficient granularity to reliably measure weather conditions	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.2.3 Capability 8: Weather forecasting ability

Capability 8: Weather forecasting ability		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. Utility has independent weather forecasting ability sufficiently accurate to fulfill PSPS requirements b. Accurate forecasts prepared at least two weeks in advance c. Weather forecasts have regional granularity d. Forecast results are error checked against historical weather patterns e. Forecast process is partially (<=50%) automated	a. Utility plans to have the ability to use a combination of accurate weather stations and external weather data to make accurate forecasts b. Accurate forecasts are planned to be prepared at least three weeks in advance c. Weather forecasts are planned to have regional granularity d. Forecast results are planned to be error checked against historical weather patterns and subsequently error checked against measured weather data e. Forecast process is planned to be mostly (>=50%) automated
3		
2		
1		
0		
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• Weather forecasting ability sufficiently accurate to fulfill PSPS requirements at circuit level	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• Weather forecasting ability sufficiently accurate to fulfill PSPS requirements at circuit level

1.2.2.4 Capability 9: External sources used in weather forecasting

Capability 9: External sources used in weather forecasting		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. Utility uses a combination of accurate weather stations and external weather data, and elects to use the data set, as a whole or in composite, that is most accurate	a. Utility plans to use a combination of accurate weather stations and external weather data, and elects to use the data set, as a whole or in composite, that is most accurate
3	b. Utility uses a mostly manual process for error checking weather stations with external data sources	b. Utility plans to use a mostly automated processes for error checking weather stations with external data sources
2	c. Weather data is used to help make decisions	c. Weather data is planned to be used to create a single visual and configurable live map that can be used to make decisions
1		
0		
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.2.5 Capability 10: Wildfire detection processes and capabilities

Capability 10: Wildfire detection processes and capabilities		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. Well-defined procedures for detecting ignitions along the grid exist b. No consistent set of equipment for detecting ignitions along grid c. Procedure exists for notifying suppression forces and key stakeholders when ignitions are detected d. Ignition detection software is not currently deployed	a. Well-defined procedures for detecting ignitions along the grid are planned to exist b. Well-defined equipment for detecting ignitions along grid is planned to be used, including remote detection equipment including cameras c. Procedure is planned to automatically, accurately, and in real time notify suppression forces and key stakeholders d. Ignition detection software in cameras that operate automatically is planned to be used as part of ignition detection procedures.
3		
2		
1		
0		
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• Remote detection equipment, including cameras, is used to help detect ignitions	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.3 C. Grid design and system hardening

1.2.3.1 Capability 11: Approach to prioritizing initiatives across territory

Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020		
2020	2023	Both	Bold responses have planned growth between 2020 and 2023		
4	a. Plan prioritizes risk reduction initiatives at the span level based on (i) risk modeling driven by local geography and climate/weather conditions, fuel loads and moisture content and topography and (ii) detailed wildfire and PSPS risk simulation across individual circuits			a. Bear Valley plans to prioritize risk reduction initiatives at the span level based on (i) risk modeling driven by local geography and climate/weather conditions, fuel loads and moisture content and topography and (ii) risk estimates across individual circuits, including estimates of actual consequence, and (iii) taking delivery power uptime into account (e.g., reliability, PSPS)	
3					
2					
1					
0					
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.3.2 Capability 12: Grid design for minimizing ignition risk

Capability 12: Grid design for minimizing ignition risk		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. Grid design meets minimum G095 requirements and loading standards in HFTD areas	a. Grid topology is planned to exceed design requirements, and is planned to be designed based on an accurate understanding of drivers of risk
3	b. Utility does not provide micro grids or islanding where traditional grid infrastructure is impracticable and wildfire risk is high	b. Utility plans to provide micro grids or islanding where traditional grid infrastructure is impracticable and wildfire risk is high
2	c. Routing of new portions of the grid takes wildfire risk into account	c. Routing of new portions of the grid plans to take wildfire risk into account
1	d. Some efforts made in HFTD areas to incorporate the latest asset management strategies and new technologies into grid topology	d. Efforts planned to be made across the entire service area to incorporate the latest asset management strategies and new technologies into grid topology
0	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.3.3 Capability 13: Grid design for resiliency and minimizing PSPS

Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020		
2020	2023	Both	Bold responses have planned growth between 2020 and 2023		
4	a. Utility's transmission architecture has (n-1) redundancy for all circuits subject to PSPS b. Utility's distribution architecture has (n-1) redundancy covering at least 70% of customers in HFTD c. Utility's distribution architecture is sectionalized to have switches in HFTD areas to individually isolate circuits, such that no more than 1000 customers sit within one switch d. Utility uses egress points as an input for grid topology design			a. Utility's transmission architecture is planned to have (n-1) redundancy for all circuits subject to PSPS b. Utility's distribution architecture is planned to have (n-1) redundancy covering at least 85% of customers in HFTD c. Utility's distribution architecture is planned to be sectionalized to have switches in HFTD areas to individually isolate circuits, such that no more than 200 customers sit within one switch d. Utility plans to have egress points available and mapped for each customer, with potential traffic mapped based on traffic simulation and taken into consideration for grid topology design	
3					
2					
1					
0					
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.3.4 Capability 14: Risk-based grid hardening and cost efficiency

Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020	
2020	2023	Both	Bold responses have planned growth between 2020 and 2023		
4	a. Utility has an accurate understanding of the relative cost and effectiveness of different initiatives		a. Utility is planned to have an accurate understanding of the relative cost and effectiveness of different initiatives, tailored to the circumstances of different location on its grid		
3	b. Estimates can be prepared with circuit-based granularity		b. Estimates can be prepared with span-based granularity		
2	c. Estimates are updated annually or more frequently		c. Estimates are planned to be updated annually or more frequently		
1	d. Utility has all grid hardening initiatives included within its evaluation		d. Utility is planned to have all grid hardening initiatives included within its evaluation and supported by independent testing		
0	e. Utility can evaluate risk reduction synergies from combinations of various initiatives		e. Utility plans to be able to evaluate risk reduction synergies from combinations of various initiatives		
	Criteria missing to reach a maturity level of 1 or more:		Criteria missing to reach a maturity level of 1 or more:		
	• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric		• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric		

1.2.3.5 Capability 15: Grid design and asset innovation

Capability 15: Grid design and asset innovation		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. New grid hardening initiatives evaluated based on installation into grid and measuring direct reduction in ignition events	a. New grid hardening initiatives planned to be evaluated based on installation into grid and measurement of direct reduction in ignition events, and measurement of reduction impact on near-miss metrics
3	b. Results of pilot and commercial deployments, including project performance, project cost, geography, climate, vegetation, etc. are shared with a limited set of partners	b. Results of pilot and commercial deployments, including project performance, project cost, geography, climate, vegetation, etc. are planned to be shared extensively with industry, academia, and other utilities
2	c. Performance of new initiatives is not independently audited	c. Performance of new initiatives is planned to be independently audited
1		
0		
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.4 D. Asset management and inspections

1.2.4.1 Capability 16: Asset inventory and condition assessments

			Capability 16: Asset inventory and condition assessments		
Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020	Bold responses have planned growth between 2020 and 2023
2020	2023	Both			
4	a. There is an accurate inventory of equipment that may contribute to wildfire risk, including age, state of wear, and expected lifecycle, including records of all inspections and repairs			a. There is planned to be an accurate inventory of equipment that may contribute to wildfire risk, including age, state of wear, and expected lifecycle, including records of all inspections and repairs and up-to-date work plans on expected future repairs and replacements	
3	b. Condition assessment is updated annually c. A system and approach are in place to reliably detect incipient malfunctions likely to cause ignition in HFTD areas d. Inventory is kept with asset-level granularity			b. Condition assessment is planned to be updated quarterly c. Sensorized, continuous monitoring equipment is planned to be in place to determine the state of equipment and reliably detect incipient malfunctions likely to cause ignition d. Inventory is planned to be kept with asset-level granularity	
2					
1					
0					
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> Inventory database is updated within 90 days of equipment inventory or conditions being collected Inventory includes age, state of wear, and expected lifecycle 			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.4.2 Capability 17: Asset inspection cycle

Automated maturity levels based on Maturity Rubric			Capability 17: Asset inspection cycle		
			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020	
2020	2023	Both	Bold responses have planned growth between 2020 and 2023		
4			<ul style="list-style-type: none"> a. Patrol inspections are above minimum regulatory requirements, with more frequent inspections for highest risk equipment b. Patrol inspections are based on annual or periodic schedules 	<ul style="list-style-type: none"> a. Patrol inspections are planned to be above minimum regulatory requirements, with more frequent inspections for highest risk equipment b. Patrol inspections are planned to be based on risk, as determined by predictive modeling of equipment failure probability and risk causing ignition c. Predictive modeling of equipment failure probability and risk is planned to be the inputs for scheduling patrol inspections d. Detailed inspections are planned to be above minimum regulatory requirements, with more frequent inspections for highest risk equipment. e. Detailed inspections are planned to be based on risk, as determined by predictive modeling of equipment failure probability and risk causing ignition f. Predictive modeling of equipment failure probability and risk is planned to be the inputs for scheduling patrol inspections g. Other inspections are planned to be above minimum regulatory requirements, with more frequent inspections for highest risk equipment h. Other inspections are based on annual or periodic schedules 	
3			<ul style="list-style-type: none"> c. At least annually updated or verified static maps of equipment and environment are the inputs for scheduling patrol inspections d. Detailed inspections are consistent with minimum regulatory requirements 	<ul style="list-style-type: none"> c. Predictive modeling of equipment failure probability and risk is planned to be the inputs for scheduling patrol inspections d. Detailed inspections are planned to be above minimum regulatory requirements, with more frequent inspections for highest risk equipment. e. Detailed inspections are planned to be based on risk, as determined by predictive modeling of equipment failure probability and risk causing ignition f. Predictive modeling of equipment failure probability and risk is planned to be the inputs for scheduling patrol inspections 	
2			<ul style="list-style-type: none"> e. Detailed inspections are based on annual or periodic schedules f. At least annually updated or verified static maps of equipment and environment are the inputs for scheduling patrol inspections 	<ul style="list-style-type: none"> e. Detailed inspections are planned to be based on risk, as determined by predictive modeling of equipment failure probability and risk causing ignition f. Predictive modeling of equipment failure probability and risk is planned to be the inputs for scheduling patrol inspections 	
1			<ul style="list-style-type: none"> g. Other inspections are above minimum regulatory requirements, with more frequent inspections for highest risk equipment h. Other inspections are based on annual or periodic schedules 	<ul style="list-style-type: none"> g. Other inspections are planned to be above minimum regulatory requirements, with more frequent inspections for highest risk equipment h. Other inspections are planned to be based on risk, as determined by predictive modeling of equipment failure probability and risk causing ignition 	
0			i. At least annually updated or verified static maps of equipment and environment are inputs for scheduling patrol inspections	h. Other inspections are planned to be based on risk, as determined by predictive modeling of equipment failure probability and risk causing ignition	

Capability 17: Asset inspection cycle		
		i. Predictive modeling of equipment failure probability and risk is planned to be inputs for scheduling patrol inspections
	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.4.3 Capability 18: Asset inspection effectiveness

Capability 18: Asset inspection effectiveness		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. Patrol, detailed, enhanced, and other inspection procedures and checklists include all items required by statute and regulations	a. Patrol, detailed, enhanced, and other inspection procedures and checklists are planned to include all items required by statute and regulations, and to include all items required by statute and regulations, and to include lines and equipment typically responsible for ignitions and near misses
3	b. Procedure and inspection checklists determined based on statute and regulatory guidelines only	b. Procedure and inspection checklists determined are planned to be based on predictive modeling that considers vegetation and equipment type, age, and condition
2	c. Checklists, training, and procedures are customized across the service territory	c. Checklists, training, and procedures are planned to be customized at the circuit level
1		
0		
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.4.4 Capability 19: Asset maintenance and repair

Capability 19: Asset maintenance and repair		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. Electrical lines and equipment maintained as required by regulation, and additional maintenance done in areas of grid at highest wildfire risk based on detailed risk mapping	a. Electrical lines and equipment are planned to be maintained as required by regulation, and additional maintenance done in areas of grid at highest wildfire risk is planned to be based on detailed risk mapping
3	b. Service intervals are set based on wildfire risk in relevant circuit	b. Service intervals are planned to be set based on wildfire risk in relevant circuit, as well as real-time monitoring from sensors
2	c. Maintenance and repair procedures take wildfire risk, performance history, and past operating conditions into account	c. Maintenance and repair procedures are planned to take wildfire risk, performance history, and past operating conditions into account
1		
0		
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.4.5 Capability 20: QA/QC for asset management

Capability 20: QA/QC for asset management		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	<p>a. Contractor activity is audited through an established and functioning audit process, where contractor activity is subject to semi-automated audits using technologies capable of sampling the contractor's work (e.g., LiDAR scans, photographic evidence) to manage and confirm work completed by subcontractors</p>	<p>a. Contractor activity is planned to be audited through an established and functioning audit process to manage and confirm work completed by subcontractors, where contractor activity is subject to semi-automated audits using technologies capable of sampling the contractor's work (e.g., LiDAR scans, photographic evidence)</p>
3	<p>b. Contractors follow the same processes and standards as utility's own employees</p>	<p>b. Contractors are planned to follow the same processes and standards as utility's own employees</p>
2	<p>c. QA/QC information is regularly used to identify deficiencies in quality of work performance and inspections performance</p>	<p>c. QA/QC information is planned to be regularly used to identify deficiencies in quality of work performance and inspections performance</p>
1	<p>d. QA/QC information is used to identify systemic deficiencies in quality of work and inspections, and recommend training based on weakness</p>	<p>d. QA/QC information is planned to be used to identify systemic deficiencies in quality of work and inspections, grade individuals, and recommend training based on weaknesses</p>
0	<p>e. Workforce management software tools are used to manage and confirm work completed by subcontractors</p>	<p>e. Workforce management software tools are planned to be used to manage and confirm work completed by subcontractors</p>
	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.5 Vegetation Management and inspections

1.2.5.1 Capability 21: Vegetation inventory for condition assessments

			Capability 21: Vegetation inventory for condition assessments		
Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020	Bold responses have planned growth between 2020 and 2023
2020	2023	Both			
4	a. There is a centralized inventory of vegetation clearances based on most recent inspections			a. There is planned to be a centralized inventory of vegetation clearances based on most recent inspection	
3	b. Inventory is updated within 1 week of collection			b. Inventory is planned to be updated within 1 day of collection	
2	c. Inspections are independently verified by third party experts			c. Inspections are planned to be independently verified by third party experts	
1	d. Inventory has asset-based granularity			d. Inventory is planned to have asset-based granularity	
0					
	Criteria missing to reach a maturity level of 1 or more:			Criteria missing to reach a maturity level of 1 or more:	
	<ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 			<ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.5.2 Capability 22: Vegetation inspection cycle

Capability 22: Vegetation inspection cycle		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. All types of vegetation inspections are above minimum regulatory requirements, with more frequent inspections for highest risk areas	a. All types of vegetation inspections are planned to be above minimum regulatory requirements, with more frequent inspections for highest risk areas
3	b. Vegetation inspections are scheduled based on up-to-date static maps of predominant vegetation species and environment	b. Vegetation inspections are planned to be scheduled based on risk, as determined by predictive modeling of vegetation growth and growing conditions
2	c. Up-to-date, static maps of vegetation and environment, as well as data on annual growing conditions are the inputs for scheduling vegetation inspections	c. Predictive modeling of vegetation growth is planned to be the input for scheduling vegetation inspections
1		
0		
	Criteria missing to reach a maturity level of 1 or more:	Criteria missing to reach a maturity level of 1 or more:
	<ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	<ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.5.3 Capability 23: Vegetation inspection effectiveness

Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020		
2020	2023	Both	Bold responses have planned growth between 2020 and 2023		
4	a. Patrol, detailed, enhanced, and other inspection procedures and checklists include all items required by statute and regulations		a. Patrol, detailed, enhanced, and other inspection procedures and checklists are planned to include all items required by statute and regulations, and include vegetation types typically responsible for ignitions and near misses		
3	b. Procedures and checklists are based on statute and regulatory guidelines only		b. Procedures and checklists are planned to be based on predictive modeling based on vegetation and equipment type, age, and condition, and validated by experts		
2	c. Checklists, training, and procedures are customized across a region		c. Checklists, training, and procedures are planned to be customized at the circuit level		
1					
0					
	Criteria missing to reach a maturity level of 1 or more:		Criteria missing to reach a maturity level of 1 or more:		
	<ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 		<ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 		

1.2.5.4 Capability 24: Vegetation grow-in mitigation

Automated maturity levels based on Maturity Rubric			Capability 24: Vegetation grow-in mitigation		
			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020	
2020	2023	Both	Bold responses have planned growth between 2020 and 2023		
4			<ul style="list-style-type: none"> a. Utility exceeds minimum statutory and regulatory clearance around all lines and equipment b. Utility meets or exceeds minimum statutory or regulatory clearances during all seasons c. Ignition risk modeling is used to guide clearances around lines and equipment 	<ul style="list-style-type: none"> a. Utility plans to exceed minimum statutory and regulatory clearances around all lines and equipment b. Utility plans to meet or exceed minimum statutory or regulatory clearances during all seasons c. Ignition and propagation risk modeling is planned to be used to guide clearances around lines and equipment 	
3			<ul style="list-style-type: none"> d. Species growth rates and species limb failure rates, cross referenced with local climatological conditions, are used to guide clearance around lines and equipment 	<ul style="list-style-type: none"> d. Species growth rates and species limb failure rates, cross referenced with local climatological conditions, are planned to be used to guide clearance around lines and equipment 	
2			<ul style="list-style-type: none"> e. Community organizations are engaged in setting local clearances and protocols f. Utility removes vegetation waste along its right of way across the entire grid 	<ul style="list-style-type: none"> e. Community organizations are planned to be engaged in setting local clearances and protocols f. Utility plans to remove vegetation waste along its right of way across the entire grid 	
1			<ul style="list-style-type: none"> g. Utility removes vegetation waste along the right of way on the same day as cutting h. Utility works with local landowners to provide a cost effective use for cutting vegetation 	<ul style="list-style-type: none"> g. Utility plans to remove vegetation waste along the right of way on the same day as cutting h. Utility plans to work with local landowners to provide a cost effective use for cutting vegetation 	
0			<ul style="list-style-type: none"> i. Utility works with partners to identify new cost effective uses for vegetation, taking into consideration environmental impacts and emissions of vegetation waste 	<ul style="list-style-type: none"> i. Utility plans to work with partners to identify new cost effective uses for vegetation, taking into consideration environmental impacts and emissions of vegetation waste 	

Capability 24: Vegetation grow-in mitigation		
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.5.5 Capability 25: Vegetation fall-in mitigation

Capability 25: Vegetation fall-in mitigation		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	<ul style="list-style-type: none"> a. Utility systematically removes vegetation outside of right of way b. Potential vegetation that may pose a threat identified based on the height of trees with potential to make contact with electric lines and equipment c. Vegetation is removed with cooperation from the community 	<ul style="list-style-type: none"> a. Utility plans to systematically remove vegetation outside of right of way, and to inform relevant communities of removal b. Potential vegetation that may pose a threat identified is planned to be based on the probability and consequences of impact on electric lines and equipment as determined by risk modeling c. Vegetation is planned to be removed with cooperation from the community
3	<ul style="list-style-type: none"> d. Utility removes vegetation waste outside its right of way across the entire grid e. Utility removes vegetation outside its right of way on the same day as cutting f. Utility works with local landowners to provide a cost effective use for cutting vegetation j. Utility works with partners to identify new cost effective uses for vegetation, taking into consideration environmental impacts and emissions of vegetation waste 	<ul style="list-style-type: none"> d. Utility plans to remove vegetation waste outside its right of way across the entire grid e. Utility plans to remove vegetation outside its right of way on the same day as cutting f. Utility plans to work with local landowners to provide a cost effective use for cutting vegetation g. Utility plans to work with partners to identify new cost effective uses for vegetation, taking into consideration environmental impacts and emissions of vegetation waste
2		
1		
0		
	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • Utility removes vegetation within 1 week of cutting vegetation 	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • Utility removes vegetation within 1 week of cutting vegetation

1.2.5.6 Capability 26: QA/QC for vegetation management

Capability 26: QA/QC for vegetation management		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	<p>a. Contractor and employee activity audited through an established and demonstrably functioning audit process to manage and confirm work completed by subcontractors, where contractor activity is subject to semi-automated audits using technologies capable of sampling the contractor’s work (e.g., LiDAR scans, photographic evidence)</p>	<p>a. Contractor and employee activity are planned to be actively audited through an established and demonstrably functioning audit process to manage and confirm work completed by subcontractors, where contractor activity is subject to semi-automated audits using technologies capable of sampling the contractor’s work (e.g., LiDAR scans, photographic evidence)</p>
3	<p>b. Contractors follow the same processes and standards as utility’s own employees</p> <p>c. QA/QC information is regularly used to identify deficiencies in quality of work performance and inspections performance</p>	<p>b. Contractors are planned to follow the same processes and standards as utility’s own employees</p> <p>c. QA/QC information is planned to be used regularly to identify deficiencies in quality of work performance and inspections performance</p>
2	<p>d. QA/QC information is used to identify systemic deficiencies in quality of work and inspections, and recommend training based on weaknesses</p>	<p>d. QA/QC information is planned to be used to identify systemic deficiencies in quality of work and inspections, grade individuals, and recommend specific pre-made and tested training based on weaknesses</p>
1	<p>e. Workforce management software tools are used to manage and confirm work completed by subcontractors</p>	<p>e. Workforce management software tools are planned to be used to manage and confirm work completed by subcontractors</p>
0	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.6 F. Grid operations and protocols

1.2.6.1 Capability 27: Protective equipment and device settings

			Capability 27: Protective equipment and device settings		
Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020	Bold responses have planned growth between 2020 and 2023
2020	2023	Both			
4			a. Utility increases sensitivity of risk reduction elements during high threat weather conditions and monitors near misses	a. Utility plans to increase sensitivity of risk reduction elements during high threat weather conditions based on risk mapping and monitors near misses b. A fully automated process is planned to adjust sensitivity of grid elements and evaluate effectiveness c. Bear Valley plans to have a predetermined protocol driven by fire conditions for adjusting sensitivity of grid elements	
3					
2					
1					
0					
			Criteria missing to reach a maturity level of 1 or more:	Criteria missing to reach a maturity level of 1 or more:	
			<ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	<ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.6.2 Capability 28: Incorporating ignition risk factors in grid control

Capability 28: Incorporating ignition risk factors in grid control		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. Utility has a clearly explained process for determining whether to operate the grid beyond current or voltage designs	a. Utility plans to have a clearly explained process for determining whether to operate the grid beyond current or voltage designs
3	b. Utility has systems in place to automatically track operation history including current, loads, and voltage throughout the grid at circuit level	b. Utility plans to have systems in place to automatically track operation history including current, loads, and voltage throughout the grid at circuit level
2	c. Utility does not use predictive modeling to estimate the expected life and make equipment maintenance, rebuild, or replacement decisions	c. Utility plans to use predictive modeling to estimate the expected life and make equipment maintenance, rebuild, or replacement decisions based on grid operating history; modeling not evaluated by external experts
1	d. Utility never operates the grid above rated voltage and current load	d. Utility plans to never operate the grid above rated voltage and current load
0	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.6.3 Capability 29: PSPS op. model and consequence mitigation

Capability 29: PSPS op. model and consequence mitigation		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. PSPS event generally forecasted accurately with fewer than 25% of predictions being false positives b. PSPS events are communicated to >99% of affected customers and >99.9% of medical baseline customers in advance of PSPS action c. Less than 0.5% of customers complain during PSPS events d. Website does not go down during PSPS events e. Average downtime per customer is less than 0.1 hours f. Specific resources are not provided to all affected customers to alleviate the impact of the power shutoff (e.g., providing backup generators, supplies, batteries, etc.)	a. PSPS event planned to be generally forecasted accurately with fewer than 25% of predictions being false positives b. PSPS events are planned to be communicated to >99.9% of affected customers and 100% of medical baseline customers in advance of PSPS action c. Less than 0.5% of customers are planned to complain during PSPS events d. Website is planned to not go down during PSPS events e. Average downtime per customer is planned to be less than 0.1 hours f. Specific resources are planned to be provided to all affected customers to alleviate the impact of the power shutoff (e.g., providing backup generators, supplies, batteries, etc.)
3		
2		
1		
0		
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.6.4 Capability 30: Protocols for PSPS initiation

Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020		
2020	2023	Both	Bold responses have planned growth between 2020 and 2023		
4	<p>a. Utility has explicit policies and explanation for the thresholds above which PSPS is activated, but maintains grid in sufficiently low risk condition to not require any PSPS activity, though it may de-energize specific circuits upon detection of damaged condition of electrical lines and equipment, or contact with foreign objects</p>			<p>a. Utility plans to have explicit policies and explanation for the thresholds above which PSPS is activated, but also plans to maintain grid in sufficiently low risk condition to not require any PSPS activity, though it may de-energize specific circuits upon detection of damaged condition of electrical lines and equipment, or contact with foreign objects</p> <p>b. Utility plans to take into account a partially automated system which recommends circuits for which PSPS should be activated and is validated by SMEs when making PSPS decisions</p>	
3	<p>b. Utility takes into account SME opinion when making PSPS decisions</p> <p>c. Utility de-energizes circuits when circuit presents a safety risk to suppression or other personnel and when equipment has come into contact with foreign objects posing ignition risk</p>			<p>c. Utility plans to de-energize circuits when circuit presents a safety risk to suppression or other personnel and when equipment has come into contact with foreign objects posing ignition risk</p>	
2	<p>c. Utility de-energizes circuits when circuit presents a safety risk to suppression or other personnel and when equipment has come into contact with foreign objects posing ignition risk</p> <p>d. Given condition of the grid, utility expects less than 5% probability of any large scale PSPS events affecting more than 10,000 people to occur in the coming year; grid is in sufficiently low risk condition that PSPS events will not be required, and the only circuits which may require de-energization have sufficient redundancy that energy supply to customers will not be disrupted</p>			<p>d. Given condition of the grid, Utility plans to expect less than 5% probability of any large scale PSPS events affecting more than 10,000 people to occur in the coming year; grid is planned to be in sufficiently low risk condition that PSPS events will not be required, and the only circuits which may require de-energization have sufficient redundancy that energy supply to customers will not be disrupted</p>	
1					
0					

Capability 30: Protocols for PSPS initiation		
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.6.5 Capability 31: Protocols for PSPS re-energization

Capability 31: Protocols for PSPS re-energization		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. There is an existing process for accurately inspecting de-energized sections of the grid prior to re-energization	a. There is planned to be an existing process for accurately inspecting de-energized sections of the grid prior to re-energization, augmented with sensors and aerial tools
3	b. There is a partially automated (<=50%) process for inspecting de-energized sections of the grid prior to re-energization	b. There is planned to be a mostly automated (>=50%) process for inspecting de-energized sections of the grid prior to re-energization
2	c. Average time it takes to re-energize grid from a PSPS once weather has subsided to below your de-energization threshold is less than 8 hours	c. Average time it takes to re-energize grid from a PSPS once weather has subsided to below your de-energization threshold is planned to be less than 8 hours
1	d. Utility has some probability estimates for ignitions after PSPS events across the grid	d. Utility plans to have some probability estimates for ignitions after PSPS events across the grid
0	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.6.6 Capability 32: Ignition prevention and suppression

Capability 32: Ignition prevention and suppression		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	<ul style="list-style-type: none"> a. Utility has explicit policies about the role of crews at the site of ignition b. Training and communications tools are provided to immediately report ignitions caused by workers or in immediate vicinity of workers; in addition, suppression tools and training to suppress small ignitions caused by workers or in immediate vicinity of workers are provided 	<ul style="list-style-type: none"> a. Utility plans to have explicit policies about the role of crews, including contractors and subcontractors, at the site of ignition b. Training and communications tools are planned to be provided to immediately report ignitions caused by workers or in immediate vicinity of workers; in addition, suppression tools and training to suppress small ignitions caused by workers or in immediate vicinity of workers are planned to be provided; communication tools function without cell reception and training by suppression professionals is provided
3	<ul style="list-style-type: none"> c. No Cal/OSHA reported injuries or fatalities occurred in the last year in events where workers have encountered an ignition d. Utility does not provide training to other workers at other utilities and outside the utility industry on best practices to minimize, report, and suppress ignition 	<ul style="list-style-type: none"> c. No Cal/OSHA reported injuries or fatalities are planned to occur in events where workers have encountered an ignition d. Utility plans to provide training to other workers at other utilities and outside the utility industry on best practices to minimize, report, and suppress ignition
2		
1		
0		
	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.7 G. Data Governance

1.2.7.1 Capability 33: Data collection and curation

			Capability 33: Data collection and curation		
Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020	Bold responses have planned growth between 2020 and 2023
2020	2023	Both			
4			a. Utility does not have a centralized database of situational, operational, and risk data b. Utility is not able to use advanced analytics on its centralized database of situational, operational, and risk data to make operational and investment decisions c. Utility collects data from all sensored portions of electric lines, equipment, weather stations, etc. d. Utility’s database of situational, operational, and risk data is not able to ingest and share data using real-time API protocols with a wide variety of stakeholders e. Utility identifies highest priority additional data sources to improve decision making f. Utility does not share best practices for database management and use with other utilities in California and beyond	a. Utility plans to have a centralized database of situational, operational, and risk data b. Utility plans to be able to use advanced analytics on its centralized database of situational, operational, and risk data to make short-term operational and investment decisions c. Utility plans to collect data from all sensored portions of electric lines, equipment, weather stations, etc. d. Utility’s database of situational, operational, and risk data is planned to be able to ingest and share data using real-time API protocols with a wide variety of stakeholders e. Utility plans to identify highest priority additional data sources to improve decision making, and plans to incorporate these sources into its centralized database of situational, operational and risk data f. Utility plans to share best practices for database management and use with other utilities in California and beyond through a specified process	
3					
2					
1					
0					
Criteria missing to reach a maturity level of 1 or more:			Criteria missing to reach a maturity level of 1 or more:	<ul style="list-style-type: none"> Utility has a centralized repository of accurate situational, operational, and risk data <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.7.2 Capability 34: Data transparency and analytics

Capability 34: Data transparency and analytics		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	<p>a. There is not a single document cataloguing all fire-related data and algorithms, analyses, and data processes</p> <p>b. There is not an explanation of the sources, cleaning processes, and assumptions made in the single document catalog</p> <p>c. Not all analyses, algorithms, and data processing are documented</p> <p>d. There is not a system capable of sharing across at least three levels of permissions</p> <p>e. Most relevant wildfire related data algorithms is disclosed to regulators and other relevant stakeholders upon request</p>	<p>a. There is planned to be a single document cataloguing all fire-related data and algorithms, analyses, and data processes</p> <p>b. There is planned to be an explanation of the sources, cleaning processes, and assumptions made in the single document catalog</p> <p>c. All analyses, algorithms, and data processing are planned to be documented and explained</p> <p>d. Bear Valley plans to have a system capable of sharing across at least two levels of permissions, including utility-regulator permissions and first responder permissions</p> <p>e. Most relevant wildfire related data algorithms is planned to be disclosed publicly in WMP upon request</p>
3		
2		
1		
0		
	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • All wildfire-related data and algorithms used by utility are catalogued in a single document, • including an explanation of the sources, and assumptions made 	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.7.3 Capability 35: Near-miss tracking

Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020		
2020	2023	Both	Bold responses have planned growth between 2020 and 2023		
4	a. Utility tracks near miss data for all near misses with wildfire ignition potential b. Utility is not able to simulate wildfire potential given an ignition based on event characteristics, fuel loads, and moisture based on near miss data captured c. Utility captures data related to the specific mode of failure when capturing near-miss data d. Utility is not able to predict the probability of a near miss in causing an ignition based on a set of event characteristics e. Utility uses data from near misses to change grid operation protocols in real time			a. Utility plans to track near miss data for all near misses with wildfire ignition potential b. Utility plans to be able to simulate wildfire potential given an ignition based on event characteristics, fuel loads, and moisture based on near miss data captured c. Utility plans to capture data related to the specific mode of failure when capturing near-miss data d. Utility plans to be able to predict the probability of a near miss in causing an ignition based on a set of event characteristics e. Utility plans to use data from near misses to change grid operation protocols in real time	
3					
2					
1					
0					
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.7.4 Capability 36: Data sharing with research community

Capability 36: Data sharing with research community		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	a. Utility makes required data disclosures, but does not share data beyond what is required	a. Utility plans to make required data disclosures, and to share data beyond what is required
3	b. Utility participates in collaborative research	b. Utility plans to participate in collaborative research
2	c. Utility research addresses utility ignited wildfires and risk reduction initiatives	c. Utility research plans to address utility ignited wildfires and risk reduction initiatives
1	d. Utility promotes best practices based on latest independent scientific and operational research	d. Utility plans to promote best practices based on latest independent scientific and operational research
0		
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.8 H. Resource allocation methodology

1.2.8.1 Capability 37: Scenario analysis across different risk levels

			Capability 37: Scenario analysis across different risk levels		
Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020	Bold responses have planned growth between 2020 and 2023
2020	2023	Both			
4			a. Utility provides an accurate high-risk reduction and low-risk reduction scenario, in addition to their proposed scenario, and the projected cost and total risk reduction potential	a. Utility plans to provide an accurate high-risk reduction and low-risk reduction scenario, in addition to their proposed scenario, and the projected cost and total risk reduction potential	
3			b. Utility provides projections for each scenario with region-level granularity	b. Utility plans to provide projections for each scenario with circuit-level granularity	
2			c. Utility includes a long term (e.g., 6-10 year) risk estimate taking into account macro factors (climate change, etc.) as well as planned risk reduction initiatives in its scenarios	c. Utility plans to include a long term (e.g., 6-10 year) risk estimate taking into account macro factors (climate change, etc.) as well as planned risk reduction initiatives in its scenarios	
1			d. Utility provides an estimate of impact on reliability factors in its scenarios	d. Utility plans to provide an estimate of impact on reliability factors in its scenarios	
0			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.8.2 Capability 38: Presentation of relative risk spend efficiency for portfolio of initiatives

Capability 38: Presentation of relative risk spend efficiency for portfolio of initiatives		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	<ul style="list-style-type: none"> a. Utility presents accurate qualitative rankings for its initiatives by risk spend efficiency (RSE) b. All commercial and emerging initiatives are captured in the ranking of risk spend efficiency 	<ul style="list-style-type: none"> a. Utility plans to present accurate qualitative rankings for its initiatives by risk spend efficiency b. All commercial and emerging initiatives are planned to be captured in the ranking of risk spend efficiency
3	<ul style="list-style-type: none"> c. Utility includes figures for present value cost and project risk reduction impact of each initiative, clearly documenting all assumptions (e.g., useful life, discount rate, etc.) 	<ul style="list-style-type: none"> c. Utility plans to include figures for present value cost and project risk reduction impact of each initiative, clearly documenting all assumptions (e.g., useful life, discount rate, etc.)
2	<ul style="list-style-type: none"> d. Utility provides an explanation of their investment in each particular initiative, including the expected overall reduction in risk e. Utility provides risk efficiency figures with region-level granularity 	<ul style="list-style-type: none"> d. Utility plans to provide an explanation of their investment in each particular initiative, including the expected overall reduction in risk and estimates of impact on reliability factors e. Utility plans to provide risk efficiency figures with circuit-level granularity
1		
0		
	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.8.3 Capability 39: Process for determining risk spend efficiency of vegetation management initiatives

Capability 39: Process for determining risk spend efficiency of vegetation management initiatives		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	<ul style="list-style-type: none"> a. Utility has accurate quantitative understanding of cost and effectiveness to produce a reliable risk spend efficiency estimate of vegetation management initiatives 	<ul style="list-style-type: none"> a. Utility plans to have accurate quantitative understanding of cost, including sensitivities, and effectiveness to produce a reliable risk spend efficiency estimate of vegetation management initiatives
3	<ul style="list-style-type: none"> b. Risk spend efficiency estimates of vegetation management initiatives can be prepared with region-level granularity 	<ul style="list-style-type: none"> b. Risk spend efficiency estimates of vegetation management initiatives planned to be prepared with circuit-level granularity
2	<ul style="list-style-type: none"> c. Risk spend efficiency estimates of vegetation management initiatives are updated annually or more frequently 	<ul style="list-style-type: none"> c. Risk spend efficiency estimates of vegetation management initiatives are planned to be updated annually or more frequently
1	<ul style="list-style-type: none"> d. All vegetation management initiatives are included within its evaluation 	<ul style="list-style-type: none"> d. All vegetation management initiatives are planned to be included within its evaluation and supported by independent testing
0	<ul style="list-style-type: none"> e. Utility evaluates risk reduction synergies from combination of various initiatives 	<ul style="list-style-type: none"> e. Utility plans to evaluate risk reduction synergies from combination of various initiatives
	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.8.4 Capability 40: Process for determining risk spend efficiency of system hardening initiatives

Capability 40: Process for determining risk spend efficiency of system hardening initiatives		
Automated maturity levels based on Maturity Rubric	Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>	
Legend	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
2020 2023 Both		Bold responses have planned growth between 2020 and 2023
4	<ul style="list-style-type: none"> a. Utility has accurate quantitative understanding of cost and effectiveness to produce a reliable risk spend efficiency estimate of system hardening initiatives 	<ul style="list-style-type: none"> a. Utility plans to have an accurate quantitative understanding of cost, including sensitivities, and effectiveness to produce a reliable risk spend efficiency estimate of system hardening initiatives
3	<ul style="list-style-type: none"> b. Risk spend efficiency of system hardening initiatives can be prepared with region-based granularity c. Estimates of system hardening initiatives are updated annually or more frequently 	<ul style="list-style-type: none"> b. Risk spend efficiency of system hardening initiatives can be prepared with circuit-based granularity c. Estimates of system hardening initiatives are updated annually or more frequently
2	<ul style="list-style-type: none"> d. All commercially available grid hardening initiatives are included in the utility risk spend efficiency analysis e. Utility evaluates risk reduction effects from the combination of various initiatives 	<ul style="list-style-type: none"> d. All commercially available grid hardening initiatives are planned to be included in the utility risk spend efficiency analysis, as well as those initiatives that are lab tested e. Utility plans to evaluate risk reduction effects from the combination of various initiatives
1		
0		
	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	<p>Criteria missing to reach a maturity level of 1 or more:</p> <ul style="list-style-type: none"> • N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.8.5 Capability 41: Portfolio-wide initiative allocation methodology

Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020		
2020	2023	Both	Bold responses have planned growth between 2020 and 2023		
4	a. Utility uses accurate RSE estimates for all initiatives to determine capital allocation across portfolio (e.g., prioritizing between vegetation management and grid hardening)			a. Utility plans to use accurate RSE estimates for all initiatives to determine capital allocation across portfolio (e.g., prioritizing between vegetation management and grid hardening)	
3	b. Utility takes into account specific information by initiative, including state of equipment and location where initiative will be implemented			b. Utility plans to take into account specific information by initiative at the asset level, including state of specific assets and location where initiative will be implemented	
2	c. Utility verifies RSE estimates with historical or experimental pilot data			c. Utility plans to verify RSE estimates with historical or experimental pilot data, and confirmed by independent experts or other utilities in CA	
1	d. Utility considers impact on safety, reliability, and other priorities when making spending decisions			d. Utility plans to consider impact on safety, reliability, and other priorities when making spending decisions	
0	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> Utility allocates spend within each category of wildfire risk reduction by accurate risk spend efficiency estimates 			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> Utility allocates spend within each category of wildfire risk reduction by accurate risk spend efficiency estimates 	

1.2.8.6 Capability 42: Portfolio-wide innovation in new wildfire initiatives

Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020		
2020	2023	Both	Bold responses have planned growth between 2020 and 2023		
4	a. Utility uses pilots, followed by in-field testing, and measures direct reduction in ignition events and near-misses to develop and evaluate the efficacy of new wildfire initiatives b. Utility uses total cost of ownership to develop and evaluate the RSE of new wildfire initiatives c. Utility measures efficacy of new wildfire initiatives across the entire territory d. Reviews of innovative initiatives are not audited by independent parties e. Utility shares the findings of its evaluation of innovative initiatives with other utilities, academia, and the general public			a. Utility plans to use pilots, followed by in-field testing, and measure direct reduction in ignition events and near-misses to develop and evaluate the efficacy of new wildfire initiatives b. Utility plans to use total cost of ownership to develop and evaluate the risk spend efficiency of new wildfire initiatives c. Utility plans to measure efficacy of new wildfire initiatives with circuit-level granularity d. Reviews of innovative initiatives are planned to be audited by independent parties e. Utility shares the findings of its evaluation of innovative initiatives with other utilities, academia, and the general public	
3					
2					
1					
0	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.9 I. Emergency planning and preparedness

1.2.9.1 Capability 43: Wildfire plan integrated with overall disaster / emergency plan

			Capability 43: Wildfire plan integrated with overall disaster / emergency plan		
Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020	Bold responses have planned growth between 2020 and 2023
2020	2023	Both			
4			a. Wildfire plan is an integrated component of overall disaster and emergency plans b. Utility runs drills to audit the viability and execution of its wildfire plans c. Impact of confounding events or multiple simultaneous disasters is considered in the planning process d. Plan is integrated with disaster and emergency preparedness plans of other relevant stakeholders (e.g., CAL FIRE, Fire Safe Councils, etc.) e. Utility takes a leading role in planning, coordinating, and integrating plans across stakeholders	a. Wildfire plan is planned to be an integrated component of overall disaster and emergency plans b. Utility plans to run drills to audit the viability and execution of its wildfire plans c. Impact of confounding events or multiple simultaneous disasters is planned to be considered in the planning process d. Wildfire plan is planned to be integrated with disaster and emergency preparedness plans of other relevant stakeholders (e.g., CAL FIRE, Fire Safe Councils, etc.) e. Utility plans to take a leading role in planning, coordinating, and integrating plans across stakeholders	
3					
2					
1					
0					
			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.9.2 Capability 44: Plan to restore service after wildfire related outage

			Capability 44: Plan to restore service after wildfire related outage		
			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend 2020 2023 Both			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020 Bold responses have planned growth between 2020 and 2023	
4	a. Detailed and actionable procedures are in place to restore service after a wildfire related outage		b. Employee and subcontractor crews are trained in and aware of plans	c. Procedures to restore service after a wildfire-related outage are customized with circuit-level granularity	d. Customized procedure to restore service is based on topography, vegetation, and community needs
3	a. Detailed and actionable procedures are in place to restore service after a wildfire related outage		b. Employee and subcontractor crews are trained in and aware of plans	c. Procedures to restore service after a wildfire-related outage are planned to be customized with circuit-level granularity	d. Customized procedure to restore service is planned to be based on topography, vegetation, and community needs
2	a. Detailed and actionable procedures are in place to restore service after a wildfire related outage		b. Employee and subcontractor crews are trained in and aware of plans	c. Procedures to restore service after a wildfire-related outage are planned to be customized with circuit-level granularity	d. Customized procedure to restore service is planned to be based on topography, vegetation, and community needs
1	a. Detailed and actionable procedures are in place to restore service after a wildfire related outage		b. Employee and subcontractor crews are trained in and aware of plans	c. Procedures to restore service after a wildfire-related outage are planned to be customized with circuit-level granularity	d. Customized procedure to restore service is planned to be based on topography, vegetation, and community needs
0	a. Detailed and actionable procedures are in place to restore service after a wildfire related outage		b. Employee and subcontractor crews are trained in and aware of plans	c. Procedures to restore service after a wildfire-related outage are planned to be customized with circuit-level granularity	d. Customized procedure to restore service is planned to be based on topography, vegetation, and community needs
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 		Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 		

1.2.9.3 Capability 45: Emergency community engagement during and after wildfire

Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020		
2020	2023	Both	Bold responses have planned growth between 2020 and 2023		
4	a. Utility provides clear and substantially complete communication of available information relevant to affected customers, as well as referrals to other emergency management resources b. >99.9% of customers receive complete details of available information c. >99.9% of affected medical baseline customers receive complete details of available information d. Utility assists where helpful with communication of information related to power outages to customers through availability of relevant evacuation information and links on website / toll-free telephone number, and assists disaster response professionals as requested e. Utility has detailed and actionable established protocols for engaging with emergency management organizations f. Utility communicates and coordinates resources to communities during emergencies (e.g., shelters, supplies, transportation, etc.)			a. Utility plans to provide clear and substantially complete communication of available information relevant to affected customers, as well as referrals to other emergency management resources b. >99.9% of customers are planned to receive complete details of available information c. >99.9% of affected medical baseline customers are planned to receive complete details of available information d. Utility plans to assist where helpful with communication of information related to power outages to customers through availability of relevant evacuation information and links on website/toll-free telephone number, and to assist disaster response professionals as requested e. Utility plans to have detailed and actionable established protocols for engaging with emergency management organizations f. Utility plans to communicate and coordinate resources to communities during emergencies (e.g., shelters, supplies, transportation, etc.)	
3					
2					
1					
0					
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.9.4 Capability 46: Protocols in place to learn from wildfire events

Capability 46: Protocols in place to learn from wildfire events		
Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend 		
Automated maturity levels based on Maturity Rubric	Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020
4	a. There is a protocol in place to record the outcome of emergency events and to clearly and actionably document learnings and potential process improvements	a. Bear Valley plans to have a protocol in place to record the outcome of emergency events and to clearly and actionably document learnings and potential process improvements
3	b. There is a defined process and staff responsible for incorporating learnings into emergency plan	b. Bear Valley plans to have a defined process and staff responsible for incorporating learnings into emergency plan
2	c. Bear Valley uses “dry runs” to test plans updated based on learnings and improvements to confirm its effectiveness	c. Bear Valley plans to have “dry runs” to test plans updated based on learnings and improvements to confirm its effectiveness
1	d. There is a defined process to solicit input from a variety of other stakeholders and incorporate learnings from other stakeholders into the emergency plan	d. Bear Valley plans to have a defined process to solicit input from a variety of other stakeholders and incorporate learnings from other stakeholders into the emergency plan
0	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none">• N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric

1.2.9.5 Capability 47: Processes for continuous improvement after wildfire and PSPS

			Capability 47: Processes for continuous improvement after wildfire and PSPS		
Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020	
2020	2023	Both		Bold responses have planned growth between 2020 and 2023	
4	a. Utility conducts an evaluation or debrief process after a wildfire b. Utility conducts a customer survey and utilizes partners to disseminate requests for stakeholder engagement c. Utility engages in public listening sessions, and debriefs with partners d. Utility shares findings with partners about what can be improved e. Feedback and recommendations on potential improvements are made public f. Utility conducts proactive outreach to local agencies and organizations to solicit additional feedback on what can be improved g. Utility has a clear plan for post-event listening and incorporating lessons learned from all stakeholders h. Utility tracks the implementation of recommendations and report upon their impact i. Utility has a process to conduct reviews after wildfires in other territories of other utilities and states to identify and address areas of improvement			a. Utility plans to conduct an evaluation or debrief process after a wildfire b. Utility plans to conduct a customer survey and utilize partners to disseminate requests for stakeholder engagement c. Utility plans to engage in public listening sessions, debriefs with partners, and others d. Utility plans to share findings with partners about what can be improved e. Feedback and recommendations on potential improvements are planned to be made public f. Utility plans to conduct proactive outreach to local agencies and organizations to solicit additional feedback on what can be improved g. Utility plans to have a clear plan for post-event listening and incorporating lessons learned from all stakeholders h. Utility plans to track the implementation of recommendations and report upon their impact i. Utility plans to have a process to conduct reviews after wildfires in other territories of other utilities and states to identify and address areas of improvement	
3					
2					
1					
0	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.10 J. Stakeholder cooperation and community engagement

1.2.10.1 Capability 48: Cooperation and best practice sharing with other utilities

			Capability 48: Cooperation and best practice sharing with other utilities		
Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020	Planned state for 2023 “Three years from now” as of February 2020	Bold responses have planned growth between 2020 and 2023
2020	2023	Both			
4			a. Utility actively works to identify best practices from other global utilities through a clearly defined operational process b. Utility successfully adopts and implements best practices identified from other utilities c. Utility seeks to share best practices and lessons learned in a consistent format	a. Utility plans to actively work to identify best practices from other global utilities through a clearly defined operational process b. Utility plans to successfully adopt and implement best practices identified from other utilities c. Utility plans to seek to share best practices and lessons learned in a consistent format	
3			d. Utility shares best practices and lessons via a consistent and predictable set of venues / media e. Utility participates in annual benchmarking exercises with other utilities to find other areas for improvement f. Utility has implemented a defined process for testing lessons learned from other utilities to ensure local applicability	d. Utility plans to share best practices and lessons via a consistent and predictable set of venues / media e. Utility plans to participate in annual benchmarking exercises with other utilities to find other areas for improvement f. Utility plans to implement a defined process for testing lessons learned from other utilities to ensure local applicability	
2					
1					
0					
			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.10.2 Capability 49: Engagement with communities on utility wildfire mitigation initiatives

Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>			
Legend			Current state As of February 2020			
2020	2023	Both	Bold responses have planned growth between 2020 and 2023			
4	a. Utility has a clear and actionable plan to develop or maintain a collaborative relationship with local communities b. There are not communities in HFTD areas where meaningful resistance is expected in response to efforts to mitigate fire risk (e.g., vegetation clearance) c. Less than 0.5% of landowners are non-compliant with utility initiatives (e.g., vegetation management) d. Less than 1% of landowners complain about utility initiatives (e.g., vegetation management) e. Utility has a demonstratively cooperative relationship with communities containing >90% of the population in HFTD areas (e.g., by being recognized by other agencies as having a cooperative relationship with those communities in HFTD areas) f. Utility has records of landowners throughout communities containing >90% of the population in HFTD areas reaching out to notify of risks, dangers, or issues in the past year			a. Utility plans to have a clear and actionable plan to develop or maintain a collaborative relationship with local communities b. Bear Valley does not plan to have communities in HFTD areas where meaningful resistance is expected in response to efforts to mitigate fire risk (e.g., vegetation clearance) c. Bear Valley plans to have less than 0.5% of landowners non-compliant with utility initiatives (e.g., vegetation management) d. Bear Valley plans to have less than 1% of landowners complain about utility initiatives (e.g., vegetation management) e. Utility plans to have a demonstratively cooperative relationship with communities containing >90% of the population in HFTD areas (e.g., by being recognized by other agencies as having a cooperative relationship with those communities in HFTD areas) f. Utility plans to have records of landowners throughout communities containing >90% of the population in HFTD areas reaching out to notify of risks, dangers, or issues in the past year		
3						
2						
1						
0						
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 		

1.2.10.3 Capability 50: Engagement with LEP and AFN populations

Capability 50: Engagement with LEP and AFN populations		
Automated maturity levels based on Maturity Rubric		Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>
Legend		Current state As of February 2020
2020	2023	Both
4	a. Utility does not provide a plan to partner with organizations representing Limited English Proficiency (LEP) and Access & Functional Needs (AFN) communities	a. Utility does not plan to provide a plan to partner with organizations representing Limited English Proficiency (LEP) and Access & Functional Needs (AFN) communities
3	b. Utility cannot outline how partnerships with LEP and AFN communities create pathways for implementing suggested activities to address the needs of these communities	b. Utility does not plan to be able to outline how partnerships with LEP and AFN communities create pathways for implementing suggested activities to address the needs of these communities
2	c. Utility cannot point to clear examples of how relationships with LEP and AFN communities have driven the utility's ability to interact with and prepare these communities for wildfire mitigation activities	c. Utility does not plan to be able to point to clear examples of how relationships with LEP and AFN communities have driven the utility's ability to interact with and prepare these communities for wildfire mitigation activities
1	d. Utility does not have a specific annually-updated action plan to further reduce wildfires and PSPS risk to LEP & AFN communities	d. Utility does not plan to have a specific annually-updated action plan to further reduce wildfires and PSPS risk to LEP & AFN communities
0	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> Utility has a plan for partnering with organization representing LEP and AFN communities Utility is able to provide information about the nature of these partnerships 	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> Utility has a plan for partnering with organization representing LEP and AFN communities Utility is able to provide information about the nature of these partnerships

1.2.10.4 Capability 51: Collaboration with emergency response agencies

Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020		
2020	2023	Both	Bold responses have planned growth between 2020 and 2023		
4	a. Utility cooperates with suppression agencies by working cooperatively with them to detect ignitions, in addition to notifying them of ignitions as needed b. Utility is cooperating with suppression agencies throughout utility service areas c. Utility accurately predicts and communicates the forecasted fire propagation path using available analytics resources and weather data d. Utility communicates fire paths to the community as requested e. Utility works to assist suppression crews logically where possible			a. Utility plans to cooperate with suppression agencies by working cooperatively with them to detect ignitions, in addition to notifying them of ignitions as needed b. Utility plans to cooperate with suppression agencies throughout utility service areas c. Utility plans to be able to accurately predict and communicate the forecasted fire propagation path using available analytics resources and weather data d. Utility plans to be able to communicate fire paths to the community as requested e. Utility plans to work to assist suppression crews logically where possible	
3					
2					
1					
0					
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.2.10.5 Capability 52: Collaboration on wildfire mitigation planning with stakeholders

Automated maturity levels based on Maturity Rubric			Responses to survey questions <i>Each letter indicates a survey question, with the relevant response shown below.</i>		
Legend			Current state As of February 2020		
2020	2023	Both	Bold responses have planned growth between 2020 and 2023		
4	a. Utility conducts fuel management throughout service area b. Utility shares fuel management plans with other stakeholders, and coordinates fuel management activities, including adjusting plans, to cooperate with other stakeholders state-wide to focus on areas that would have the biggest impact in reducing wildfire risk c. Utility cultivates a native vegetative ecosystem across territory that is consistent with lower fire risk d. Utility funds local groups (e.g., fire safe councils) to support fuel management			a. Utility is plans to conduct fuel management throughout service area b. Utility plans to share fuel management plans with other stakeholders, and to proactively coordinate fuel management activities, including adjustment of plans, to cooperate with other stakeholders state-wide to focus on areas that would have the biggest impact in reducing wildfire risk c. Utility plans to cultivate a native vegetative ecosystem across territory that is consistent with lower fire risk d. Utility plans to fund local groups (e.g., fire safe councils) to support fuel management	
3					
2					
1					
0					
	Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 			Criteria missing to reach a maturity level of 1 or more: <ul style="list-style-type: none"> N/A – all criteria to reach a 1 are met based on survey responses and maturity rubric 	

1.3 Bear Valley: Numerical maturity summary

Please reference the Guidance Resolution for the Maturity Rubric and for necessary context to interpret the levels shown below. **All levels are based solely on the Maturity Rubric and on Bear Valley's responses to the Utility Wildfire Mitigation Maturity Survey.**

"2020" refers to February 2020, and "2023" refers to February 2023. See the Survey for more detail.

Legend	2020 Maturity Level					2023 Maturity Level					Maturity Level for 2020 and 2023																
Category	Capability I					Capability II					Capability III					Capability IV					Capability VI						
A. Risk assessment and mapping	1. Climate scenario modeling	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4	N/A					
B. Situational awareness and forecasting	6. Weather variables collected	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4	N/A					
C. Grid design and system hardening	11. Approach to prioritizing initiatives across territory	0	1	2	3	4	12. Grid design for minimizing ignition risk	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4	N/A				
D. Asset management and inspections	16. Asset inventory and condition assessments	0	1	2	3	4	17. Asset inspection cycle	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4	N/A				
E. Vegetation management and inspections	21. Vegetation inventory for condition assessment	0	1	2	3	4	22. Vegetation inspection cycle	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4
F. Grid operations and operating protocols	27. Protective equipment and device settings	0	1	2	3	4	28. Incorporating ignition risk factors in grid control	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4
G. Data governance	33. Data collection and curation	0	1	2	3	4	34. Data transparency and analytics	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4	N/A	N/A	N/A		
H. Resource allocation methodology	37. Scenario analysis across different risk levels	0	1	2	3	4	38. Presentation of relative risk spend efficiency for portfolio of initiatives	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4
I. Emergency planning and preparedness	43. Wildfire plan integrated with overall disaster / emergency plan	0	1	2	3	4	44. Plan to restore service after wildfire related outage	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4
J. Stakeholder cooperation and community engagement	48. Cooperation and best practice sharing with other utilities	0	1	2	3	4	49. Engagement with communities on utility wildfire mitigation initiatives	0	1	2	3	4	50. Engagement with LEP and AFN populations	0	1	2	3	4	51. Collaboration with emergency response agencies	0	1	2	3	4	52. Collaboration on wildfire mitigation planning with stakeholders	N/A	
	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4	0	1	2	3	4							

(End of Appendix C)

APPENDIX D

Definitions of Mitigation Initiatives from Section 5 of WMP Guidelines

5.3.11 Definitions of initiatives by category

Category	Initiative	Definition
A. Risk mapping and simulation	A summarized risk map that shows the overall ignition probability and estimated wildfire consequence along the electric lines and equipment	Development and use of tools and processes to develop and update risk map and simulations and to estimate risk reduction potential of initiatives for a given portion of the grid (or more granularly, e.g., circuit, span, or asset). May include verification efforts, independent assessment by experts, and updates.
	Climate-driven risk map and modelling based on various relevant weather scenarios	Development and use of tools and processes to estimate incremental risk of foreseeable climate scenarios, such as drought, across a given portion of the grid (or more granularly, e.g., circuit, span, or asset). May include verification efforts, independent assessment by experts, and updates.
	Ignition probability mapping showing the probability of ignition along the electric lines and equipment	Development and use of tools and processes to assess the risk of ignition across regions of the grid (or more granularly, e.g., circuits, spans, or assets).
	Initiative mapping and estimation of wildfire and PSPS risk-reduction impact	Development of a tool to estimate the risk reduction efficacy (for both wildfire and PSPS risk) and risk-spend efficiency of various initiatives.
	Match drop simulations showing the potential wildfire consequence of ignitions that occur along the electric lines and equipment	Development and use of tools and processes to assess the impact of potential ignition and risk to communities (e.g., in terms of potential fatalities, structures burned, monetary damages, area burned, impact on air quality and greenhouse gas, or GHG, reduction goals, etc.).
B. Situational awareness and forecasting	Advanced weather monitoring and weather stations	Purchase, installation, maintenance, and operation of weather stations. Collection, recording, and analysis of weather data from weather stations and from external sources.
	Continuous monitoring sensors	Installation, maintenance, and monitoring of sensors and sensorized equipment used to monitor the condition of electric lines and equipment.
	Fault indicators for detecting faults on electric lines and equipment	Installation and maintenance of fault indicators.
	Forecast of a fire risk index, fire potential index, or similar	Index that uses a combination of weather parameters (such as wind speed, humidity, and temperature), vegetation and/or fuel conditions, and other factors to judge current fire risk and to create a forecast indicative of fire risk. A sufficiently granular index shall inform operational decision-making.
	Personnel monitoring areas of electric lines and equipment in elevated fire risk conditions	Personnel position within utility service territory to monitor system conditions and weather on site. Field observations shall inform operational decisions.
	Weather forecasting and estimating impacts on electric lines and equipment	Development methodology for forecast of weather conditions relevant to utility operations, forecasting weather conditions and conducting analysis to incorporate into utility decision-making, learning and updates to reduce false positives and false negatives of forecast PSPS conditions.

Category	Initiative	Definition
C. Grid design and system hardening	Capacitor maintenance and replacement program	Remediation, adjustments, or installations of new equipment to improve or replace existing capacitor equipment.
	Circuit breaker maintenance and installation to de-energize lines upon detecting a fault	Remediation, adjustments, or installations of new equipment to improve or replace existing fast switching circuit breaker equipment to improve the ability to protect electrical circuits from damage caused by overload of electricity or short circuit.
	Covered conductor installation	Installation of covered or insulated conductors to replace standard bare or unprotected conductors (defined in accordance with GO 95 as supply conductors, including but not limited to lead wires, not enclosed in a grounded metal pole or not covered by: a “suitable protective covering” (in accordance with Rule 22.8), grounded metal conduit, or grounded metal sheath or shield). In accordance with GO 95, conductor is defined as a material suitable for: (1) carrying electric current, usually in the form of a wire, cable or bus bar, or (2) transmitting light in the case of fiber optics; insulated conductors as those which are surrounded by an insulating material (in accordance with Rule 21.6), the dielectric strength of which is sufficient to withstand the maximum difference of potential at normal operating voltages of the circuit without breakdown or puncture; and suitable protective covering as a covering of wood or other non-conductive material having the electrical insulating efficiency (12kV/in. dry) and impact strength (20ft.-lbs) of 1.5 inches of redwood or other material meeting the requirements of Rule 22.8-A, 22.8-B, 22.8-C or 22.8-D.
	Covered conductor maintenance	Remediation and adjustments to installed covered or insulated conductors. In accordance with GO 95, conductor is defined as a material suitable for: (1) carrying electric current, usually in the form of a wire, cable or bus bar, or (2) transmitting light in the case of fiber optics; insulated conductors as those which are surrounded by an insulating material (in accordance with Rule 21.6), the dielectric strength of which is sufficient to withstand the maximum difference of potential at normal operating voltages of the circuit without breakdown or puncture; and suitable protective covering as a covering of wood or other non-conductive material having the electrical insulating efficiency (12kV/in. dry) and impact strength (20ft.-lbs) of 1.5 inches of redwood or other material meeting the requirements of Rule 22.8-A, 22.8-B, 22.8-C or 22.8-D.
	Crossarm maintenance, repair, and replacement	Remediation, adjustments, or installations of new equipment to improve or replace existing crossarms, defined as horizontal support attached to poles or structures generally at right angles to the conductor supported in accordance with GO 95.
	Distribution pole replacement and reinforcement, including with composite poles	Remediation, adjustments, or installations of new equipment to improve or replace existing distribution poles (i.e., those supporting lines under 65kV), including with equipment such as composite poles manufactured with materials reduce ignition probability by increasing pole lifespan and resilience against failure from object contact and other events.
	Expulsion fuse replacement	Installations of new and CAL FIRE-approved power fuses to replace existing expulsion fuse equipment.

Category	Initiative	Definition
	Grid topology improvements to mitigate or reduce PSPS events	Plan to support and actions taken to mitigate or reduce PSPS events in terms of geographic scope and number of customers affected, such as installation and operation of electrical equipment to sectionalize or island portions of the grid, microgrids, or local generation.
	Installation of system automation equipment	Installation of electric equipment that increases the ability of the utility to automate system operation and monitoring, including equipment that can be adjusted remotely such as automatic reclosers (switching devices designed to detect and interrupt momentary faults that can reclose automatically and detect if a fault remains, remaining open if so).
	Maintenance, repair, and replacement of connectors, including hotline clamps	Remediation, adjustments, or installations of new equipment to improve or replace existing connector equipment, such as hotline clamps.
	Mitigation of impact on customers and other residents affected during PSPS event	Actions taken to improve access to electricity for customers and other residents during PSPS events, such as installation and operation of local generation equipment (at the community, household, or other level).
	Other corrective action	Other maintenance, repair, or replacement of utility equipment and structures so that they function properly and safely, including remediation activities (such as insulator washing) of other electric equipment deficiencies that may increase ignition probability due to potential equipment failure or other drivers.
	Pole loading infrastructure hardening and replacement program based on pole loading assessment program	Actions taken to remediate, adjust, or install replacement equipment for poles that the utility has identified as failing to meet safety factor requirements in accordance with GO 95 or additional utility standards in the utility's pole loading assessment program.
	Transformers maintenance and replacement	Remediation, adjustments, or installations of new equipment to improve or replace existing transformer equipment.
	Transmission tower maintenance and replacement	Remediation, adjustments, or installations of new equipment to improve or replace existing transmission towers (e.g., structures such as lattice steel towers or tubular steel poles that support lines at or above 65kV).
	Undergrounding of electric lines and/or equipment	Actions taken to convert overhead electric lines and/or equipment to underground electric lines and/or equipment (i.e., located underground and in accordance with GO 128).
	Updates to grid topology to minimize risk of ignition in HFTDs	Changes in the plan, installation, construction, removal, and/or undergrounding to minimize the risk of ignition due to the design, location, or configuration of utility electric equipment in HFTDs.

Category	Initiative	Definition
D. Asset management and inspections	Detailed inspections of distribution electric lines and equipment	In accordance with GO 165, careful visual inspections of overhead electric distribution lines and equipment where individual pieces of equipment and structures are carefully examined, visually and through use of routine diagnostic test, as appropriate, and (if practical and if useful information can be so gathered) opened, and the condition of each rated and recorded.
	Detailed inspections of transmission electric lines and equipment	Careful visual inspections of overhead electric transmission lines and equipment where individual pieces of equipment and structures are carefully examined, visually and through use of routine diagnostic test, as appropriate, and (if practical and if useful information can be so gathered) opened, and the condition of each rated and recorded.
	Improvement of inspections	Identifying and addressing deficiencies in inspections protocols and implementation by improving training and the evaluation of inspectors.
	Infrared inspections of distribution electric lines and equipment	Inspections of overhead electric distribution lines, equipment, and right-of-way using infrared (heat-sensing) technology and cameras that can identify "hot spots", or conditions that indicate deterioration or potential equipment failures, of electrical equipment.
	Infrared inspections of transmission electric lines and equipment	Inspections of overhead electric transmission lines, equipment, and right-of-way using infrared (heat-sensing) technology and cameras that can identify "hot spots", or conditions that indicate deterioration or potential equipment failures, of electrical equipment.
	Intrusive pole inspections	In accordance with GO 165, intrusive inspections involve movement of soil, taking samples for analysis, and/or using more sophisticated diagnostic tools beyond visual inspections or instrument reading.
	LiDAR inspections of distribution electric lines and equipment	Inspections of overhead electric transmission lines, equipment, and right-of-way using LiDAR (Light Detection and Ranging, a remote sensing method that uses light in the form of a pulsed laser to measure variable distances).
	LiDAR inspections of transmission electric lines and equipment	Inspections of overhead electric distribution lines, equipment, and right-of-way using LiDAR (Light Detection and Ranging, a remote sensing method that uses light in the form of a pulsed laser to measure variable distances).
	Other discretionary inspection of distribution electric lines and equipment, beyond inspections mandated by rules and regulations	Inspections of overhead electric transmission lines, equipment, and right-of-way that exceed or otherwise go beyond those mandated by rules and regulations, including GO 165, in terms of frequency, inspection checklist requirements or detail, analysis of and response to problems identified, or other aspects of inspection or records kept.
	Other discretionary inspection of transmission electric lines and equipment, beyond inspections mandated by rules and regulations	Inspections of overhead electric distribution lines, equipment, and right-of-way that exceed or otherwise go beyond those mandated by rules and regulations, including GO 165, in terms of frequency, inspection checklist requirements or detail, analysis of and response to problems identified, or other aspects of inspection or records kept.,
	Patrol inspections of distribution electric lines and equipment	In accordance with GO 165, simple visual inspections of overhead electric distribution lines and equipment that is designed to identify obvious structural problems and hazards. Patrol inspections may be carried out in the course of other company business.

Category	Initiative	Definition
	Patrol inspections of transmission electric lines and equipment	Simple visual inspections of overhead electric transmission lines and equipment that is designed to identify obvious structural problems and hazards. Patrol inspections may be carried out in the course of other company business.
	Pole loading assessment program to determine safety factor	Calculations to determine whether a pole meets pole loading safety factor requirements of GO 95, including planning and information collection needed to support said calculations. Calculations shall consider many factors including the size, location, and type of pole; types of attachments; length of conductors attached; and number and design of supporting guys, per D.15-11-021.
	Quality assurance / quality control of inspections	Establishment and function of audit process to manage and confirm work completed by employees or subcontractors, including packaging QA/QC information for input to decision-making and related integrated workforce management processes.
	Substation inspections	In accordance with GO 175, inspection of substations performed by qualified persons and according to the frequency established by the utility, including record-keeping.
E. Vegetation management and inspection	Additional efforts to manage community and environmental impacts	Plan and execution of strategy to mitigate negative impacts from utility vegetation management to local communities and the environment, such as coordination with communities to plan and execute vegetation management work or promotion of fire-resistant planting practices
	Detailed inspections of vegetation around distribution electric lines and equipment	Careful visual inspections of vegetation around the right-of-way, where individual trees are carefully examined, visually, and the condition of each rated and recorded.
	Detailed inspections of vegetation around transmission electric lines and equipment	Careful visual inspections of vegetation around the right-of-way, where individual trees are carefully examined, visually, and the condition of each rated and recorded.
	Emergency response vegetation management due to red flag warning or other urgent conditions	Plan and execution of vegetation management activities, such as trimming or removal, executed based upon and in advance of forecast weather conditions that indicate high fire threat in terms of ignition probability and wildfire consequence.
	Fuel management and reduction of "slash" from vegetation management activities	Plan and execution of fuel management activities that reduce the availability of fuel in proximity to potential sources of ignition, including both reduction or adjustment of live fuel (in terms of species or otherwise) and of dead fuel, including "slash" from vegetation management activities that produce vegetation material such as branch trimmings and felled trees.
	Improvement of inspections	Identifying and addressing deficiencies in inspections protocols and implementation by improving training and the evaluation of inspectors.
	LiDAR inspections of vegetation around distribution electric lines and equipment	Inspections of right-of-way using LiDAR (Light Detection and Ranging, a remote sensing method that uses light in the form of a pulsed laser to measure variable distances).
	LiDAR inspections of vegetation around transmission electric lines and equipment	Inspections of right-of-way using LiDAR (Light Detection and Ranging, a remote sensing method that uses light in the form of a pulsed laser to measure variable distances).

Category	Initiative	Definition
	Other discretionary inspections of vegetation around distribution electric lines and equipment	Inspections of rights-of-way and adjacent vegetation that may be hazardous, which exceeds or otherwise go beyond those mandated by rules and regulations, in terms of frequency, inspection checklist requirements or detail, analysis of and response to problems identified, or other aspects of inspection or records kept.
	Other discretionary inspections of vegetation around transmission electric lines and equipment	Inspections of rights-of-way and adjacent vegetation that may be hazardous, which exceeds or otherwise go beyond those mandated by rules and regulations, in terms of frequency, inspection checklist requirements or detail, analysis of and response to problems identified, or other aspects of inspection or records kept.
	Patrol inspections of vegetation around distribution electric lines and equipment	Visual inspections of vegetation along rights-of-way that is designed to identify obvious hazards. Patrol inspections may be carried out in the course of other company business.
	Patrol inspections of vegetation around transmission electric lines and equipment	Visual inspections of vegetation along rights-of-way that is designed to identify obvious hazards. Patrol inspections may be carried out in the course of other company business.
	Quality assurance / quality control of vegetation inspections	Establishment and function of audit process to manage and confirm work completed by employees or subcontractors, including packaging QA/QC information for input to decision-making and related integrated workforce management processes.
	Recruiting and training of vegetation management personnel	Programs to ensure that the utility is able to identify and hire qualified vegetation management personnel and to ensure that both full-time employees and contractors tasked with vegetation management responsibilities are adequately trained to perform vegetation management work, according to the utility's wildfire mitigation plan, in addition to rules and regulations for safety.
	Remediation of at-risk species	Actions taken to reduce the ignition probability and wildfire consequence attributable to at-risk vegetation species, such as trimming, removal, and replacement.
	Removal and remediation of trees with strike potential to electric lines and equipment	Actions taken to remove or otherwise remediate trees that could potentially strike electrical equipment, if adverse events such as failure at the ground-level of the tree or branch breakout within the canopy of the tree, occur.
	Substation inspection	Inspection of vegetation surrounding substations, performed by qualified persons and according to the frequency established by the utility, including record-keeping.
	Substation vegetation management	Based on location and risk to substation equipment only, actions taken to reduce the ignition probability and wildfire consequence attributable to contact from vegetation to substation equipment.
	Vegetation inventory system	Inputs, operation, and support for centralized inventory of vegetation clearances updated based upon inspection results, including (1) inventory of species, (2) forecasting of growth, (3) forecasting of when growth threatens minimum right-of-way clearances ("grow-in" risk) or creates fall-in/fly-in risk.
	Vegetation management to achieve clearances around electric lines and equipment	Actions taken to ensure that vegetation does not encroach upon the minimum clearances set forth in Table 1 of GO 95, measured between line conductors and vegetation, such as trimming adjacent or overhanging tree limbs.

Category	Initiative	Definition
F. Grid operations and protocols	Automatic recloser operations	Designing and executing protocols to deactivate automatic reclosers based on local conditions for ignition probability and wildfire consequence.
	Crew-accompanying ignition prevention and suppression resources and services	Those firefighting staff and equipment (such as fire suppression engines and trailers, firefighting hose, valves, and water) that are deployed with construction crews and other electric workers to provide site-specific fire prevention and ignition mitigation during on-site work
	Personnel work procedures and training in conditions of elevated fire risk	Work activity guidelines that designate what type of work can be performed during operating conditions of different levels of wildfire risk. Training for personnel on these guidelines and the procedures they prescribe, from normal operating procedures to increased mitigation measures to constraints on work performed.
	Protocols for PSPS re-energization	Designing and executing procedures that accelerate the restoration of electric service in areas that were de-energized, while maintaining safety and reliability standards.
	PSPS events and mitigation of PSPS impacts	Designing, executing, and improving upon protocols to conduct PSPS events, including development of advanced methodologies to determine when to use PSPS, and to mitigate the impact of PSPS events on affected customers and local residents.
	Stationed and on-call ignition prevention and suppression resources and services	Firefighting staff and equipment (such as fire suppression engines and trailers, firefighting hose, valves, firefighting foam, chemical extinguishing agent, and water) stationed at utility facilities and/or standing by to respond to calls for fire suppression assistance.
G. Data governance	Centralized repository for data	Designing, maintaining, hosting, and upgrading a platform that supports storage, processing, and utilization of all utility proprietary data and data compiled by the utility from other sources.
	Collaborative research on utility ignition and/or wildfire	Developing and executing research work on utility ignition and/or wildfire topics in collaboration with other non-utility partners, such as academic institutions and research groups, to include data-sharing and funding as applicable.
	Documentation and disclosure of wildfire-related data and algorithms	Design and execution of processes to document and disclose wildfire-related data and algorithms to accord with rules and regulations, including use of scenarios for forecasting and stress testing.
	Tracking and analysis of near miss data	Tools and procedures to monitor, record, and conduct analysis of data on near miss events.
H. Resource allocation methodology	Allocation methodology development and application	Development of prioritization methodology for human and financial resources, including application of said methodology to utility decision-making.
	Risk reduction scenario development and analysis	Development of modelling capabilities for different risk reduction scenarios based on wildfire mitigation initiative implementation; analysis and application to utility decision-making.
	Risk spend efficiency analysis	Tools, procedures, and expertise to support analysis of wildfire mitigation initiative risk-spend efficiency, in terms of MAVF and/or MARS methodologies.

Category	Initiative	Definition
I. Emergency planning and preparedness	Adequate and trained workforce for service restoration	Actions taken to identify, hire, retain, and train qualified workforce to conduct service restoration in response to emergencies, including short-term contracting strategy and implementation.
	Community outreach, public awareness, and communications efforts	Actions to identify and contact key community stakeholders; increase public awareness of emergency planning and preparedness information; and design, translate, distribute, and evaluate effectiveness of communications taken before, during, and after a wildfire, including Access and Functional Needs populations and Limited English Proficiency populations in particular.
	Customer support in emergencies	Resources dedicated to customer support during emergencies, such as website pages and other digital resources, dedicated phone lines, etc.
	Disaster and emergency preparedness plan	Development of plan to deploy resources according to prioritization methodology for disaster and emergency preparedness of utility and within utility service territory (such as considerations for critical facilities and infrastructure), including strategy for collaboration with Public Safety Partners and communities.
	Preparedness and planning for service restoration	Development of plans to prepare the utility to restore service after emergencies, such as developing employee and staff trainings, and to conduct inspections and remediation necessary to re-energize lines and restore service to customers.
	Protocols in place to learn from wildfire events	Tools and procedures to monitor effectiveness of strategy and actions taken to prepare for emergencies and of strategy and actions taken during and after emergencies, including based on an accounting of the outcomes of wildfire events.
J. Stakeholder cooperation and community engagement	Community engagement	Strategy and actions taken to identify and contact key community stakeholders; increase public awareness and support of utility wildfire mitigation activity; and design, translate, distribute, and evaluate effectiveness of related communications. Includes specific strategies and actions taken to address concerns and serve needs of Access and Functional Needs populations and Limited English Proficiency populations in particular.
	Cooperation and best practice sharing with agencies outside CA	Strategy and actions taken to engage with agencies outside of California to exchange best practices both for utility wildfire mitigation and for stakeholder cooperation to mitigate and respond to wildfires.
	Cooperation with suppression agencies	Coordination with CAL FIRE, federal fire authorities, county fire authorities, and local fire authorities to support planning and operations, including support of aerial and ground firefighting in real-time, including information-sharing, dispatch of resources, and dedicated staff.
	Forest service and fuel reduction cooperation and joint roadmap	Strategy and actions taken to engage with local, state, and federal entities responsible for or participating in forest management and fuel reduction activities; and design utility cooperation strategy and joint stakeholder roadmap (plan for coordinating stakeholder efforts for forest management and fuel reduction activities).

(End of Appendix D)

APPENDIX E

Public Utilities Code Section 8386

8386.

- (a) Each electrical corporation shall construct, maintain, and operate its electrical lines and equipment in a manner that will minimize the risk of catastrophic wildfire posed by those electrical lines and equipment.
- (b) Each electrical corporation shall annually prepare and submit a wildfire mitigation plan to the Wildfire Safety Division for review and approval. In calendar year 2020, and thereafter, the plan shall cover at least a three-year period. The division shall establish a schedule for the submission of subsequent comprehensive wildfire mitigation plans, which may allow for the staggering of compliance periods for each electrical corporation. In its discretion, the division may allow the annual submissions to be updates to the last approved comprehensive wildfire mitigation plan; provided, that each electrical corporation shall submit a comprehensive wildfire mitigation plan at least once every three years.
- (c) The wildfire mitigation plan shall include all of the following:
- (1) An accounting of the responsibilities of persons responsible for executing the plan.
 - (2) The objectives of the plan.
 - (3) A description of the preventive strategies and programs to be adopted by the electrical corporation to minimize the risk of its electrical lines and equipment causing catastrophic wildfires, including consideration of dynamic climate change risks.
 - (4) A description of the metrics the electrical corporation plans to use to evaluate the plan's performance and the assumptions that underlie the use of those metrics.
 - (5) A discussion of how the application of previously identified metrics to previous plan performances has informed the plan.
 - (6) Protocols for disabling reclosers and deenergizing portions of the electrical distribution system that consider the associated impacts on public safety. As part of these protocols, each electrical corporation shall include protocols related to mitigating the public safety impacts of disabling reclosers and deenergizing portions of the electrical distribution system that consider the impacts on all of the following:
 - (A) Critical first responders.
 - (B) Health and communication infrastructure.
 - (C) Customers who receive medical baseline allowances pursuant to subdivision (c) of Section 739. The electrical corporation may deploy backup electrical resources or provide financial assistance for backup electrical resources to a customer receiving a medical baseline allowance for a customer who meets all of the following requirements:
 - (i) The customer relies on life-support equipment that operates on electricity to sustain life.
 - (ii) The customer demonstrates financial need, including through enrollment in the California Alternate Rates for Energy program created pursuant to Section 739.1.
 - (iii) The customer is not eligible for backup electrical resources provided through medical services, medical insurance, or community resources.
 - (D) Subparagraph (C) shall not be construed as preventing an electrical corporation from deploying backup electrical resources or providing financial assistance for backup electrical resources under any other authority.

(7) Appropriate and feasible procedures for notifying a customer who may be impacted by the deenergizing of electrical lines, including procedures for those customers receiving a medical baseline allowance as described in paragraph (6). The procedures shall direct notification to all public safety offices, critical first responders, health care facilities, and operators of telecommunications infrastructure with premises within the footprint of potential deenergization for a given event.

(8) Plans for vegetation management.

(9) Plans for inspections of the electrical corporation's electrical infrastructure.

(10) Protocols for the deenergization of the electrical corporation's transmission infrastructure, for instances when the deenergization may impact customers who, or entities that, are dependent upon the infrastructure.

(11) A list that identifies, describes, and prioritizes all wildfire risks, and drivers for those risks, throughout the electrical corporation's service territory, including all relevant wildfire risk and risk mitigation information that is part of the Safety Model Assessment Proceeding and the Risk Assessment Mitigation Phase filings. The list shall include, but not be limited to, both of the following:

(A) Risks and risk drivers associated with design, construction, operations, and maintenance of the electrical corporation's equipment and facilities.

(B) Particular risks and risk drivers associated with topographic and climatological risk factors throughout the different parts of the electrical corporation's service territory.

(12) A description of how the plan accounts for the wildfire risk identified in the electrical corporation's Risk Assessment Mitigation Phase filing.

(13) A description of the actions the electrical corporation will take to ensure its system will achieve the highest level of safety, reliability, and resiliency, and to ensure that its system is prepared for a major event, including hardening and modernizing its infrastructure with improved engineering, system design, standards, equipment, and facilities, such as undergrounding, insulation of distribution wires, and pole replacement.

(14) A description of where and how the electrical corporation considered undergrounding electrical distribution lines within those areas of its service territory identified to have the highest wildfire risk in a commission fire threat map.

(15) A showing that the electrical corporation has an adequately sized and trained workforce to promptly restore service after a major event, taking into account employees of other utilities pursuant to mutual aid agreements and employees of entities that have entered into contracts with the electrical corporation.

(16) Identification of any geographic area in the electrical corporation's service territory that is a higher wildfire threat than is currently identified in a commission fire threat map, and where the commission should consider expanding the high fire threat district based on new information or changes in the environment.

(17) A methodology for identifying and presenting enterprisewide safety risk and wildfire-related risk that is consistent with the methodology used by other electrical corporations unless the commission determines otherwise.

(18) A description of how the plan is consistent with the electrical corporation's disaster and emergency preparedness plan prepared pursuant to Section 768.6, including both of the following:

(A) Plans to prepare for, and to restore service after, a wildfire, including workforce mobilization and prepositioning equipment and employees.

- (B) Plans for community outreach and public awareness before, during, and after a wildfire, including language notification in English, Spanish, and the top three primary languages used in the state other than English or Spanish, as determined by the commission based on the United States Census data.
- (19) A statement of how the electrical corporation will restore service after a wildfire.
- (20) Protocols for compliance with requirements adopted by the commission regarding activities to support customers during and after a wildfire, outage reporting, support for low-income customers, billing adjustments, deposit waivers, extended payment plans, suspension of disconnection and nonpayment fees, repair processing and timing, access to electrical corporation representatives, and emergency communications.
- (21) A description of the processes and procedures the electrical corporation will use to do all of the following:
- (A) Monitor and audit the implementation of the plan.
 - (B) Identify any deficiencies in the plan or the plan's implementation and correct those deficiencies.
 - (C) Monitor and audit the effectiveness of electrical line and equipment inspections, including inspections performed by contractors, carried out under the plan and other applicable statutes and commission rules.
- (22) Any other information that the Wildfire Safety Division may require.
- (d) The Wildfire Safety Division shall post all wildfire mitigation plans and annual updates on the commission's internet website for no less than two months before the division's decision regarding approval of the plan. The division shall accept comments on each plan from the public, other local and state agencies, and interested parties, and verify that the plan complies with all applicable rules, regulations, and standards, as appropriate.

(Amended by Stats. 2019, Ch. 410, Sec. 2.3. (SB 560) Effective January 1, 2020.)

(End of Appendix E)