

Decision 22-04-001 April 5, 2022

BEFORE THE PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Order Instituting Rulemaking to Consider Streamlining Interconnection of Distributed Energy Resources and Improvements to Rule 21.

Rulemaking 17-07-007

ORDER CORRECTING ERRORS IN DECISION 20-09-035

Pursuant to Rule 16.5 of the Commission’s Rules of Practice and Procedure (Rules) this order corrects several obvious errors in Decision (D.) 20-09-035, *Decision Adopting Recommendations from Working Groups Two, Three, and Subgroup.*

The Commission has been informed of two errors in Ordering Paragraph (OP) 6 of D.20-09-035. OP 6 currently reads:

Modification 1 of Proposals 8f, 8g, 8h, and 8j is adopted. Pacific Gas and Electric Company, San Diego Gas & Electric Company, and Southern California Edison Company shall modify interconnection Rule 21 to allow interconnection projects less than 30 kilowatt volt amperes to bypass Screens F, G, H, and J.

In this paragraph, two corrections should be made: the phrase “30 kilowatt volt amperes” should be corrected to “less than or equal to 30 kilovolt amperes” to improve terminology and be consistent with the language on pages 23 and 43-44 of D.20-09-035. These two errors are obvious and should be corrected.

Pursuant to Commission Resolution (Res.) A-4661 and Rule 16.5, the Commission's Executive Director is authorized to sign, on behalf of the Commission, orders involving the correction of clerical and other obvious inadvertent errors and omissions in Commission decisions. Accordingly, the corrections to D.20-09-035 should be adopted pursuant to Commission Res. A-4661 and Rule 16.5 of the Commission's Rules of Practice and Procedure.

The Commission has not resolved the issues being addressed in Phase II of this proceeding. Accordingly, Rulemaking 17-07-007 should remain open.

IT IS ORDERED that:

1. Ordering Paragraph (OP) 6 of Decision 20-09-035 is corrected by revising the phrase "30 kilowatt volt amperes" to "less than or equal to 30 kilovolt amperes". OP 6 now reads as follows:

Modification 1 of Proposals 8f, 8g, 8h, and 8j is adopted. Pacific Gas and Electric Company, San Diego Gas & Electric Company, and Southern California Edison Company shall modify interconnection Rule 21 to allow interconnection projects less than or equal to 30 kilovolt amperes to bypass Screens F, G, H, and J.

2. Rulemaking 17-07-007 remains open.

This order is effective today.

Dated April 5, 2022, at San Francisco, California.

/s/ RACHEL PETERSON

Rachel Peterson
Executive Director