

Application: 21-06-021
(U 39 M)
Exhibit No.: (PG&E-2)
Date: June 30, 2021
Witness(es): Various

PACIFIC GAS AND ELECTRIC COMPANY

2023 GENERAL RATE CASE

EXHIBIT (PG&E-2)

**RISK MANAGEMENT, SAFETY, OPERATING RHYTHM, AND CLIMATE
RESILIENCE**

WORKPAPERS SUPPORTING

PREPARED TESTIMONY CHAPTER 1

VOLUME 2 OF 2



PACIFIC GAS AND ELECTRIC COMPANY
2023 GENERAL RATE CASE
EXHIBIT (PG&E-2) RISK MANAGEMENT, SAFETY, OPERATING
RHYTHM, AND CLIMATE RESILIENCE

WORKPAPERS SUPPORTING
CHAPTER 1, ENTERPRISE RISK MANAGEMENT PROGRAM

TABLE OF CONTENTS

Subject	Page No.
Risk-Based Portfolio Prioritization Framework, Utility Risk Standard: RISK-5400S, Publication Date 1/15/2021	WP1-1
PG&E's Responses to Safety Policy Division and Interested Party Feedback to PG&E's 2020 Risk Assessment Mitigation Phase (RAMP) Report	WP 1-12
PG&E Mitigation and Control Risk Spend Efficiencies (RSE) – (1) Sorted by Mitigation/Control Number; and, (2) Sorted by RSE Value	WP 1-69
PG&E presentation deck to the CPUC, 12/08/20 Wildfire Risk Model Overview Final v.1	WP 1-78
PG&E's 2023 GRC forecasts compared to 2020 RAMP Cost Estimates for Risk Mitigations and Pilot Controls	WP 1-117
PG&E's 2020 RAMP Report, Application (A.) 20-06-012 (June 30, 2020)	WP 1-136

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 11
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: FAILURE OF ELECTRIC
DISTRIBUTION OVERHEAD ASSETS

PACIFIC GAS AND ELECTRIC COMPANY
 CHAPTER 11
 RISK ASSESSMENT AND MITIGATION PHASE
 RISK MITIGATION PLAN: FAILURE OF ELECTRIC DISTRIBUTION OVERHEAD
 ASSETS

TABLE OF CONTENTS

A. Executive Summary.....	11-1
1. Risk Overview	11-3
2. Risk Definition	11-3
B. Risk Assessment.....	11-3
1. Background and Evolution	11-3
2. Risk Bowtie	11-6
a. Difference from 2017 Risk Bowtie	11-7
3. Exposure to Risk	11-7
4. Tranches	11-7
5. Cross-Cutting Factors	11-9
6. Drivers and Associated Frequency	11-9
7. Consequences	11-11
C. Controls and Mitigations	11-14
1. 2019 Controls and Mitigations.....	11-18
a. Controls	11-18
b. Mitigations	11-22
c. 2017 RAMP Update.....	11-26
D. 2020-2022 Control and Mitigation Plan	11-27
1. Changes to Controls	11-27
2. Changes to Mitigations.....	11-28
E. 2023-2026 Proposed Control and Mitigation Plan	11-32
1. Changes to Controls and RSE for Piloted Control	11-32
2. Changes to Mitigations.....	11-35

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 11
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: FAILURE OF ELECTRIC DISTRIBUTION OVERHEAD
ASSETS

TABLE OF CONTENTS
(CONTINUED)

3. Mitigation Risk Spend Efficiencies	11-36
F. Alternative Analysis	11-40
1. Alternative Plan 1: M11a – Remote Grid	11-40
2. Alternative Plan 2: A2 (M12) – Targeted Transformer Replacement to Mitigate Overloading	11-41
3. Alternative Plan 3: A3 – Wildfire – Targeted System Upgrades	11-42
4. Alternative Plan 4: A4 – System Hardening-Hybrid.....	11-43

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 11
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: FAILURE OF ELECTRIC DISTRIBUTION
OVERHEAD ASSETS

A. Executive Summary

The Failure of Electric Distribution Overhead Assets (Failure of DOH Assets) risk is defined as failure of electric distribution overhead assets or lack of remote operational functionality that may result in public or employee safety issues, property damage, environmental damage, or inability to deliver energy. The drivers for this risk event are: Distribution Line Equipment Failure; Other; Vegetation; Animal; Natural Hazard; Other Pacific Gas and Electric Company (PG&E) Assets or Processes; and Human Performance. The cross-cutting factors Seismic, Information Technology Asset Failure, Skilled and Qualified Workforce, Climate Change, Records and Information Management, and Emergency Preparedness and Response also impact this risk.

Exposure to this risk is based on the 80,716 circuit miles of primary overhead distribution lines in PG&E's electric system. The risk model estimates approximately 24,834 risk events (outages) each year.¹ The Distribution Line Equipment Failure and Vegetation drivers together account for 56 percent of the risk events. The Other driver accounts for 30 percent of the risk events. The mitigations PG&E will implement from 2020-2026 are designed to address these key risk drivers.

The risk of ignitions associated with asset failures is modeled as part of the Wildfire risk rather than the Failure of DOH Assets risk. See Chapter 10. In terms of other types of consequence, asset failures not coincident with Seismic events or IT Asset Failure account for 98 percent of the risk events and 87 percent of the risk score. Asset failures associated with seismic events account for less than 1 percent of the risk events but 12 percent of the risk score.

¹ 24,834 is PG&E's forecast for annual number of outages for 2023-26 in the absence of proposed mitigations from 2023-26.

1 PG&E identified five tranches for this risk event: two tranches for groups of
2 circuits with issues historically identified as carrying an increased risk for asset
3 failure and three tranches based on circuits' reliability performance. The highest
4 tranche-level risk is associated with circuits with poor reliability performance
5 (56 percent of the risk) and circuits with a significant amount of small copper
6 conductor (21 percent of the risk).

7 Failure of DOH Assets has the ninth highest 2023 test year baseline safety
8 score (18) and the third highest 2023 test year baseline total risk score (526) of
9 PG&E's 12 Risk Assessment and Mitigation Phase (RAMP) risks. The 2020
10 baseline risk score, 546, improves by 9 percent when the planned and proposed
11 mitigations are applied: the 2023 test year baseline risk score is 526 and the
12 2026 post-mitigation risk score is 500.

13 PG&E is proposing a suite of controls and mitigations to address the key risk
14 drivers. The Grasshopper/KPF Switch Replacement program has the highest
15 2023-2026 Risk Spend Efficiency (RSE) and the 3A and 4C Line Recloser
16 Controller Replacement program has the highest total 2023-2026 risk reduction
17 score of the mitigations primarily focused on Failure of DOH Assets risk.²

² The information herein is subject to those limitations described in Chapter 2, Section D.

**TABLE 11-1
RISK OVERVIEW**

Line No.	Risk Name	Failure of DOH Assets
1	In Scope	Failure of assets associated with PG&E's overhead electrical distribution system that include: poles and support structures; primary and secondary conductor; voltage regulating equipment; protection equipment; switching equipment; transformers; and PG&E-owned streetlights. Outage incidents caused by PG&E ignitions are considered reliability consequences; such incidents are captured in the Wildfire risk.
2	Out of Scope	Consequences of any ignitions associated with the failure of the electrical distribution system assets described above (which are included in the scope of the Wildfire risk) and failure of assets due to the activities of PG&E employees, PG&E contractors, and third parties (which are included in the scope of the Employee Safety Incident, Contractor Safety Incident, Third-Party Incident and Motor Vehicle Incident risks) are not considered.
3	Data Quantification Sources ^(a)	Data associated with the drivers/source of failures and data associated with reliability impact of failures are taken from PG&E's DOH Outage Dataset from January 1, 2015 to December 31, 2019. Data associated with the safety consequences of failures is taken from PG&E's Electric Incident Reports from January 1, 2015 to December 31, 2019. Data associated with the financial impact of failures is taken from PG&E's DOH Restoration Costs Dataset from January 1, 2017 to September 30, 2019.
(a) Source documents will be provided with the workpapers on July 17, 2020.		

1. Risk Overview

PG&E's Electric Operations line of business manages more than 80,000 circuit miles of primary overhead distribution lines and associated equipment. Failure of these assets can result in outages and can also have significant public safety impacts.

2. Risk Definition

Failure of distribution overhead assets or lack of remote operational functionality may result in public or employee safety issues, property damage, environmental damage, or inability to deliver energy.

B. Risk Assessment

1. Background and Evolution

Historically, PG&E analyzed the risk of electric overhead distribution system asset failures on an asset type basis, with a separate risk profile for each asset type such as primary conductors, poles, transformers, etc. When the 2017 RAMP was filed, the Electric Operations Risk Register had

eight different risks related to overhead distribution assets.³ Only one of these risks, DOH Conductor – Primary, was included in the 2017 RAMP.⁴

In 2018, Electric Operations combined the risks associated with individual overhead distribution system asset types into a consolidated Failure of DOH Assets risk that includes all asset types. This is part of PG&E's migration towards an event-based risk register. The consolidation supports a holistic analysis of the risk of overhead electric distribution asset failure as it addresses all the drivers that may cause a failure "event."

The Failure of DOH Assets risk in the 2020 RAMP includes the equipment failure-related components of the DOH Conductor – Primary risk from the 2017 RAMP, as well as additional scope related to failures of all the other electric distribution overhead asset types (i.e., poles, voltage regulating equipment, protective equipment, switching equipment, transformers, secondary conductor, and streetlights).

In the 2017 RAMP discussion of the DOH Conductor – Primary risk, PG&E noted that its risk model had "highlighted the need to differentiate between the two events currently included in the Third-Party Safety Incident, and Motor Vehicle Safety Incident risks, i.e., contact with intact conductor and wire down events" because the two events had significantly different causes and consequences. PG&E stated that it would evaluate whether to separate the third-party contact with intact driver from the DOH Conductor – Primary risk.⁵ PG&E performed the evaluations and concluded that safety incidents involving conductors caused by PG&E employees, PG&E contractors, and third-parties should be analyzed and managed separately from safety incidents due to equipment failures related to conductor, because the consequences and mitigations are quite different. These

³ These eight risks were: (1) Distribution Overhead Conductor – Primary; (2) Distribution Poles; (3) Distribution Overhead Line Equipment – Voltage Regulators, Booster, and Capacitors; (4) Distribution Overhead Line Equipment – Protective; (5) Distribution Overhead Conductor – Secondary; (6) Distribution Overhead Transformers; (7) Distribution Overhead Streetlight Structures; and, (8) Distribution Overhead – General.

⁴ 2017 RAMP Report of PG&E, Investigation (I.) 17-11-003 (Nov. 30, 2017) (2017 RAMP Report), Chapter 9.


⁵ 2017 RAMP Report, p. 9-28.

1 employee, contractor, and third-party incidents are now being managed by
2 PG&E's Safety, Health, Enterprise Corrective Action Plan (ECAP),
3 Department of Transportation (DOT) (collectively, SHED) organization in the
4 Third-Party Safety Incident, Employee Safety Incident, Contractor Safety
5 Incident, and Motor Vehicle Safety Incident risks.⁶

6 The drivers, controls, and mitigations for the DOH Conductor – Primary
7 2017 RAMP risk are broadly applicable to the other asset types as
8 described in connection with the new Failure of DOH Assets 2020 RAMP
9 risk. There have been some adjustments in drivers and consequences and
10 certain additional controls and mitigations have been considered because of
11 the additional equipment types covered by the new risk.

⁶ The Third-Party Safety Incident, Employee Safety Incident, Contractor Safety Incident, and Motor Vehicle Safety Incident risks are discussed in Chapters 14 through 18 of this report.

2. Risk Bowtie

FIGURE 11-1
RISK BOWTIE

1 **a. Difference from 2017 Risk Bowtie**

2 Failure of DOH Assets was not included as a risk in the 2017
3 RAMP.

4 **3. Exposure to Risk**

5 PG&E's electric overhead distribution system consists of more than
6 80,000 circuit miles of primary conductor and associated assets. PG&E
7 models its exposure to the Failure of DOH Assets risk based on the number
8 of circuit miles of primary distribution conductor on its system. PG&E uses
9 outages as a proxy for electric distribution overhead asset failures.

10 **4. Tranches**

11 When PG&E presented its preliminary tranching of the Failure of DOH
12 Assets risk to the California Public Utilities Commission (CPUC or
13 Commission) and intervenors at the February 4, 2020 workshop, PG&E
14 used two tranches: circuits with (1) a less than 50 percent or (2) a greater
15 than 50 percent chance of conductor failure based on historical asset health
16 and other factors. PG&E received feedback that it should consider tranches
17 based on location/environmental characteristics and that it should also
18 attempt to capture failures of other asset types besides conductor as part of
19 its tranching. Based on this feedback, PG&E is now dividing the Failure of
20 DOH Assets risk into five tranches. Two of these five tranches are used to
21 separate out two groups of circuits that PG&E has historically identified as
22 carrying an increased risk for asset failure:

23 Elevated Wire-downs (Small Copper Conductors): Small copper conductor
24 (4-CU and 6-CU) contributes to many wire-down incidents and is a focus for
25 PG&E's risk reduction efforts. Some small copper conductor is present on
26 more than 80 percent of PG&E's distribution circuits. To create a
27 reasonable tranche that would differentiate between circuits with a small
28 amount of copper conductor and a more significant amount, PG&E set the
29 threshold for this tranche as any circuit with 7.5 percent or more of its length
30 wired with either 4-CU or 6-CU conductor, or a combination of the two. This
31 tranche includes 22,298 circuit miles or approximately 28 percent of PG&E's
32 overhead distribution system.

Circuits with Aluminum Conductor Steel-Reinforced (ACSR) in Corrosion

Zones: These are circuits with ACSR in designated corrosion zones in the Central Coast and Los Padres Divisions. PG&E had previously identified these circuits as having a significantly higher historical failure rate for conductor and connectors than the system average. This tranche includes 4,796 circuit miles or 6 percent of PG&E's overhead distribution system.

After separating out the two tranches described above, PG&E further divided the remaining circuits into three additional tranches based on reliability performance:

Poor Reliability Performance: Circuits within the 66th to 100th percentile of the reliability scores provided in Electric Operations Work Plan 2020. This tranche includes 33,349 circuit miles or approximately 41 percent of PG&E's overhead distribution system.

Moderate Reliability Performance: Circuits within the 33rd to 66th percentile of reliability scores provided in Electric Operations Work Plan 2020. This tranche includes 15,798 circuit miles or approximately 20 percent of PG&E's overhead distribution system.

High Reliability Performance: Circuits within the 0-33rd percentile of reliability scores provided in Electric Operations Work Plan 2020. This tranche includes 4,475 circuit miles or approximately 6 percent of PG&E's overhead distribution system.

Table 11-2 below provides the tranche-level results of the risk analysis.

**TABLE 11-2
TRANCHE LEVEL RISK ANALYSIS RESULTS**

Line No.	Tranche	Percent Exposure	Safety Risk Score	Reliability Risk Score	Financial Risk Score	Total Risk Score	Percent Risk
1	Elevated Wire-Downs (Small Copper Conductor)	28%	4.4	92.8	15.7	112.9	21%
2	Circuits w/ Aluminum Conductor Steel-Reinforced in Corrosion Zones	6%	1.6	48.1	6.0	55.8	11%
3	Poor Reliability Performance	41%	7.9	259.3	29.1	296.3	56%
4	Moderate Reliability Performance	20%	3.0	40.9	10.9	54.8	10%
5	High Reliability Performance	6%	0.6	3.4	2.1	6.1	1%
6	Total	100%	17.6	444.6	63.8	526.0	100%

5. Cross-Cutting Factors

A cross-cutting factor is a driver or control that is related to multiple risks. PG&E is presenting eight cross-cutting factors in the 2020 RAMP. The cross-cutting factors that impact the Failure of DOH Assets risk are shown in Table 11-3 below. The cross-cutting factors and the mitigations and controls that PG&E is proposing to mitigate the cross-cutting factors are described in Chapter 20.

**TABLE 11-3
CROSS-CUTTING FACTOR SUMMARY**

Line No.	Cross-Cutting Factor	Impacts Likelihood	Impacts Consequence
1	Climate Change	X	
2	Emergency Preparedness and Response		X
3	Information Technology Asset Failure		X
4	Physical Attack	X	
5	Records and Information Management	X	X
6	Seismic	X	X
7	Skilled and Qualified Workforce	X	

When analyzing the Failure of DOH Assets risk PG&E considered the cross-cutting factor Climate Change. Climate change presents ongoing and future risks to PG&E's assets, operations, employees, customers, and the communities it serves. Electric distribution overhead assets can be sensitive to natural hazards, including extreme heat events, major rain events, major snow/ice events, extreme wind, lightning, flooding due to extreme precipitation, subsidence, and others. To reflect the impact of changing climate conditions on this risk, PG&E used climate projections to modify the expected frequency of these natural hazard sub-drivers and thereby the frequency of risk occurrence.

PG&E is continuing to evaluate the impact that Cyber Attack has on RAMP risks and expects to present Cyber Attack as a cross-cutting factor relative to additional RAMP risks in the 2023 GRC.

6. Drivers and Associated Frequency

PG&E identified nine drivers and 61 sub-drivers for the Failure of DOH Assets risk. Each driver and its associated 2023 test-year estimated

frequency is discussed below. A complete list of sub-drivers is provided in supporting workpapers.⁷

D1 – Distribution Line (D-Line) Equipment Failure: Failure events due to transformer, conductor, connector, cross-arm, and other electric distribution overhead asset failures. The D-Line Equipment Failure driver accounts for 8,663 (35 percent) of the 24,834 annual expected number of outages.

D2 – Other: Failure events without known causes (e.g., patrol found nothing). The Other driver accounts for 7,348 (30 percent) of the 24,834 annual expected number of outages.

D3 – Vegetation: Failure events caused by trees, tree limbs, or other vegetation. Sub-drivers for the Vegetation driver capture whether the incident was due to a tree falling into lines (including whether the tree has visible defects), a branch (including whether the branch was overhanging or not and, if not, what distance it was from the lines), or a grow-in. The Vegetation driver accounts for 5,279 (21 percent) of the 24,834 annual expected number of outages.

D4 – Animal: Failure events caused by animals such as birds or squirrels. The Animal driver accounts for 1,999 (8 percent) of the 24,834 annual expected number of outages.

D5 – Natural Hazard: Failure events caused by natural hazards such as lightning, flood, ice or snow, and heat wave. The Natural Hazard driver accounts for 1,188 (5 percent) of the 24,834 annual expected number of outages.

D6 – Other PG&E Assets or Processes: Failure events caused by PG&E processes (e.g., return circuit normal) or non-overhead assets such as generators, metering equipment, etc. The Other PG&E Assets or Processes driver accounts for 149 (1 percent) of the 24,834 annual expected number of outages.

D7 – Human Performance: Failure events caused by PG&E employees based on improper construction, operating error or other actions. The

⁷ A list of sub-drivers will be included in the modeling workpapers that will be provided on July 17, 2020.

Human Performance driver accounts for 119 (less than 1 percent) of the 24,834 annual expected number of outages.

D8 – Seismic Scenario (Cross-Cutting): Failure events caused by seismic activity. This risk is described further in Chapter 20 of this filing. The Seismic Scenario driver accounts for 41 (less than 1 percent) of the 24,834 annual expected number of outages.

D9 – Skilled and Qualified Workforce (Cross-Cutting): Failure events caused by lack of a sufficiently trained workforce. This risk is described further in Chapter 20 of this filing. The Skilled and Qualified Workforce driver accounts for 15 (less than 1 percent) of the 24,834 annual expected number of outages.

7. Consequences

The Failure of DOH Assets bowtie includes four outcomes for an asset failure:

Asset Failures Associated with an Ignition: If an ignition was found to be associated with an outage on the electric distribution overhead system, that outage is tagged as an “asset failure associated with an ignition.” Asset failures associated with an ignition account for approximately 2 percent of the frequency associated with the Failure of DOH Assets risk. The consequences of failures associated with ignitions are considered in PG&E’s Wildfire risk model, but PG&E is including them in the bowtie here so that it is clear what portion of Failure of DOH Assets incidents contribute to the Wildfire model. For the purposes of the Failure of DOH Assets model, PG&E is setting the risk score of these incidents to zero.

Asset Failures Associated with a Seismic Scenario: Electric distribution overhead asset failures caused by seismic activity account for less than 1 percent of the frequency associated with this risk but 12 percent of the risk score.

Asset Failures Associated with an Information Technology (IT) Asset Failure: These failures are estimated to account for less than 1 percent of both the frequency and the risk score for this risk.

Failure Not Associated with an Ignition, and not Coincident with IT Asset Failure: Outages on the electric distribution overhead system not

1 associated with an ignition, seismic scenario, or IT asset failure account for
2 98 percent of the frequency and 87 percent of the risk score for this risk.

3 Table 11-4 shows the consequences of this risk event. Model attributes
4 are discussed in Chapter 3, Risk Modeling and Risk Spend Efficiency.

TABLE 11-4
RISK EVENT CONSEQUENCES

	CoRE			Natural Units Per Event			CoRE			Natural Units per Year			Attribute Risk Score		
	%Freq	%Risk	Freq	Safety EF/event	Electric Reliability MCMI/event	Financial \$M/event	Safety	Electric Reliability	Financial	Safety EF/yr	Electric Reliability MCMI/yr	Financial \$M/yr	Safety	Electric Reliability	Financial
Asset Failure / Not associated with Ignition / Not coincided with IT Asset Failure	0.02	98%	87%	24338	0.031	0.005	0.0007	0.016	0.003	0.350	756	127.1	17.5	378.1	63.6
Asset Failure / Associated with Ignition	-	1.8%	-	442	-	-	-	-	-	-	-	-	-	-	-
Asset Failure / Seismic scenario	1.6	0.2%	12%	41	2.680	0.009	0.0007	1.592	0.004	0.001	110	0.4	0.0	65.1	0.2
Asset Failure / Not associated with Ignition / Coincided with IT Asset Failure	0.1	0.1%	0%	13	0.00001	0.222	0.0007	0.113	0.003	0.000	3	0.1	0	1	0
Aggregated	0.02	100%	100%	24834	0.035	0.005	0.0007	0.018	0.003	0.351	869	127.5	18	445	64

1 **C. Controls and Mitigations**

2 PG&E did not include Failure of DOH Assets as a 2017 RAMP risk, but it did
3 include the Distribution Overhead Conductor – Primary (DOCP) risk, most of
4 which is now integrated into the Failure of DOH Assets risk. Tables 11-5 and
5 11-6 list all the controls and mitigations for the DOCP risk that PG&E included in
6 its 2017 RAMP and 2020 GRC, and maps them to the Failure of DOH Assets
7 controls and mitigations discussed the 2020 RAMP (for 2020-2022 and 2023-
8 2026). The tables provide a view as to those controls and mitigations that are
9 ongoing, those that are no longer in place, and new mitigations. In the following
10 sections PG&E describes the controls and mitigations for Failure of DOH Assets
11 in place in 2019, changes to the 2019 mitigations and controls presented in the
12 2017 RAMP, and then discusses new mitigations and/or significant changes to
13 mitigations and/or controls during the 2020-2022 and 2023-2026 periods.

**TABLE 11-5
CONTROLS SUMMARY**

Line No.	Control Name and Number	2017 RAMP (2016 Controls)	2020 GRC (2017-2019)	2020 GRC (2020-2022)	2020 RAMP (2020-2022)	2020 RAMP (2020-2023)
1	C1 (2017) – Public Awareness Programs	X	X	X	Becomes part of C2/C3 for Third Party Safety Incident risk	
2	C2 (2017) – Vegetation Management	X	X	X	Becomes C1	
3	C3 (2017) – Catastrophic Event Memorandum Account – Vegetation Management	X	X	X	Becomes C2	
4	C4 (2017) – Overhead Electric Distribution Preventive Maintenance	X	X	X	Becomes C3	
5	C5 (2017) – Overhead Conductor Replacement	X	X	X	Becomes C4	
6	C6 (2017) – Overhead Patrols and Inspections	X	X	X	Becomes C5	
7	C7 (2017) – Overhead Infrared Inspections	X	X	X	Becomes C6	
8	C8 (2017) – Targeted Circuits Program	X	X	X	Becomes C12	
9	C9 (2017) – Supervisory Control and Data Acquisition	X	X	X	Becomes C7	
10	C10 (2017) – Annual Protection Reviews	X	X	X	Becomes C8	
11	C11 (2017) – Electric Distribution Line and Equipment Capacity	X	X	X	Becomes C9	
13	C1 – Vegetation Management (was C2 (2017))				X	X
14	C2 – Vegetation Management - Catastrophic Event Memorandum Account – (was C3 (2017))				X	X
15	C3 – Equipment Preventive Maintenance and Replacement – Distribution Overhead (was C4 (2017))				X	X

**TABLE 11-5
CONTROLS SUMMARY
(CONTINUED)**

Line No.	Control Name and Number	2017 RAMP (2016 Controls)	2020 GRC (2017-2019)	2020 GRC (2020-2022)	2020 RAMP (2020-2022)	2020 RAMP (2020-2023)
16	C4 – Overhead Conductor Replacement (was C5 (2017))				X	X
17	C5 – Patrols and Inspections – Distribution Overhead (was C6 (2017))				X	X
18	C6 – Overhead Infrared Inspections (was C7 (2017))				X	X
19	C7 – Supervisory Control and Data Acquisition (was C9 (2017))				X	X
20	C8 – Annual Protection Reviews (was C10 (2017))				X	X
21	C9 – Electric Distribution Line and Equipment Capacity (was part of C8 (2017))				X	X
22	C10 – Design Standards				X	X
23	C11 – Pole Programs				X	X
24	C12 – Targeted Reliability Program (was C8 (2017))				X	X
25	C13-Enhanced Inspections-Distribution				X	X

**TABLE 11-6
MITIGATIONS SUMMARY**

Line No.	Mitigation Name and Number	2017 RAMP (2017-2019)	2020 GRC (2017-2019)	2020 GRC (2020-2022)	2020 RAMP (2020-2022)	2020 RAMP (2023-2026)
1	M3 (2017) – Additional Public Awareness	X	X	X	Becomes part of C2/C3 for Third Party Safety Incident risk	
2	M8 (2017) – Overhang Clearing	X	Becomes part of M8 (2020 GRC)			
3	M8 (2020 GRC) – Enhanced Vegetation Management		X	X	Becomes M1	
4	M1 – Enhanced Vegetation Management				X	X
5	M2 – System Hardening				X	X
6	M3 – Non-Exempt Surge Arrester Replacement				X	X
7	M4 – Expulsion Fuse Replacement				X	X
8	M5 – Additional Asset Data Capture – Outage Information Reporting, Outage Cause, and Failure Analysis				X	X
9	M6 – Grasshopper/KPF Switch Replacement				X	X
10	M7 – Regulated Output (RO) Streetlight Replacement				X	X
11	M8 – Ceramic Post Insulator Replacement				X	X
12	M9 – Improved Distribution Risk Model				X	X
13	M10 – 3A and 4C Line Recloser Controller Replacement				X	X
14	M11 – Remote Grid				X	

1. 2019 Controls and Mitigations

a. Controls

C1 – Vegetation Management – Distribution Overhead: PG&E’s Vegetation Management program was developed in coordination with General Order (GO) 95, Rule 35 and California Public Resources Code sections 4292 and 4293. The program includes “routine” compliance-based vegetation management, including periodic inspections, clearing of vegetation around lines and around poles with equipment that poses a fire risk, and quality assurance. In 2018 and 2019, PG&E increased vegetation-to-conductor clearances from 18 inches to 48 inches in High Fire Threat District (HFTD) areas as required by the CPUC in Decision 17-12-024. This control has the potential to reduce the Vegetation driver.

C2 – Vegetation Management – Catastrophic Emergency Memorandum Account (CEMA): Since 2014, PG&E has undertaken several initiatives intended to address the risks associated with tree mortality stemming from prolonged drought conditions and bark beetle infestation, which caused California’s Governor to declare an ongoing state of emergency in 2015.⁸ These initiatives, which are funded through the Catastrophic Emergency Memorandum Account, include additional inspections and tree work in areas of PG&E’s service territory that are at higher risk for tree mortality or wildfire, including HFTD areas, State Responsibility Areas, and Wildland-Urban Interface. This control has the potential to reduce the Vegetation driver.

C3 – Equipment Preventive Maintenance and Replacement – Distribution Overhead: Proactive identification and repair or replacement of critical overhead distribution equipment, such as cross-arms, transformers, capacitors, reclosers and switches. Equipment is identified through the Patrol and Inspections – Distribution Overhead (C5) control or through ad hoc inspection. This control involves both expense and capital work.

⁸ Governor’s Proclamation of a State of Emergency, October 30, 2015.

1 In 2019, PG&E's accelerated and enhanced Wildfire Safety
2 Inspection Program (WSIP) inspection process in Tier 2 and Tier 3
3 HFTD areas (described below in connection with the Patrol and
4 Inspections – Distribution Overhead (C5) control) identified a substantial
5 amount of repair and replacement work (maintenance tags) to be
6 completed. PG&E has completed the high priority corrective actions
7 identified as necessary during the WSIP inspections and will complete
8 the lower priority work over the next three years, with prioritization based
9 on a risk-based approach. This control has the potential to reduce the
10 D-Line Equipment Failure driver.

11 **C4 – Overhead Conductor Replacement:** The overhead conductor
12 replacement program replaces spans of conductor that have failed or
13 are likely to fail, based on historical events and conductor attributes that
14 include number of splices, fault duty, and exposure to harsh
15 environments, such as coastal salt and fog. The program also includes
16 post-wire down event investigations and splice data reviews. Note that
17 this program involves the replacement of bare conductor with upgraded
18 bare conductor in non-HFTD areas. In HFTD areas, when PG&E
19 replaces existing bare conductor, it installs covered conductor as part of
20 the M2 System Hardening mitigation described below. The Overhead
21 Conductor Replacement control has the potential to reduce the D-Line
22 Equipment Failure driver, specifically the Conductor sub-driver.

23 **C5 – Patrols and Inspections – Distribution Overhead:** PG&E
24 regularly patrols and inspects its electric distribution overhead facilities
25 to identify damaged assets, compelling abnormal conditions, regulatory
26 conditions, and third-party caused infractions that negatively impact
27 safety or reliability, including conditions that may pose a risk of
28 equipment failure. The pre-2019 baseline inspection program was
29 designed in accordance with regulatory requirements (GO 165).

30 In 2019, PG&E performed supplemental inspections, using
31 enhanced inspection criteria and expanded documentation
32 requirements, of all its electric distribution overhead facilities located in
33 HFTD Tier 2 and Tier 3 areas as part of its WSIP. This supplemental
34 assessment included the use of mobile applications instead of paper

1 maps and the collection of additional asset condition data and
2 photographs. Going forward, PG&E will integrate WSIP criteria, tools,
3 and process controls into its routine overhead inspection process for
4 PG&E's entire distribution system. In addition, PG&E will adjust the
5 cadence of inspections in alignment with wildfire risk and other risks. As
6 discussed further in Section E.1, below, PG&E is piloting an RSE
7 calculation for the portion of this control that relates to overhead
8 inspections, which is designated as C13 – Enhanced Inspections. This
9 control has the potential to reduce the D-Line Equipment Failure driver.

10 **C6 – Overhead Infrared Inspections:** The infrared inspection program
11 targets the physical inspection of overhead conductors using
12 thermographic technology to identify damaged or deteriorated
13 conductors and connectors. Through 2019, infrared inspections
14 included a multi-year, system-wide survey to identify and record the
15 number and location of splices on electric distribution overhead primary
16 conductors for future use in the evaluation of system risk and
17 prioritization of conductor replacement projects. Going forward, infrared
18 inspections will be conducted on circuits on a risk-prioritized basis, with
19 a focus on Tier 2 and Tier 3 HFTD areas. This control has the potential
20 to reduce the D-Line Equipment Failure driver.

21 **C7 – Supervisory Control and Data Acquisition:** This program
22 includes the installation, upgrade and replacement of remotely
23 controlled automation and protection equipment in distribution
24 substations and on feeder circuits. This work improves operating
25 efficiency, enables better outage response and diagnosis, improves
26 system protection, and improves employee and public safety by
27 enabling PG&E to automatically and remotely de-energize lines in
28 response to emergencies such as wires down. This control has the
29 potential to reduce the Other driver.

30 **C8 – Annual Protection Reviews:** This engineering program primarily
31 covers electric distribution engineering and planning work which
32 supports a variety of asset management activities and is necessary to
33 safely and reliably plan, design, and operate PG&E's electric distribution
34 system. General engineering work includes reviews of distribution

1 system protection equipment and settings to ensure the devices will
 2 operate correctly and in a coordinated fashion. This control has the
 3 potential to reduce the D-Line Equipment Failure driver.

4 **C9 – Electric Distribution Line and Equipment Capacity:** Although
 5 the primary purpose of PG&E’s capacity program is to mitigate existing
 6 or projected overloads and voltage levels, these anomalies can also
 7 lead to equipment failure. When overloaded line equipment and
 8 conductors fail, service reliability is reduced and public safety concerns
 9 (such as wires down) can be created. These effects are mitigated by
 10 addressing potential overload conditions before they occur by installing
 11 and/or replacing equipment to increase capacity. These projects also
 12 sometimes include conductor replacement. This control has the
 13 potential to reduce the D-Line Equipment Failure and Other drivers.

14 **C10 – Design Standards:** General standards for proper installation,
 15 maintenance and operation of equipment to ensure safe and reliable
 16 operation. PG&E is continually evolving its design standards to improve
 17 efficiency and reduce risk.⁹ For example, Utility Bulletin TD-9001B-009
 18 sets forth standards to be used in new construction and system
 19 upgrades in HFTD areas. This control has the potential to reduce all
 20 drivers.

21 **C11 – Pole Programs:** This control includes multiple activities related
 22 to distribution poles, including intrusive testing, remediation, and loading
 23 assessment. Distribution wood poles are remediated (through
 24 replacement or reinforcement) when necessary, based on observed
 25 degradation. In addition, in 2019 PG&E initiated a new pole loading
 26 assessment proof of concept to enhance the analysis of its existing
 27 distribution wood poles. At the same time, PG&E has strengthened the
 28 safety factor requirements included in its pole loading model
 29 parameters. For example, sizing for new and replacement distribution
 30 poles now considers peak historical wind speeds in areas where they

9 PG&E Utility Bulletin TD-9001B-009, Rev. 2, Fire Rebuild Design Guidance for System Hardening (Nov. 15, 2019). The Bulletin was first published in October 2018 and continues to evolve.

1 exceed GO 95 wind speeds. This control has the potential to reduce the
2 D-Line Equipment Failure driver.

3 **C12 – Targeted Reliability Program:** This control includes targeted
4 work to improve reliability. Typically, the work involves a combination of
5 new fuse and line recloser installations, conductor replacements,
6 installation of fault indicators, reframing of poles to increase phase
7 separation, installation of bird/animal guards, and other maintenance,
8 inspection, and vegetation management work. At the time of the 2017
9 RAMP, this work was performed as part of PG&E’s Targeted Circuits
10 program. PG&E’s current program focuses more narrowly on localized
11 reliability issues rather than considering entire circuits. This control has
12 the potential to reduce the D-Line Equipment Failure driver.

13 **b. Mitigations**

14 **M1 – Enhanced Vegetation Management (EVM):** Since 2018, PG&E
15 has significantly expanded its traditional vegetation management
16 activities around distribution lines in HFTD areas to reduce the likelihood
17 of vegetation contacting lines. Though intended primarily as a mitigation
18 for the Wildfire risk, EVM also has the potential to reduce the Vegetation
19 driver of the Failure of Electric Distribution Overhead Assets risk.¹⁰

20 **M2 – System Hardening:** The System Hardening program is an
21 ongoing, long-term capital investment program to rebuild portions of
22 PG&E’s overhead electric distribution system. Over the course of this
23 program, PG&E plans to upgrade approximately 7,100 miles of
24 overhead distribution circuit in HFTD areas. Though intended primarily
25 as a mitigation for the Wildfire risk, System Hardening also reduces the
26 D-Line Equipment Failure, Animal, Natural Hazard, Other, Other PG&E

¹⁰ The EVM mitigation is discussed in greater detail in connection with the Wildfire risk in Chapter 10. EVM is a mitigation that impacts two RAMP risks—Wildfire and Failure of Electric Distribution Overhead Assets—because it will reduce both ignitions and equipment failure. The primary benefit of the mitigation is to reduce Wildfire risk. PG&E calculated the aggregated risk reduction for both risks and divided that score by the total cost of the mitigation to calculate the overall RSE for the mitigation.

Assets or Processes and Vegetation driver of the Failure of Electric Overhead Assets risk.¹¹

M3 – Non-Exempt Surge Arrester Replacement: This program, which is being implemented throughout PG&E’s system, will replace non-exempt surge arresters with new exempt surge arresters, and correct abnormal grounding conditions where necessary. The purpose of this mitigation is primarily to reduce fire risk and bring grounding into compliance, but it will also reduce the likelihood of equipment failures associated with surge arresters by replacing old equipment with new equipment.¹² In 2019, PG&E replaced 4,611 non-exempt surge arresters as part of this program. The program is expected to continue through 2023. This mitigation has the potential to reduce the D-Line Equipment Failure driver.

M4 – Expulsion Fuse Replacement: Beginning in 2019, PG&E is targeting replacement of 625 non-exempt fuses per year for seven years on poles located in HFTD areas. Although the primary purpose of this program is to reduce Wildfire risk, it will also reduce the risk of equipment failure associated with the fuses that are replaced.¹³

¹¹ The System Hardening mitigation is discussed in greater detail in connection with the Wildfire risk in Chapter 10. System Hardening is a mitigation that impacts three RAMP risks—Wildfire, Failure of Distribution Overhead Assets, Third Party Safety Incident—because it will reduce both ignitions and equipment failure, and reduce the potential for third party contact with energized conductors. The primary benefit of the mitigation is to reduce Wildfire risk. PG&E calculated the aggregated risk reduction score for all three risks and divided that score by the total cost of the mitigation to calculate the overall RSE for the mitigation.

¹² Non-Exempt Surge Arrester Replacement is a mitigation for two RAMP risks—Wildfire and Failure of Electric Distribution Overhead Assets—because it will reduce both ignitions and equipment failure. The primary benefit of the mitigation is to reduce Wildfire risk. PG&E calculated the aggregated risk reduction score for both risks and divided that score by the total cost of the mitigation to calculate the overall RSE for the mitigation.

¹³ The Expulsion Fuse mitigation is discussed in greater detail in connection with the Wildfire risk in Chapter 10. The Expulsion Fuse program is a mitigation for two RAMP risks—Wildfire and Failure of Electric Distribution Overhead Assets—because it will reduce both ignitions and equipment failure. The primary benefit of the mitigation is to reduce Wildfire risk. PG&E calculated the aggregated risk reduction score for both risks and divided that score by the total cost of the mitigation to calculate the overall RSE for the mitigation.

1 This mitigation has the potential to reduce the D-Line Equipment
2 Failure driver.

3 **M5 – Additional Asset Data Capture – Outage Information**

4 **Reporting, Outage Cause, and Failure Analysis:** This mitigation
5 consists of various efforts to improve PG&E's ability to capture
6 information about the location and cause of outages, and about the
7 reasons for equipment failures. It may include facilitating asset data
8 capture on mobile devices in the field or automatically, efforts to improve
9 PG&E's outage database, and changes in standards and procedures to
10 expand the amount of asset failure information gathered by field
11 personnel. These improvements will facilitate PG&E's move towards a
12 more data-driven, risk-based asset management strategy. PG&E
13 considers this to be a foundational activity because it supports other
14 controls and mitigations rather than directly reducing risk. As a result,
15 PG&E is not calculating a risk reduction score or an RSE for this
16 mitigation.

17 **M6 – Grasshopper/KPF Switch Replacement:** Grasshopper and KPF
18 switches are obsolete types of overhead distribution line switches which
19 PG&E is eliminating from its system. PG&E's ongoing
20 Grasshopper/KPF Switch Replacement Program proactively replaces
21 obsolete switches installed between 1950 and 1970 to minimize
22 potential safety issues during routine and emergency switching
23 operations and improve reliability. In 2019, PG&E replaced eight
24 switches as part of this program. PG&E estimates that as of the end of
25 2019 there are 151 additional switches that need to be replaced. This
26 mitigation has the potential to reduce the D-Line Equipment Failure
27 driver.

28 **M7 – Regulated Output (RO) Streetlight Replacement:** This is a
29 program to replace a small number of antiquated RO streetlights that
30 PG&E owns and operates in San Francisco. These RO streetlights are
31 prone to failure and difficult to maintain; in some cases, spare parts are
32 no longer manufactured and cannot be obtained. PG&E completed
33 replacement of 22 of 24 RO loops in 2019; there are still 49 additional
34 streetlights that need to be converted to complete work on the remaining

2 RO loops. PG&E is not currently planning to perform any work in this program in 2020-2022 because of the City and County of San Francisco's (CCSF) 5-year paving moratorium, which went into effect in late 2017. Instead, PG&E plans to replace the 49 remaining RO streetlights in 2023 when the 5-year moratorium expires.¹⁴ This mitigation has the potential to reduce the Other PG&E Assets or Processes driver.

M8 – Ceramic Post Insulator Replacement: This program will replace ceramic post insulators manufactured prior to 1972. Manufacturing techniques for ceramic insulators in the 1960s and 1970s were not as advanced as today. PG&E has determined that over time these older insulators may experience failures at lower-than-rated cantilever strength. PG&E linemen have expressed safety concerns regarding these insulators and, depending on failure mode, a failed ceramic post insulator can carry an energized conductor down to the ground creating a potential safety hazard to the public and utility workers. This mitigation program is targeted at replacing the existing population of vintage ceramic insulators with newer post insulators made of composite materials that have a lower risk of breaking. The program will focus on poles that are already being targeted through PG&E's ongoing Non-Exempt Surge Arrester Replacement program. PG&E estimates that it will replace older ceramic post insulators on approximately 4,589 poles in connection with the Non-Exempt Surge Arrester Replacement program. Additional replacements will occur on an ad hoc basis in other ongoing programs when they identify older ceramic post insulators, but these replacements are outside the scope of the mitigation considered here. As of February 2020, PG&E has replaced approximately 820 older ceramic post insulators through the program; the program is scheduled to end in 2023 at the same time the Non-Exempt Surge Arrester Replacement program is completed.

¹⁴ PG&E has approached CCSF about the possibility of making an exception to the paving moratorium for this work. If CCSF agrees, PG&E may complete the remaining replacements prior to 2023.

1 This program has the potential to mitigate the D-Line Equipment
2 Failure driver.

3 **c. 2017 RAMP Update**

4 With a couple of exceptions, PG&E is presenting the same controls
5 for the Failure of DOH Assets risk in the 2020 RAMP as it did for the
6 DOCP risk in the 2017 RAMP though the numbering and in some cases
7 naming of the controls is slightly different. One DOCP control from the
8 2017 RAMP, Public Awareness, has not been carried forward to the
9 Failure of DOH Assets risk because that program was designed to
10 reduce third party contact with energized conductors, which is now
11 addressed as part of the Third-Party Safety Incident RAMP risk. PG&E
12 has added two new controls – Design Standards and Pole Programs –
13 which relate to electric distribution overhead assets other than
14 conductor. Also, the scope of asset-based controls such as Equipment
15 Preventive Maintenance and Replacement now extends to all electric
16 distribution overhead line assets, not just conductor.

17 PG&E proposed two mitigations for DOCP in the 2017 RAMP. One
18 of these, Additional Public Awareness Outreach, is not carried forward
19 to the Failure of DOH Assets risk because, like the Public Awareness
20 control discussed above, it is now in the scope of the Third-Party Safety
21 Incident RAMP risk. The second mitigation, Overhang Clearing, was
22 subsumed in the Enhanced Vegetation Management mitigation
23 presented in the GRC, and that continues to be the case here. PG&E is
24 proposing several asset-based mitigations for Failure of DOH Assets in
25 the 2020 RAMP that post-date the filing of the 2017 RAMP and/or which
26 target electric distribution overhead assets other than conductor and
27 therefore would not have been mitigations for DOCP risk. These
28 mitigations include: System Hardening, Non-Exempt Surge Arrester
29 Replacement, Expulsion Fuse Replacement, Grasshopper/KPF Switch
30 Replacement, RO Streetlight Replacement, Ceramic Post Insulator
31 Replacement, and 3A and 4C Line Recloser Controller Replacement.
32 Two other proposed mitigations—Asset Data Capture and Improved
33 Distribution Risk Model—are new activities that did not exist at the time
34 the 2017 RAMP was filed.

1 D. 2020-2022 Control and Mitigation Plan

2 1. Changes to Controls

3 In general, PG&E will continue to implement the same controls in
4 2020-2022 as it did in 2019. Significant changes to existing controls are
5 discussed below.

6 **C4 – Overhead Conductor Replacement:** PG&E is evaluating a possible
7 increase in its current planned mileage of overhead conductor replacement.
8 This increase could begin as early as 2022. PG&E will discuss any such
9 proposed increase in the 2023 GRC.

10 **C5 – Overhead Patrols and Inspections:** For 2020 and beyond, PG&E is
11 incorporating fire-risk considerations identified as part of the WSIP process
12 and baseline compliance guidelines into a checklist-guided paperless
13 approach for facilities inspections. PG&E will perform detailed overhead
14 inspections of overhead electric distribution facilities located in HFTD areas
15 on a risk-informed cycle; in 2020 PG&E plans to inspect all its facilities in
16 HFTD Tier 3 and one-third of its facilities in HFTD Tier 2. PG&E's current
17 plan for non-HFTD facilities is to continue with the historical cadence of
18 detailed inspections once every five years. Future year inspection scope
19 and cadence may be adjusted based on the results of this initial cycle of
20 enhanced inspections and may shift toward more risk-informed or
21 condition-dependent cycles linked to PG&E predictive models. However, for
22 forecasting purposes, this filing assumes that PG&E will continue to inspect
23 all facilities in HFTD Tier 3 annually and facilities in HFTD Tier 2 once every
24 three years. PG&E is also performing Field Safety Reassessments of
25 pending maintenance notifications that will not be completed before the start
26 of the upcoming fire season to verify that previously identified maintenance
27 conditions have not further deteriorated to the point that they require more
28 immediate resolution.

29 **C6 – Infrared Inspections:** PG&E completed its systemwide infrared splice
30 inventory in 2019 but will continue infrared inspections of the system on a
31 regular, risk-prioritized cadence focused primarily on HFTD areas.

32 **C11 – Pole Programs:** In 2020, PG&E will begin regular use of the new
33 pole loading infrastructure assessment that it piloted in 2019. PG&E's initial
34 goal is to assess all poles located in Tier 2 and Tier 3 HFTD areas by 2024,

1 at a rate of approximately 230,000 poles per year, to determine whether
2 existing poles are adequate under PG&E's current loading criteria.

3 **2. Changes to Mitigations**

4 In general, PG&E plans to implement the same mitigations in 2020-2022
5 as it did in 2019. Significant changes to the mitigation plan are discussed
6 below:

7 **M1 – Enhanced Vegetation Management:** PG&E's EVM program will
8 perform similar pruning and tree removal work in 2020-2022 to what it did in
9 2019. However, PG&E plans to complete less EVM work on distribution
10 lines in 2020-2022 than it did in 2019 (approximately 1,800 miles of
11 distribution line per year in 2020-2022 versus 2,498 miles in 2019). Based
12 on its assessment of routine and enhanced vegetation management work on
13 the system as a whole, beginning in 2020 PG&E plans to shift some EVM
14 resources to expand rights of way and remove incompatible trees around
15 lower voltage transmission lines (similar work is already performed around
16 higher voltage transmission lines as part of PG&E's routine vegetation
17 management).

18 **M2 – System Hardening:** PG&E plans to progressively increase the pace
19 of system hardening in the 2020-2022 period with a goal of completing
20 approximately 1,060 circuit miles in that period.

21 **M6 – Grasshopper/KPF Switch Replacement:** PG&E estimates that, as of
22 the beginning of 2020, there are approximately 151 grasshopper and KPF
23 switches that still need to be replaced. Program management anticipates
24 completing the replacement of all 151 remaining switches between 2020
25 and 2025, including 1 switch in 2020, and 30 switches per year from
26 2021-2025.

27 **M7 – RO Streetlight Replacement:** As discussed above, PG&E is not
28 currently planning to perform any RO Streetlight Replacement work in
29 2020-2022 because of the City and County of San Francisco (CCSF) paving
30 moratorium that is in effect until 2023. Work will resume in 2023.

31 PG&E is implementing three new mitigations beginning in the
32 2020-2022 time period:

33 **M9 – Improved Distribution Risk Model:** PG&E is developing an
34 improved distribution risk model that when fully implemented will provide a

more risk-based framework for decisions about asset inspection, maintenance, and replacement of all overhead electric distribution assets. Each asset will receive a risk score, in line with the Multi-Attribute Value Function Framework, that considers the probability of failure (based on asset health factors) and the resulting consequences (based on the function and location of the assets). PG&E believes this risk-based approach will address drivers of asset failure more effectively than the traditional, compliance-based approach. PG&E will be continually evolving this improved model through at least 2026. PG&E considers this to be a foundational activity because it supports other controls and mitigations rather than directly reducing risk. As a result, PG&E is not calculating a risk reduction score or an RSE for this mitigation.

M10 – 3A and 4C Line Recloser Controller Replacement: PG&E uses line reclosers across its electric distribution overhead system to manage, locate, and isolate faults and to re-energize circuits in the event of an outage. Some of these line recloser units use older model 3A or 4C controllers, which have limited functionality compared to newer controller models. These functional limitations increase the risk of circuit failure and impact PG&E's ability to isolate faults and re-energize circuits in the event of an outage. Line reclosers are also categorized as protective devices and are programmed to protect customers from safety hazards due to fault conditions including wire-down incidents and sustained outages. There is a high risk of such fault incidents if these devices do not operate as intended. In particular, because the sensor technology in existing 3A controllers is less sophisticated than in newer controllers, a line recloser equipped with a 3A controller may not detect all the faults that a newer controller would, which may lead to a higher incidence of energized wires down. To mitigate this risk, PG&E proposes to replace all 3A and 4C line recloser controllers in its system with newer models.¹⁵

¹⁵ 3A and 4C Line Recloser Controller Replacement is a mitigation for two RAMP risks—Failure of DOH Assets and Third-Party Safety Incident—because it will reduce outages and third-party contact with energized conductor. The primary benefit of the mitigation is to reduce Failure of DOH Assets risk. PG&E calculated the aggregated risk reduction score for both risks and divided that score by the total cost of the mitigation to calculate the overall RSE for the mitigation.

PG&E estimates that there are approximately 810 of these units that will need to be replaced as part of the program.¹⁶ PG&E plans to pilot this program by replacing five 3A units in both 2021 and 2022 and then launch a full-scale program in 2023.

M11 – Remote Grid: Remote Grid is an effort to use decentralized energy sources to permanently supply energy to certain remote customers instead of using hardened traditional utility infrastructure for electricity. PG&E's service territory contains pockets of isolated small customer loads that are served via long electric distribution feeders; some of these feeders pass through HFTD areas and some have been disconnected due to damage from recent wildfires. PG&E is proposing to remove some of these long feeders and instead serve customers from local, decentralized energy sources. This could reduce fire ignition risk, and will also reduce outages. Remote Grid could also be a cost-effective alternative to the high maintenance and restoration costs associated with these long feeder lines in remote areas. This mitigation addresses the D-Line Equipment Failure, Vegetation, Third Party, Animal, Natural Hazard, Human Performance, Other PG&E Assets or Processes and Other drivers.

In 2020, PG&E plans to deploy three Remote Grid projects at two sites to validate use cases, design standards, deployment processes, and commercial arrangements. One project is located in Briceburg, in HFTD Tier 2, and will remove 1.37 miles of line. This project is being modeled as a mitigation to both the Wildfire and Failure of DOH Assets risks.

Two projects are located at the Carrizo Plain pilot site, which is outside the HFTD but involves circuit segments with high maintenance costs, and will remove 23.8 miles of line. If the results of the initial projects are favorable, PG&E will determine whether to propose further remote grid projects in 2021 and beyond. For modeling purposes, PG&E assumes there will be no remote grid work in 2021 or 2022 but is presenting remote grid work as an alternative mitigation for 2023-2026. See Section D.1 below.

¹⁶ PG&E estimates that there are approximately 860 of these controllers on the system, but that approximately 50 will be replaced by other programs.

1 The volume of mitigation work PG&E plans to complete in the
 2 2020-2022 period is shown in Table 11-7 below.

TABLE 11-7
PLANNED MITIGATIONS 2020-2022

Line No.	Mitigation Name and Number	Units	2020 RAMP Planned Units of Work			
			2020	2021	2022	Total
1	M1 – Enhanced Vegetation Management	Miles	1,800	1,800	1,800	5,400
2	M2 – System Hardening	Miles	241	377	442	1,060
3	M3 – Non-Exempt Surge Arrester Replacement	Poles with surge arresters	2,511	3,091	19,340	24,942
4	M4 – Expulsion Fuse Replacement	Fuses	625	625	625	1,875
5	M5 – Additional Asset Data Capture	N/A	–	–	–	
6	M6 – Grasshopper/ KPF Switch Replacement	Switches	1	30	30	61
7	M7 – RO Streetlight Replacement	Streetlight	0	0	0	0
8	M8 – Ceramic Post Insulator Replacement	Poles with insulators	1,410	1,048	1,048	3,506
9	M9 – Improved Distribution Risk Model	N/A	–	–	–	
10	M10 – 3A and 4C Line Recloser Controller Replacements	Controller	0	5	5	10
11	M10 – Remote Grid	Miles Removed	25	0	0	25

3 The estimated costs for the work planned in 2020-2022 are shown in
 4 Tables 11-8 and 11-9 below.

**TABLE 11-8
FORECAST COSTS^(b)
EXPENSE (\$000) 2020-2022**

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	Total
1	M5	Additional Asset Data Capture	AB	\$4,200	\$1,230	\$1,261	\$6,691
2	M9	Improved Distribution Risk Model	AB	2,900	1,435	1,471	5,806
3		Total		\$7,100	\$2,665	\$2,732	\$12,497

(a) Mitigation M1 (Enhanced Vegetation Management) is not shown in this table because the costs for this work are aligned to the Wildfire risk (Chapter 10).

(b) See WP 11-1.

**TABLE 11-9
FORECAST COSTS^(b)
CAPITAL (\$000) 2020-2022**

Line No.	Mit. No. ^(a)	Mitigation Name	MWC	2020	2021	2022	Total
1	M3	Non-Exempt Surge Arrester Replacement	2AR	\$8,132	\$14,359	\$62,632	\$85,123
2	M6	Grasshopper and KPF Switch Replacement	08S	30	1,135	1,165	2,330
3	M7	Regulated Output Streetlight Replacement	2AG	–	–	–	–
4	M8	Ceramic Post Insulator Replacement	2AQ	3,440	2,620	2,686	8,746
5	M10	3A and 4C Line Recloser Replacement	49B	–	513	525	1,038
6		Total		\$11,602	\$18,627	\$67,008	\$97,237

(a) Mitigation M2 (System Hardening) is not shown in this table because the costs for this work are aligned to the Wildfire risk (Chapter 10).

(b) See, WP 11-1.

E. 2023-2026 Proposed Control and Mitigation Plan

1. Changes to Controls and RSE for Piloted Control

In general, PG&E plans to continue the same level of work for controls in 2023-2026 as it has planned for the 2020-2022 period.

PG&E committed to piloting the calculation of a risk reduction score and RSE for one Electric Operations RAMP risk control in the 2020 RAMP.

Electric Operations is piloting the C13 – Enhanced Inspection control for the Failure of DOH Assets risk. The Enhanced Inspection control consists of the inspection portion of the C5 – Overhead Patrols and Inspections control

1 and includes the changes in inspection scope and cadence that began with
2 the WSIP in 2019. For modeling purposes, PG&E assumes, based on its
3 2020 work plan, that will inspect circuits in Tier 3 HFTD areas every year
4 and circuits in Tier 2 HFTD areas every three years. However, PG&E
5 continues to assess the effectiveness of the increased cadence of the
6 program and may shift its strategy as more data is made available.
7 Enhanced Inspections, which has a preliminary RSE of 0.37 for the Failure
8 of DOH Assets risk¹⁷, will reduce the D-Line Equipment Failure risk driver
9 and provide PG&E with a better understanding of its asset conditions and
10 maintenance practices. The table below shows the forecast program
11 spending and preliminary RSE for the Enhanced Inspections control.

¹⁷ Enhanced Inspections will also reduce Wildfire risk, but PG&E has not calculated a Wildfire-related risk reduction score at this time. PG&E will calculate risk reduction related to the Wildfire risk for enhanced inspections in the 2023 GRC, either separately or as part of larger inspections control.

TABLE 11-10
FORECAST COSTS, RSE AND RISK REDUCTION^(b)
EXPENSE 2023-2026
(\$000)

Line No.	Ctrl No.	Control Name	MAT	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	C13	Enhanced Inspections-Distribution	BFB	\$164,367	\$168,475	\$172,688	\$177,005	\$682,535	0.37	187.5
2		Total		\$164,367	\$168,475	\$172,688	\$177,005	\$682,535		

(a) See Mitigation Effectiveness workpapers (MW) included in the source document modeling package for information used to calculate the RSE.

(b) See, WP 11-1.

2. Changes to Mitigations

In general, PG&E plans to implement the same mitigations in 2023-2026 as it did in the 2020-2022. Significant changes to the mitigation plan are discussed below:

M2 – System Hardening: PG&E plans to continue to increase the pace of system hardening with a goal of completing approximately 2,118 circuit miles in the 2023-2026 period.

M3 – Non-Exempt Surge Arrester Replacement: PG&E expects to complete all replacements in the program by 2023.

M5 – Grasshopper/KPF Switch Replacement: Based on PG&E's current work plan, PG&E expects to replace 30 switches per year from 2023-2025, at which point the all replacements will be completed.

M7 – RO Streetlight Replacement: PG&E is planning to resume work in this program and complete all replacements in 2023.

M10 – 3A and 4C Line Recloser Controller Replacement: PG&E plans to incorporate lessons learned from the pilot replacements in 2021 and 2022 to launch a full-scale replacement program in 2023. PG&E is targeting replacement of all remaining 3A and 4C controllers over a 10-year period beginning in 2023, replacing approximately 81 units per year.

The volume of mitigation work PG&E plans to complete in the 2023-2026 period is shown in Table 11-11 below.

**TABLE 11-11
PLANNED MITIGATIONS 2023-2026**

Line No.	Mitigation Name and Number	Units	2020 RAMP Planned Units of Work				
			2023	2024	2025	2026	Total
1	M1 – Enhanced Vegetation Management	Miles	1,800	1,800	1,800	1,800	7,200
2	M2 – System Hardening	Miles	504	540	538	536	2,118
3	M3 – Non-Exempt Surge Arrester Replacement	Poles with surge arresters	15,890	0	0	0	15,890
4	M4 – Expulsion Fuse Replacement	Fuses	625	625	625	625	2,500
5	M5 – Additional Asset Data Capture	N/A	–	–	–	–	–
6	M6 – Grasshopper/ KPF Switch Replacement	Switches	30	30	30	0	90
7	M7 – RO Streetlight Replacement	Streetlight	49	0	0	0	49
8	M8 – Ceramic Post Insulator Replacement	Poles with insulators	499	0	0	0	499
9	M9 – Improved Distribution Risk Model	N/A	–	–	–	–	–
10	M10 – 3A and 4C Line Recloser Replacement	Controller	81	81	81	81	324

3. Mitigation Risk Spend Efficiencies

Tables 11-12 and 11-13 below show the planned cost, RSE and risk reduction score for each of the Failure of DOH Assets risk mitigations PG&E plans to implement in the 2023-26 period.

TABLE 11-12
FORECAST COSTS, RSE AND RISK REDUCTION^(e)
EXPENSE (\$000) 2023-2026

Line No.	Mit No.	Mitigation Name	MWC	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	M1	Enhanced Vegetation Management	HN ^(b)						(c)	16.5
2	M5	Additional Asset Data Capture	AB	\$1,292	\$1,325	\$1,358	\$1,392	\$5,366	(d)	(d)
3	M9	Improved Distribution Risk Model	AB	1,508	1,545	1,584	1,624	6,261	(d)	(d)
4		Total		\$2,800	\$2,870	\$2,942	\$3,015	\$11,627		

(a) See Mitigation Effectiveness workpapers (MW) included in the source document modeling package for information used to calculate the RSE.

(b) PG&E is recording costs for this work in temporary MWC IG# but expects to forecast costs for this work in the 2023 GRC in MWC HN.

(c) The costs and RSE or this mitigation are aligned to the Wildfire risk (Chapter 10).

(d) Foundational mitigation. PG&E does not calculate an RSE or risk reduction score for foundational mitigations.

(e) WP 11-1.

TABLE 11-13
FORECAST COSTS, RSE AND RISK REDUCTION^(d)
CAPITAL (\$000) 2023-2026

Line No.	Mit No.	Mitigation Name	MAT	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	M2	System Hardening	08W						(b)	122.0
2	M3	Non-Exempt Surge Arrester Replacement	2AR	\$47,686	–	–	–	\$47,686	0.02	0.8
3	M4	Expulsion Fuse Replacement	2AP						(b)	0.4
4	M6	Grasshopper and KPF Switch Replacement	08S	1,195	1,224	1,255	–	3,674	3.69	10.3
5	M7	Regulated Output Streetlight Replacement	2AG	5,277	–	–	–	5,277	<0.01	<0.01
6	M8	Ceramic Post Insulator Replacement	2AQ	1,310	–	–	–	1,310	0.72	0.8
7	M10	3A and 4C Line Recloser Replacement	49B	8,723	8,941	9,164	9,394	36,222	1.54 ^(c)	37.0
8		Total		\$64,192	\$10,165	\$10,419	\$9,394	\$94,169		

(a) See Mitigation Effectiveness workpapers (MW) included in the source document modeling package for information used to calculate the RSE.

(b) The costs and RSE of this mitigation are aligned to the Wildfire risk (Chapter 10).

(c) The RSE includes the risk reduction for both the Failure of Electric Distribution Overhead Assets risk and the Third-Party Safety Incident risk.

(d) See, WP 11-1.

1 More than 95 percent of PG&E's 2023-2026 spending on mitigations
2 that reduce the Failure of DOH Assets risk is for three mitigations, EVM,
3 System Hardening, and Expulsion Fuse Replacement, that are primarily
4 targeted at reducing PG&E's Wildfire risk, but also have the secondary
5 effect of reducing the number of outages due to equipment failure in the
6 areas where they are implemented. The cost of those programs and their
7 RSEs, which aggregate risk reduction of the Wildfire and Failure of DOH
8 Assets risk, are discussed in Chapter 10. The RSEs for EVM, System
9 Hardening, and Expulsion Fuse Replacement (2.6, 7.2, and 1.0,
10 respectively) are all relatively high and demonstrate that PG&E's investment
11 in those mitigations is reasonable.

12 Non-Exempt Surge Arrester Replacement accounts for 45 percent of
13 2023-2026 spending on mitigations that are primarily focused on the Failure
14 of DOH Assets risk. The program, which will be completed in 2023, has a
15 relatively low 2023-2026 RSE of 0.02, but PG&E believes the grounding
16 portion of the work is mandatory in order to bring surge arrester installation
17 into compliance with GO 95 and that the simultaneous replacement of surge
18 arresters is prudent asset management.

19 3A and 4C Line Recloser Controller Replacements accounts for
20 34 percent of 2023-2026 spending on mitigations that are primarily for the
21 Failure of DOH Assets risk and has a 2023-2026 RSE of 1.39.
22 Grasshopper/KPF Switch Replacements accounts for 3 percent of
23 2023-2026 spending on mitigations that are primarily for the Failure of DOH
24 Asset risks and has a 2023-2026 RSE of 3.69. Ceramic Post Insulator
25 Replacement, accounting for 1 percent of 2023-2026 spending on
26 mitigations that are primarily for the Failure of DOH Assets risk, has a
27 2023-2026 RSE of 0.72. These mitigations have relatively high RSE scores
28 and address public and employee safety concerns, as well as potentially
29 reducing outages.

30 The RO Streetlight Replacement program accounts for 5 percent of
31 2023-2026 spending on mitigations that are primarily for the Failure of DOH
32 Assets risk; it has a 2023-2026 RSE of less than 0.01. PG&E believes it
33 likely that its current model significantly understates the risk reduction value
34 (and RSE) of the program because it does not differentiate between

“normal” streetlight outages on non-RO systems, and streetlight outages on RO systems. Outages on RO systems are more complicated to resolve, as one failure can lead to multiple failures in unison, and RO system outages may last for extended periods of time due to the lack of availability of spare parts. In any event, PG&E believes this investment is prudent from an asset management perspective to eliminate the last few antiquated PG&E-owned RO streetlights from its system.

The two foundational activities for the Failure of DOH Assets risk, Additional Asset Data Capture and Improved Distribution Risk Model, account for 5 percent and 6 percent, respectively, of 2023-2026 spending on mitigations that are primarily for the Failure of DOH Assets risk. PG&E believes it is prudent to invest in these mitigations because they will improve PG&E’s ability to capture information about the location and cause of outages and the reasons for equipment failures. This information will help PG&E improve its more risk-based framework for decisions about asset inspection, maintenance, and replacement for all overhead distribution assets.

F. Alternative Analysis

In addition to the proposed mitigations described in Section E.2 above, PG&E also considered alternative mitigations. The mitigations described in Section E.2 above constitute the Proposed Plan. The Alternative Plans consist of a combination of some or all of the proposed mitigations, along with the alternative mitigation(s). PG&E describes each of the alternative mitigations it considered below and then provides a table showing the forecast costs, RSEs and risk reduction scores for each of the Alternative Plans.

1. Alternative Plan 1: M11a – Remote Grid

As discussed above, in 2020 PG&E is piloting three Remote Grid projects, one of which is in an HFTD area. If the outcome of the pilots is favorable, PG&E proposes to expand the program to additional feeders as a mitigation for 2023-2026. Since PG&E has not determined the scale or future location of additional Remote Grid projects, for modeling purposes PG&E assumed that remote grid work in 2023-2026 will continue at the

1 same level as 2020 and allocated the mileage proportionally across all
2 tranches.

TABLE 11-14
FORECAST COSTS, RSE AND RISK REDUCTION^(c)
CAPITAL (\$000) 2023-2026

Line No.	Mit. No.	Mitigation Name	RSE ^(a)	Risk Reduction
1	M11a	Remote Grid	(b)	5.1

(a) See Mitigation Effectiveness workpapers (MW) included in the source document modeling package for information used to calculate the RSE.

(b) The costs and RSE of this mitigation are aligned to the Wildfire risk (Chapter 10).

(c) See WP 11-1.

3 **2. Alternative Plan 2: A2 (M12) – Targeted Transformer Replacement to** 4 **Mitigate Overloading**

5 Due to rising temperatures in California related to global warming,
6 PG&E expects increasing demand for air conditioning from its customers.
7 Increased demand is likely to overload certain elements of the overhead
8 electric distribution system—this mitigation focuses on addressing the risk of
9 overloaded transformers. Over the next 10 to 20 years, PG&E estimates
10 that up to 1 percent of the approximately 750,000 overhead transformers in
11 its electric distribution system could become susceptible to failure from
12 overloading due to increases in demand. PG&E is currently evaluating a
13 program to proactively identify and upgrade its most vulnerable overhead
14 distribution transformers with higher capacity units to minimize risk of
15 overloading. Electric Program Investment Charge programs 3.13 and 3.20
16 are currently funding research to collect statistical data on transformer
17 loading to help identify at-risk transformers, using remote sensing and
18 SmartMeter™ devices. The program is in the early stages of development,
19 and PG&E has not identified a scope or prepared risk reduction or cost
20 estimates. As a result, PG&E has not calculated an RSE. PG&E will
21 continue to develop this program and may present it as a mitigation in the
22 2023 GRC.

3. Alternative Plan 3: A3 – Wildfire – Targeted System Upgrades

In addition to its currently proposed M2 System Hardening mitigation, PG&E is evaluating a broad spectrum of other system modifications to reduce Wildfire risk. These other options range from modest improvements, such as additional animal protection on existing lines, to system hardening packages that are only slightly less extensive than the current M2 specification. These alternatives involve less work and provide less risk reduction than the M2 mitigation, but at a lower cost. PG&E believes that the alternative system modifications under consideration may be appropriate substitutes for the M2 mitigation in some areas, and may also be an appropriate means for PG&E to achieve risk reduction in HFTD areas currently outside the scope of the approximately 7,100 miles currently planned for the M2 mitigation.

To show the risk reduction potential of the wide range of options under consideration, PG&E is modeling two representative packages of system modifications as alternative mitigations for M2 System Hardening. The A3 – Wildfire – Targeted System Upgrades alternative mitigation (discussed in this section) involves significantly less work and a much lower per mile cost than the existing M2 mitigation. The A4 – System Hardening-Hybrid alternative mitigation (discussed in the next section) falls between the A3 alternative mitigation and the existing M2 mitigation. PG&E's consideration of the feasibility and effectiveness of various alternatives to M2 System Hardening is still in the early stages; no pilot or workplan has been developed for implementation of any of these alternatives.

The A3 Wildfire – Targeted System Upgrades alternative is a scenario whereby PG&E does not replace its existing bare wire with covered conductor. Instead, PG&E will employ several system modifications to reduce the potential for outages that could result in ignitions. The upgrades include: animal protection work (i.e., installation of insulated wire covers, dead-end covers, covered jumpers, and cut-out/bushing covers); work to improve separation between phases of conductor to reduce the likelihood of wire-to-wire contact in high wind (i.e., installation of spreader brackets or reframing of cross-arms); assessment of poles under current pole loading standards; and, use of trusses, guys or pole replacement to bring deficient

poles up to standard. This alternative can also include the installation of additional protective devices to enable the use of DCD (Downed Conductor Detection) and SGF (Sensitive Ground Fault) modes. PG&E believes that this alternative may be especially effective in areas with low vegetation density (including HFTD areas) that are currently outside the scope of the approximately 7,100 miles currently planned for the M2 mitigation.

PG&E is modeling this alternative as part of a mitigation plan that would include the currently forecast amount of M2 System Hardening work, plus sufficient additional mileage of A3 – Wildfire – Targeted System Upgrades work, to bring the total mileage of system hardening performed up to 1,000 miles per year from 2021-2026. That would result in a Wildfire – Targeted System Upgrades target of 623 miles in 2021, 558 miles in 2022, 496 miles in 2023, 460 miles in 2024, 462 miles in 2025, and 464 miles in 2026.

TABLE 11-15
FORECAST COSTS, RSE AND RISK REDUCTION
CAPITAL 2023-2026
(\$000)

Line No.	Mit. No.	Mitigation Name	RSE	Risk Reduction
1	A3	Wildfire-Targeted System Upgrades	(a)	19.6

(a) The costs and RSE for this mitigation are aligned to the Wildfire risk (Chapter 10).

4. Alternative Plan 4: A4 – System Hardening-Hybrid

The System Hardening-Hybrid alternative is a package of system modifications that falls somewhere between the existing M2 mitigation and the A3 – Wildfire-Targeted System Upgrades alternative. It entails replacing existing bare wire with covered conductor that is lighter (i.e., has a smaller cross-section) than the current M2 specification. This lighter conductor, and pole strengthening technologies such as Extended and Tapered (ET) Trusses, would allow PG&E to significantly reduce the number of poles it needs to replace on System Hardening projects. All poles would be assessed to determine whether they need to be strengthened or replaced. Cross-arms would be replaced to improve separation of phases, and animal

protection work (as described in the A3 – Wildfire-Targeted System Upgrades alternative) would be performed. Non-exempt equipment replacement and other low impact work is not included in the scenario being modeled.

As with the Wildfire–Targeted System Upgrades alternative, PG&E is modeling the System Hardening–Hybrid alternative as part of a mitigation plan that would include the currently forecast amount of M2 System Hardening work, plus sufficient additional mileage of System Hardening – Hybrid work, to bring the total mileage of system hardening performed up to 1,000 miles per year from 2021-2026. That would result in a System Hardening - Hybrid target of 623 miles in 2021, 558 miles in 2022, 496 miles in 2023, 460 miles in 2024, 462 miles in 2025, and 464 miles in 2026.

As modeled, both Wildfire – Targeted System Upgrades and System Hardening-Hybrid have comparable RSEs to the existing M2 System Hardening mitigation, with a lower cost but less risk reduction per circuit mile. PG&E believes that it is appropriate to invest in the higher level of absolute risk reduction from M2 System Hardening program in many cases, especially for the higher-risk priority circuits that are the current focus of the System Hardening program. PG&E is continuing to evaluate a range of possible system modifications as substitutes for, or supplements to, M2 System Hardening, and may include them as part of its funding request in the 2023 GRC.

TABLE 11-16
FORECAST COSTS, RSE AND RISK REDUCTION
CAPITAL 2023-2026
(\$000)

Line No.	Mit. No.	Mitigation Name	RSE	Risk Reduction
1	A3	System Hardening-Hybrid	(a)	72.5

(a) The costs and RSE for this mitigation are aligned to the Wildfire risk (Chapter 10).

Table 11-17 compares the proposed and alternative mitigation plans:

TABLE 11-17
MITIGATION PLAN ALTERNATIVES ANALYSIS^(c)
(\$000)

Line No.	Risk Mitigation Plan	Plan Components ^(a)	Total Expense (2023-2026)	Total Capital (2023-2026)	Risk Reduction (NPV) ^(b)	Total Spend (NPV)	RSE
1	Proposed	M1, M2, M3, M4, M6, M7, M8, M10	–	\$94,169	188	\$73,597	2.55
2	Alternative 1	Proposed + M11a	–	\$94,169	193	\$73,597	2.62
3	Alternative 2	Proposed + A3	–	\$94,169	207	\$73,597	2.81
4	Alternative 3	Proposed + A4	–	\$94,169	258	\$73,597	3.50
5	Inherent	Control 13	\$682,535	–	209	\$501,683	0.37

(a) Plan Components refers to the Mitigations presented in Tables 11-5 and 11-6.

(b) Information presented in terms of Net Present Value (NPV) to account for the discounting of benefits.

(c) See, WP 11-2.

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 12
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: FAILURE OF ELECTRIC
DISTRIBUTION NETWORK ASSETS

PACIFIC GAS AND ELECTRIC COMPANY
 CHAPTER 12
 RISK ASSESSMENT AND MITIGATION PHASE
 RISK MITIGATION PLAN: FAILURE OF ELECTRIC DISTRIBUTION NETWORK
 ASSETS

TABLE OF CONTENTS

A. Executive Summary.....	12-1
1. Risk Overview	12-2
2. Risk Definition	12-3
B. Risk Assessment.....	12-3
1. Background and Evolution	12-3
2. Risk Bow Tie	12-5
3. Exposure to Risk	12-5
4. Tranches	12-5
5. Drivers and Associated Frequency	12-6
6. Cross-Cutting Factors	12-7
7. Consequences	12-8
C. Controls and Mitigations	12-11
1. 2019 Controls and Mitigations.....	12-11
a. Controls	12-11
b. Mitigations	12-13
D. 2020-2022 Control and Mitigation Plan	12-14
1. Changes to Controls	12-14
2. Changes to Mitigations.....	12-14
E. 2023-2026 Control and Mitigation Plan	12-16
1. Changes to Controls	12-16
2. Changes to Mitigations.....	12-16
3. Mitigation Risk Spend Efficiencies	12-18
F. Alternative Analysis	12-21

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 12
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: FAILURE OF ELECTRIC DISTRIBUTION NETWORK
ASSETS

TABLE OF CONTENTS
(CONTINUED)

1. Alternative Plan 1: A1 – Install Completely Submersible SCADA Enclosures	12-21
2. Alternative Plan 2: M5a – Reduce Proposed Rate of Dry-Type Transformer Replacement	12-22
3. Alternative Plan 3: A3 – Replace Network Transformers Based on Age, Instead of Condition.....	12-23

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 12
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: FAILURE OF ELECTRIC DISTRIBUTION
NETWORK ASSETS

A. Executive Summary

The Failure of Electric Distribution Network Assets¹ risk is defined as the failure of distribution network assets or lack of remote operation functionality that may result in public or employee safety issues, property damage, environmental damage, or inability to deliver energy. The drivers for this risk event are underground network equipment failure, human performance, and natural hazards. The cross-cutting factors, seismic, physical attack, skilled and qualified workforce, and records and information management also impact this risk.

Exposure to this risk is based on the 188 circuit miles of networked circuits. The risk model estimates approximately 10 risk events each year.² Equipment failure, human performance, and the seismic scenario cross-cutting scenario together account for 99 percent of the risk events. Two sub-drivers, primary cable failure and primary splice failure, account for 77 percent of the equipment failure risk, which is 66 percent of the risk. Catastrophic asset failures (defined as failures that result in a vault explosion, manhole cover displacement, and/or a fire) unrelated to a seismic scenario account for 96 percent of the risk and 18 percent of the risk events; asset failures associated with a seismic scenario account for 1 percent of risk and 1 percent of the risk events.³ The mitigations Pacific Gas and Electric Company (PG&E) will implement from 2020-2026 are designed to address these key risk drivers.

PG&E identified three tranches for this risk event based on differences in the network asset replacement strategy: circuits with a high failure rate that are a current priority for replacement; circuits where older network cable has already

¹ The risk name can also be referred to as Failure of Distribution Underground Network Assets.

² 10 is PG&E's forecast for the number of the risk events per year for 2023-2026 in the absence of proposed mitigations from 2023-2026.

³ The percentages are based on 2023 test year (TY) baseline frequency and risk scores.

1 been replaced; and all other circuits: The highest tranche-level risk, 89 percent,
2 is associated with those circuits prioritized for replacement.

3 Failure of Electric Distribution Network Assets has the eleventh highest 2023
4 TY baseline safety score (6) and the lowest 2023 TY baseline total risk score (7)
5 of PG&E's 12 Risk Assessment and Mitigation Phase (RAMP) risks. The 2020
6 baseline risk score, 15, is reduced by 61 percent when the planned mitigations
7 are applied: the 2023 TY baseline risk score is 7 and the 2026 post-mitigation
8 risk score is 6.

9 PG&E is presenting a suite of controls and mitigations to address the key
10 risk drivers. The CMD-Type Network Protector Replacement and Incremental
11 Primary Network Cable Replacement mitigation programs have the highest risk
12 spend efficiency (RSE) scores and the highest total risk reduction scores among
13 2023-2026 mitigations for this risk.⁴

**TABLE 12-1
RISK OVERVIEW**

Line No.	Risk Name	Failure of Electric Distribution Network Assets
1	In Scope	Failure of assets associated with urban underground electrical distribution networks (in downtown San Francisco and Oakland) including Network transformers, Network protectors and Network cables, primary and secondary.
2	Out of Scope	Failure of assets associated with underground transmission cables or the non-network aspects of the underground distribution system.
3	Data Quantification Sources ^(a)	<p><u>Events</u>: PG&E records of network equipment failures from February 2008 through December 2019.</p> <p><u>Outcomes</u>: Safety Outcomes are estimated based on Subject Matter Expert (SME) judgment (methodology discussed in Section B.7 below); Reliability and non-Safety-related Financial consequences are based on Distribution Underground Outage Restoration Costs from January 1, 2017 through September 2019.</p>
(a) Source documents will be provided with the workpapers on July 17, 2020.		

14 **1. Risk Overview**

15 PG&E maintains networked distribution systems in downtown San
16 Francisco and downtown Oakland to provide reliable service to key electric

⁴ The information herein is subject to those limitations described in Chapter 2, Section D.

1 customers. In a networked system, customers can receive power from one
2 of several sources, so that an outage on one of those sources will not result
3 in an outage for the customer. Overall, PG&E's networked distribution
4 systems consist of 188 circuit miles of cable in 12 network groups, ten in
5 San Francisco and two in Oakland. In addition to cable, associated facilities
6 include network transformers, protectors, and relays, monitoring equipment
7 including Supervisory Control and Data Acquisition (SCADA), and the
8 underground vaults where most network equipment is located.

9 Because PG&E's networked distribution facilities are located in dense
10 urban areas, the consequences of asset failure may be different than for
11 other aspects of the electric distribution system. Because of this, and
12 because of the different asset mix relative to other aspects of the distribution
13 system, PG&E considers the risk of failure of network assets separately
14 from the failure of other distribution assets.

15 Failure of Electric Distribution Network Assets was not included in the
16 2017 RAMP. The 2017 RAMP noted that there was a risk on the Electric
17 Operations (EO) risk register called "Network Components (in Urban/High
18 Density Areas)." This risk was equivalent to Failure of Electric Distribution
19 Network Assets risk, but did not have a high enough risk score to be
20 included as a 2017 RAMP risk. However, as discussed further in
21 Section B.7 below, at the end of 2019 PG&E changed its methodology for
22 estimating the safety consequences of the Failure of Distribution Network
23 Assets risk. As a result, its risk score went up, causing it to score high
24 enough to be included as a risk in the 2020 RAMP.

25 **2. Risk Definition**

26 The failure of distribution network assets or lack of remote operation
27 functionality may result in public or employee safety issues, property
28 damage, environmental damage, or inability to deliver energy.

29 **B. Risk Assessment**

30 **1. Background and Evolution**

31 As described above, the Failure of Electric Distribution Network Assets
32 risk has been on the EO risk register since 2014 but was not included in the
33 2017 RAMP because it had a relatively low risk score. However, due to a

1 change in PG&E's assessment of the potential safety consequences of a
2 failure incident, the safety risk score for the Failure of Electric Distribution
3 Network Assets risk has increased and PG&E is including it in the 2020
4 RAMP.

5 Network assets such as network cable, network transformers and other
6 network transformer components can fail in the course of regular operation,
7 as the result of human error, or due to natural hazards such as earthquakes.
8 Catastrophic failures of network assets can cause fires, manhole
9 displacements, and/or vault explosions with significant public safety
10 consequences; all network asset failures potentially affect customer
11 reliability.

12 PG&E established its current Network Asset Management Plan in 2008.
13 PG&E has put in place a number of programs to mitigate both the risk and
14 consequences of network asset failure including condition-based monitoring
15 and/or testing of cable and network components, regular maintenance and
16 replacement of cable and network components, installation and
17 maintenance of a SCADA system, and a targeted program to install venting
18 manhole covers on underground vaults, including network vaults, to reduce
19 the consequences of a vault explosion.

2. Risk Bow Tie

**FIGURE 12-1
RISK BOW TIE**



3. Exposure to Risk

PG&E maintains approximately 188 circuit miles of networked circuits. The Failure of Electric Distribution Network Assets risk exposure includes all network cable, network transformers, and other associated equipment such as network protectors and relays.

4. Tranches

PG&E identified three tranches for the Failure of Electric Distribution Network Assets risk based on differences in the network asset replacement strategy for:

- Circuits with a high failure rate (prioritized for replacement based on failures and cable testing⁵): These circuits make up 132 (70 percent) of the 188 circuit miles of PG&E's network distribution system and are associated with 89 percent of network asset failure risk.

⁵ Cable testing involves an electrical process for applying voltage signals to cable to assess the integrity of the cable's insulation (and concentric neutral when applicable).

- Reconductored circuits (circuits whose older vintage network cables have been replaced as of end of year 2019): These circuits make up 33 (18 percent) of the 188 circuit miles of PG&E's network distribution system and are associated with 1 percent of network asset failure risk.
 - All other circuits (circuits with newer vintage ethylene propylene rubber (EPR) type cable): These circuits make up 23 (12 percent) of the 188 circuit miles of PG&E's network distribution system and are associated with 9 percent of network asset failure risk.
- Table 12-2 below shows the risk analysis results at the tranche level.

TABLE 12-2
TRANCHE LEVEL RISK ANALYSIS RESULTS

Line No.	Tranche	Percent Exposure	Safety Risk Score	Reliability Risk Score	Financial Risk Score	Total Risk Score	Percent Risk
1	Circuits with a High Failure Rate	70%	5.70	0.16	0.02	5.88	89%
2	Reconductored Circuits	18%	0.00	0.08	0.01	0.09	1%
3	All Other Circuits	12%	0.59	0.02	0.00	0.61	9%
4	Total	100%	6.29	0.26	0.03	6.58	100%

5. Drivers and Associated Frequency

PG&E identified seven drivers (four of which are cross-cutting factors) and 24 sub-drivers of the Failure of Electric Distribution Network Assets risk. Each driver and its associated 2023 TY estimated frequency is discussed below. A complete list of sub-drivers is provided in supporting workpapers.⁶

D1 – Underground Network Equipment Failure: Failure events due to primary cable, primary splice, secondary cable failure, or other components of the network. These events account for 7.9 (77 percent) of the 10.2 expected annual number of network asset failures.

D2 – Human Performance: Failure events caused by PG&E employees based on improper construction, operating error, or other actions. These events account for 2.0 (19 percent) of the 10.2 expected annual number of network asset failures.

⁶ Sub-drivers are listed in the modeling workpapers which will be provided on July 17, 2020.

D3 – Seismic Scenario (Cross-Cutting): Failure events caused by seismic activity. This risk is described further in Chapter 20 of this report. These events account for 0.08 (<1 percent) of the 10.2 expected annual number of network asset failures.

D4 – Skilled and Qualified Workforce (Cross-Cutting): Failure events caused by lack of a sufficiently trained workforce. This risk is described further in Chapter 20 of this report. These events account for 0.2 (2 percent) of the 10.2 expected annual number of network asset failures.

D5 – Records and Information Management (Cross-Cutting): Failure events caused by not implementing fully an effective records and information management program and controlling data quality. This risk is described further in Chapter 20 of this report. These events account for less than 0.08 (<1 percent) of the 10.2 expected annual number of network asset failures.

D6 – Physical Attack (Cross-Cutting): Failure events caused by physical attack on PG&E assets. This risk is described further in Chapter 20 of this report. These events account for less than 0.01 (<1 percent) of the 10.2 expected annual number of network asset failures.

D7 – Natural Hazards: Failure events caused by a natural hazard event such as flood, rain, etc., (but excluding earthquakes, which are the basis for the seismic cross-cutting factor). These events did not account for any network asset failures in the period PG&E used as the historical basis for its modeling, but they do have a potential to cause network asset failures.

6. Cross-Cutting Factors

A cross-cutting factor is a driver or control that is interrelated to multiple risks. PG&E is presenting eight cross-cutting factors in the 2020 RAMP. The cross-cutting factors that impact the Failure of Electric Distribution Network Assets risk are shown in Table 12-3 below. A description of the cross-cutting factors and the mitigations and controls that PG&E is proposing to mitigate the cross-cutting factors are described in Chapter 20.

**TABLE 12-3
CROSS-CUTTING FACTOR SUMMARY**

Line No.	Cross-Cutting Factor	Impacts Likelihood	Impacts Consequence
1	Climate Change	X	
2	Emergency Preparedness and Response		X
3	Physical Attack	X	
4	Records and Information Management	X	X
5	Seismic	X	X
6	Skilled and Qualified Workforce	X	

PG&E is continuing to evaluate the impact that Cyber Attack and Information Technology (IT) Asset Failure have on RAMP risks and may present them as cross-cutting factors relative to the Failure of Electric Distribution Network Assets risk in the 2023 General Rate Case (GRC).

7. Consequences

Historically, PG&E estimated the safety consequences (potential injuries and/or fatalities) of the Failure of Electric Distribution Network Assets risk based on historical data from PG&E's Electric Incident Reports. However, PG&E has concluded that this approach likely understates the potential for high safety consequence incidents of network asset failure (which have been very infrequent, but have occurred on PG&E's system). Therefore, EO decided to incorporate SME judgment regarding potential safety consequences of a network asset failure in its modeling. Specifically, EO updated the model to include SME judgment that a failure of an electric distribution network asset will result in a serious injury incident once every 10 years and a fatality incident once every 15 years.

PG&E separately analyzed the consequences of: (1) asset failures associated with a seismic scenario; (2) asset failures associated with catastrophic outcomes (defined as failures that resulted in a vault explosion, manhole cover displacement, and/or a fire) other than those caused by a seismic scenario; and (3) asset failures not associated with catastrophic outcomes or with a seismic scenario.

- Asset failures related to a seismic scenario account for 1 percent of the frequency associated with this risk and 1 percent of the risk score.

- 1 • Catastrophic asset failures not associated with a seismic scenario
- 2 account for 18 percent of the frequency, but 96 percent of the risk score.
- 3 • Non-catastrophic asset failures not associated with a seismic scenario
- 4 account for 81 percent of the frequency, but 3 percent of the risk score.
- 5 Table 12-4 below shows the consequences of this risk event. Model
- 6 attributes are described in Chapter 3, "Risk Modeling and Risk Spend
- 7 Efficiency."

TABLE 12-4
RISK EVENT CONSEQUENCES

	CoRE %Freq %Risk			Natural Units Per Event			CoRE			Natural Units per Year			Attribute Risk Score		
				Safety EF/event	Electric Reliability MCM/event	Financial Reliability \$M/event	Safety	Electric Reliability	Financial	Safety EF/yr	Electric Reliability MCM/yr	Financial \$M/yr	Safety	Electric Reliability	Financial
Asset Failure / Not Catastrophic	0.0	81%	3%	-	0.05	0.006	-	0.0	0.0	-	0	0.05	-	0.2	0.02
Asset Failure / Catastrophic	3.4	18%	96%	0.06	0.04	0.005	3.4	0.0	0.0	0.10	0	0.01	6	0.0	0.00
Asset Failure / Seismic scenario	0.8	1%	1%	0.01	0.45	0.012	0.5	0.2	0.0	0.00	0	0.0	0	0.0	0.0
Aggregated	0.6	100%	100%	0.01	0.05	0.006	0.6	0.0	0.0	0.11	1	0.1	6	0	0.0

1 C. Controls and Mitigations

2 Because the Failure of Electric Distribution Network Assets risk was not
3 included in the 2017 RAMP, PG&E has not previously presented a list of
4 controls and mitigations for this risk. In the following sections, PG&E describes
5 the baseline controls and mitigations in place in 2019, and then discusses any
6 new mitigations and/or significant changes to mitigations and/or controls during
7 the 2020-2022 and 2023-2026 periods.

8 1. 2019 Controls and Mitigations

9 a. Controls

10 PG&E had the following controls in place for the Failure of Electric
11 Distribution Network Assets risk as of 2019:

12 **C1 – Network Cable Replacement and Switch Installations:** This
13 control consists of the systematic replacement of network cable assets
14 and installation of switches in downtown San Francisco and Oakland
15 networks. Many of the existing network primary and secondary cables
16 date from the 1920s to the 1960s and are nearing the end of their useful
17 life. The network systems replacement program is an on-going program
18 that started in 2011. The program work includes replacing primary and
19 secondary cables, modifying network transformers to accept the new
20 primary cables, and installing switches. PG&E is installing switches at
21 the same time cables are replaced to meet operational requirements by
22 providing a switching location outside the substation to establish feeder
23 clearance points. Switch installation also improves work efficiency and
24 emergency response times by eliminating the need to involve substation
25 personnel for clearing and grounding at the station for feeder clearance
26 work that needs to be performed outside the substation. This control
27 has the potential to reduce the Underground Network Equipment Failure
28 driver.

29 **C2 – Network Maintenance and Corrective Work:** Maintenance work
30 associated with PG&E's Network Asset Management Plan includes
31 inspection and oil sampling of all major oil-filled network components of
32 transformers, inspection and testing of network protectors, maintenance
33 and routine replacement of the network SCADA system, and electric

corrective notification work in network vaults. This control has the potential to reduce the Underground Network Equipment Failure driver.

C3 – Network Component (Transformer, Protector) Replacements

Condition Based: PG&E routinely monitors the condition of its network transformers and network protectors by means of inspection, insulating oil analysis, testing, and on-line sensor monitoring. PG&E replaces network components identified as needing replacement due to their condition with new, safer and more reliable technologies. Replacement transformers are either explosion-resistant or dry-type and use a single-tank design to minimize the risk of catastrophic failure. Network protectors are replaced at the same time as transformers since they have a similar life span. This control has the potential to reduce the Underground Network Equipment Failure driver.

C4 – Asset Information Improvements/Asset Data Comparison and

Updates: This control consists of various initiatives to validate and improve the quality of data in PG&E's IT systems concerning electric distribution network assets. These initiatives include automating some data entry processes that are currently manual to ensure accuracy and data synchronization, updating IT applications based on construction change sketches, and correcting data based on discrepancy reports for assets and attributes in PG&E databases. PG&E has also initiated an Electric Program Investment Charge project to expand the capabilities of its condition-based maintenance alarm system to use more data sources. This control has the potential to reduce the Underground Network Equipment Failure driver.

C5 – Network Health Report (Units Offline): This is a report used to spot check the number of units offline to use as an indicator of the operational health of the network to highlight any prolonged clearances and increased reliability risks. This control has the potential to reduce the Underground Network Equipment Failure driver.

C6 – Standards, Processes, and Training: This Includes Workmanship Skills and Training, Standards, Bulletins, Guidelines, Utility Procedures, and Personnel Training & Qualifications. This control

has the potential to reduce the Skilled and Qualified Workforce cross-cutting factor.

b. Mitigations

PG&E had the following mitigations in place for the Failure of Electric Distribution Network Assets risk in 2019:

M1 – Network Component Replacements – Targeted Replacement of Oil-Filled Transformers in High-Rise Buildings: PG&E is currently engaged in a targeted program to replace older, oil-filled transformers located in high-rise buildings with dry-type units to improve reliability and minimize fire risk in the event of a transformer failure. PG&E replaced nine transformers in 2019 as part of the program and plans to complete oil-filled high-rise replacements in 2022.⁷ This mitigation has the potential to reduce the Underground Network Equipment Failure driver.

M2 – Venting Manhole Cover Replacements: This is an ongoing program to replace existing solid and grated manhole covers on vaults with hinged venting manhole covers designed to stay in place in the event of a vault explosion. A venting cover that stays in place during a vault explosion reduces the potential for exposure to hot gasses from the vault, eliminates the risk of a projectile manhole cover, and reduces the force of the explosion. This program began in 2010 and has been focused on covers to vaults located in High Pedestrian Zones (HPZ) in San Francisco and Oakland, which includes many network vaults. PG&E has completed approximately 90 percent of the necessary replacements in HPZs in San Francisco; most of the remaining HPZ locations have non-standard vaults/covers, which have a higher cost and tend to require more permitting. In 2019, PG&E replaced 540 manhole covers as part of this program. PG&E expects to complete replacement of manhole covers on network vaults by 2022, but replacements will continue on vaults that are not part of the network

⁷ In its 2020 GRC, PG&E forecast that oil-filled, high rise replacements would be completed by 2021. In response to a request from the Office of the Safety Advocate, PG&E agreed that it would notify the California Public Utilities Commission of any changes to that schedule and provide a new timeline for completing the project. PG&E now forecasts that it will complete all replacements in 2022 and will provide an update on the program in the 2023 GRC.

1 system after that. This mitigation has the potential to reduce the
2 consequences of a network equipment failure by reducing the likelihood
3 and negative effects of an underground vault explosion.

4 **M3 – Installation of SCADA Equipment for Safety Monitoring:** This
5 is a targeted program to upgrade PG&E's original 1980s vintage SCADA
6 monitoring equipment on its 12 network groups. The upgraded system
7 provides additional equipment condition information, which allows PG&E
8 to identify equipment conditions that can be addressed before in-service
9 failure occurs. It also allows PG&E to operate some equipment in
10 network vaults remotely, instead of having to send crews to the vault to
11 operate the equipment manually. The new features enhance the safety,
12 reliability, and efficiency of the network systems. PG&E began its
13 targeted SCADA upgrades in 2009 and currently forecasts that they will
14 be completed by 2028. In 2019, PG&E completed work on one network
15 group and began work on another. PG&E considers SCADA upgrades
16 to be a foundational activity because they support other controls and
17 mitigations rather than directly reducing risk. As a result, PG&E is not
18 assigning a risk score or calculating an RSE for this mitigation.

19 **D. 2020-2022 Control and Mitigation Plan**

20 **1. Changes to Controls**

21 In general, PG&E plans to continue to implementing the same controls
22 in the 2020-2022 period that it did in 2019. PG&E will continue to review its
23 controls to incorporate new developments and lessons learned.

24 The M1 – Network Component Replacements – Targeted Replacement
25 of Oil-Filled Transformers in High-Rise Buildings mitigation is expected to be
26 completed in 2022. Maintenance of these new transformers will become
27 part of the C2 – Network Maintenance and Corrective Work control going
28 forward.

29 **2. Changes to Mitigations**

30 PG&E plans to continue to implement the same mitigations in the
31 2020-2022 period that it did in 2019. As discussed below, two of these
32 mitigation programs are scheduled for completion in 2022

M1 – Network Component Replacements – Targeted Replacement of

Oil-Filled Transformers in High-Rise Buildings: PG&E plans to complete the remaining 14 replacements in this program by 2022. The current target is to replace six transformers in 2020, six more transformers in 2021, and the final two transformers in 2022.

M2 – Venting Manhole Cover Replacements: PG&E plans to complete its planned replacement of manhole covers on network vaults by 2022, with an estimated 200 replacements in 2020, 341 replacements in 2021, and 241 replacements in 2022.

M3 – Installation of SCADA Equipment for Safety Monitoring: PG&E plans to continue replacing SCADA equipment on the network at a rate of approximately one network group per year.

The volume of mitigation work PG&E plans to complete in the 2020-2022 period is shown in Table 12-5 below.

**TABLE 12-5
PLANNED MITIGATIONS 2020-2022**

Line No.	Mitigation Name and Number	2020 RAMP Planned Units of Work				
		Units	2020	2021	2022	Total
1	M1 – Network Component Replacements – High-Rise Oil-Filled Transformers	Transformers	6	6	2	14
2	M2 – Venting Manhole Cover Replacements	Covers	200	341	241	782
3	M3 – Installation of SCADA Equipment for Safety Monitoring	Groups	1	1	1	3

The forecast costs for the work PG&E plans to complete, RSEs and risk reduction scores for the work PG&E plans to complete in the 2020-2022 period is shown in Table 12-6 below.

**TABLE 12-6
FORECAST COSTS
2020-2022 CAPITAL
(THOUSANDS OF DOLLARS)**

Line No.	Mit. No.	Mitigation Name	Maintenance Activity Type (MAT)	2020	2021	2022	Total
1	M1	Network Component Replacements – Targeted Replacement of Oil-Filled Transformers in High-Rise Buildings	2CC	\$3,467	\$3,553	\$1,634	\$8,654
2	M2	Venting Manhole Cover Replacements	2CD	2,597	5,533	4,307	12,437
3	M3	Installation of SCADA Equipment for Safety Monitoring	2CE	8,467	8,873	9,110	26,449
4	M4	Incremental Primary Network Cable Replacements	56N	–	–	–	–
5	M5	Network Component Replacements – Targeted Replacement of Dry-Type Transformers in High-Rise Buildings	2CC	–	–	–	–
6	M6	Network Component Replacements – Targeted Replacement of CMD-Type Network Protectors	2CC	–	–	–	–
7		Total		\$14,531	\$17,959	\$15,051	\$47,541

Note See WP 12-1.

1 E. 2023-2026 Control and Mitigation Plan

2 1. Changes to Controls

3 In general, PG&E plans to continue implementing the same controls in
4 the 2023-2026 period that it did it in the 2020-2022 period. PG&E will
5 continue to review its controls to incorporate new developments and lessons
6 learned.

7 2. Changes to Mitigations

8 PG&E expects to complete replacements in the M1 – Network
9 Component Replacements – High-Rise Oil-Filled Transformers mitigation
10 and the network-related portion of the M2 – Venting Manhole Cover
11 Replacements mitigation by the end of 2022.

12 PG&E is proposing three new mitigations for 2023-2026:

1 **M4 – Incremental Primary Network Cable Replacements:** Since 2011,
2 PG&E has been proactively replacing older Paper Insulated Lead Covered
3 (PILC) cable in its electric distribution network with EPR cable. Newer EPR
4 cables are significantly less likely to fail than older PILC cables and industry
5 studies also suggest that EPR cables have higher tolerance to overload
6 conditions. Beginning in 2023, PG&E is proposing to increase the number
7 of circuit miles of network cable replaced in this existing program (described
8 in the C1 control above) by 25 percent, which would result in replacement of
9 approximately three additional miles of network cable per year from
10 2023-2026. This mitigation has the potential to reduce the Underground
11 Network Equipment Failure driver.

12 **M5 – Network Component Replacements – Targeted Replacement of**
13 **Dry-Type Transformers in High-Rise Buildings:** PG&E plans to complete
14 its replacement of oil-filled network transformers in high-rise buildings in
15 2022. In 2023-2026 period, PG&E is planning to replace some older
16 dry-type transformers also located in high-rise buildings. PG&E has
17 identified 22 of these older dry-type transformers, mostly installed in the
18 1980s, located in four high-rise buildings (three in San Francisco and one in
19 Oakland). These units are at the end of their useful lives and some of them
20 have rust and other corrosion. PG&E estimates that replacing these
21 22 transformers will take three years and cost approximately \$10 million,
22 with nine replacements per year planned for 2023 and 2024 and four
23 replacements planned for 2025. This mitigation has the potential to reduce
24 the Underground Network Equipment Failure driver.

25 **M6 – Network Component Replacements – Targeted Replacement of**
26 **CMD-Type Network Protectors:** PG&E has approximately 1,390 network
27 protectors in its electric distribution network system. There are four different
28 kinds of network protectors in service currently: GE, CM22, CM52, and
29 CMD. Based on service records, PG&E has concluded that CMD network
30 protectors are more difficult to repair and replace as they are of an older
31 style and have obsolete components. This program aims to replace all CMD
32 units in the PG&E network with more reliable network protector models.
33 PG&E estimates there are 229 CMD network protectors on its electric
34 distribution network system. PG&E is proposing an 8-year program to

replace these units beginning in 2023 at a rate of approximately 30 units per year.⁸ This mitigation has the potential to reduce the Underground Network Equipment Failure driver.

The volume of mitigation work PG&E plans to complete in the 2023-2026 period is shown in Table 12-7 below.

**TABLE 12-7
2023-2026 PLANNED MITIGATIONS**

Line No.	Mitigation Name and Number	Units	2020 RAMP Planned Units of Work				
			2023	2024	2025	2026	Total
1	M3 – Installation of SCADA Equipment for Safety Monitoring (Installation)	Groups	1	1	1	1	4
2	M4 – Incremental Primary Network Cable Replacements (MAT 56N)	Circuit Miles	2.86	2.86	2.86	2.86	11.44
3	M5 – Network Component Replacements – High-Rise Dry-Type Transformers	Transformers	9	9	4	0	22
4	M6 – Network Component Replacements – Targeted Network Protector Replacement	Network Protectors	30	30	30	30	120

3. Mitigation Risk Spend Efficiencies

Table 12-8 below shows the planned cost, RSE and risk reduction score for each of the Failure of Electric Distribution Network Assets risk mitigations PG&E plans to implement in the 2023-26 period.

⁸ PG&E assumes 225 units will be replaced in the program and four units will be replaced through other programs.

TABLE 12-8
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MAT	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	M1	Network Component Replacements – Targeted Replacement of Oil-Filled Transformers in High-Rise Buildings	2CC	–	–	–	–	–	–	–
2	M2	Venting Manhole Cover Replacements	2CD	–	–	–	–	–	–	–
3	M3	Installation of SCADA Equipment for Safety Monitoring	2CE	\$9,337	\$9,571	\$9,810	\$10,055	\$38,774	(b)	(b)
4	M4	Incremental Primary Network Cable Replacements	56N	6,510	6,673	6,840	7,011	27,033	0.07	1.44
5	M5	Network Component Replacements - Targeted Replacement of Dry-Type Transformers in High-Rise Buildings	2CC	4,077	4,615	2,301	–	10,992	<0.01	<0.01
6	M6	Network Component Replacements - Targeted Replacement of CMD-Type Network Protectors	2CC	1,615	1,656	1,697	1,740	6,708	0.37	1.85
7		Total		\$21,540	\$22,514	\$20,648	\$18,806	\$83,507		

(a) See Mitigation Effectiveness workpapers (MW) included in the source document modeling package for information used to calculate the RSE

(b) Foundational mitigation. No RSE or risk reduction calculated

Note See WP 12-1.

1 Approximately 45 percent of PG&E's planned Failure of Electric
2 Distribution Network Assets mitigation spending for the 2023-2026 period is
3 for installation of upgraded network SCADA equipment to replace SCADA
4 installed in the 1980s which is at the end of its useful life and has less
5 capability than modern SCADA equipment. PG&E began these
6 replacements in 2009 and plans to complete all replacements by 2028.
7 PG&E considers this a foundational activity (and has not calculated a risk
8 score or RSE) because it does not directly reduce risk, but instead provides
9 information about the network system, including equipment condition, that
10 can be used to reduce risk. PG&E believes that this investment is prudent
11 because it replaces assets at the end of their useful life with assets that
12 have more extensive capabilities, and because the visibility and remote
13 operation capacity that modern SCADA provides will improve the safety,
14 reliability, and efficiency of PG&E's electric distribution network system.

15 Two other mitigations – incremental primary network cable replacement
16 (0.07 RSE) and targeted network protector replacement (0.37 RSE) are
17 asset management programs that achieve their risk reductions by replacing
18 older equipment that is prone to failure with newer equipment. As this risk
19 focuses on work in highly-urban areas that have a wide distribution of safety
20 consequences, the mitigation programs are considered investments that
21 minimize large safety impacts.

22 The M5 mitigation – replacement of older dry-type transformers in
23 high-rise buildings – received a low RSE (less than 0.01). PG&E believes
24 that its current model understates the risk reduction of this program because
25 the model assigns the same safety and reliability consequences to all
26 potential failures of network transformers. But, for several reasons, the
27 consequences of a failure of any of the 22 dry-type, high rise transformers
28 that are the focus of this program would be much more severe than failure of
29 a "typical" network transformer. First, these transformers serve buildings
30 with critical facilities such as large data centers and transportation
31 infrastructure. Second, while most network transformers are
32 interchangeable and PG&E has an inventory of spares, the dry-type
33 transformers that are the focus of this program are custom built and require
34 substantial lead time. Third, as a general matter, replacing high rise

transformers requires substantial lead time because it usually involves a crane and extensive permitting. PG&E believes that it is important to proactively replace these units before they fail to avoid the possibility of a long period of transformer downtime.

F. Alternative Analysis

In addition to the proposed mitigations described in Section E above, PG&E also considered alternative mitigations. The mitigations described in Section E constitute the Proposed Plan. The Alternative Plans consist of a combination of some or all of the proposed mitigations along with the alternative mitigation(s). PG&E describes each of the alternative mitigations it considered below and then provides a table showing the forecast costs, RSEs and risk reduction scores for each of the Alternative Plans.

1. Alternative Plan 1: A1 – Install Completely Submersible SCADA Enclosures

One risk to PG&E's electric distribution network system is that rising tide levels associated with global warming will lead to more flooding of underground vaults containing network equipment. PG&E considered the possibility of installing completely submersible SCADA enclosures to prevent SCADA system components in vaults in San Francisco and Oakland from failing due to saltwater intrusion.

Approximately 40 manholes were already upgraded with submersible SCADA enclosures in or around 2005, leaving 750 additional locations that still need an upgrade. The currently available submersible enclosure is large and heavy and cannot be installed in some vaults because of space constraints; PG&E estimates that there are 710 locations where an installation would be feasible.

PG&E is still in the process of modeling the risk associated with SCADA system component failure since these types of failures do not directly result in loss of power (as would be the case for a transformer failure), but rather the ability to monitor the system real-time, which may result in higher risk of asset failure due to changes in operating conditions. As a result, PG&E has not calculated an RSE for this program. PG&E will continue to evaluate the

- 1 potential for risk reduction from installation of submersible SCADA
 2 enclosures and may present it as a mitigation program in the 2023 GRC.

TABLE 12-9
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026 CAPITAL
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total	RSE	Risk Reduction
1	A1	Install Completely Submersible SCADA Enclosures	\$8,594	\$8,808	\$9,029	\$9,254	\$35,685	(a)	(a)
2		Total	\$8,594	\$8,808	\$9,029	\$9,254	\$35,685		

(a) PG&E is not calculating an RSE or risk reduction score for this program.

Note: See WP 12-1.

2. Alternative Plan 2: M5a – Reduce Proposed Rate of Dry-Type Transformer Replacement

PG&E is proposing the M5 mitigation to replace 22 dry-type network transformers in four high-rise buildings in San Francisco and Oakland over the course of three years. PG&E also considered an alternative mitigation that would have replaced those same transformers, but over a 6-year period (2023-2028) instead of a 3-year period (2023-25). The 6-year program was estimated to be marginally more expensive due to a larger cost escalation impact over the course of the program, resulting in a slightly lower RSE score. Although not currently modeled, PG&E also determined based on past experience with high rise projects that a 6-year program would likely have additional expenses and logistical complexity associated with lengthier labor contracts and installation permits. Ultimately, PG&E concluded that a 3-year program is feasible and that completing the work in three rather than six years is preferable because it will reduce risk more quickly.

TABLE 12-10
FORECAST COSTS, RSE AND RISK REDUCTION
CAPITAL 2023-2026
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	M5a	Reduce Proposed Rate of Dry-Type Transformer Replacement	\$1,977	\$2,152	\$1,597	\$1,672	\$7,398	<0.001	0.002
2		Total	\$1,977	\$2,152	\$1,597	\$1,672	\$7,398		

(a) See MW included in the source document modeling package for information used to calculate the RSE.
Note See WP 12-1.

3. Alternative Plan 3: A3 – Replace Network Transformers Based on Age, Instead of Condition

As part of its regular asset maintenance programs, PG&E monitors the health of the transformers in its electric distribution network system through regular testing (e.g., Dissolved Gas Analysis for oil-filled transformers). This condition-based assessment allows PG&E to make maintenance decisions based on operating conditions (voltage, temperature etc.), which are more significant drivers of transformer operating life than years in service. This alternative mitigation considers the impact of changing from a condition-based replacement program to an age-based asset replacement program for these network transformers.

Switching to an age-based approach would eliminate inspections of transformers below a certain age threshold but would not address the risk of premature failures of “younger” transformers which would have been identified and mitigated as part of a condition-based approach. The incremental risk of these premature failures was estimated as the weighted average of the number of transformers under the age-based replacement threshold and the average failure rate associated with transformers of a given age. On average, PG&E replaces approximately 12 transformers annually under the condition-based replacement program. PG&E assumes the same replacement rate in the age-based replacement scenario, so PG&E would replace 12 transformers annually between 2023-2026, but prioritize units based on age instead of condition. This would reduce

inspection costs by approximately \$2.4 million (the amount spent annually on oil-filled transformer testing) but increase the overall risk of transformer failure by approximately 9.3 percent. PG&E does not consider this trade-off acceptable.

The table below shows the proposed spending and RSE associated with each of PG&E's proposed alternative mitigations for the electric distribution network system.

TABLE 12-11
FORECAST COSTS, RSE AND RISK REDUCTION^(c)
2023-2026
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total(a)	RSE ^(b)	Risk Reduction
1	A3	Replace Network Transformers Based on Age Instead of Condition	<u>\$(2,675)</u>	<u>\$(2,742)</u>	<u>\$(2,810)</u>	<u>\$(2,881)</u>	<u>\$(11,108)</u>	<0.001	<0.001
2		Total	<u>\$(2,675)</u>	<u>\$(2,742)</u>	<u>\$(2,810)</u>	<u>\$(2,881)</u>	<u>\$(11,108)</u>		

(a) Implementing this alternative mitigation would reduce inspection costs for oil-filled transformer testing.

(b) See MW included in the source document modeling package for information used to calculate the RSE.

Note See WP 12-1.

Table 12-12 compares the proposed and alternative mitigation plans.

TABLE 12-12
MITIGATION PLAN ALTERNATIVES ANALYSIS
(THOUSANDS OF DOLLARS)

Line No.	Risk Mitigation Plan	Plan Components ^(a)	Total Expense (2023-2026)	Total Capital (2023-2026) ^(c)	Risk Reduction (NPV) ^(b)	Total Spend (NPV)	RSE
1	Proposed	M4, M5, M6	–	\$152,057	11	\$112,145	0.097
2	Alternative 1	Proposed + A1	–	\$152,057	11	\$112,145	0.097
3	Alternative 2	M4, M6 + M5a	–	\$148,462	11	\$109,173	0.100
4	Alternative 3	Proposed + A3	–	\$140,949	11	\$103,981	0.105

(a) Plan Components refers to the Mitigations described in Sections C, D and E.

(b) Information presented in terms of Net Present Value (NPV) to account for the discounting of benefits.

(c) Plan components include the risk reduction benefits and costs of C1-Network Cable Replacement and Switch Installations.

Note See WP 12-2.

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 13
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN:
LARGE UNCONTROLLED WATER RELEASE

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 13
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN:
LARGE UNCONTROLLED WATER RELEASE

TABLE OF CONTENTS

A. Executive Summary	13-3
1. Risk Overview	13-4
2. Risk Definition	13-6
B. Risk Assessment	13-7
1. Background and Evolution	13-7
2. Risk Bow Tie	13-8
a. Difference from 2017 Risk Bow Tie	13-8
3. Exposure to Risk.....	13-9
4. Tranches	13-10
5. Drivers and Associated Frequency.....	13-11
a. Sub-Drivers	13-14
6. Cross-Cutting Factors	13-15
7. Consequences	13-15
C. Controls and Mitigations	13-19
1. 2017-2019 Controls	13-20
2. 2017-2019 Mitigations	13-22
3. 2017 RAMP Update	13-25
D. 2020-2022 Controls and Mitigation Plan.....	13-26
1. Controls	13-26
2. Mitigations	13-27
E. 2023-2026 Proposed Mitigation Plan	13-29
F. Alternative Analysis	13-33
1. Alternative Plan 1: Internal Erosion Mitigation, Geomembrane Liners...	13-33

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 13
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN:
LARGE UNCONTROLLED WATER RELEASE

TABLE OF CONTENTS
(CONTINUED)

2. Alternative Plan 2: Geosciences Engineering and Risk Research Plan	13-35
3. Alternative Plan 3: PMF Studies	13-36

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 13
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN:
LARGE UNCONTROLLED WATER RELEASE

A. Executive Summary

The Large Uncontrolled Water Release risk represents the potential for a large release of water from one of Pacific Gas and Electric Company's (PG&E or the Company) significant or high hazard dams adversely impacting the public, Company, or federal lands. The drivers for this risk event are flood, seismic, internal erosion, and physical attack. The cross-cutting factors Information Technology (IT) Asset Failure, Cyber Attack, Physical Attack, Records and Information Management, and Emergency Preparedness and Response also impact the risk event. Climate is incorporated into the flood driver through the conservative calculations used.

Exposure to this risk is derived from the 61 PG&E dams classified as high or significant hazards by Federal Energy Regulatory Commission (FERC).¹ The risk model includes approximately 0.015 risk events each year (one event every 67 years). The flood driver accounts for 86 percent of the risk events, seismic accounts for 10 percent, internal erosion accounts for 4 percent, and Physical attack accounts for 0.1 percent of the risk events. PG&E's planned mitigations for 2020-2026 are designed to address these key risk drivers.

Each of PG&E's 61 high and significant hazard dams is its own tranche. While many dams share similar characteristics, each dam is unique, and PG&E evaluates potential risks for each individual dam. Spaulding No. 2, Spaulding No. 3, and Belden Forebay account for 64 percent of the tranche-level risk due to downstream consequences.

¹ The FERC hazard potential classification is a system that categorizes dams according to the degree of adverse incremental consequences of a failure or mis-operation of a dam. The hazard potential classification does not reflect in any way on the current condition of the dam (e.g., safety, structural integrity, flood routing capacity). See Federal Emergency Management Agency (FEMA), Federal Guidelines for Dam Safety, Hazard Potential Classification System for Dams, April 2004, p. 2.

Large Uncontrolled Water Release has the eighth highest 2023 test year (TY) safety score (41) and ninth highest 2023 TY total risk score (70) of PG&E's 12 Risk Assessment and Mitigation Phase (RAMP) risks. PG&E proposes a series of controls and mitigations to address the Large Uncontrolled Water Release risk. The 2020 baseline risk score of 73.0 is expected to improve by 24 percent when the planned mitigations are completed, with a projected 2023 TY baseline risk score of 69.8 and 2026 post-mitigation risk score of 55.9. The Spillway Remediation and Internal Erosion Mitigation programs have the highest Risk Spend Efficiency (RSE) scores and the highest total risk reduction scores.²

**TABLE 13-1
RISK OVERVIEW**

Line No.	Risk Name	Large Uncontrolled Water Release
1	In Scope	High and significant hazard dams per the FERC classification
2	Out of Scope	Low hazard dams, canals, waterways, powerhouses, and other hydroelectric assets
3	Data Quantification Sources ^(a)	<u>Exposure</u> : FERC classifications <u>Flood</u> : Probable Maximum Flood (PMF), Potential Failure Model Analysis (PFMA) <u>Seismic</u> : FERC 2000-year design criterion <u>Internal Erosion</u> : Site specific analyses <u>Financial</u> : Average property values, quantity of structures destroyed, qualitative infrastructure factors, dam restoration costs, power replacement costs <u>Safety</u> : Inundation maps, Emergency Action Plans (EAP), FEMA flood studies
(a) Source documents will be provided with workpapers on July 17, 2020.		

1. Risk Overview

PG&E's water storage and conveyance systems consist of dams, reservoirs, tunnels, canals, flumes, siphons, and penstocks which enable PG&E to store and transport water from runoff and aquifer flows for flexible generation at PG&E's hydro powerhouses. Additionally, the conveyance

² The information presented herein is subject to the limitations described in Chapter 2, Section D.

1 and storage systems are operated to provide water storage and delivery for
2 water conservation, fish and wildlife habitat protection and enhancement,
3 domestic water usage, recreational water requirements, and agricultural
4 water needs.

5 Collectively, the system consists of approximately: 96 reservoirs,
6 73 diversions, 169 dams, 168 miles of canals, 43 miles of flumes, 132 miles
7 of tunnels, 57 miles of pipe (penstocks, siphons, and low head pipes),
8 four miles of natural waterways, and 140,000 acres of fee-owned land.

9 PG&E's Power Generation organization is responsible for managing its
10 hydro portfolio. Within Power Generation, the Dam Safety Program (DSP) is
11 managed by Power Generation's Engineering Department, which is
12 responsible for ensuring the long-term safe and reliable operation of PG&E's
13 dams. PG&E's dams are regulated by both the FERC and the California
14 Department of Water Resource's Division of Safety of Dams (DSOD).

15 PG&E's DSP is aligned with FERC's Owner's DSP guidelines. Due to the
16 potentially catastrophic impact of a dam failure, this risk is overseen by the
17 Safety and Nuclear Oversight committee of PG&E's Board of Directors.

18 PG&E has also established a Dam Safety Advisory Board made up of
19 industry experts who critically evaluate the performance of the DSP.

20 Furthermore, PG&E's recent organizational optimization included expanding
21 the scope of the Nuclear Quality Verification organization to provide support
22 to the entire Generation Organization. PG&E also maintains active
23 membership and involvement with industry groups like the National
24 Hydropower Association and The Centre for Energy Advancement through
25 Technological Innovation. Further, PG&E internally applies lessons learned
26 from events in the industry such as the 2017 Oroville dam spillway incident
27 and the ongoing investigations on the Edenville and Sanford dam failures in
28 Michigan.

29 In addition to planning and implementing actions to maintain dam safety,
30 the DSP implements programs that educate the public about dam and
31 waterway safety hazards; install hazard warning signs through the hydro
32 system; and maintain prevention, preparedness, education, and outreach
33 activities.

1 Power Generation strives to continuously improve its processes, deliver
2 high quality work, and meet and exceed compliance requirements with
3 standards and procedures through its Dam Safety and Asset Management
4 programs. One critical element of the Dam Safety and Asset Management
5 programs is quantification of asset risk. PG&E's Dam Safety team is
6 enhancing its risk tools through implementation of the Vulnerability Index.
7 The Vulnerability Index was developed by the British Columbia Hydro and
8 Power Authority (BC Hydro). The Vulnerability Index, currently in the early
9 stages of development for PG&E, is an innovative risk-informed tool for
10 evaluating dam health, safety, and criticality, was used to support this RAMP
11 Report. Further, as asset risks are identified, PG&E mitigates and controls
12 the risks through: operational changes and restrictions; increased or
13 modified maintenance; monitoring and surveillance; and repair,
14 refurbishment, or replacement projects.

15 FERC and DSOD inspect PG&E's dams every 1-3 years depending on
16 the hazard classification. PG&E complies with federal regulations that
17 require an independent qualified dam safety consultant to perform an
18 inspection of its high and significant hazard dams every 5 years.³ The
19 independent consultant inspection is a comprehensive review of the physical
20 condition of the dam, dam operations, instrumentation, and confirmation of
21 the dam design relative to design-basis floods, seismic events, and static
22 conditions. The inspection also includes a PFMA that postulates ways a
23 dam could fail and provides guidance about monitoring the dams for signs of
24 potential failures. PG&E receives reports following the FERC, DSOD, and
25 independent safety consultant inspections that may include recommended
26 actions to maintain or improve dam safety. PG&E prioritizes and addresses
27 the identified issues.

28 **2. Risk Definition**

29 Given the inherent risk of owning and operating hydro assets, there is a
30 potential for a large uncontrolled water release adversely impacting the
31 public, the Company, or state and federal lands.

3 18 Code of Federal Regulations (CFR) Part 12D.

1 B. Risk Assessment

2 1. Background and Evolution

3 PG&E's 2017 RAMP included a Hydro-System Safety – Dams risk⁴ that
4 is similar to the Large Uncontrolled Water Release included in this 2020
5 RAMP.

6 The 2020 RAMP includes 61 dams, significantly more than the
7 20 highest consequence dams included in the 2017 RAMP. The 20 dams
8 included in the 2017 RAMP were identified by PG&E's dam safety experts
9 based on an assessment of the dams that would have the highest
10 consequences from catastrophic failure. The 61 dams included in the 2020
11 RAMP are all High and Significant Hazard dams, by FERC classification,
12 owned and operated by PG&E.

13 In the 2017 RAMP, PG&E identified three dam failure drivers: seismic,
14 flood, and seepage. A fourth driver, Physical Security, has been added to
15 the 2020 RAMP risk. In the 2020 RAMP, the "seepage" driver is renamed
16 "internal erosion." The frequency of events occurring due to seismic, flood,
17 or internal erosion events is similar in 2020 as it was presented in 2017 with
18 the flood driver being responsible for approximately 86 percent of the
19 potential event occurrences.⁵ PG&E is currently performing probabilistic
20 risk assessment studies in order to add the mis-operation driver to the
21 RAMP model, but the current planned completion is end of year 2021, so
22 the driver will not be available in the 2020 RAMP.

23 PG&E's 2017 RAMP analyses were based on assessments informed by
24 PG&E data, industry data, and Subject Matter Experts (SME). In 2020,
25 PG&E's analysis of its Large Uncontrolled Water Release risk is additionally
26 informed by PMF studies, FERC data, site-specific analyses, inundation
27 zone maps, and FEMA flood studies, as well as PG&E's response to the
28 incident at Oroville Dam which resulted in many of the mitigations proposed
29 in this report.

30 Since the portfolio risk is represented by a sum of the risk of each
31 individual dam failure, and PG&E added 41 dams to this RAMP, the

4 PG&E's RAMP Report, Investigation 17-11-003 (Nov. 30, 2017), Chapter 13.

5 PG&E's 2017 RAMP Report, p. 13-4 to p. 13-6.


aggregated frequency of failure for the portfolio of dams increased compared to the 2017 RAMP, though the risk for each individual dam from the 2017 RAMP is relatively unchanged.

2017 RAMP = 1 failure of high consequence dam per 140 years

2020 RAMP = 1 large uncontrolled water release per 68 years

2. Risk Bow Tie

**FIGURE 13-1
RISK BOW TIE**



a. Difference from 2017 Risk Bow Tie

PG&E's use of the bow tie has evolved to better show the conceptual information that informs the results of the risk modeling. Each driver has an initiating event frequency as shown on the left side of the bow tie. As shown in the source documents referenced in WP 13-3, each dam is given a catastrophic failure likelihood for each driver expressed as a percent; combining the driver frequency by the failure likelihood results in the catastrophic failure frequency. The catastrophic failure likelihood considers characteristics of the dam. As an example, if the dam is known to have additional spillway freeboard over the flow required for the PMF, then the catastrophic failure likelihood would be used to decrease the probability of catastrophic failure of the dam as it would be expected to withstand the initiating event. Alternatively, if a dam has a known deficiency that would impact its capability to withstand the initiating event, the catastrophic failure likelihood would be used to increase the probability of catastrophic failure. For example, if a dam

had no additional freeboard over the PMF and a known condition affecting its capability to pass water through the spillway, the catastrophic failure likelihood would be over 100 percent.

3. Exposure to Risk

The assets in scope for PG&E's 2020 RAMP risk Large Uncontrolled Water Release are the 61 PG&E dams⁶ classified as high or significant hazard dams per FERC. Expanding the list of dams to the entire portfolio of high and significant hazard dams greatly improves PG&E's ability to compare and rank each dam's risk. Further, it reduces uncertainty as dams with similar consequences and features can be compared to ensure outcomes are commensurate.

FERC defines a significant hazard potential as:

...those dams where failure or mis-operation results in no probable loss of human life but can cause economic loss, environmental damage, disruption of lifeline facilities, or can impact other concerns. Significant hazard potential classification dams are often located in predominantly rural or agricultural areas but could be located in areas with population and significant infrastructure.⁷

FERC defines a high hazard potential as, "...those where failure or mis-operation will probably cause loss of human life."⁸

The DSOD classifies the downstream hazard potential of all state jurisdictional dams based on a sunny-day loading condition. Significant hazard potential is defined as:

[N]o probable loss of human life but can cause economic loss, environmental damage, impacts to critical facilities, or other significant impacts.

High hazard potential is defined as, "[e]xpected to cause loss of at least one human life." Extreme high hazard potential is defined as:

[E]xpected to cause loss of at least one human life and one of the following: [r]esult in an inundation of at least 1000 persons or more, or [r]esult in the inundation of facilities or infrastructure, the inundation of

⁶ The 61 dams in scope are listed in supporting workpapers. See WP 13-3.

⁷ FEMA, Federal Guidelines for Dam Safety, Hazard Potential Classification System for Dams, April 2004, p. 5.

⁸ FEMA, Federal Guidelines for Dam Safety, Hazard Potential Classification System for Dams, April 2004, p. 6.

which poses a significant threat to public safety as determined by the department on a case-by-case basis.⁹

DSOD's extremely high and high hazard classifications are effectively subdivisions of the high hazard classification used by FERC.

The DSP implements measures to manage and reduce the risks of owning and operating PG&E's dams. In addition to well-established regulatory driven deterministic approaches for evaluating the safety of dams, PG&E has undertaken many initiatives to better understand and quantify drivers, dam health, and potential outcomes to a catastrophic dam failure. Data sources used in the 2020 RAMP model include information collected during:

- Routine observations by trained Hydro operations and maintenance (O&M) personnel;
- Regular inspections by qualified engineers in PG&E's DSP;
- Regular inspections by the FERC and DSOD;
- 5-year Independent Consultant Safety Inspections in accordance with 18 CFR Part 12D;
- Environmental assessments of each site; and
- Engineering evaluations of dam stability, seismicity, spillway design capacity, and other design and operational issues as conditions and engineering guidelines evolve.

4. Tranches

PG&E identified 61 tranches for the Large Uncontrolled Water Release risk. Each of PG&E's 61 high and significant hazard dams is its own tranche. While many dams share similar characteristics, each dam is unique, and PG&E evaluates potential risks for each individual dam. In a few instances, a dam failure may result in flows that could fail a downstream dam, known as a cascading dam failure, in which case the failure of the upstream dam includes the impact of failure of the downstream dam. Including in these instances, each dam is modeled independently and the model features dam-specific driver and consequence data. The aggregated bow tie combines the modeled results of all the dam failures, though dam

⁹ California Code of Regulations, § 335.4, Section (a).

failures are independent events with the exception of cascading failures. A list of the 61 dams, its FERC and DSOD classifications, dam type and location is included in supporting workpapers.¹⁰

Table 13-2 shows the tranche-level results of the risk analysis for the top 10 tranches based on total risk score.

**TABLE 13-2
TRANCHE LEVEL RISK ANALYSIS RESULTS**

Line No.	Tranche	Percent Exposure	Safety Risk Score	Financial Risk Score	Total Risk Score	Percent of Total Risk
1	Spaulding No. 2	1.6%	7.05	15.43	22.48	32%
2	Spaulding No. 3	1.6%	3.51	7.68	11.19	16%
3	Belden Forebay	1.6%	10.92	0.20	11.12	16%
4	Fordyce	1.6%	1.21	2.35	3.56	5%
5	Spaulding No. 1	1.6%	1.16	1.66	2.82	4%
6	Salt Springs	1.6%	2.32	0.32	2.63	4%
7	McCloud	1.6%	2.45	0.12	2.57	4%
8	Bucks Lake (Storage)	1.6%	1.55	0.03	1.58	2%
9	Pit 5 Open Conduit	1.6%	1.38	0.01	1.40	2%
10	Pit 3	1.6%	0.93	0.04	0.97	1%
11	All Remaining Dams	84%	8.98	0.53	9.51	14%
12	Total	100%	41.46	28.37	69.82	100%

5. Drivers and Associated Frequency

PG&E identified four drivers and two sub-drivers for the Large Uncontrolled Water Release risk. Each driver and its associated 2023 TY baseline frequency is discussed below.

D1 – Flood: Flooding typically occurs as a result of heavy rain or snowmelt, or a combination of rain on snow. Equipment failure or sudden releases from upstream water control structures can also lead to flooding. Weather-related flooding events typically are easier to predict in the short term and are managed through the use of reservoir storage, releases through spillways and outlets, and coordinating high flow events with upstream and downstream dam operators. The risk model uses historic flow data that PG&E maintains for each dam to develop index-level flood frequency data combined with the deterministic Probable Maximum Precipitation/Probable Maximum Flood (PMP/PMF) analyses and rated

¹⁰ See WP 13-3.

1 spillway capacity to estimate the frequency of a flood that would exceed
2 each dam's capacity to safely pass a flood event. Climate change data is
3 inherently included in this driver as the PMP/PMF calculations consider
4 trends in recent and historical precipitation and flood data. The analyses
5 resulted in a cumulative likelihood of a catastrophic dam failure for all
6 61 high and significant hazard dams as of one possible event in 77 years.
7 Flood accounted for 0.013 (86 percent) of the 0.015 expected annual
8 number of events.

9 **D2 – Seismic:** Due to the nature of seismic events, the precise size,
10 location, and timing of earthquakes cannot be predicted. PG&E is in the
11 process of moving towards quantification of the seismic risk. In this report,
12 different methods are used for calculation of the seismic risk for concrete
13 and embankment dams.

14 In calculating seismic risk for concrete dams, the seismic risk model
15 (developed outside of the RAMP's operational risk model and used as input
16 to the RAMP operational risk model) is based on an underlying assumption
17 that, on average, the deterministic ground motions currently used to
18 evaluate PG&E's dams conservatively equate to approximately a 2000-year
19 seismic event recurrence interval. Based on the residual stability of the
20 structure evaluated for that deterministic event, a subjective catastrophic
21 failure factor was applied to determine the likelihood of a seismic induced
22 failure. Dam structures with higher residual stability received a higher
23 subjective factor; whereas, structures just meeting or near guidelines were
24 given a factor of 1.0 or no change from the 2000-year base event frequency.

25 In calculating the seismic risk for embankment dams, the seismic risk
26 model uses the entire seismic hazard curve, which defines the probability of
27 exceeding a specific ground motion level. For a given ground motion
28 loading level, the response of the embankment dam is modeled by a
29 simplified numerical model that computes the expected deformation. This
30 deformation is then related to a probability of failure using fragility curves
31 based on the relative deformation of the dam or the residual freeboard.
32 Annual failure rates are then computed by considering the probability of
33 failure over the entire range of loading levels. Additionally, uncertainty in

analysis (ground motion, dam response, analytical model, and fragility) are considered.

The aggregate evaluation of the portfolio of 61 dams resulted in an average likelihood that one seismic event with the potential to cause dam failure could occur every 714 years. Seismic events accounted for 0.0014 (10 percent) of the 0.015 expected annual number of events.

D3 – Internal Erosion (formerly Seepage): All dams experience seepage, which is water migration through the dam and can occur through pore spaces, cracks, and joints in the dam structure, foundation, and abutments. Seepage is a normal occurrence and typically presents little or no risk to the integrity of the dam. However, seepage that is not properly managed or controlled can lead to internal erosion potentially resulting in progressive, catastrophic dam failure. For the earthfill dams, the estimated frequency of such failures is based on the Association of State Dam Safety Officials (ASDSO) Dam Safety Incidents Database filtered for recent failures resulting from internal or foundation/abutment erosion.¹¹ For the rockfill dams, the failure probability was determined by extrapolating the results of a Probabilistic Risk Assessment performed for Fordyce Dam. In general, the rockfill dams are less likely to fail due to internal erosion than earthfill dams. Concrete dams rarely, if ever, fail due to excessive internal erosion and, as a result, these dams do not contribute to the frequency of this driver. Climate change data impacting this driver is not included in the model. Cyclical or rapid environmental temperature changes can worsen the condition of concrete and other protective features of dams, but data to support trending of such temperature changes was not available. The aggregate evaluation of the portfolio of 61 dams resulted in an average likelihood that one internal erosion initiating event with the potential to cause dam failure could occur every 1,667 years. Internal erosion events

¹¹ The ASDSO Dam Safety Incident Database (damsafety.org/incidents) provides basic information on dam safety incidents and lists the incident driver among other information. Review of the database showed a significant increase in the number of events reported starting in 2008 with 2018 being the last complete year in the dataset at the time of the analysis. For the 11 years of data, failures were filtered for those resulting from internal or foundation/abutment erosion to develop an annual failure rate for this driver.

accounted for 0.0006 (4 percent) of the 0.015 expected annual number of events.

D4 – Physical Attack: PG&E implements the hydropower security program in compliance with FERC guidance.¹² Controls and mitigations PG&E has in place or plans to enact are sensitive in nature and are not discussed or credited in this report. After assessing the quantification data for frequency, there are no instances of a dam failure driven by Physical Attack in the United States. Combining data from the Department of Homeland Security¹³ and a recent study by the United States Society of Dams¹⁴ with the assumption that the next dam attacked would result in dam failure gives an event frequency of once per 4.4 million years. Physical Attack events accounted for 0.00001 (0.1 percent) of the 0.015 expected annual number of events.

a. Sub-Drivers

SD1 – Information Technology Asset Failure: An IT asset failure coincident with conditions that cause a risk event (Flood, Seismic, Internal Erosion, Physical Attack) will increase the likelihood that a catastrophic outcome will occur. Critical System Availability goals are 99.9 percent and IT has mapped 39 asset categories to the dam failure risk. This results in an estimated frequency of IT asset failure to be one in 26 years.

SD2 – Cyber Attack: A cyber attack coincident with conditions that cause a risk event (Flood, Seismic, Internal Erosion, Physical Attack) will increase the likelihood that a catastrophic outcome will occur.

A sunny-day cyber attack has the potential to put recreators

¹² FERC: Division of Dam Safety and Inspections FERC Security Program for Hydropower Projects, Revision 3A. March 30, 2016. <https://www.ferc.gov/industries/hydropower/safety/guidelines/security/security.pdf>. (as of June 17, 2020).

¹³ Worldwide Attacks Against Dams: A Historical Threat Resource for Owners and Operators. 2012. <https://damfailures.org/wp-content/uploads/2019/04/Worldwide-Attacks-Against-Dams.pdf>. (as of June 17, 2020).

¹⁴ Next Generation of Dam Safety and Security Frameworks: A Big Picture. Fall 2019. <https://www.ussdams.org/wp-content/uploads/2019/10/Fall-2019-for-web.pdf>. (as of June 17, 2020)

downstream of a dam at risk, however this risk event is excluded from this risk as the outcome would be significantly lower than the catastrophic dam failure modeled by this risk. Power Generation has controls in place to prevent this event; beyond controls in the IT systems, instruments measuring component status and flow would alert operators to components out of alignment. Further, at some watersheds, physical device controls are in place during recreation preventing incidental movement and some components also cannot be operated remotely. For either event, the frequency of a cyber attack event is estimated to be one in 280 years.

6. Cross-Cutting Factors

A cross-cutting factor is a driver or control that is interrelated to multiple risks. PG&E is presenting eight cross-cutting factors in the 2020 RAMP. The cross-cutting factors that impact the Large Uncontrolled Water Release risk are shown in Table 13-3 below and described above in Section B.5. A description of the cross-cutting factors and the mitigations and controls that PG&E is proposing to mitigate the cross-cutting factors are described in Chapter 20.

**TABLE 13-3
CROSS-CUTTING FACTORS SUMMARY**

Line No.	Cross-Cutting Risk	Impacts Likelihood	Impacts Consequence
1	Climate Resilience	X ^(a)	—
2	Cyber Attack	X	—
3	Emergency Preparedness and Response	—	X
4	IT Asset Failure	X	—
5	Physical Attack	X	—
6	Records and Information Management	—	X
7	Seismic	X ^(b)	—

(a) Climate impacts are inherently captured in the PMF studies.

(b) Seismic events are included as an inherent driver.

7. Consequences

In developing consequence inputs, PG&E relied on PG&E inundation maps included in the EAP to analyze the consequences of the Large Uncontrolled Water Release risk. The inundations maps provide areas of

1 expected impact in the event of a dam failure based on FERC and DSOD
 2 guidelines. The data used to evaluate this risk was supported by PG&E
 3 SME judgement. The PG&E SMEs used up to date dam-specific
 4 inspections, technical documents, and industry data to estimate driver,
 5 mitigation, and consequence model data.

6 Safety: Fatality severity distribution was derived by applying the results
 7 of the Dekay-McClelland empirical method¹⁵ with the variables of
 8 Population at Risk (PAR), force of water (Fd), and warning time (Wt)
 9 developed for each dam. PAR was determined by counting the number of
 10 structures within the inundation zone from the flood maps for each dam and
 11 estimating one person per structure: Fd is a binary value of “0” or “1” that
 12 was defined as “1” when a structure was less than 30 minutes from the
 13 expected time of inundation after dam failure; and Wt is measured in hours
 14 and assumed to be equivalent to the front of the inundation wave arrival time
 15 derived from the inundation maps for each high consequence dam. The
 16 result of each dam-specific calculation is used to create a distribution
 17 sample for the fatality severity input to the RAMP model for the quantity of
 18 fatalities occurring in the event of dam failure. To estimate the number of
 19 injuries that could result from a catastrophic failure at each dam, as the
 20 Dekay-McClelland empirical method does not have a value for injury, PG&E
 21 applied a ratio of 1.87 injuries per fatality based on the National Oceanic and
 22 Atmospheric Administration flood data for California. Based on these safety
 23 consequence inputs and the likelihood of the risk event at each dam, the
 24 model results show a portfolio average annualized safety consequence of
 25 0.13 equivalent fatalities expected per year.

26 Reliability: The impact to the electric grid resulting from a catastrophic
 27 dam failure is expected to be negligible because in most cases, the
 28 generation can be replaced quickly, and the homes of customers directly
 29 impacted by the inundation would be uninhabitable. Thus, the impact of the
 30 loss of generation from powerhouses in the inundation zones is included in

¹⁵ Dekay, Michael L., and McClelland, Gary H., “Predicting Loss of Life in Cases of Dam Failure and Flash Floods” 1993.

1 the Financial consequence as it does not fit the units provided in the
2 Multi-Attribute Value Function attributes for reliability.

3 Environmental: Impact to the environment due to a catastrophic dam
4 failure is included with the Financial consequence. Factors considered for
5 determining the environmental costs included the cost of clean-up and
6 remediation, which would vary based on the amount of water released, soil
7 displacement, and the duration of clean-up.

8 Financial: PG&E relied on average home prices, number of structures
9 damaged, infrastructure factors, expected dam restoration costs, and loss of
10 generation estimates to determine financial impacts. Specifically, PG&E
11 counted the number of structures inundated and estimated that 50 percent
12 of the expected average property value would be the cost necessary to
13 repair the damage. Dam restoration cost was estimated using dam size and
14 type and reservoir size as variables with an escalation factor applied.
15 Lastly, an infrastructure factor was applied to the property damage to
16 consider the cost of damages to roads, powerlines, and other infrastructure.
17 To capture the reliability impacts of dam failure, power replacement costs
18 from each powerhouse in the inundation zone of each dam is also included
19 in the financial impact. The aggregated model results provide a baseline
20 financial impact of dam failure at \$8.0 million per year.

21 Consequences of this risk event are shown in Table 13-4 below. Model
22 attributes are described in Chapter 3, "Risk Modeling and Risk Spend
23 Efficiency."

TABLE 13-4
RISK EVENT CONSEQUENCES

	CoRE %Freq 100% %Risk			Natural Units Per Event		CoRE		Natural Units per Year		Attribute Risk Score	
				Safety EF/event	Financial \$/event	Safety	Financial	Safety EF/yr	Financial \$/yr	Safety	Financial
Aggregated	4,739	100%	100%	8.8	544.9	2,814	1,925	0.13	8.0	41	28.4
Aggregated	4,739	100%	100%	8.8	544.9	2,814	1,925	0.13	8.0	41	28.4

1 C. Controls and Mitigations

2 Tables 13-5 and 13-6 list all the controls and mitigations PG&E included in
 3 its 2017 RAMP, 2020 General Rate Case (GRC), and 2020 RAMP (2020-2022
 4 and 2023-2026). The tables provide a view as to those controls and mitigations
 5 that are ongoing, those that are no longer in place or completed, and new
 6 mitigations. In the following sections, PG&E describes the controls
 7 and mitigations in place in 2019, changes to the 2019 mitigations and controls
 8 presented in the 2017 RAMP, and then discusses new mitigations and
 9 significant changes to mitigations or controls during the 2020-2022 and
 10 2023-2026 periods.

**TABLE 13-5
CONTROLS SUMMARY**

Line No.	Control Name and Number	2017 RAMP Controls	2020-2022 GRC Controls	2020-2022 RAMP Controls	2023-2026 RAMP Controls
1	C1 – Hydro Operations Maintenance	X	X	Incorporated in C5	
2	C2 – Facility Safety Inspections	X	X	Incorporated in C5	
3	C3 – FERC and DSOD Inspections	X	X	Incorporated in C5	
4	C4 – Part 12D Inspections and Follow-Up	X	X	Incorporated in C5	
5	C5 – DSP	X	X	X	X

**TABLE 13-6
MITIGATIONS SUMMARY**

Line No.	Mitigation and Number	2017 RAMP Mitigations	2020-2022 GRC 2017-2020 Mitigations	2020-2022 RAMP Mitigations	2023-2026 RAMP Mitigations
1	M1 – Internal Erosion Mitigations	X	X	X	X
2	M1a – Lake Fordyce Dam	X	X	X	X
3	M1b – Main Strawberry Dam	X	X	X	X
4	M1c – Relief Dam	X	X		
5	M1d – Courtright Dam	X	X		
6	M2 – Spillway Remediations			X	X
7	M2a – Scott Dam	X	X	X	
8	M2b – Belden Dam	X	X	X	X
9	M2c – Salt Springs Dam	X	X	X	
10	M3 – Seismic Retrofit	X	X	X	X
11	M3a – Crane Valley Intake Tower	X	X	X	
12	M4 – Low-Level Outlet (LLO) Refurbishments	X	X	X	X
13	M4a – Pit 1 Forebay	X	X	X	
14	M4b – Relief Dam	X	X		
15	M4c – Spaulding Dam	X	X		
16	M4d – Lake Almanor	X	X	X	
17	M5 – Internal Erosion Mitigations	X	X	X	X

1. 2017-2019 Controls

The five 2017-2019 controls address overall dam safety, including the three RAMP risk drivers, flood, seepage (internal erosion), and seismic. The five 2017-2019 controls were previously separate elements of the DSP and have been combined into the single DSP control for the years 2020 and beyond.

C1 – Hydro O&M: Trained O&M personnel routinely observe dams. These personnel are stationed in the watersheds where the PG&E dams are located. During regular visits to the dams, the O&M personnel perform visual observations of the dams, collect monitoring data, and report any changed or unusual conditions that could potentially impact dam safety or PG&E's ability to operate the facility's spillways and outlet structures.

1 **C2 – Facility Safety Inspections:** Facility safety engineers perform
2 inspections of PG&E's dams at an interval between annually to triennially,
3 depending on the size and hazard classifications of each dam. These
4 inspections identify any unusual conditions that may affect dam safety and
5 develop responses to those conditions to ensure safe and reliable operation.
6 The dam safety engineers also review monitoring data for each high and
7 significant hazard dam whenever readings are above threshold levels or as
8 part of the Dam Safety Surveillance and Monitoring Plan/Report that is
9 prepared annually. PG&E's Chief Dam Safety Engineer (CDSE) supervises
10 the work performed by the facilities safety engineers. PG&E uses
11 consultants who have expertise in dam safety to perform evaluations and
12 studies that support the facility's safety inspections and follow-up activities
13 when issues arise to augment its internal inspection efforts.

14 **C3 – FERC and DSOD Inspections:** FERC and DSOD engineers inspect
15 PG&E's dams at an interval of annually to triennially, depending on the
16 dams' DSOD and FERC hazard classifications. These agencies provide
17 inspection reports that include observations, recommendations, and
18 requirements to address issues that are identified. PG&E addresses issues
19 documented in these inspections and communicates with the regulators to
20 fulfill requirements and expectations.

21 **C4 – Part 12 D Inspections and Follow-Up:** 18 CFR Part 12D requires an
22 independent consultant to perform a safety inspection every five years. This
23 inspection is a comprehensive review of the physical condition of the dam,
24 dam operations, and confirmation of the dam design relative to design-basis
25 floods, seismic events, and static conditions. This process also includes a
26 PFMA that takes a comprehensive look at ways a dam could fail and guides
27 monitoring observations to focus on signs of the potential failure modes in
28 addition to the overall observations. PG&E has implemented the Part 12D
29 inspections as required and maintains and tracks completion of
30 recommendations from those inspections.

31 **C5 –DSP:** PG&E's CDSE is responsible for implementing the DSP. The
32 DSP includes measures to reduce the risks of owning and operating a dam.
33 FERC establishes guidelines for the DSP. PG&E's DSP exceeds FERC
34 guidelines for an Owner's DSP by employing an independent panel of

experts, the Dam Safety Advisory Board, to audit the DSP and to advise on dam safety issues. For complex dam safety issues, a Board of Consultants may be convened to opine and advise on issues and help guide PG&E's actions to address those issues.

2. 2017-2019 Mitigations

M1 – Seepage Mitigation Projects: Multiple seepage mitigation projects began in 2017-2019. Seepage mitigation projects addressed the internal erosion risk driver.

M1a – Fordyce Dam: The major seepage mitigation project commenced on Fordyce dam in 2016 will continue through 2023. This mitigation will address seepage through the upstream toe of this rockfill concrete face dam by installation of a geomembrane liner. The major capital investment work began in 2018 with another significant increase in spend in 2020-2023 as the foundational project work completes and the geomembrane installation begins.

M1b – Main Strawberry Dam: Repeated freeze and thaw on the Main Strawberry Dam face have degraded the concrete face and exposed reinforcing steel through excessive spalling. Spalling is addressed by removing and replacing damaged sections of spalled concrete. This multi-year project began in January 2017 and is expected to continue through 2024. The capital cost projections are flat as the work for each year is standard concrete restoration work and often repeated throughout the industry.

M1c – Relief Dam: Relief Dam is in a similar condition to Main Strawberry Dam due to freeze-thaw cycles. The project was delayed in 2017 and an alternative analysis is ongoing.

M1d – Courtright Dam: Cracks and spalling of various concrete joints were present in the Courtright Dam face as a result of compression caused by dam settlement. The project was further evaluated and determined to not be necessary.

M2 – Spillway Remediation and Improvement Projects: PG&E continues to engage with regulators and the industry in the combined response to the incident at Oroville Dam. The projects below were included in PG&E's 2017-2019 plans and did not include a response to Oroville Dam as

1 investigations were still ongoing. Spillway remediation and improvement
2 projects address the flood risk driver.

3 **M2a – Scott Dam:** Projects were planned at Scott Dam to remediate
4 spillways. The remediations were recommended in the 18 CFR Part 12
5 Independent Consultant Inspection report. In response to the
6 recommendations, PG&E made structural modifications and is in the
7 process of designing, procuring, and installing one mobile self-contained
8 radial gate hoist. This project is scheduled to complete by the end of
9 2020.

10 **M2b – Belden Dam:** PG&E found cracking along the base of a wall
11 panel on the Belden Spillway during unrelated excavation work.
12 Subsequent analysis found that the crack was likely caused by
13 overstress as a result of oversaturated soil surrounding the spillway
14 chute wall causing the wall to deflect inwards from the original
15 constructed position. Two potential plans to address the problem were
16 evaluated: (1) construct a cantilevered reinforced concrete retaining
17 wall extending away from the chute; or (2) construct a reinforced
18 concrete retaining wall with an anchor block element and vertical
19 post-tensioned corrosion protected anchors. PG&E further evaluated
20 these conditions in 2018 to determine which method would best address
21 the spillway base cracking. As a result of this evaluation, PG&E
22 determined the spillway had insufficient capacity based on the current
23 PMF. PG&E has hired a consultant to further advance the PMF
24 analyses and determine the final design needed for the spillway. This
25 mitigation is included in the updated 2023-2026 quantified spillway
26 mitigations.

27 **M2c – Salt Springs Dam:** By November 2019, PG&E replaced the
28 seals on all 13 radial gates at Salt Springs were replaced and repainted
29 the gates. This mitigation has been completed.

30 **M3 – Seismic Retrofit:** The seismic retrofit planned for the Crane Valley
31 Project intake tower will begin in 2022. The seismic retrofit mitigations
32 address the seismic risk driver.

33 **M3a – Crane Valley Intake Tower:** The intake tower at Crane Valley
34 services both the powerhouse and the LLO. It was identified during the

2014 Independent Consultant Safety Inspection at the Crane Valley Project that the intake tower had not been evaluated using current seismic analysis methods. PG&E performed an updated analysis and determined that the intake tower is vulnerable to a brittle shear failure at either the construction joint near elevation 3,321 feet or at elevation 3,333 feet above the location where the diagonal struts connect to the main tower. PG&E's DSP engineers determined that designs provided by the original vendor in 2019 were unacceptable. A new vendor has been selected, but this has resulted in delays to implementing the project. This mitigation is now planned to be included by 2022 and is included in this RAMP Report.

M4 – LLO Refurbishments: Pit 1 LLO and radial gate retrofit, initiated as part of a FERC recommendation, Relief Dam LLO bevel gear replacements, and dredging in Spaulding Dam were planned to ensure reliable operation of the LLOs at these three dams. LLO refurbishments address the seismic and internal erosion risk drivers.

M4a – Pit 1 Forebay: During the work originally scheduled for completion by 2019, it was determined the valve needed a new actuator to ensure reliable operation. In order to procure and install a new actuator, this project was extended through 2020 and is included in this RAMP Report.

M4b – Relief Dam: Replacement of the bevel gears described in the previous section was completed by the end of 2017.

M4c – Spaulding Dam: After completing some dredging at Spaulding Dam in 2016 and 2017, additional dredging was determined to not be necessary.

M4d – Lake Almanor: As PG&E identified in its 2020 GRC testimony, additional work was determined to be necessary to complete this mitigation.¹⁶ The project is still on track to complete in 2021 and is included in this RAMP Report.

¹⁶ Application 18-12-009, Exhibit (PG&E-5), p. 2-13, Lines 16-26.

3. 2017 RAMP Update

In the 2017 RAMP, PG&E proposed five controls including Control C5, DSP. PG&E will continue to implement the DSP and the work previously conducted as part of controls C1, C2, C3, and C4 will be incorporated into C5 in 2020 and beyond.

In the 2017 RAMP, PG&E proposed four types of mitigations with individual projects assigned to each type.

M1 – Seepage Mitigations: PG&E proposed four seepage mitigation projects.

M1a – Fordyce Dam: Design and preconstruction efforts for the installation of a geomembrane liner were underway as of 2019.

M1b – Main Strawberry Dam: The work to remove damaged sections of spalled concrete proceeded as planned during the 2017-2019 period.

M1c – Relief Dam: The work to remove damaged sections of spalled concrete was delayed and an alternative analysis is being performed.

M1d – Courtright Dam: PG&E evaluated the plan to address cracks and remove and replace spalled concrete sections. The project was cancelled based on the results of the evaluation.

M2 –Spillway Mitigations: PG&E proposed three spillway mitigation projects.

M2a – Scott Dam: Modification of the radial gates proceeded as planned. Structural modifications have been implemented and PG&E will install a mobile self-contained radial gate hoist by the end of 2020.

M2b – Belden Dam: PG&E has repaired joints, performed inflow design flood analysis and patched concrete. PG&E continues to evaluate the design of the spillway and plans to complete this project by 2024. This mitigation is included in the updated 2023-2026 quantified spillway mitigations.

M2c – Salt Springs Dam: PG&E completed replacement of 13 radial gates between 2017 and 2019. The project was expedited and is complete.

M3 – Seismic Mitigations: PG&E proposed one seismic mitigation project, the Crane Valley Intake Tower Seismic Retrofit. In 2019, the selected vendor delivered a design that PG&E's DSP engineers deemed

unacceptable. PG&E selected a replacement vendor for this project, which has delayed the completion of the project until 2020.

M4 – LLO Refurbishments: PG&E proposed four LLO refurbishment projects.

M4a – Pit 1 Forebay: PG&E completed painting the gate and replacing seals. PG&E identified the need for a new actuator and the project completion date was extended through 2020.

M4b – Relief Dam: The project to replace bevel gears proceeded as planned and was completed in 2017.

M4c – Spaulding Dam: Project deemed unnecessary after initial dredging in 2016 and 2017 and planned further dredging was cancelled.

M4d – Lake Almanor: The project to replace the LLO gates was rescope in 2018 and is now projected to be complete in 2021.

D. 2020-2022 Controls and Mitigation Plan

1. Controls

PG&E will continue to implement the DSP and the work previously conducted as part of controls C1, C2, C3, and C4 will be incorporated into C5. The scope of the DSP is unchanged from 2017 and defined as:

C5 – Dam Safety Program: The primary responsibility of PG&E's DSP is continual long-term safe and reliable operation of PG&E owned dams, which is achieved by:

- Implementing inspections and programs to protect the public and the Company's assets through overall management of dam safety risks, including: O&M inspections; annual Dam Safety Inspections; annual FERC and DSOD inspections, 5-year Independent Consultant Inspections; public safety programs; EAP programs; and operations reviews programs.
- Maintaining a well-trained and resourced organization with a primary focus on public and employee safety as well as compliance with FERC and DSOD requirements;
- Clear communication of policies and expectations regarding dam safety and regulatory compliance to all DSP team members, O&M personnel,

and other stakeholders focused on maintaining and reducing the inherent risk in operating a dam;

- Defined protocols for communicating and reporting dam safety issues to aid in ensuring public safety and allowing the regulators to stay informed of PG&E’s hydro assets; and
- Defining the responsibilities and authority of the CDSE to be accountable for achieving dam safety with support from PG&E’s senior leadership.

2. Mitigations

PG&E is proposing four types of mitigations for the 2020-2022 period: Spillway Remediations; Seismic Retrofits; Internal Erosion Mitigations; and LLO Refurbishments. A list of projects by mitigation is included in supporting workpapers.¹⁷

M1 – Internal Erosion Mitigations: Excessive internal erosion through concrete face rockfill dams and earthfill dams can lead to a potential piping of finer grained materials through a dam with graded materials. For rockfill dams, this erosion is more likely with “dirty” rockfill dams (those with a larger quantity of finer grained materials between the rocks) and typically develops from cracking and deterioration of the concrete face or other anomalies in the seepage barrier that form due to dam settlement and allow water to pass through the dam. When this seepage becomes excessive, it can cause migration of finer materials creating voids that can eventually lead to a failure of the dam. Internal erosion mitigations address the driver through three primary methods—repairing or sealing cracks and joints in the upstream face, restoring spalled concrete and grouting, or less commonly, providing a new liner or water barrier partially or fully covering the upstream face. Repairing and sealing cracks and joints and restoring spalled concrete are the primary methods common both in the industry and to PG&E as proven methods effective at reducing internal erosion.

Installing a geomembrane liner is a longer-term resolution whereas the joint repairs and concrete patching typically deteriorate over a few years and require continual maintenance and re-application. However, a potential

¹⁷ See WP 13-4.

1 major cost impact of installing geomembrane liners could result from
2 additional work to install a cutoff at the toe of the dam to alleviate differential
3 hydraulic pressure in the dam created by installing the liner. Excessive
4 hydraulic pressure differential could exacerbate internal erosion. PG&E
5 measures the effectiveness of the mitigation and need for additional
6 maintenance or re-application through visual inspection of flow through the
7 downstream toe of each dam and downstream flow instrumentation. PG&E
8 is planning five internal erosion mitigation projects. The complete list of
9 internal erosion mitigation projects is provided in the supporting workpapers.

10 **M2 – Spillway Remediations:** This mitigation category ensures spillways
11 and necessary components in the spillway are available to control flow,
12 particularly during high reservoir level or other high-water flow events
13 including the flood risk driver. PG&E has categorized 43 projects as
14 spillway remediations between 2020 and 2022. The complete list of spillway
15 remediation projects is included in supporting workpapers.¹⁸

16 **M3 – Seismic Retrofits:** This mitigation category is for projects that ensure
17 the robustness of dams and reliability of components of dams after
18 postulated major seismic events. The Crane Valley Dam intake tower
19 project was included in the 2017 RAMP but the scheduled end date has
20 been extended from 2020-2022. The scope of work for this mitigation has
21 not changed. As the Crane Valley Dam intake tower project ensures
22 reliability of an LLO during a postulated seismic event, the modeling has
23 been updated to mitigate both the seismic and internal erosion drivers.
24 Further PG&E has identified radial gates requiring seismic retrofits; these
25 projects mitigate the flood driver as they ensure the reliability of radial gates
26 which are used to control flow during floods that may occur coincident with
27 or shortly after a seismic event. PG&E will conduct six seismic retrofit
28 projects. The complete list of seismic retrofit projects is included in
29 supporting workpapers.

30 **M4 – LLO Refurbishments:** Although LLOs will not directly mitigate the
31 three major drivers, maintaining reliable operation of these features is critical
32 to safely relieving the water loading on a dam during or after a seismic or

18 WP 13-4.

internal seepage event to potentially prevent a more catastrophic failure.
 PG&E has categorized eight LLO Refurbishments between 2020 and 2023.
 The complete list of LLO refurbishment projects is included in supporting
 workpapers.

Tables 13-7 and 13-8 below shows the estimated costs for the mitigation
 work planned from 2020-2022.

**TABLE 13-7
 FORECAST COSTS
 2020-2022 EXPENSE
 (THOUSANDS OF DOLLARS)**

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	Total
1	M1	Internal Erosion Mitigations	AXR	\$1,050	\$829	–	\$1,879
2	M2	Spillway Remediations	AXR	5,714	6,286	2,345	14,345
3	M4	LLO Refurbishments	AXR	50	–	–	50
4		Total		\$6,814	\$7,115	\$2,345	\$16,274

Note: See WP 13-1.

**TABLE 13-8
 FORECAST COSTS
 2020-2022
 (THOUSANDS OF DOLLARS)**

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	Total
1	M1	Internal Erosion Mitigations	2LR, 2NR	\$4,174	\$16,903	\$17,628	\$38,705
2	M2	Spillway Remediations	2LR, 2NR	4,033	19,802	42,059	65,893
3	M3	Seismic Retrofits	2LR	12,780	3,707	10,507	26,995
4	M4	LLO Refurbishments	2LR, 2NR	9,818	4,063	6,279	20,160
5		Total		\$30,805	\$44,474	\$76,474	\$151,753

Note: See WP 13-1.

E. 2023-2026 Proposed Mitigation Plan

PG&E is proposing four types of mitigations for the 2023-2026 period:
 internal erosion mitigations, spillway remediations, seismic retrofits, and LLO

1 refurbishments. A list of projects by mitigation is included in supporting
2 workpapers.¹⁹

3 **M1 – Internal Erosion Mitigations:** PG&E does not currently anticipate starting
4 any internal erosion projects between 2023 and 2026. PG&E will continue to
5 inspect the dams and continuously evaluate and prioritize the need for additional
6 mitigations during this time period. Of the five internal erosion projects in the
7 2020-2022 time period, two will continue into the 2023-2026 time period.

8 **M2 – Spillway Remediations:** PG&E does not anticipate starting any spillway
9 remediation projects between 2023 and 2026. PG&E will continue to inspect the
10 dams and continuously evaluate and prioritize the need for additional mitigations
11 during this time period. Of the 43 projects in the 2020-2022 time period, 22 will
12 continue into the 2023-2026 time period.

13 **M3 – Seismic Retrofits:** PG&E anticipates starting one seismic retrofit in the
14 2023-2026 time period. PG&E will continue to inspect the dams and
15 continuously evaluate and prioritize the need for additional mitigations during
16 this time period. Three of the six projects in the 2020-2022 time period will
17 continue into the 2023-2026 time period.

18 **M4 – LLO Refurbishments:** PG&E does not anticipate starting any LLO
19 refurbishments in the 2023-2026 time period. PG&E will continue to inspect the
20 dams and continuously evaluate and prioritize the need for additional mitigations
21 during this time period. Three of the eight projects in the 2020-2022 time period
22 will continue into the 2023-2026 time period.

23 Tables 13-9 (expense) and 13-10 (capital) below show the forecast costs for
24 the mitigation work planned from 2023-2026. The RSE and risk reduction
25 scores for each mitigation are shown in Table 13-10.

19 See WP 13-4.

TABLE 13-9
FORECAST COSTS
2023-2026 EXPENSE
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2023	2024	2025	2026
1	M1	Internal Erosion Mitigations	AXR	—	—	—	—
2	M2	Spillway Remediations	AXR	\$350	—	—	—
3	M4	LLO Refurbishments	AXR	—	—	—	—
4		Total		\$350	—	—	—

Note: See WP 13-1.

TABLE 13-10
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026 CAPITAL
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	M1	Internal Erosion Mitigations	2LR, 2NR	\$20,662	\$1,900	—	—	\$22,562	0.37	6.7
2	M2	Spillway Remediations	2LR, 2NR	78,850	107,700	40,000	40,000	266,550	0.69	139.0
3	M3	Seismic Retrofits	2LR	19,700	7,300	7,000	5,500	39,500	0.01	0.4
4	M4	LLO Refurbishments	2LR, 2NR	1,202	—	—	—	1,202	0.14	0.14
5		Total		\$120,413	\$116,900	\$47,000	\$45,500	\$329,813		

(a) See Mitigation Effectiveness workpapers (MW) included in the source document modeling package for information used to calculate the RSE.
 Note: See WP 13-1.

1 Table 13-10 shows that the Spillway Remediation program has both the
2 greatest risk reduction and highest RSE. Commensurate with these modeling
3 results PG&E is proposing to spend approximately 80 percent of its forecast
4 costs on this high value program.

5 **F. Alternative Analysis**

6 In addition to the proposed mitigations described in Section E above, PG&E
7 considered alternative mitigations as well. The mitigations described in
8 Section E constitute the Proposed Plan. The Alternative Plans consist of a
9 combination of some or all of the proposed mitigations along with the alternative
10 mitigation(s). PG&E describes each of the alternative mitigations it considered
11 below and then provides a table showing the forecast costs, RSEs and risk
12 reduction scores for each of the Alternative Plans.

13 **1. Alternative Plan 1: Internal Erosion Mitigation, Geomembrane Liners**

14 In response to a suggestion from the Public Advocates Office at the
15 California Public Utilities Commission regarding PG&E's 2017 RAMP, PG&E
16 considered the alternative of installing geomembrane liners on all high and
17 significant hazard dams that currently have projects planned to reduce
18 internal erosion, but those projects do not include installing a geomembrane
19 liner. This mitigation would require geomembrane liners to be installed for
20 Strawberry and Spaulding No. 1. This proposed alternative would be
21 performed instead of the proposed Internal Erosion Mitigation Plan.

22 This alternative represents a significant increase in spend over the next
23 several years. Because the model does not currently have a degradation
24 curve that would better represent the lifespan of the geomembrane liner
25 (approximately 50 years) versus the lifespan of the original projects
26 (approximately 3-5 years), mitigation effectiveness is given with the standard
27 discounted rate over the 50-year impact. However, a significant risk
28 reduction is still seen in the decrease in initiating event frequency of internal
29 erosion due to the benefits of the geomembrane liners.

TABLE 13-11
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026 CAPITAL
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	A1	Internal Erosion Mitigation, Geomembrane Liner	\$50,963	\$32,201	\$30,701	\$30,701	\$144,565	0.06	6.6
2		Total	\$50,963	\$32,201	\$30,701	\$30,701	\$144,565		

(a) See MWs included in the source document modeling package for information used to calculate the RSE.
 Note: See WP 13-1.

2. Alternative Plan 2: Geosciences Engineering and Risk Research Plan

Alternative 2 – Geosciences Engineering and Risk Research Plan: PG&E Geosciences developed a proposal to better quantify the seismic hazards and risk to PG&E Hydro assets through applied research. This proposal should be considered supplemental to the proposed mitigation plan. The program consists of three subject areas: Seismic Source Characterization (SSC), Ground Motion Characterization (GMC), and Engineering and Risk. The SSC area focuses on identifying and characterizing seismic sources. The GMC area focuses on improving our ability to model earthquake ground motions and uncertainty. The Engineering and Risk area focuses on collecting data and developing and implementing methodologies that improve our ability to quantify seismic risk. In order to organize the research program, 5-year windows of research activities are planned and each year's activities would be reviewed by external panels.

Notably, since this is a research project, the forecasted risk reduction cannot be quantified. Completing this study would improve the accuracy of our model and our understanding of the possible seismic impacts to PG&E's hydro assets. This would allow for better prioritization of work and mitigation of existing, but currently unknown hazards and risks and does have the potential to decrease spend through more accurate project designs.

The expected cost of the plan is \$200,000 per year for 5 years

**TABLE 13-12
FORECAST COSTS
2023-2026 EXPENSE
(THOUSANDS OF DOLLARS)**

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total
1	A2	Geosciences Engineering and Risk Research Plan	\$200	\$200	\$200	\$200	\$800
2		Total	\$200	\$200	\$200	\$200	\$800

Note: See WP 13-1.

3. Alternative Plan 3: PMF Studies

Alternative 2 – PMF Studies: PG&E has piloted an updated methodology for PMP analysis and is currently working with regulators to ensure acceptability of the analysis. It would require 21 additional studies to update all of PG&E's high and significant hazard dams. This alternative should be considered as supplemental to the proposed mitigation plan.

Notably, since this is a research project, the forecasted risk reduction cannot be quantified. Completing this study would improve the accuracy of our model and our understanding of the possible flood impacts to PG&E's hydro assets. This would also allow for better prioritization of work and mitigation of existing but currently unknown hazards and risks. There is further potential this will reduce the cost of future mitigations through more accurate spillway capacity designs. This alternative is expected to cost \$6,500,000 over three years to complete the study.

**TABLE 13-13
FORECAST COSTS
2023-2026 EXPENSE
(THOUSANDS OF DOLLARS)**

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total
1	A3	PMF Studies	\$2,200	\$2,200	\$2,100	–	\$6,500
2		Total	\$2,200	\$2,200	\$2,100	–	\$6,500

Note: See WP 13-1.

Table 13-14 compares the proposed and alternative mitigation plans.

TABLE 13-14
MITIGATION PLAN ALTERNATIVES ANALYSIS
(THOUSANDS OF DOLLARS)

Line No.	Risk Mitigation Plan	Plan Components ^(a)	Total Expense (2023-2026)	Total Capital (2023-2026)	Risk Reduction (NPV) ^(b)	Total Spend (NPV)	RSE
1	Proposed	M1, M2, M3, M4	\$350	\$329,813	146.21	\$250,656	0.58
2	Alternative 1	M2, M3, M4 + A1	\$350	\$451,816	146.09	\$340,481	0.43
3	Alternative 2	Proposed + A2	\$350	\$329,813	146.21	\$250,656	0.58
4	Alternative 3	Proposed +A3	\$350	\$329,813	146.21	\$250,656	0.58

(a) Plan Components refers to the Mitigations presented in Table 13-6.

(b) Information presented in terms of Net Present Value (NPV) to account for the discounting of benefits.

Note: See WP 13-1.

GAS AND ELECTRIC COMPANY
CHAPTER 14
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: REAL ESTATE AND
FACILITIES FAILURE

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 14
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: REAL ESTATE AND
FACILITIES FAILURE

TABLE OF CONTENTS

A. Executive Summary	14-2
1. Risk Overview	14-4
2. Risk Definition	14-5
B. Risk Assessment	14-5
1. Background and Evolution	14-5
2. Risk Bow Tie	14-6
3. Exposure to Risk.....	14-6
4. Tranches	14-7
5. Drivers and Associated Frequency.....	14-8
6. Cross-Cutting Factors	14-9
7. Consequences	14-9
C. Controls and Mitigations	14-13
1. 2019 Control Work.....	14-14
D. 2020-2022 Controls and Mitigation Plan.....	14-15
1. 2020-2022 Controls	14-15
2. 2020-2022 Foundational Mitigations	14-17
E. PG&E 2023-2026 Mitigations	14-20
F. Alternative Analysis	14-22
1. Alternative Plan 1: A1 Relocate Facilities for Climate Change (Other Than SFGO)	14-22
2. Alternative Plan 2: A2 Renovate or Relocate the SFGO.....	14-25

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 14
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: REAL ESTATE AND
FACILITIES FAILURE

A. Executive Summary

The Real Estate Facilities and Failure Risk is the risk of an event which causes a building, facility or property within Pacific Gas and Electric Company's (PG&E or the Company) service area to be deemed unsafe, or inaccessible for operation or occupancy, such that PG&E is unable to use the building or property to support operational needs. Key risk drivers include a seismic, flood, landslide, building fire, or physical security event.

The scope of this risk includes all PG&E-owned or leased buildings and facilities. All other non-facility-related PG&E assets, such as electric and gas transmission and distribution systems, dams, and substations are covered under other risks.

Exposure to this risk is based on a tranche-level analysis of 50 representative buildings from the subset of facilities managed by Corporate Real Estate Strategy and Services (CRESS) that included high-, mid-, and low-rise office buildings, service centers, conference centers, and critical facilities in predominately high seismic areas of the state. The risk model analysis indicates that the expected number of events per year is approximately eight for this risk. 62 percent of the risk events are seismic events while physical security, flood, landslide, and building fire account for 38 percent of the risk events. Seismic risk also makes up more than 99 percent of the total risk impact score and physical security, flood, landslide, and building fire events comprise the remaining portion of the risk score. Based on this analysis, PG&E's planned mitigations primarily address seismic risk events.

71 percent of the tranche-level risk is related to two high-rise, highly-populated buildings located in a relatively high seismic zone (San Francisco General Office (SFGO) Complex). 12 percent of the tranche-level risk is related to five mid-rise buildings, and the remaining

17 percent is based on the sample of single story or low-rise buildings found in service centers, office complexes, and other facilities.¹

Real Estate Facilities and Failure Risk has the seventh highest 2023 test year (TY) baseline safety score (69) and sixth highest 2023 TY baseline total risk score (97) of PG&E's top 12 Risk Assessment and Mitigation Phase (RAMP) risks. The 2020 baseline risk score, 103, improves by 16 percent when the planned mitigations are applied: the 2023 TY baseline risk score is 97 and the 2026 post-mitigation risk score is 87.²

Between 2020 and 2022, PG&E will conduct foundational activities, such as surveying buildings that meet a certain criterion. This criterion will include parameters, such as age (to determine contemporaneous codes that were applied to design and construction), location (to determine local seismic activity), height or stories (to determine potential building performance), and/or population density (to weigh potential safety risks) that will inform the multi-year seismic mitigation programs. The buildings or structures will be reviewed against a seismic performance criterion to determine if the structures should be renovated or replaced either by redevelopment or relocation (relocation is particularly related to leased facilities). PG&E will begin renovation or replacing targeted facilities identified during the foundational survey starting in 2023 or sooner depending on the implementation of CRESS' Service Center Investment Program currently outlined in the 2020 General Rate Case (GRC) request or within PG&E's proposed regionalization plans.³

PG&E completed its RAMP analyses at the end of May 2020. In June 2020, PG&E announced Company headquarters will move from San Francisco to Oakland beginning in 2022. This upcoming move is not reflected in the risk analysis presented herein, but will be incorporated into the 2023 GRC.

¹ See WP 14-3.

² During the February 4, 2020 RAMP Workshop a California Public Utilities Commission (CPUC) staff member asked PG&E if the risk score for the Real Estate and Facilities failure risk is based on past events or if it is based on United States Geological Survey (USGS) data sources. PG&E's risk model considers the probability of seismic events based on rates of peak ground acceleration exceedance. The USGS Hazard Analysis used in PG&E's model does not rely solely on historical events, but rather, uses data collected from both past seismic events, models of ground motion and the potential recurrence of those events.

³ The information herein is subject to those limitations described in Chapter 2, Section D.

**TABLE 14-1
RISK OVERVIEW**

Line No.	Risk Name	Real Estate and Facilities Failure
1	In Scope	Building, facilities or property owned or leased by PG&E
2	Out of Scope	Other non-facility related PG&E assets, such as electric and gas transmission and distribution assets, power generation assets, substations.
3	Data Quantification Sources ^(a)	<p><u>Seismic Data</u> – Recent studies of three sites in October 2019; initial modeling data of 15 sites as of November 2019. Analysis includes seismic hazard developed by USGS and building damage vulnerability by risk assessment software SP3 developed by the consulting firm “Haselton Baker Risk Group (HB Risk)” using simplified Federal Emergency Management Agency (FEMA) procedure P-58 methodology. Used available building specific information. The initial study was used as surrogate for further expansion to a sample of 50.</p> <p><u>Flood Data</u> – Current and historical FEMA Flood Zone Data, PG&E Geographic Information System Analytics Department.</p> <p><u>Landslide Data</u> – Data from PG&E Meteorology Department.</p> <p><u>Physical Attack Data</u> – Crimes-Against-Persons Index aggregated property crime evaluation Federal Bureau of Investigation crime data.</p> <p><u>Fire Data</u> – National Fire Protection Association, National Fire Incident Reporting System, Commercial Building Energy Consumption Survey.</p>
(a) Source documents will be provided with the workpapers on July 17, 2020.		

1. Risk Overview

PG&E owns more than 3,000 buildings throughout its 72,000 square mile service area. PG&E continually manages the exposure of these facilities to unplanned natural disasters, such as fires, floods, landslides, and seismic events, and other risks, such as trespass, theft, and physical attacks on PG&E property.

CRESS manages a subset of PG&E facilities that is primarily comprised of “occupied spaces.” These facilities include office buildings, service centers (including operations buildings, shops, warehouses, equipment yards, and vehicle maintenance garages), data centers and other facilities that house critical operating infrastructure, contact or call centers, and Customer Service Offices (CSO) where customers conduct in-person transactions with PG&E representatives. CRESS does not manage structures or facilities, whether occupied or only housing equipment, that are part of PG&E’s electric, gas, and/or information technology infrastructure.

1 For example, certain substations have buildings that were previously used
2 for substation maintenance or circuit switching. These other buildings are
3 not managed by CRESS but instead managed by other lines of business,
4 such as PG&E's Electric Distribution Operations teams.

5 **2. Risk Definition**

6 The Real Estate Facilities and Failure Risk is an event which causes a
7 building, facility or property within PG&E's territory to be deemed unsafe, or
8 inaccessible for operation or occupancy, such that PG&E is unable to use
9 the building or property to support operational needs.


10 **B. Risk Assessment**

11 **1. Background and Evolution**

12 The Real Estate and Facilities Failure risk was added to PG&E's
13 Enterprise Risk Register in 2019 and is a new risk in the 2020 RAMP.
14 Previously this risk was disaggregated into two separate risks: the Seismic
15 Vulnerability Risk and the Fire Life Safety Risk. For the 2020 RAMP, the
16 Real Estate and Facilities Failure Risk incorporates these two risks into one
17 risk which also includes additional risk drivers, such as flood, landslide and
18 physical attack, which results in a higher overall risk score than the previous
19 disaggregated seismic and fire risks.

2. Risk Bow Tie

**FIGURE 14-1
RISK BOW TIE**



3. Exposure to Risk

Exposure to this risk is based on an analysis of a representative sample of 50 facilities managed by CRESS and includes low-, mid-, and high-rise facilities. Most of the facilities are in higher seismic areas, primarily the San Francisco Bay Area, and/or facilities that are higher in employee density. The list also includes facilities that house crucial core computer or customer support operations, such as data centers, grid and gas control centers, emergency operations centers, telecom hubs, and customer contact centers. The risk model is based on approximately eight risk events occurring each year.

As discussed in more detail below, seismic event(s) account for the majority of the Real Estate and Facilities Failure risk. PG&E's facilities are in various seismic zones throughout its service territory including relatively high seismic zones in the coastal regions, most significantly the greater San Francisco Bay Area, and others located in relatively low seismic zones, such as the San Joaquin Valley and Sierra Nevada Foothills. Each PG&E facility is required to meet the seismic ordinances, codes, and/or standards promulgated by the local jurisdiction or Agency Having Jurisdiction (AHJ) at

the time the facilities were first permitted and constructed, or when certain levels of renovation trigger compliance with then-current building codes. While all PG&E buildings were built to contemporaneous codes and standards, some are believed to be at risk of failure during a certain design earthquake greater than the design earthquake in the building code when the building was constructed. This is mainly due to the evolution and/or maturity of seismic knowledge, mapping of faults, and experience with building performance during recent significant seismic events.

4. Tranches

The Real Estate and Facilities Failure risk model includes a representative sample of 50 facilities, each of which is its own tranche. The 50 individual facilities are grouped into 4 groups of facilities that share similar characteristics.

- Group 1 – The SFGO Complex: High rise facilities in San Francisco making up PG&E’s Headquarters (PG&E’s only high-rise structures);
- Group 2 – Mid to High Risk Facilities Other than SFGO: Mid-rise (greater than four stories) office buildings, e.g., San Jose, San Ramon, and Concord.
- Group 3 – Low-Rise Structures: Structures typically found at service centers, office complexes, or conference centers.
- Group 4 – Critical Facilities: Critical facilities house core computer or customer support operations, such as data centers, grid and gas control centers, emergency operations centers, telecom hubs, and customer contact centers.

Table 14-2 below shows the results of the tranche-level analysis.

**TABLE 14-2
RISK EXPOSURE AND PERCENT RISK BY TRANCHE**

Line No.	Tranche	Percent Exposure	Safety Risk Score	Financial Risk Score	Total Risk Score	Percent Risk Score
1	High-Rise – 2 Buildings	4%	48.19	20.37	68.56	71%
2	Mid-Rise – 5 Buildings	10%	8.28	3.34	11.62	12%
3	Low-Rise/Single-Story – 43 Buildings	86%	12.84	3.57	16.41	17%
4	Total	100%	69.31	27.28	96.59	100%

5. Drivers and Associated Frequency

PG&E identified five drivers for the Real Estate and Facilities Failure risk. Each driver and its associated 2023 TY baseline frequency are discussed below.

Seismic: This driver includes seismic events in PG&E's service territory and accounts for five (62 percent) of the eight expected number of the risk events per year. There are four sub-drivers identified for this risk aligned to the Seismic driver: Seismic Minor; Seismic Moderate; Seismic Strong; and Seismic Severe.

Physical Attack: Physical attack includes attacks against PG&E buildings or facilities, such as a bomb threat, active shooter, or other crimes against PG&E's facilities. This driver also includes theft, property vandalism, trespass, and adjacent non-lawful assembly near PG&E's facilities. This driver accounts for two (27 percent) of the eight expected number of the risk events per year. Although the frequency of risk events from the Physical Attack driver is the second highest among the drivers, the Physical Attack driver has a low impact on financial consequences due to experience with resultant losses (materials theft and/or fence damage).

Building Fire: This driver includes fire-related incidents in PG&E's buildings or facilities and accounts for fewer than one incident (11 percent) of the eight expected number of the risk events per year. The Fire Risk driver is projected to have little effect on financial outcomes because the risk impact is primarily on non-structural elements, e.g., smoke damage, water damage due to sprinklers.

Flood: Includes flood-related incidents in PG&E's buildings or facilities. This driver accounts for fewer than one incident (1 percent) of the eight expected number of the risk events per year. Flood is projected to have little effect on financial outcomes because the risk impact is primarily on non-structural elements, e.g., flooding only in parking areas.

Landslide: Includes landslide related incidents impacting PG&E's buildings or facilities. This driver accounts for fewer than one incident (1 percent) of the eight expected number of the risk events per year. Landslide is projected to have little effect on financial outcomes because PG&E's

facilities are primarily built on flat land and not adjacent to steep terrain, slopes or mountainous areas.

6. Cross-Cutting Factors

A cross-cutting factor is a driver or control that is interrelated to multiple risks. PG&E is presenting eight cross-cutting factors in the 2020 RAMP. The cross-cutting factors that impact the Real Estate and Facilities Failure risk are shown in Table 14-3 below. A description of the cross-cutting factors and the mitigations and controls that PG&E is proposing to mitigate the cross-cutting factors are described in Chapter 20.

**TABLE 14-3
CROSS-CUTTING FACTOR SUMMARY**

Line No.	Cross-Cutting Factor	Impacts Likelihood (Driver)	Impacts Consequence
1	Seismic	X	X
2	Physical Attack	X	
3	Records and Information Management		X
4	Emergency Preparedness and Response		X

Seismic driver accounts for more than 99 percent of the total risk score and results in consequence of risk events more severe than other risk drivers.

7. Consequences

The consequence impacts for the Real Estate and Facilities Failure risk are related to safety and finance:

Safety: Safety consequences in the risk model are driven primarily by a seismic event resulting in employee injuries and/or fatalities as a result of structural and/or non-structural damage to PG&E's facilities. Injuries and fatalities are influenced by the number of seated employees for those buildings in the risk model. Fire, flood, and landslide events did not result in potential injuries and/or employee fatalities in the risk model because the consequences of these events were generally non-structural in nature associated with minor damage to the building or grounds. Physical attacks against PG&E facilities are rare. If they occur, they primarily consisted of incidents of property theft.

Financial: Financial consequences in the risk model are driven by the cost to rebuild a structure after a seismic event. Building costs are based on typical PG&E and/or industry costs to rebuild on a cost per square foot of building space.

- Fire, flood, and landslide events did not result in significant financial costs because consequences of these events were generally non-structural in nature associated with minor damage to the building or grounds.

- Financial consequences resulting from physical attack were also low as the nature of actual physical attack resulted in incidents of property theft.

The severity of a seismic event is the largest driver of safety and financial consequences. The severity of a seismic event is divided into four possible outcomes based on the measure of peak ground acceleration (greater than 0.05 g)—a measure of how hard the earth shakes at a given geographic point. Events causing ground shaking less than 0.05 g were judged to have insignificant impact based on historical experience and as such were not considered consequential.⁴

Each of the four possible outcomes described above results in varying probabilities of building failure for the individual buildings or tranches in the risk model.

- Minor (0.05g-0.20g) – Accounts for 50 percent of the risk event occurrences and 22 percent of the risk.
- Moderate (0.21g-0.40g) – Accounts for 8 percent of the risk event occurrences and 28 percent of the risk.
- Strong (0.41g-0.60g) – Accounts for 2 percent of the risk event occurrences and 24 percent of the risk.
- Severe (>0.60g) – Accounts for 1 percent the risk event occurrences and 25 percent of the risk.

⁴ During the February 4, 2020 RAMP Workshop, a CPUC staff member asked PG&E for a translation of seismic outcomes that were expressed as the ground shaking intensity (measured in units of gravity “g”) into Richter magnitude scale units. The potential earthquake magnitudes considered for modeling this risk range from small (~M5) to large (M7+). However, the location of the earthquake has a significant impact on the shaking levels (measured in units of gravity “g”) that will be experienced at various facilities, i.e., buildings close to the fault shake harder than buildings further away.

1 Table 14-4 shows the consequences of the risk analysis. Model
2 attributes are discussed in Chapter 3, "Risk Modeling and Risk Spend
3 Efficiency."

TABLE 14-4
RISK EVENT CONSEQUENCES

	CoRE %Freq %Risk			Freq	Natural Units Per Event		CoRE		Natural Units per Year		Attribute Risk Score	
	Safety EF/event	Financial \$/event	Safety EF/yr		Financial \$/yr	Safety EF/yr	Financial \$/yr	Safety	Financial			
Seismic Moderate	40	8% 28%	0.7	0.3	8.3	26	14	0.19	5.7	18	9	
Seismic Severe	200	1% 25%	0.1	0.8	29.8	157	43	0.10	3.6	19	5	
Seismic Strong	135	2% 24%	0.2	0.6	18.7	105	31	0.10	3.2	18	5	
Seismic Minor	5	50% 22%	4.1	0.1	1.5	3	2	0.28	6.0	14	7	
Minor Damage	0.1	38% 0.2%	3.1	-	0.1	-	0.1	-	0.4	-	0.2	
Aggregated	12	100% 100%	8.2	0.1	2.3	8	3	0.66	18.9	69	27	

1 C. Controls and Mitigations

2 Tables 14-5 and 14-6 list all the controls and mitigations PG&E included in
3 2020 GRC, as well as those planned in the 2020 RAMP (2020-2022, the design
4 and analyze phase) and 2023-2026 (the mitigation implementation phase). The
5 tables provide a view as to controls and mitigations that are on-going, those that
6 are no longer in place, and new mitigations.

7 The Real Estate and Facilities Failure risk was not included in the 2017
8 RAMP. However, PG&E did identify mitigations and controls in the 2020 GRC
9 shown in the tables below.

**TABLE 14-5
CONTROLS SUMMARY**

Line No.	Control Name and Number	2017 RAMP	2020-2022 GRC 2017-2020 Controls	2020-2022 RAMP	2023-2026 RAMP
1	C1 – Regional Optimization ^(a)		X	X	X
2	C2 – Service Center Optimization ^(b)		X	X	X
3	C3 – CSO Optimization		X	X	X
4	C4 – Facilities Management Preventive Maintenance Program		X	X	X
5	C5 – Site Design Structural and Engineering Reviews ^(c)		X	X	X
6	C6 – Segregation of Assets ^(c)		X	X	X
7	C7 – Facility Inspection Program		X	X	X
8	C8 – Security System Hardening		X	X	X
<p>(a) C1 –Regional Optimization is currently paused.</p> <p>(b) C2 –Service Center Optimization is currently paused. PG&E discusses this control in Sections C.1 and D.1 below.</p> <p>(c) This control is included in PG&E’s 2020 GRC, though not always specifically identified as such.</p>					

**TABLE 14-6
MITIGATIONS SUMMARY**

Line No.	Mitigation Name and Number	2017 RAMP 2017-2019 Mitigations	2020 GRC 2020-2022 Mitigations	2020 RAMP 2020-2022 Mitigations	2020 RAMP 2023-2026 Mitigations
1	M1 – Seismically Risk Rank Facilities Using Tiered System			Foundational Mitigation ^(a)	
2	M2 – Identify Seismic Risk Reduction for Multistory Buildings			Foundational Mitigation	
3	M3 – Develop an Updated Seismic Standard			Foundational Mitigation	
4	M4 – Additional Fire Inspections of Older Facilities			Foundational Mitigation	
5	M5 – Refresh/Review of Key Sites Potentially Impacted by Flood/Landslide/Physical Attack			Foundational Mitigation	
6	M6 – Renovate or Relocate Facilities Other than SFGO		X		X
<p>(a) PG&E defines foundational mitigations as activities that support risk reduction but do not reduce risk themselves. Because these activities do not directly reduce risk, PG&E does not provide a risk score or risk spend efficiency score (RSE) for them.</p>					

Between 2020 and 2022, PG&E will complete several foundational activities that will inform the CRESS multi-year seismic mitigation programs.

1. 2019 Control Work

In 2019, CRESS continued to implement its Facilities Management Preventive Maintenance Program, Facility Inspection Program, and to invest in Security System Hardening as controls, e.g., additional security gates and updated fencing. The Regional Optimization control is currently paused due to affordability measures but may be reintroduced as the Company implements its regionalization strategy.

Service Center Optimization (Control C2) incorporates two distinct efforts: (1) service center investment; and (2) Service Center Optimization. service center investment focuses on renovations, maintenance, compliance issues and upgrades, often to resolve site safety concerns. Service Center Optimization focuses on optimizing Service Center operations. Service Center Optimization is currently paused as PG&E evaluates its regionalization strategy.

As part of on-going portfolio management, PG&E continues to make service center investments that may result in indirect improvements that reduce risk, e.g., renovation or replacement of older facilities with newer facilities. Site Design Structural and Engineering Reviews are implemented as a normal course of renovating or standing up new facilities and those costs are embedded within PG&E's Portfolio Budget. Segregation of Assets, such as main and backup electric grid control or distribution control centers have been implemented in previous years and not accounted for in 2019 costs.

D. 2020-2022 Controls and Mitigation Plan

Real Estate and Facilities Failure was not a 2017 RAMP risk. While PG&E did not specifically identify programs as RAMP controls or mitigations in its 2020 GRC, CRESS actively develops and implements programs to mitigate facilities risk, enhance safety, and/or maintain compliance. The controls and mitigations described below were included in PG&E's 2020 GRC, though not always specifically identified as such, and have been in place prior to 2019 with the exception of the Regional Office and Service Center Optimization Programs which started in 1995 but were paused in December 2018. The programs will most likely restart in 2021 as part of PG&E's proposed regionalization plan.

1. 2020-2022 Controls

C1 – Regional Office Optimization: PG&E will consolidate offices, group similar job functions, exit leased facilities and replace them with owned facilities, and/or optimize under-utilized buildings to reduce operational costs to drive affordability. When consolidating offices or exiting facilities, PG&E will consider where opportunities for seismic, flood, landslide, fire, physical attack, and/or climate change risk reductions exist. CRESS is assisting with development of a regional office optimization strategy to support realignment of Company operations to a regional structure. This strategy will also consider additional or alternate workplaces to support ongoing wildfire mitigation efforts. As part of these efforts, PG&E will prioritize renovation of, or relocation from, buildings/workplace that present risks mentioned above. This control impacts seismic, flood, landslide, fire, and physical attack drivers.

C2 – Service Center Optimization: Service Center Optimization addresses service centers, yards, and operational facilities throughout PG&E’s service area that are core to customer support and emergency response and restoration efforts. These facilities house field operations, equipment, vehicles, and materials. Facility hardening efforts to reduce risks at these centers include updating perimeter security and fencing to current PG&E standards, upgrading site drainage capabilities and storm water runoff infrastructure, and replacing non-permitted temporary or legacy structures with current code compliant structures. This control impacts seismic, flood, landslide, fire, and physical attack drivers.

C3 – CSO Optimization: The CSO Optimization Plan addresses all CSOs throughout PG&E’s service territory. These offices are staffed by PG&E employees who provide face-to-face service to customers and process bill payments and other non-payment transactions. The CSO Optimization plan will enable a better customer experience and drive operational efficiencies and affordability by closing or re-locating underutilized CSOs to locations with larger foot traffic for easier customer access.⁵ The CSO Optimization Plan also considers potential seismic and physical security risks at CSO facilities. This control impacts seismic, flood, landslide, fire, and physical attack drivers.

C4 – Facilities Management Preventive Maintenance Program: PG&E’s Facilities Management Preventive Maintenance Program includes preventive maintenance services for the entire CRESS-managed portfolio including specific activities in support of maintaining fire and life safety systems and components. This includes facility inspections conducted by PG&E building mechanics, third parties, alliance partners, and external regulators to confirm that PG&E equipment is properly maintained and complies with all fire and life safety laws and regulations. Preventive Maintenance programs include inspections of fire alarms, protection and detection systems, and validating all required maintenance and updates. This control primarily impacts fire and physical attack drivers.

⁵ Issues related to PG&E’s Customer Service Centers are addressed in PG&E’s 2020 GRC proposed settlement.

C5 – Site Design Structural and Engineering Reviews: All new and retrofitted PG&E facilities must be built to current local codes and ordinances related to site and/or building design criteria promulgated by AHJs. Additionally, architectural and engineering design review is conducted as part of the local permit process with sign-off from local AHJs prior to permits being issued for occupancy. This control impacts seismic, flood, landslide, and fire drivers.

C6 – Segregation of Assets: PG&E's critical assets, such as main and backup electric grid control or distribution control centers, gas control and dispatch centers, data centers, and customer call centers are placed in different areas or regions ensuring a local disaster does not affect all facets of critical operations. This control primarily impacts the seismic or flood driver.

C7 – Facility Inspection Program: The Facility Inspection program focuses on monthly visual inspections for all CRESS-managed buildings and sites by CRESS facilities services personnel. Inspections include reviews of safety house-keeping items including personal appliances in facilities, daisy-chaining of extension cords which could start a fire, and non-structural seismic issues, such as racking and vertical storage issues to reduce risks during a seismic event. This control impacts seismic, fire, and physical attack drivers.

C8 – Security System Hardening: CRESS works with PG&E's Corporate Security Department to identify areas for security system hardening, such as installing higher fencing, automatic gates, and/or enhanced perimeter surveillance devices. This control impacts the physical attack driver.

2. 2020-2022 Foundational Mitigations

Between 2020 and 2022, PG&E will complete several foundational mitigations that will inform the CRESS multi-year seismic mitigation programs.

M1 – Seismically Risk Rank Facilities Using Tiered System: The CRESS Seismic Program will risk rank PG&E facilities using a tiered system commensurate to the risk significance. The risk ranking will start with facilities in the greater Bay Area and then be expanded to the entire PG&E

service area based on ranking and selection criteria. The risk ranking will consist of:

- An initial effort to identify safety concerns based on key parameters, such as location, type of building, occupancy levels, age of buildings, previous retrofits, within certain seismic zones, structural and non-structural vulnerabilities; and
- Additional efforts to provide improved risk estimates.

M2 – Identify Seismic Risk Reduction for Multi-Story Buildings:

Multistory buildings (>four stories) are a dominant contributor to the seismic driver of the Real Estate and Facilities Failure Risk. The focus of this foundational activity is to improve the risk estimates and identify potential risk reduction plans for these buildings.

M3 – Develop an Updated Seismic Standard: PG&E buildings were built to contemporaneous codes and standards. However, more recent seismic experiences indicate that some could be at risk of failure when experiencing an earthquake greater than the design earthquake at the time of construction. All buildings will be assessed to determine the necessary performance level and reviewed for seismic performance and potential damage. CRESS' updated seismic standard will define the minimum criteria by facility type and will focus first on high risk/high population density buildings managed by CRESS. The standard will require:

- Mission Critical Facilities perform to the Fully Operational level (no consequential damage, continuous service);
- Business Critical Facilities perform to the Operational level (most operations and functions can resume immediately);
- Occupied buildings perform to the Life Safety level (structure damage may occur but will not compromise safe exit from the building); and
- Non-occupied structures perform to the Collapse Prevention level (structural damage may be severe, but collapse is prevented though non-structural elements may fail);

Continued validation is required to appropriately classify buildings and understand their seismic risk as business needs may be expanded, buildings and systems age and may experience degradation, and/or seismic modeling maturity may suggest increased resiliency.

M4 – Additional Fire Inspections of Older Facilities: Approximately 75 percent of the Company’s service centers are more than 45 years old and certain buildings or systems may be nearing end of useful lifespan. Many do not comply with current fire codes related to fire sprinklers or fire dampening. This foundational activity involves conducting additional fire life safety inspections for older facilities. As PG&E renovates or replaces them, these facilities will be brought up to the current standards and code requirements that ultimately enhance the ability to detect and extinguish a workplace fire. In the meantime, CRESS has augmented its visual inspections to mitigate this risk.

M5 – Refresh/Review of Key Sites Potentially Impacted by Flood/Landslide/Physical Attack: CRESS will review certain sites that could be impacted by floods and/or landslides including non-PG&E sites adjacent to PG&E facilities. This review will also focus on areas that may have changes in flood plains and/or experience from recent storm events. Geotechnical and engineering screening may be completed through the review of refreshed flood and liquefaction maps throughout the PG&E service area to look for ground faulting or failure. As PG&E renovates or replaces facilities, these facilities will be brought up to current standards and code requirements. Any site that is identified with an immediate threat will be reviewed for potential renovations to mitigate risks as required. CRESS will continue to work with PG&E’s Corporate Security department to address any facilities that may have a higher potential of physical attack determined from recent experience or from Corporate Security’s crime incident models.

Table 14-7 below shows the forecast costs for the planned 2020-2022 mitigations.

**TABLE 14-7
FORECAST COSTS
2020-2022 EXPENSE
(THOUSANDS OF DOLLARS)**

Line No.	Mit. No.	Mitigation Name	MWC/MAT	2020	2021	2022	Total
1	M1-M5	Foundational Mitigations	BI	\$500	\$1,000	\$1,000	\$2,500
2	Total			\$500	\$1,000	\$1,000	\$2,500

Note: See WP 14-1.

E. PG&E 2023-2026 Mitigations

PG&E's 2023-2026 mitigation plan will focus on reducing seismic risk across its building portfolio by renovating or relocating low-, mid-, and high-rise complexes that do not meet minimum performance criteria. Planning, design, and analysis will occur in 2020-2022 (the foundational mitigations described above) with renovation or relocation efforts occurring 2023-2026 and beyond.

PG&E is proposing one mitigation that consists of two concurrent efforts:

M6 – Renovate or Relocate Facilities Other than SFGO:

Effort 1: Renovate or Relocate Low Rise Facilities

PG&E will systematically evaluate and retrofit or relocate all low-rise facilities such as service centers and office buildings that do not meet a minimum seismic performance level to reduce seismic risk. This collection of buildings is the highest number of buildings but with relatively low risk scores, as compared to mid- and high-rise structures. Renovation or relocation of buildings will also be coupled with workplace strategies driven by Company regionalization efforts.

Effort 2: Renovate or Relocate Mid Rise and High-Rise Structures (Other Than SFGO)

PG&E will review midrise and high-rise structures against the minimum seismic performance criteria and renovate or relocate facilities accordingly. This collection of buildings is a relatively low number of buildings but with relatively high-risk scores, as compared to low-rise structures. This effort will also be coordinated with Company regionalization efforts.

Tables 14-8 below shows the forecast costs for the planned 2023-2026 mitigations.

TABLE 14-8
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2023	2024	2025	2026	Total ^(a)	RSE ^(b)	Risk Reduction
1	M6	Renovate or Relocate Facilities Other than SFGO	BI	\$1,000	\$1,000	\$1,000	\$1,000	\$4,000	-	-
2		Total Expense		\$1,000	\$1,000	\$1,000	\$1,000	\$4,000	-	-
3	M6	Renovate or Relocate Facilities Other than SFGO	22	\$20,000	\$20,000	\$20,000	\$20,000	\$80,000	-	-
4		Total Capital		\$20,000	\$20,000	\$20,000	\$20,000	\$80,000	-	-
5				-	-	-	-	-	0.83	51.14

(a) Renovation and relocation costs represented in this table may be greater depending on the number of facilities targeted.

(b) See Mitigation Effectiveness worksheets included in the source document modeling package for information used to calculate the RSE.

Note: See WP 14-1.

PG&E's risk analysis demonstrates that the combination of the proposed mitigation and Alternative 2 (described below) provides the greatest overall risk reduction (see Table 14-11 below). Alternative 2, Renovate or Relocate the SFGO, has the highest contribution to risk impact, but is expected to have a relatively high cost compared to the proposed mitigation. In early June 2020 PG&E announced plans to relocate the SFGO to Oakland and to sell the current General Office complex.

PG&E believes the proposed mitigation plan is appropriate because facilities that pose the greatest seismic risk to the Company are prioritized for review and corrective actions.

Alternative 1 also has a high risk reduction score. PG&E will continue to evaluate this alternative mitigation—alone and in combination with the proposed mitigation—as it develops and implements its real estate and facilities strategy.

F. Alternative Analysis

In addition to the proposed mitigations described in Section 3 above, PG&E considered alternative mitigations as well. The mitigations described in Section E constitute the Proposed Plan. The Alternative Plans consist of a combination of some or all of the proposed mitigations along with the alternative mitigation(s). PG&E describes each of the alternative mitigations it considered below and then provides a table showing the forecast costs, RSEs and risk reduction scores for each of the Alternative Plans.

1. Alternative Plan 1: A1 Relocate Facilities for Climate Change (Other Than SFGO)

As part of PG&E's overall strategy to relocate facilities and employees, PG&E will consider relocating buildings located in areas of potential sea level rise, and/or employ local or site-specific mitigation efforts to avoid flood impacts to those facilities. PG&E has certain facilities that are located in areas of potential rising sea level and tides (e.g., cities along the Pacific Coast—Eureka, Pismo Beach, Santa Cruz, and Point Arena) and others adjacent to the San Francisco Bay (e.g., Oakland, San Carlos, Fremont, and Richmond). PG&E is undertaking a multi-year Climate Vulnerability Assessment that will consider the extent to which sea-level rise may impact PG&E facilities and when such impacts could occur. Relocation

1 opportunities will also consider regionalization strategies as well as facility
2 optimization.

3 This alternative was not selected because the risk of flood at PG&E
4 facilities is low and relocation costs are high. This mitigation may be
5 reconsidered depending on the Climate Vulnerability Assessment findings.

TABLE 14-9
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026 CAPITAL
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	A1	Relocate Facilities for Climate Change (other than SFGO)	\$125,000	\$125,000	\$125,000	\$125,000	\$500,000	–	–
2		Total	\$125,000	\$125,000	\$125,000	\$125,000	\$500,000	0.13	47.08

(a) See mitigation effectiveness worksheets included in the source document modeling package for information used to calculate the RSE. Forecasted costs on this table are represented by placeholders and may be adjusted depending on the number of facilities impacted.

Note: See WP 14-1.

2. Alternative Plan 2: A2 Renovate or Relocate the SFGO

PG&E will evaluate options related to renovating or replacing the SFGO complex.⁶

This alternative mitigation has the highest risk reduction impact (71 percent) of any of the mitigations considered. While this alternative has the highest RSE, the estimated cost of this alternative is relatively high, as compared to cost to reduce risks throughout the portfolio. Risk related to the SFGO complex is primarily driven by the perceived performance of the largest building (77 Beale) during an extreme seismic event.

PG&E provided high-level cost estimates for this alternative. These estimates were developed solely for developing an initial RSE and should not be considered actual forecasts for performing this work.

⁶ PG&E's RAMP risk analysis was complete by the end of May 2020. In June 2020 PG&E announced plans to relocate the SFGO to Oakland and to sell the current General Office complex.

TABLE 14-10
FORECAST COSTS, RSE AND RISK REDUCTION
2023-2026 CAPITAL
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	A2	Renovate or Relocate the SFGO	\$187,500	\$187,500	\$187,500	\$187,500	\$750,000		
2		Total	\$187,500	\$187,500	\$187,500	\$187,500	\$750,000	1.17	645.27

(a) See mitigation effectiveness worksheets included in the source document modeling package for information used to calculate the RSE. Forecasted costs on this table are represented by placeholders and may be adjusted depending whether renovation or relocation strategies are implemented.

Note: See WP 14-2.

1 Table 14-11 compares the proposed and alternative mitigation plans.

TABLE 14-11
MITIGATION PLAN ALTERNATIVES ANALYSIS
(THOUSANDS OF DOLLARS)

Line No.	Risk Mitigation Plan	Plan Components ^(a)	Total Expense (2023-2026)	Total Capital (2023-2026)	Risk Reduction (NPV) ^(b)	Total Spend (NPV)	RSE
1	Proposed	M6	\$4,000	\$80,000	51	\$61,873	0.83
2	Alternative 1	M6+ A1	\$4,000	\$580,000	92	\$430,166	0.21
3	Alternative 2	M6 + A2	\$4,000	\$830,000	696	\$614,312	1.13

(a) Plan Components refers to the Mitigations presented in Table 14-6

(b) Information presented in terms of Net Present Value (NPV) to account for the discounting of benefits.

Note: See WP 14-2

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 15
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: THIRD-PARTY SAFETY INCIDENT

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 15
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: THIRD-PARTY SAFETY INCIDENT

TABLE OF CONTENTS

A. Executive Summary.....	15-3
1. Risk Overview	15-4
2. Risk Definition	15-7
B. Risk Assessment.....	15-7
1. Background and Evolution	15-7
2. Risk Bow Tie	15-8
3. Exposure to Risk.....	15-8
4. Tranches	15-9
5. Drivers and Associated Frequency	15-10
6. Cross-Cutting Factors	15-11
7. Consequences	15-12
C. Controls and Mitigations	15-14
1. 2019 Controls.....	15-18
a. Controls	15-18
1) Gas Operations Controls.....	15-18
2) Electric Operations Controls.....	15-20
3) Power Generation Controls	15-23
b. Mitigations	15-25
1) Gas Operations Mitigations	15-25
2) Electric Operations Mitigations.....	15-26
3) Power Generation Mitigations	15-26
D. 2020-2022 Controls and Mitigations	15-28
E. 2023-2026 Proposed Mitigation Plan.....	15-29

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 15
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: THIRD-PARTY SAFETY INCIDENT

TABLE OF CONTENTS
(CONTINUED)

F. Alternative Analysis	15-31
1. Alternative Plan 1: Targeted Third-Party Electric Safety Pilot Program	15-31
2. Alternative Plan 2: Delay Installation of Canals and Waterways Safety Barriers	15-32

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 15
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: THIRD-PARTY SAFETY INCIDENT

A. Executive Summary

Third-Party Safety Incident refers to a Pacific Gas and Electric Company (PG&E or the Utility) recordable third-party injury or fatality that is due to an interaction with or use of a PG&E facility or location, not involving an asset failure. Recordable injuries include those which may result in a serious injury in alignment with the Division of Occupational Safety and Health (DOSH)—better known as “Cal/OSHA”—definition or a fatality. Third party refers to a member of the public who is a non-PG&E employee and is not a PG&E contractor. The drivers for this risk event are car pole/guy; electric contact; others; drowning or other incidents on PG&E managed/owned property; job site; slip/trip/fall; suicide; falling object/vegetation; and motor vehicle incident (non-pole related).

Exposure to this risk is measured within the PG&E system territory and divided into four tranches to facilitate the quantitative risk analysis: third-party interaction with electric operations assets and job sites; third-party interaction with gas operations assets and job sites; third-party interaction with PG&E managed land and water; and third-party interaction with power generation assets. The risk model includes approximately 3,378 risk events each year based on available data which includes Electric Operations incidents only (i.e., car pole/guy and electric contact). The risk outcomes include third-party interaction with reliability impact and third-party interaction. The risk consequences include third-party serious injuries and fatalities. The mitigations PG&E will implement from 2020-2026 are designed to address the risk drivers.

Third-Party Safety Incident has the second highest 2023 baseline test year safety (887) score and second highest 2023 baseline total risk score (944) of PG&E’s 12 Risk Assessment and Mitigation Phase (RAMP) risks. The 2020 baseline risk score is 949, the 2023 baseline test year risk score is 944 and the 2026 post-mitigation risk score is 932.

1 Public safety within the PG&E service territory is the primary focus of the
 2 lines of business (LOB) programs and projects included in this chapter as
 3 controls and mitigations.¹

**TABLE 15-1
RISK OVERVIEW**

Line No.	Risk Name	Third-Party Safety Incident
1	In Scope	Recordable third-party (public) injuries or fatalities due to interaction with or during the use of a PG&E facility, not involving asset failure.
2	Out of Scope	Third-party recordable injuries or fatalities resulting from the failure of an asset. Third-party gas dig-in recordable injuries or fatalities are included as key drivers for Gas Operations Loss of Containment Risks. Non-preventable motor vehicle incidents involving third-party interaction are included in the Motor Vehicle Safety Incident risk.
3	Data Quantification Sources	PG&E data including third-party initiated incidents logged in the Integrated Logging Information System, Transmission Operation Tracking & Logging tool, Serious Incidents Reports from PG&E's RiskMaster Database and Electric Incident Reports from 2012 through December 2019. ^(a)
(a) Source documents will be provided with the workpapers on July 17, 2020.		

4 **1. Risk Overview**

5 To place greater emphasis on third-party safety incidents, which do not
 6 involve the failure of a PG&E asset, and in alignment with PG&E's transition
 7 to an event-based risk register, with mutually exclusive risks that can be
 8 clearly modeled, the Third-Party Safety Incident risk has been added to the
 9 PG&E risk register and is included as a separate chapter in the 2020 RAMP
 10 Report.

11 PG&E's 70,000 square mile service territory in northern and central
 12 California consists of approximately 106,000 circuit miles of distribution
 13 electric lines, 18,000 circuit miles of interconnected transmission lines,
 14 42,000 miles of natural gas distribution pipelines, 6,400 miles of

¹ The information herein is subject to those limitations described in Chapter 2, Section D.

transmission pipelines, 67 powerhouses² and an extensive collection of facilities that support this infrastructure. With PG&E facilities located throughout northern and central California, third-party interaction with them is inevitable. Third-party interaction with PG&E facilities is addressed by PG&E's operating lines of business: Gas Operations, Electric Operations, and Power Generation, who have developed and have implemented or are continuing to implement programs to address third-party safety incidents unique to their facilities.

Significant third-party safety incidents with impacts to Gas Operations facilities include: Damage at Measurement and Control (M&C) Transmission or Distribution facilities due to vandalism or vehicle incidents; threats from construction and excavation activities; pipe damage through a third-party dig-in (discussed further in the Gas Operations Loss of Containment risks and out of scope for this risk); well failure arising from third-party damage; and meter station vehicular damage. PG&E's Third-Party Safety Incident risk controls and mitigation efforts for Gas Operations include public awareness programs, gas safety education, patrols, physical security, and the replacement, remediation, and retirement of facilities.

Public awareness programs reduce the threat of third-party damage to pipelines through educational outreach regarding safe excavation near pipelines. PG&E's gas safety communication efforts use a variety of media to effectively reach the greatest population possible within PG&E's service territory. These efforts include sending bill inserts, e-mails, brochures or letters to communicate gas safety information, providing targeted agricultural excavation safety messaging, and hosting 811 "Call Before You Dig" workshops. Patrols help to identify third-party threats from construction and excavation activities. Vandalism is mitigated through enhanced physical security efforts. Third-party safety is further enhanced with the retirement of gas gathering facilities, including idle pressurized pipe, and the replacement

² Company profile:
https://www.pge.com/en_US/about-pge/company-information/profile/profile.page
 (as of June 17, 2020).

1 and remediation of exposed and shallow pipe. This work further reduces the
2 likelihood of third-party contact.

3 Significant third-party safety incidents with impacts to Electric
4 Operations facilities include: wire down events; contact with energized
5 intact conductors; pole failures due to car-pole incidents, and vandalism and
6 third-party sabotage at substations. PG&E's Third-Party Safety Incident risk
7 controls and mitigation efforts for Electric Operations are focused on public
8 awareness programs, education, outreach efforts, and physical security
9 improvements.

10 Public awareness programs to educate non-PG&E contractors and
11 non-PG&E employees about power line safety and the hazards associated
12 with wire down events and are intended to reduce the number of third-party
13 electrical contacts. Outreach efforts include social media campaigns
14 focused on increasing customer awareness of overhead lines,
15 representation at local fire safe councils and community events and the
16 automated customer notification system. Security improvements can
17 include proactive equipment replacement, security measures and intrusion
18 detection devices.

19 Significant third-party safety incidents with impacts to Power Generation
20 facilities include: drownings, suicides, and boating incidents related to
21 PG&E-managed or owned hydroelectric facilities (dams, waterways, and
22 canals); interaction with job sites; falling object or vegetation-related
23 incidents. Hydroelectric Program objectives include third-party risk
24 reduction and public safety. Procedures are in place for planning for
25 unusual water releases along with their associated safety warnings.
26 Additional Power Generation compliance programs that support these
27 objectives include Public Safety Plans (PSP) as required by PG&E
28 hydroelectric facility Federal Energy Regulatory Commission (FERC)
29 licenses and FERC required Emergency Action Plans (EAP) for all
30 significant and high hazards dams. The Plans are exercised annually with a
31 seminar and phone drill.

32 Hydroelectric public awareness programs include hydroelectric safety
33 education, patrols, physical security, and facilities review. Programs such

1 as Time-Sensitive Dams/Sudden Failure Assessments, and Canals and
2 Waterways Safety are also being implemented.

3 A sunny-day cyber-attack at a dam could potentially put recreators
4 downstream of a dam at risk. This risk event would involve a component
5 failure due to cyber-attack. This event is also discussed in the Large
6 Uncontrolled Water Release (Dam Failure) risk chapter. Power Generation
7 has controls in place to prevent this event beyond controls in the IT systems;
8 instruments measuring component status and flow would alert operators to
9 components out of alignment. Further, at some watersheds, physical device
10 controls are in place during recreation preventing incidental movement and
11 some components also cannot be operated remotely.

12 Hydroelectric safety communication efforts use a variety of methods to
13 effectively reach the greatest population possible within PG&E's service
14 territory. These efforts include sending bill inserts, e-mails, brochures or
15 letters to communicate hydrogeneration facilities safety information. As an
16 example, in 2019, the Safe Kids Program resulted in reaching out to
17 66,000 teachers and educating 295,000 students.

18 **2. Risk Definition**

19 The definition of the Third-Party Safety incident risk is a PG&E
20 recordable third-party injury or fatality that is due to an interaction with or
21 during the use of a PG&E facility, not involving asset failure. Recordable
22 injuries include those which may result in a serious injury in alignment with
23 the DOSH definition or a fatality. Third party refers to a member of the
24 public who is a non-PG&E employee or a non-PG&E contractor.


25 **B. Risk Assessment**

26 **1. Background and Evolution**

27 The Third-Party Safety Incident risk is a new risk and has been added to
28 the PG&E event-based risk register. It is included in the 2020 RAMP based
29 on its risk score. The Third-Party Safety Incident risk places greater
30 emphasis on third-party safety incidents that do not involve the failure of a
31 PG&E asset and aligns with PG&E's transition to an event-based risk
32 register with mutually exclusive risks that can be clearly modeled.

2. Risk Bow Tie

**FIGURE 15-1
RISK BOW TIE – 2023 TEST YEAR**



3. Exposure to Risk

To quantify the Third-Party Safety Incident risk exposure, PG&E's RAMP model uses data from the PG&E Serious Incidents Reports, relevant information from PG&E's Riskmaster database and PG&E's Electric Incident Report (EIR). Electric Utilities must report to the CPUC any incident which results in a fatality or personal injury rising to the level of in-patient hospitalization; are the subject of significant public attention or media coverage; or, result in damage to property of the utility or others estimated to exceed \$50,000 and are attributable or allegedly attributable to utility-owned facilities. EIR data are also used to analyze reliability consequences. Annually, PG&E Electric Operations experiences approximately 3,400 incidents. Fewer than 1 percent of these result in a third-party serious injury or fatality. Note that Gas Operations reporting for dig-in incidents is out of scope for the risk.

4. Tranches

PG&E identified four tranches for the Third-Party Safety Incident risk.

- Third-party interaction with Electric Operations assets and job sites;
- Third-party interaction with Gas Operations assets and job sites;
- Third-party interaction with PG&E managed land and water; and
- Third-party interaction with Power Generation assets.

Third-party interaction with Electric Operations assets and job sites:

This tranche includes third-party safety incidents by driver and consequences related to serious injuries and fatalities, as well as reliability in Customer Minutes Interrupted, which are used to measure the duration of the customer's loss of power. Incidents that meet one or more of the electric incident reporting requirements are reported to the CPUC in the EIR. These incidents may also meet PG&E's reporting requirements for serious injuries or a fatality and are included in the PG&E Serious Incidents Report.

Third-party interaction with Gas Operations assets and job sites:

This tranche includes third-party safety incidents by driver and consequences related to serious injury and fatality, other than third-party gas dig-ins. Serious injuries and fatalities are included in the PG&E Serious Incidents Report.

Third-party interaction with Power Generation assets and PG&E managed/owned property:

The remaining two tranches include third-party interaction with power generation assets and PG&E managed/owned property. The tranches include third-party safety incidents by driver and consequences related to serious injury and fatality. Serious injuries and fatalities are included in the PG&E Serious Incidents Report.

The percent exposure and percent risk by tranche is shown in Table 15-2 below.

**TABLE 15-2
EXPSOURE AND RISK BY TRANCHE**

Line No.	Tranche Description	Percent Exposure	Electric Reliability Risk Score	Safety Risk Score	Total Risk Score	Percent Risk
1	Third-Party Interaction with Electric Operations Assets and Job Sites	25%	56	652	708	75%
2	Third-Party Interaction with Gas Operations Assets and Job Sites	25%	–	59	59	6%
3	Third-Party Interaction with Power Generation Assets and Job Sites	25%	–	7	7	1%
4	Third-Party Interaction with PG&E Managed Land and Water	25%	–	170	170	18%
5	Total	100%	56	887	944	100%

5. Drivers and Associated Frequency

PG&E identified nine drivers and five sub-drivers for the Third-Party Safety Incident risk. Each driver and its associated 2023 test year baseline frequency and key sub drivers are discussed below.

D1 – Car Pole/Guy: Refers to third-party vehicular contact with a PG&E pole or guy wire. Car pole/guy events accounted for 1,974 (58 percent) of the 3,417 expected annual number of risk events not involving an asset failure.

D2 – Electrical Contact: Refers to third-party contact with a PG&E electric asset. Electrical contact events accounted for 1,344 (39 percent) of the 3,417 expected annual number of risk events not involving an asset failure.

D3 – Others: Refers to a third-party incident that is not addressed by any of the other Third-Party Safety Incident risk drivers. Other events accounted for 92 (3 percent) of the 3,417 expected annual number of risk events that do not involve asset failure.

D4 – Job Site: Refers to a third-party incident resulting in a recordable injury or fatality that occurs at a PG&E job site. This driver includes three sub-drivers: job site slip, trip, fall-related; job site falling object/vegetation; and job site motor vehicle incident related. There are two annual expected interactions involving a PG&E job site included in the RAMP model dataset. The data for this driver is limited to those recorded in the PG&E Serious Incidents Report.

D5 – Drowning or Other Incidents at PG&E Owned/Managed Property:

Refers to third-party drownings or other water-related incidents resulting in a recordable injury or fatality that occur at a PG&E owned or managed property. This driver includes two sub-drivers: drowning or other incidents in PG&E managed/owned property; and drowning or other incidents in PG&E managed/owned property-hydro spill. There are two annual expected drownings or other incidents in PG&E managed/owned Property interactions included in the RAMP model dataset. The data for this driver is limited to those recorded in the PG&E Serious Incidents Report.

D6 – Slip/Trip/Fall: Refers to third-party slips, trips or falls resulting in a recordable injury or fatality that are the result of contact with a PG&E asset or that occur at PG&E job site or facility. There are two annual expected slip trip, or fall interactions included in the RAMP model dataset. The data for this driver is limited to those recorded in the PG&E Serious Incidents Report.

D7 – Suicide: Refers to third-party suicide that occurs on or at a PG&E asset or facility. There is one annual average suicide event associated with interactions included in the RAMP model dataset. The data for this driver is limited to those recorded in the PG&E Serious Incidents Report.

D8 – Falling Object/Vegetation: Refers to a recordable injury or fatality that is the result of a PG&E asset that falls onto or otherwise contacts a third party, or due to vegetation management activities (e.g., trimming or removal) by PG&E or PG&E contactors and that falls onto or otherwise contacts a third party. There are 0.5 annual expected interactions included in the RAMP model dataset. The data for this driver is limited to those recorded in the PG&E Serious Incidents Report.

D9 – Motor Vehicle Incident (non-pole related): Refers to third-party vehicular contact with a PG&E asset or facility (non-pole related) resulting in a recordable injury or fatality. There are 0.1 annual expected interactions in this category included in the RAMP model dataset which resulted in two fatalities. The data for this driver is limited to those recorded in the PG&E Serious Incidents Report.

6. Cross-Cutting Factors

A cross-cutting factor is a driver or control that is interrelated to multiple risks. PG&E is presenting eight cross-cutting factors in the 2020 RAMP.

1 There are no cross-cutting factors that directly impact Third-Party Safety
2 Incident risk.

3 When analyzing this risk PG&E considered the cross-cutting risk
4 Climate Change. Climate change presents ongoing and future risks to
5 PG&E's assets, operations, employees, customers, and the communities it
6 serves. During this RAMP period PG&E will conduct a Climate Vulnerability
7 Assessment (CVA) to further assess how its assets, operations, and
8 employees are vulnerable to the projected impacts of climate change.
9 PG&E intends to use findings from the CVA as well as developments in
10 climate science and internal data gathering to continue to advance the
11 quantification of all event-based risks, including RAMP risks, over this
12 RAMP period.

13 **7. Consequences**

14 The basis for measuring the consequences of the Third-Party Safety
15 Incident risk is: Does third-party interaction with a PG&E facility result in a
16 recordable injury or fatality.

17 The consequences of a third-party Incident risk event occurring are:

- 18 • Safety: Third-party Interaction with Injury or Fatality
- 19 • Reliability: Third-party Interaction with Reliability Impact.

20 PG&E relied on the PG&E Serious Incidents Reports and Electric
21 Incidents Reports from 2012 through 2019 to analyze the safety
22 consequences of the Third-Party Safety Incident risk. The PG&E Serious
23 Incidents Report includes serious injuries and fatalities related to third-party
24 events.

25 PG&E relied on the PG&E Electric Reliability Reports for customer
26 outage data from 2014 through 2019 to analyze the reliability consequences
27 of the Third-Party Safety Incident risk. The reported customer outage data
28 provides the duration of electric outages by circuit.

29 PG&E did not model financial consequences due to data confidentiality.

30 The consequences of the risk event are shown in Table 15-3 below.
31 Model attributes are described in Chapter 3, "Risk Modeling and Risk Spend
32 Efficiency."

TABLE 15-3
RISK EVENT CONSEQUENCES

	CoRE %Freq %Risk			Freq	Natural Units Per Event			CoRE		Natural Units per Year		Attribute Risk Score	
					Safety EF/event	Electric Reliability MCM/yr		Safety	Electric Reliability	Safety EF/yr	Electric Reliability MCM/yr	Safety	Electric Reliability
Public Interaction with Reliability Impact	0.2	99.8%	75%	3,412	0.004	0.03		0.2	0.02	12.5	113	652	56
Public Interaction	43	0.2%	25%	5	0.8	-		43	-	4.5	-	236	-
Aggregated	0.3	100%	100%	3,417	0.00	0.03		0.26	0.02	17.0	113	887	56

C. Controls and Mitigations

Tables 15-4 and 15-5 list all the controls and mitigations PG&E included in its 2017 RAMP (for the most part these are the 2019 baseline controls and mitigations), 2019 Gas Transmission and Storage Rate Case (GT&S), 2020 General Rate Case (GRC) and 2020 RAMP (2020-2022 and 2023-2026). The tables provide a view as to those controls and mitigations that are ongoing, those that are no longer in place, and new mitigations. In the following sections PG&E describes the controls and mitigations in place in 2019, changes to the 2019 mitigations and controls presented in the 2017 RAMP, and then discusses new mitigations and/or significant changes to mitigations and/or controls during the 2020-2022 and 2023-2026 periods.

**TABLE 15-4
CONTROLS SUMMARY**

Line No.	Control Name and Number	Line of Business and Reference to 2020 GRC ^(a)	2017 RAMP (Ref. to 2017 RAMP) ^(b)	2020-2022 GRC 2017-2020 Controls	2020-2022 RAMP	2023-2026 RAMP
1	C1 – PG&E Code of Safe Practices (CSP)	Gas Operations (GO), Electric Operations (EO), Power Generation (PGen)				X
2	C2 – Public Awareness Programs	EO (Exhibit (PG&E-4), Ch. 18)		X	X	X
3	C3 – Public Awareness Program (Bill Inserts)	EO (Exhibit (PG&E-4), Ch. 18)		X	X	X
4	C4 – Gas Operations Physical Security Controls	GO				X
5	C5 – Public Awareness Programs	GO (Exhibit (PG&E-3), Ch. 6)		X	X	X
6	C6 – Meter Protection Program	GO (Exhibit (PG&E-3), Ch. 4)		X ^(c)	X	X
7	C7 – Safe Kids Program – K-8 Safety Education	EO, GO, PGen			X	X
8	C8 – Hydroelectric FERC License PSP	PGen			X	X
9	C9 – Early Warning Systems, Signage and Alarms	PGen			X	X
10	C10 – Streetlight Conversions to LED Technology	EO (Exhibit (PG&E-4), Ch. 6)		X ^(d)		

**TABLE 15-4
CONTROLS SUMMARY
(CONTINUED)**

Line No.	Control Name and Number	Line of Business and Reference to 2020 GRC ^(a)	2017 RAMP (Ref. to 2017 RAMP) ^(b)	2020-2022 GRC 2017-2020 Controls	2020-2022 RAMP	2023-2026 RAMP
11	C11 – PG&E Electric Design Pole Location Requirements	EO			X	X
12	C12 - Visibility Strips on Electric Distribution Poles and Guy Markers	EO			X	X
13	C13 - Anti-Climbing Guard Assemblies for Steel Towers	EO			X	X
14	C14 – Hydro Facility Unusual Water Releases and Water Safety Warning Standard and accompanying procedure (PG-2727S and PG-2727P-01).	PGen			X	X
15	C15 - PG&E Dam Safety Surveillance and Monitoring Program (PG-2762S)	PGen			X	X
<p>(a) Application (A.) 18-12-009.</p> <p>(b) Investigation (I.) 17-11-003.</p> <p>(c) The Meter Protection Program was a mitigation, not control, in the 2020 GRC.</p> <p>(d) This program is included in the 2020 GRC but not listed as a risk mitigation.</p>						

TABLE 15-5
MITIGATIONS SUMMARY

Line No.	Mitigation Name and Number	Line of Business	2017 RAMP 2017-2019 Mitigations (Ref. to 2017 RAMP)	2019 GT&S 2020 GRC 2020-2022 Mitigations	2020 RAMP 2020-2022 Mitigations	2020 RAMP 2023-2026 Mitigations
1	M1 and M2 – Shallow and Exposed Pipe Replacement and Remediation Programs	GO (2019 GT&S, p. 4-37 ^(a))			X	X, although not included in the RAMP analysis
2	M3 – Time-Sensitive Dams/Sudden Failure Assessments	PGen			X	X, although not included in the RAMP analysis
3	M4 – Canals and Waterways Safety Barriers	PGen			X	X
4	M5 – EAPs for all significant and high hazards dams.	PGen			X	X, although not included in the RAMP analysis
5	M6 – System Hardening	EO			X	X, although not included in the RAMP analysis
6	M7 – 3A and 4C Line Recloser Controller Replacement	EO				X, although not included in the RAMP analysis
(a) A.17-11-009.						

1. 2019 Controls

The controls and mitigations proposed in the 2017 RAMP for the Third-Party Safety Incident risk were included as part of the individual lines of business risks. For the purposes of aligning the controls and mitigations from the 2017 RAMP with those PG&E is proposing for the 2020-2026 period, the Third-Party Safety Incident programs included by the lines of business in their risks in 2017 are listed below.

a. Controls

1) Gas Operations Controls

C1 – PG&E Code of Safe Practices (CSP) for all PG&E LOBs, including Electric Operations, Gas Operations, and Power

Generation: The CSP includes the requirement that for job sites on or near a roadway, work area protection devices and advance warning signs shall be placed and maintained in accordance with the “California Manual on Uniform Traffic Control Devices for Streets and Highways, January 13, 2012,” and/or the California Joint Utility Traffic Control Manual, February 2014 6th Edition. The requirements apply to all employees who oversee or are directly responsible for the protection of the public, PG&E employees and contractors entering a PG&E working area.

C4 – Physical Security: Gas Operations physical security controls protect against third-party interaction with gas facilities and include: security guards at the Compression and Processing and M&C facilities (e.g., McDonald Island, Topock, Los Medanos and Hinkley); facility fencing, security cameras, and vegetation management; security enhancements such as ballistic protection around critical components such as compressor stations and tanks; protection of exposed transmission pipe and valves by adding anti-climbing or concrete barriers; security enhancements related to communication systems such as adding visual and audible alarm annunciations, and upgrading existing security technology to include video analytics.

C5 – Public Awareness Programs: PG&E's Public Awareness Program: PG&E's Public Awareness Program conducts educational outreach activities for professional excavators, local public officials, emergency responders, and the general public who lives and works within PG&E's service territory. The program communicates safe excavation practices, required actions prior to excavating near underground pipelines, availability of pipeline location information, and other gas safety information throughout the year through a variety of methods including bill inserts, e-mails, brochures, mass media advertising, press releases, and participation in community meetings and events. PG&E communicates gas safety information multiple times each year. These efforts are aimed at increasing public awareness about the importance of underground gas facilities and the need to call 811 before an excavation project is started.³

C6 – Meter Protection Program (MPP): The purpose of the MPP is to protect meters and risers that are vulnerable to vehicular damage, and to install service valves where existing service valves are inaccessible. Preventing damage from vehicles is required in accordance with Title 49 of the Code of Federal Regulations – Transportation, Section 192.353. Meter protection is accomplished in four ways: inspections to confirm field conditions; installation of bollards; installation of valves; and relocation of meter sets. Alternative meter protection measures such as customer-installed permanent structures are also available.⁴

C7 – Safe Kids Program: The PG&E Safe Kids Program has been in place since 2001 and is also in use with Power Generation Hydroelectric and Electric Operations. The program follows a robust public safety outreach communications strategy including the development and delivery of comprehensive electric, gas, and hydroelectric public safety awareness classroom materials to all

³ The Gas Operations Public Awareness Program is included in PG&E's 2020 GRC, A.18-12-009, Exhibit (PG&E-3), p. 6-14 to p. 6-16.

⁴ The Gas Operations MPP is described in PG&E's 2020 GRC, A.18-12-009, Exhibit (PG&E-3), p. 4-27.

kindergarten through 8th grade schools throughout the PG&E service territory. The overarching program objective is to Save Lives and Prevent Injuries.

2) Electric Operations Controls

C1 – PG&E CSP for all PG&E LOBs, including Electric Operations, Gas Operations, and Power Generation: The CSP includes the requirement that for job sites on or near a roadway, work area protection devices and advance warning signs shall be placed and maintained in accordance with the “California Manual on Uniform Traffic Control Devices for Streets and Highways, January 13, 2012”, and/or the California Joint Utility Traffic Control Manual, February 2014 6th Edition. The requirements apply to all employees who oversee or are directly responsible for the protection of the public, PG&E employees and contractors entering a PG&E working area.

C2 – Public Awareness Programs: Public awareness programs educate third-party workers and the public about power line safety and the hazards associated with wire down events. These programs are intended to reduce the number of third-party electrical contacts and as a control, has the potential to reduce exposure to Third-Party drivers and the consequences related to Safety Injuries and Fatalities. The programs consist of outreach efforts describing the hazards associated with working around power lines through various delivery channels. PG&E plans to continue outreach for each of the following programs, though the delivery channels may vary each year:

- Worker Beware Program: Communications targeting third-party contractors within PG&E’s service territory. Includes direct mailings of safety material, offers of additional complimentary safety and training materials.
- Logging Safety Program Outreach: Communications targeting the logging industry. Includes delivery channels such as brochures, social media, visor cards, safety posters, and DVDs.

- Third-Party Tree Workers Program: Communications targeting stakeholders with operations within PG&E’s service territory.
- Orchard Worker Safety Program: Communications targeting northern California orchards. Includes direct mailings as well as safety training videos.
- Mind-the-Lines Program: Social media campaign focused on increasing customer awareness of overhead lines.

C3 – Public Awareness Program (Bill Inserts): Draft and mail out bill inserts that inform customers of the dangers related to wire down events and the hazards associated with performing activities around intact overhead conductors. The material will be distributed in paper form and electronically within a monthly bill. Continuing to send bill inserts increases the volume of public safety messaging with the goal of making the general public more aware of the hazards associated with wire down events or overhead conductor. This may reduce the number of Third-Party Contact with Intact Conductor and the exposure related to the Third-Party (Wire Down) contact events.

C7 – Safe Kids Program: The PG&E Safe Kids program has been in place since 2001 and is also in use with Power Generation Hydroelectric and Gas Operations. The program follows a robust public safety outreach communications strategy including the development and delivery of comprehensive electric, gas, and hydroelectric public safety awareness classroom materials to all kindergarten through 8th grade schools throughout the PG&E service territory. The overarching program objective is to Save Lives and Prevent Injuries.

C10 - Streetlight Conversions to LED Technology: Electric Operations had conversion of approximately 120,000 of the 140,000 PG&E-owned conventional streetlights in PG&E’s service territory to LED technology, which improves public safety by providing brighter and more reliable lighting while reducing energy usage.

C11 – PG&E Electric Design Manual Pole Location

Requirements: The PG&E Electric Design Manual includes

specifications for locating poles so that all portions of the line are within rights-of-way and easement requirements, clearances from trees and vegetation, and states that all applicable PG&E requirements stipulating proper pole easements and locations must be followed including compliance with CPUC General Order 95. Specifications include key considerations when locating or relocating poles is to avoid car pole incidents. If at all possible, place poles away from high-risk locations and as far as practical from traveled roadways. High-risk locations include, among others: (1) The outside of roadway curves, especially curves immediately downstream from long, straight sections of roadway; (2) End-of-lane “drops” (where a traffic lane suddenly ends); (3) Traffic islands

C12 – Visibility Strips on Electric Distribution Poles and Guy

Markers: Emphasis on the presence of electric distribution system poles is a primary consideration when determining whether to mark electric distribution mark poles and guy markers. Reflective visibility strips shall be installed on wood, fiberglass, steel power poles, or guy poles, and guy markers as follows:

- a) On poles and guy markers installed on state highways, in accordance with the marking section of the Caltrans Traffic Manual.
- b) On poles and guy markers located within 15 feet from the paved surface or 15 feet from the edge of the traveled, unpaved portion of city or county roads (streets) where not protected by curbs.
- c) On poles and guy markers within 6 feet of an adjacent driveway, private roadway (street intersection), turnaround, parking lot, or thoroughfare in rural district, capable of being traversed by vehicles where not protected by curbs.

Visibility strips should not be installed where there is no reasonable expectation of traffic. For example: Cross country poles, poles through waterways or wetlands, rear easement poles, poles behind guardrails, or poles on embankments that are well above or below the road.

If existing visibility strips become damaged or otherwise do not serve their intended purpose, they shall be replaced in accordance with PG&E documentation for the Marking, Numbering, and Identification of line structures.

C13 – Anti-Climbing Guard Assemblies for Steel Towers:

Guards are placed in the vicinity of transmission tower legs to prevent potentials climbers from getting a hand or foothold. Guards must not be installed above a point on the tower leg that would prevent climbing by Company employees using a 20-foot extension ladder (approximately 16 feet).

3) Power Generation Controls

C1 – PG&E CSP for all PG&E LOBs, including Electric

Operations, Gas Operations, and Power Generation: The CSP includes the requirement that for job sites on or near a roadway, work area protection devices and advance warning signs shall be placed and maintained in accordance with the “California Manual on Uniform Traffic Control Devices for Streets and Highways, January 13, 2012”, and/or the California Joint Utility Traffic Control Manual, February 2014 6th Edition. The requirements apply to all employees who oversee or are directly responsible for the protection of the public, PG&E employees and contractors entering a PG&E working area.

C7 – Safe Kids Program: The PG&E Safe Kids program has been in place since 2001 and is also in use with Gas Operations and Electric Operations. The program follows a robust public safety outreach communications strategy including the development and delivery of comprehensive electric, gas, and hydroelectric public safety awareness classroom materials to all kindergarten through 8th grade schools throughout the PG&E service territory. The overarching program objective is to Save Lives and Prevent Injuries. For Power Generation, there is additionally focused outreach to schools within zip codes that have our hydrogeneration facilities including powerhouses and canals. The 2019 program has resulted in reaching out to 66,000 teachers and educating 295,000 students.

1 **C8 – Public Safety Plans (PSP):** Per PG&E Utility Standard
2 PG-2129S, Power Generation conducts a review of each hydro
3 project's PSP annually. PSPs are a regulatory requirement for each
4 of PG&E's hydro FERC licenses. Each PSP must be updated and
5 filed with FERC at least once every 10 years, more frequently if
6 significant changes occur or upon request by FERC. Over the past
7 five years, PG&E has implemented significant improvements to the
8 PSP format. Currently, 16 of the 25 PSPs have been re-filed in the
9 newer formats. In 2019, the Kerkoff and Mokulumne PSPs were
10 filed. An updated Drum Spaulding PSP will be filed. Over the next
11 five years, the goal is to have all 25 PSPs filed in the newer formats.

12 **C9 – Early Warning System Signage and Alarms:** In 2019 Early
13 Warning Technologies (EWT) were identified and recommended for
14 the time-sensitive dams. Examples of EWT's include sirens,
15 automated notification systems and increased signage. PG&E
16 Public Safety is working with the project planning team to launch
17 several projects to implement EWT's for time-sensitive dams. The
18 initial phases of this program are in place with continued
19 improvements in progress.

20 **C14 – Hydro Facility Unusual Water Releases and Water Safety**
21 **Warning Standard and accompanying procedure (PG-2727S**
22 **and PG-2727P-01):** The documents establish PG&E Hydro facility
23 requirements for planning and making unusual water releases or
24 high flow events and their associated safety warnings.

25 **C15 – PG&E Dam Safety Surveillance and Monitoring Program**
26 **(PG-2762S):** PG-2762S establishes and defines PG&E's Dam
27 Safety Surveillance and Monitoring Program for the continued
28 long-term safe and reliable operation of PG&E's dams. Dam
29 surveillance involves the collection of data by various means,
30 including inspections and instrumentation, whereas monitoring
31 involves the review of the collected data as obtained and over time
32 for any adverse trends.

1 **b. Mitigations**

2 **1) Gas Operations Mitigations**

3 **M1 and M2 – Shallow and Exposed Pipe:**⁵ The Shallow and
 4 Exposed Pipe Programs were established to address the risks
 5 posed by shallow and exposed pipe on both land and locations of
 6 water/levee crossings. The purpose of the land-based portion of the
 7 Shallow and Exposed Pipe Program is to identify, prioritize, and
 8 mitigate locations where pipeline: has insufficient cover; is
 9 vulnerable to exposure from third parties; or has become exposed
 10 due to natural forces. The depth of pipelines installed by PG&E
 11 meet or exceed the minimum depth requirement in effect at the time
 12 of initial construction, however, over time, initial depth of cover may
 13 become reduced or the pipe may become exposed due to natural
 14 forces, such as erosion or stream washouts. This program
 15 enhances public safety and improves system reliability by prioritizing
 16 pipe for re-burial or replacement through a risk-based engineering
 17 analysis that considers the pipeline specifications manufacturing
 18 details, as well as operating and maintenance history. The water
 19 and levee crossing portion of this program was established to
 20 organize and catalog information, maps, drawings, leases, and
 21 permits regarding pipeline installations in waterways and levees.
 22 PG&E's Water and Levee Crossing Program improves system
 23 safety and reliability by identifying and evaluating erosion, third-party
 24 damage threats, and other hazards to trenched-in pipeline
 25 installations located under waterways, and within levee structures.
 26 This program assesses and monitors: 129 jurisdictional waterways;
 27 177 levees; and an estimated 900 non-jurisdictional waterways
 28 throughout PG&E's service territory. Additionally, between 2019
 29 and 2021, this program will assess an estimated additional
 30 5,000 pipeline locations which cross intermittent or seasonal

5 See Chapter 7, "Loss of Containment on Gas Transmission Pipeline," Section C, Mitigation M5 (Shallow Pipe) and Mitigation M6 (Exposed Pipe).

waterways. PG&E replaced 0.5, 1.0, and 0.7 miles of shallow and exposed pipe in 2017, 2018, and 2019, respectively.

2) Electric Operations Mitigations

PG&E identified two Electric Distribution mitigations that will also mitigate third-party safety risk.

M6 – System Hardening: This program is described in Chapter 11, “Failure of Electric Distribution Overhead Assets.”

M7 – 3A and 4C Line Recloser Program: This program is described in Chapter 11, “Failure of Electric Distribution Overhead Assets.”

3) Power Generation Mitigations

M3 – Public Outreach, Time-Sensitive Dams, Sudden Failure

Assessments: In 2019 a sudden failure assessment was performed for PG&E’s time-sensitive dams. A sudden failure assessment analyzes the detection, verification, notification and emergency management response time and compares it with the arrival of a flood inundation wave. 33 of PG&E’s dams are classified as “time-sensitive.” Time-sensitive is defined as: in the event of a dam failure or large uncontrolled release of water; homes, businesses, or recreation facilities could be flooded by a dam inundation before being notified by local emergency management agencies. In 2019 PG&E developed and mailed a general information brochure to more than 7,000 recipients who could be affected by a time-sensitive dam, notifying them that they live near a time-sensitive area and encouraging them to plan for the unlikely event of a sudden dam failure. Each brochure notifies the reader that they live near a Time-Sensitive area and encourages them to plan for the unlikely event of a sudden dam failure. In addition to the mailer, in 2019 EWT’s were identified and recommended for the time-sensitive dams. Examples of EWT’s include sirens, automated notification systems and increased signage. PG&E Public Safety is working with the project planning team to launch several projects to implement EWT’s for time-sensitive dams. In 2020, PG&E has

1 issued a contract to have a consultant perform sudden failure
 2 assessments for the remainder of the PG&E EAP dams, to confirm
 3 that they are still not time-sensitive. Updated inundation maps are
 4 utilized with modern flood modeling and analysis of developments
 5 near PG&E dams to determine if changes exist that would make a
 6 dam time-sensitive.

7 **M4 – Canals and Waterways Safety:** In 2019 Power Generation
 8 installed 10,497 linear feet of barrier fencing along PG&E's canal
 9 systems. Most of these fencing projects were completed in the
 10 Drum system and were identified through a systematic risk ranking
 11 assessment. In 2020 PG&E is forecasting 14,000 linear feet of
 12 barrier fencing installation. In 2019 PG&E also addressed the
 13 positioning and design of canal escape aids. Using industry
 14 benchmarking and canal attributes, PG&E determined locations for
 15 escape aids, and are installing 139 ladders along the Drum system
 16 canals. In 2019, Power Generation created a new brochure and
 17 mailed it to approximately 1,100 customers. The brochure provides
 18 safety information to property owners with canals that bisect their
 19 property. In 2019, a new canal entry emergency response plan was
 20 published to guide efficient and timely communications between
 21 PG&E personnel and local first responders when responding to
 22 emergencies resulting from public entry into PG&E-owned water
 23 conveyance systems. Delays in routing these calls to the
 24 appropriate hydroelectric generation switching centers can hamper
 25 response efforts. This document provides PG&E with a defined
 26 communications plan that helps to ensure an expedient response to
 27 search and rescue/recovery efforts.

28 **M5 – Emergency Action Plans (EAP):** In accordance with State
 29 and Federal regulations, PG&E maintains EAPs for all significant
 30 and high hazards dams.⁶ Per FERC guidelines each EAP must be

6 FERC defines a significant hazard potential as:

1 tested annually with a seminar and phone drill. Every five years a
 2 tabletop and functional exercise is required. In 2019, five EAP
 3 seminars and two tabletop exercises were held. A total of
 4 172 participants joined in these exercises with participants including
 5 state and local emergency management agencies, state and federal
 6 regulators, localities impacted by dams, and PG&E personnel.
 7 Fourteen EAP phone drills were held in 2019 to verify and test
 8 PG&E emergency notification flow charts for EAP dams. A total of
 9 272 stakeholders participated in the phone drills.

10 The following EAP initiatives have been identified for 2020:

- 11 • Introduce web-based EAP training for appropriate PG&E staff.
- 12 • Establish and implement an Automated Notification System to
 13 be used in EAP activation.
- 14 • Integrate electronic EAPs and associated files (i.e., inundation
 15 maps and shapefiles) into DamWatch for stakeholder access.
- 16 • Incorporate a welcome/thanks video from Power Generation
 17 leadership into EAP exercises.

18 **D. 2020-2022 Controls and Mitigations**

19 All of the controls listed in Section C.1.a above will continue from
 20 2020-2022.

21 The Gas Operations and Power Generation mitigations described in
 22 Section C.1.b will continue through the 2020-2022 period.

23 PG&E identified one Electric Operations mitigation – System Hardening –
 24 that will also help to reduce the Third-Party Safety Incident risk, specifically the
 25 Electrical Contract driver. Electric Operations describes this mitigation in
 26 relation to two risks, Failure of Electric Distribution Overhead Assets and

“those dams where failure or mis-operation results in no probably loss of human life but can cause economic loss, environmental damage, disruption of lifeline facilities, or can impact other concerns. Significant hazard potential classification dams are often located in predominantly rural or agricultural areas but could be located in areas with population and significant infrastructure.: FERC defines a high hazard potential as, “. . . those where failure or mis-operation will probably cause loss of human life.” See, Federal Emergency Management Agency, Federal Guidelines for Dam Safety, Hazard Potential Classification System for Dams, April 2004, pp. 5-6.

Wildfire.⁷ System Hardening includes several activities designed to reduce wildfire risk, electric outages and equipment line failure. One of the System Hardening activities, replacing uninsulated wire with covered conductor, will also help to reduce Third-Party Safety Incident risk by reducing third-party contacts with electric wires. The System Hardening mitigation is described below.

M6 – System Hardening: PG&E is planning to upgrade approximately 7,000 miles of overhead distribution circuit in High Fire Thread District (HFTD) Tier 2 and Tier 3 areas to reduce the risk of wildfire ignitions associated with overhead equipment. The upgrades will include: replacing existing uninsulated wire with covered conductor; replacing poles as necessary to support the weight of the new covered conductor and/or for fire resilience; replacing non-exempt line equipment with lower fire risk equipment; and replacing transformers with lower fire-risk and higher efficiency models. In addition to reducing the risk of wildfire ignitions, this mitigation will also reduce outages and equipment failures, for example due to vegetation-conductor contact or conductor to conductor contact in high winds.

E. 2023-2026 Proposed Mitigation Plan

PG&E will continue to implement the five mitigations described in Section C.1.b above in the 2023-2026 period. The work planned for M1 and M2, Shallow and Exposed Pipe, is described in Chapter 7, “Loss of Containment on Gas Transmission Pipeline.” The controls listed in Section C.1.a above will continue from 2023 to 2026.

The activities for Mitigation 3 (Public Outreach, Time-Sensitive Dams, Sudden Failure Assessments) Mitigation 4 (Canals and Waterways Safety), Mitigation 5 (EAP) and Mitigation 6 (System Hardening) remain as described above.

Mitigation 4 (Canals and Waterways Safety) is directly applicable to reducing injuries associated with interactions with PG&E’s facilities that do not involve an asset failure. It has been included in the RAMP 2020 plan.⁸

⁷ See Chapter 11, Failure of Electric Distribution Overhead Assets, Section C, Mitigation M3 and Chapter 10, Wildfire, Section C, Mitigation M2.

⁸ Costs for this mitigation are included in WP 15-1.

PG&E identified an additional Electric Operations mitigation – 3A and 4C Line Recloser Controller Replacement – that will start in 2023 and will also help to reduce the Third-Party Safety Incident risk, specifically the Electrical Contract driver. Electric Operations describes this mitigation in relation to it Failure of Electric Distribution Overhead Assets risk.⁹ Replacing older recloser controllers is designed to improve PG&E’s ability to isolate faults and re-energize circuits. One of the benefits of replacing the 3A safety hazards due to fault conditions including wire-down incidents. The 3A and 4C Line Recloser Controller Replacement mitigation is described below.

M6 – 3A and 4C Line Recloser Replacement Program: PG&E uses line reclosers across its DOH system to manage, locate/isolate faults and re-energize circuits in the event of an outage. Some of these line recloser units use older model 3A or 4C controllers, which have limited functionality compared to newer controller models. These functional limitations increase the risk of circuit failure and impact PG&E’s ability to isolate faults and re-energize circuits in the event of an outage. Line reclosers are also categorized as protective devices, and are programmed to protect customers from safety hazards due to fault conditions including wire-down incidents, sustained outages etc. There is a high risk of such fault incidents if these devices do not operate as intended. To mitigate this risk, PG&E proposes to replace all 3A and 4C line recloser controllers in its system with newer models.

Table 15-6 below shows the risk reduction scores for the proposed mitigations. The costs for the three mitigations are borne by the line of business implementing the mitigation: System Hardening is sponsored by Electric Operations, see Chapter 10, Wildfire; Canals and Waterways Safety Barriers, is sponsored by Power Generation;¹⁰ and 3A and 4C Line Recloser Program is sponsored by Electric Operations, See Chapter 11, Failure of Electric Distribution Overhead Assets. While the costs for these mitigations are

⁹ See Chapter 11, “Failure of Electric Distribution Overhead Assets,” Section C, Mitigation M10.

¹⁰ The forecast expense costs for Mitigation 4 are: \$675,000 (2020); \$695,250 (2021); \$716,108 (2022); \$737,501 (2023); \$759,718 (2024); \$782,510 (2025); and \$805,985 (2026). See WP 15-1.

sponsored by other lines of business, the benefits of these mitigations still apply to the Third-Party Safety Incident risk.

**TABLE 15-6
RISK REDUCTION**

Line No.	Mit. No.	Mitigation Name	RSE ^(a)	Risk Reduction
1	M2	System Hardening	–	103.0
2	M4	Canals and Waterways Safety Barriers (b)	1.7	3.8
3	M10	M10- 3A and 4C Line Replacement	–	4.0

(a) See Mitigation Effectiveness workpapers (MW) included in the source document modeling package for information used to calculate the Risk Spend Efficiency (RSE).

F. Alternative Analysis

In addition to the proposed mitigations described in Section E above, PG&E considered alternative mitigations as well. The mitigations described in Section E constitute the Proposed Plan. The Alternative Plans consist of a combination of some or all of the proposed mitigations along with the alternative mitigation(s). PG&E describes each of the alternative mitigations it considered below and then provides a table showing the forecast costs, RSEs and risk reduction scores for each of the Alternative Plans.

1. Alternative Plan 1: Targeted Third-Party Electric Safety Pilot Program

PG&E will design and conduct a pilot program to target regions or circuits that have a high number of, or high rate of,¹¹ third-party contact with electric assets incidents. PG&E will analyze its third-party electric asset contact data to identify those regions or circuits where third-party contact with electric assets is most prevalent. It will evaluate the physical locations and types of incidents to determine which of the potential mitigation options are most likely to reduce the third-party electric contact risk in each specific location.

The potential mitigation options include:

¹¹ PG&E will evaluate both locations with the highest number of individual incidents and areas where there are the highest incident rates – the highest number of incidents per circuit mile.

- Eliminate the Hazard – Eliminate the hazard by undergrounding a for portion of the electric power lines.
- Engineering Control – Reduce the likelihood that a third-party vehicle will contact a PG&E pole by relocating power poles, installing crash barriers, and/or another type of pole diversion.
- Public Awareness – Increase public awareness as to the location and potential danger of contacting an electric asset by installing visibility strips, reflective paint, and/or additional signage and conducting marketing campaigns.

Designing and implementing the pilot program will require close coordination with municipalities and landowners where PG&E's assets are located. This will ensure that the mitigations PG&E is proposing meet all municipal requirements and will give PG&E an opportunity to better estimate the number and type of mitigations that reduce the most risk in different situations and are the most cost effective.

PG&E will provide an update about this pilot program in the 2023 GRC.

**TABLE 15-7
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026 CAPITAL
(THOUSANDS OF DOLLARS)**

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	A1	Targeted Third-Party Electric Safety Pilot Program	\$250	\$256	\$263	\$269	\$1,038	147	112

(a) See Mitigation Effectiveness workpapers (MW) included in the source document modeling package for information used to calculate the RSE.

Note See WP 15-1.

2. Alternative Plan 2: Delay Installation of Canals and Waterways Safety Barriers

Alternative 2 considers delaying the installation of canals and waterways safety barriers by two years. PG&E prefers to maintain the planned schedule. It is possible that this mitigation could be delayed due to resource

- 1 limitations and/or work planning or coordination issues. PG&E did not select
 2 this alternative because it would delay important safety work.

**TABLE 15-8
RSE AND RISK REDUCTION
2023-2026**

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total	RSE	Risk Reduction
1	A2	Delay Canals and Waterways Barrier Installation	\$738	\$760	\$783	\$806	\$3,086	1.7	3.8

Note See WP 15-1.

- 3 Table 15-9 compares the proposed and alternative mitigation plans.

**TABLE 15-9
MITIGATION PLAN ALTERNATIVES ANALYSIS
(THOUSANDS OF DOLLARS)**

Line No.	Risk Mitigation Plan	Plan Components ^(a)	Total Expense (2023-2026)	Total Capital (2023-2026)	Risk Reduction (NPV) ^(a)	Total Spend (NPV) ^(b)	RSE
1	Proposed	M2, M4, M10	—	\$3,086	111	\$2,267	49
2	Alternative 1	Proposed + A1	\$1,038	\$3,086	222	\$3,030	73
3	Alternative 2	M2, M10 + A2	—	\$3,086	111	\$2,267	49

(a) Plan Components refers to the Mitigations presented in Table 15-5.

(b) Information presented in terms of Net Present Value (NPV) to account for the discounting of benefits.

Note See WP 15-2.

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 16
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: EMPLOYEE SAFETY INCIDENT

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 16
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: EMPLOYEE SAFETY INCIDENT

TABLE OF CONTENTS

A. Executive Summary.....	16-1
1. Risk Overview	16-2
2. Risk Definition	16-5
B. Risk Assessment.....	16-6
1. Background and Evolution	16-6
2. Risk Bow Tie	16-7
3. Exposure to Risk.....	16-7
4. Tranches	16-8
5. Drivers and Associated Frequency	16-8
6. Cross Cutting Factors	16-10
7. Consequences	16-11
C. Controls and Mitigations	16-14
1. 2019 Controls.....	16-20
2. 2019 Mitigations.....	16-24
a. Employee Safety Risk Mitigations	16-24
b. FFD Awareness Mitigations	16-27
D. 2020-2022 Controls and Mitigations	16-27
1. Changes to Controls	16-27
2. Changes to Mitigations.....	16-27
E. 2023-2026 Proposed Mitigation Plan.....	16-31
F. Alternative Analysis	16-34
1. Alternative Plan 1: IH Program Compliance Improvements – Phase 2	16-34
2. Alternative Plan 2: Employee Safety Field Inspections for PG&E Work Locations	16-35

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 16
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: EMPLOYEE SAFETY INCIDENT

A. Executive Summary

Employee Safety Incident refers to any event resulting in an Occupational Safety and Health Administration (OSHA)-recordable¹ injury or fatality, excluding events resulting from asset failure. The drivers for this risk event are: contact with objects and equipment; exposure to harmful substances or environment; falls, slips or trips; fire and explosion; bodily reaction and exertion; and violence or other injuries by persons or animals. The cross-cutting factors of Skilled and Qualified Workforce, Records and Information Management, Physical Attack, and Climate Change also impact this risk event.

Exposure to this risk is measured as the approximately 22,000 members of Pacific Gas and Electric Company's (PG&E or the Company) workforce. The risk model includes 603 risk events each year. The drivers responsible for the most risk are: overexertion and bodily reaction, representing 18 percent of the risk events and 18 percent of the risk; typing, key-entry or mousing, representing 9 percent of the risk events and 9 percent of the risk; straining in twisting/turning, representing 8 percent of the risk events and 8 percent of the risk. The mitigations PG&E will implement from 2020 to 2026 are designed to address these key risk drivers.

PG&E identified 2 tranches for this risk event: office-based employees and field employees. The types of risk to office-based employees are significantly different than the types of risk faced by field employees. 74 percent of the risk events are associated with the field employees tranche.

Employee Safety Incident has the fifth highest 2023 test year (TY) safety score (86) and the eighth highest 2023 TY total risk score (90) of PG&E's 12 Risk Assessment and Mitigation Phase (RAMP) risks. The 2020 baseline

¹ An OSHA-recordable event is defined as work related injuries or illnesses that must be reported to OSHA and that results in any of the following: medical treatment beyond first aid; loss of consciousness; one or more days away from work following the incident; restricted work or transfer to another job; any significant injury or illness diagnosed by a physician; any work-related fatality.

1 risk score of 93, improves by 28 percent when the planned mitigations are
 2 applied: the 2023 TY risk score is 90 and the 2026 post-test year risk score
 3 is 66.

4 PG&E is proposing a series of controls and mitigations to address Employee
 5 Safety Incident risk. The Enterprise Safety Management Systems (ESMS),
 6 Vehicle Ergonomics Program and the On-Site Clinics have the highest Risk
 7 Spend Efficiency (RSE) scores. The ESMS and On-Site Clinics have the
 8 highest total risk reduction scores.²

**TABLE 16-1
RISK OVERVIEW**

Line No.	Risk Name	Employee Safety Incident
1	In Scope	PG&E employee OSHA-recordable injuries and fatalities that are not the result of an asset failure.
2	Out of Scope	PG&E employee OSHA-recordable injuries and fatalities resulting from the failure of an asset.
3	Data Quantification Sources ^(a)	PG&E data including: PG&E Human Resources Report (HR) (2008-2018). PG&E Cal-OSHA-recordable data by claim cause and claim cause category Incident Detail Report (2008-May 2019) PG&E Safety and Environmental Management System (SEMS) Database. PG&E serious employee injuries and fatalities from the Serious Incidents Report including earlier versions (2008-2019)
(a) Source documents will be provided with the July 17, 2020 RAMP update.		

9 **1. Risk Overview**

10 PG&E has approximately 22,000 employees who provide natural gas
 11 and electric services to approximately 16 million people throughout PG&E's
 12 70,000-square-mile service area.

13 PG&E's team includes safety and health professionals who focus on
 14 preventing employee illness and injuries through: strategic planning,
 15 governance, oversight, analytics and reporting functions; expert field safety

² The information presented herein is subject to the limitations described in Chapter 2, Section D.

support to drive strategy, programs and continuous improvement; workers' compensation case management and expertise helping our workforce stay at work and return to work; serious injury and fatalities prevention, life safety, regulatory compliance and governance, and workforce health programs; Safety Leadership Development (SLD), field observations, and assessing safety program impact; and incident investigations and human factor analyses.

Key programs that PG&E's Safety and Health organization is responsible for include:

- PG&E Occupational Health and Safety Plan (One Plan), which is a comprehensive view for improving employee and contractor safety and health through 2022. The One Plan is divided into Focus Areas for supporting goals and strategies and incorporates best practice safety programs. As such, it is dynamic in nature and is continually refreshed to accommodate changes in the business. As part of 2025 strategy the One Plan will transition to a foundation for performance improvement by increasing leadership presence in the field, clarifying responsibilities and work standards, and adopting lessons learned across the organization.
- Enterprise Safety Management System to manage risk to PG&E employees and contractors. As previously discussed in the 2017 RAMP, planning and preparation for the ESMS took place from 2017 through 2019 with implementation beginning in 2020. The ESMS consists of a series of capabilities (people, process, governance, and technology systems) required to define, plan, implement, and continuously improve workforce safety. The ESMS becomes the way PG&E "delivers the business of safety" and is based on a consistent and comprehensive enterprise safety controls framework reinforced with system assurance. PG&E's commitment is to implement the system by 2022.
- Field safety operations works with the lines of business (LOB) to deliver safety programs to improve safety culture, identify hazards, and reduce incidents and injuries in the field. The goal of field safety is to identify and reduce risk exposures through observations, supporting incident

investigations, training, hazard identification, safety tailboards, program implementation support and emergency response.

- PG&E's Serious Injury or Fatality (SIF) Program focuses on the specific exposures which have led to serious injuries and fatalities. PG&E worked with Behavioral Science Technology, Inc. to analyze employee incident data and identified 22 categories of exposure factors, using criteria from the Herbert William Heinrich Safety Triangle Theory for Industrial Accident Prevention and industry criteria and processes.

All injuries and reported near hits are evaluated relative to the SIF exposure factors, and the team conducts in-depth Cause Evaluations for all incidents classified as SIF-potential or SIF-actual. The results of these investigations are monitored through the Corrective Action Program (CAP) as PG&E develops corrective actions to reduce the likelihood of recurrence. PG&E also observes field work groups and provides immediate feedback relative to potential safety issues and collects data about SIF exposure factors and risky behaviors.

- Enterprise CAP The Enterprise CAP provides a centralized, standardized governance structure, and process for issue identification and resolution. The CAP process enables employees and contractors the ability to identify and report issues, or ideas, related to gas assets, and processes. The CAP process ensures that issues are categorized, assessed for risk, and assigned to the appropriate owner to resolve issues and implement effective corrective actions to help prevent recurrence. In 2019, PG&E employees and contractors submitted approximately 40,000 CAP issues company wide. Examples of how CAP improves safety:
 - A PG&E employee recognized that there were potentially counterfeit parts on a forklift PG&E had rented. The counterfeit part is known to fail at 40 percent of the stated capacity and could have resulted in a SIF. Through the CAP process, this issue was documented and reviewed and resulted in a change to PG&E's equipment rental process.
 - A PG&E employee recognized there were brass insulators being used that had a history of failing while employees were conducting

1 work, exposing employees to potential burn-related injuries.

2 Through CAP, a replacement program resulted in replacing
3 4,400 insulators at more than 100 PG&E substations.

- 4 – While reviewing PG&E's Employee Life Safety Training courses, an
5 employee noted the absence of guidance related to active shooter
6 scenarios and submitted a CAP item, then three PG&E training
7 courses were developed and implemented to provide employees
8 training on responding to an active shooter event.

9 PG&E has also instituted SLD and Operational Learning. PG&E has
10 accelerated SLD training for crew leaders (crew leaders lead teams of
11 front-line employees doing field operations and maintenance work) so they
12 have the necessary safety skills to create trust, set expectations, remove
13 barriers to safety and identify and mitigate at-risk behaviors. SLD also
14 includes reducing the administrative responsibilities on its front-line leaders
15 to enable them to spend more time in the field. Operational Learning tools
16 help drive continuous improvements in safety. For example, PG&E may
17 bring together skilled facilitators and employees to develop solutions to
18 ongoing safety issues. Operational Learning shifts the focus from blaming
19 an employee when something goes wrong to understanding what happened
20 and how to prevent it from happening again. For instance, through
21 operational learning, PG&E developed and implemented a revised vehicle
22 familiarization/driving training program to reduce preventable motor vehicle
23 incidents resulting from backing into stationary objects after learning from
24 PG&E employees that they were not adequately trained and prepared to
25 operate Company vehicles

26 **2. Risk Definition**

27 Any event resulting in an employee OSHA-recordable injury or fatality,
28 excluding events resulting from asset failure.

1 B. Risk Assessment

2 1. Background and Evolution

3 The Employee Safety risk was included in PG&E's 2017 RAMP.³ In the
4 2020 RAMP, the Employee Safety Incident event has changed from the
5 2017 RAMP. The Employee Safety Incident risk event is now defined as
6 "Employee Safety Incident" instead of the 2017 definition, "failure to identify
7 and mitigate occupational exposures that result in an employee OSHA
8 recordable injury/illness or fatality." The 2017 RAMP risk definition focused
9 on potential occupational exposures, whereas the 2020 RAMP risk event
10 focuses on actual employee safety incidents.

11 In the 2017 RAMP, PG&E presented two risks related to employee
12 safety: Employee Safety (Chapter 15) and Lack of Fitness for Duty (FFD)
13 Program Awareness (Chapter 17). The two risks are closely aligned, and
14 FFD Program Awareness is no longer a risk on PG&E's Enterprise Risk
15 Register. Previously, the Employee Safety risk was defined as the failure to
16 identify and mitigate occupational exposures that may result in employee
17 injuries or fatalities. The FFD Program Awareness risk was defined as
18 PG&E people leaders (directors, managers, superintendents and
19 supervisors) who fail to identify and act upon observed behaviors that
20 indicate an employee may be unable to work safely, which could result in an
21 employee injury or fatality. The mitigations and controls for both the
22 Employee Safety and FFD Program Awareness risks are now included in
23 this risk. They are discussed in detail below.

24 In the 2020 General Rate Case (GRC) PG&E explained that the FFD
25 Program Awareness risk will be transitioned to a control for the Employee
26 Safety risk in the future.

27 The risk drivers in the 2020 RAMP have also evolved. For the 2017
28 RAMP, as part of the initial quantitative risk analysis effort, PG&E
29 categorized its risk drivers according to the Bureau of Labor Statistics
30 Occupational Injury and Illness Classification Manual using PG&E California
31 Occupational Safety and Health Administration (Cal/OSHA)-reportable data
32 to determine frequencies. The 2020 RAMP analysis builds on the

3 PG&E's RAMP Report, Investigation 17-11-003 (Nov. 30, 2017), Chapter 15.

categorization and includes Cal/OSHA-recordable injury claim causes and also direct causes where the data are available. Approximately 70 percent of the claim cause data include a direct cause from the supervisor investigation analysis packet.

2. Risk Bow Tie

**FIGURE 16-1
RISK BOW TIE – 2023 TEST YEAR**



3. Exposure to Risk

The Employee Safety Incident risk exposure is based on an annual average of 22,265 employees—approximately 60 percent are considered office-based (i.e., work in PG&E office locations) and approximately 40 percent work primarily in the field.

PG&E relied on its GN 801 – Employee and Non-Employee Details (Internal) Reports for developing the exposure to risk data. PG&E job classifications were used to estimate the number of office and field employees for the exposure tranches.

4. Tranches

PG&E identified two tranches for the Employee Safety Incident risk based on a review of PG&E-recordable injuries and fatalities data:

- PG&E office-based employees including but not limited to Managers, Engineers and Scientists, Analysts, Planners, Learning and Development, HR, Information Technology (IT), Supply Chain, Finance, and Law professionals, (60 percent of the workforce); and
- PG&E field employees including but not limited to linemen, plant technicians, field analysts, system operators, mechanics, electricians, materials handlers, nuclear security, and troublemen (40 percent of the workforce).

The types of hazards, or risk exposures are different for office-based and field employees. Office-based employees are more susceptible to injuries such as those resulting from typing or key entry, strains, slips, trips, and falls. Field employees are more susceptible to injuries resulting from strains from lifting, pulling or pushing, repetitive use of tools, contact with objects and equipment, falls from height, and contact with electrical current. Approximately 75 percent of the PG&E employee Cal/OSHA recordables included in the RAMP model analysis are field employees. Based on the data, less than 1 percent of field related Cal/OSHA recordables have resulted in a serious injury or a fatality. Table 16-2 shows the percent risk exposure and percent risk for each tranche.

TABLE 16-2
RISK EXPOSURE AND PERCENT RISK BY TRANCHE

Line No.	Tranche	Percent Exposure	Safety Risk Score	Financial Risk Score	Total Risk Score	Percent Risk Score
1	Field Employees	40 percent	79.1	3.3	82.4	92 percent
2	Office Employees	60 percent	6.5	0.9	7.5	8 percent
3	Total	100 percent	85.6	4.3	89.9	100 percent

5. Drivers and Associated Frequency

Drivers utilize the injury categories from the RAMP 2017 analysis and are further divided into 35 drivers based on injury claim cause data. Direct cause data were used to support the analysis.

1 Driver Category One (1) – Contact with Objects and Equipment: This
2 driver category accounts for approximately 13 percent of PG&E
3 Cal/OSHA-recordable injuries and includes:

- 4 a) Caught in or compressed by equipment or objects;
- 5 b) Caught or crushed in collapsing materials (e.g., cave-in);
- 6 c) Contact with objects and equipment;
- 7 d) Jarred by tool, equipment, or vibration;
- 8 e) Rubbed or abraded by foreign matter in eye;
- 9 f) Stepped on object;
- 10 g) Struck against moving object;
- 11 h) Struck against stationary object;
- 12 i) Struck by falling object;
- 13 j) Struck by flying object; and
- 14 k) Struck by swinging or slipping object.

15 Driver Category Two (2) – Exposure to Harmful Substances or
16 Environment: This driver category accounts for approximately 9 percent of
17 PG&E Cal/OSHA-recordable injuries and includes:

- 18 a) Contact with electrical current;
- 19 b) Contact with hot or cold objects/substances;
- 20 c) Contact with skin or other exposed tissue;
- 21 d) Exposure to noise; and
- 22 e) Inhalation of substance.

23 Driver Category Three (3) – Falls, Slips and Trips: This driver category
24 accounts for approximately 12 percent of PG&E Cal/OSHA-recordable
25 injuries and includes:

- 26 a) Fall down stairs or steps/escalator;
- 27 b) Fall from ladder or scaffolding;
- 28 c) Fall from non-moving vehicle;
- 29 d) Fall onto or against objects;
- 30 e) Fall to floor, walkway, or other surface on same level;
- 31 f) Fall to lower level; and
- 32 g) Slip, trip, loss of balance—without fall.

33 Driver Category Four (4) – Fire and Explosion: Includes fire and
34 explosion related injuries such as burns (chemical and electrical), welder's

1 flash, and heatstroke. This driver accounts for less than 1 percent of PG&E
2 Cal/OSHA-recordable injuries.

3 Driver Category Five (5) – Bodily Reaction and Exertion, Unspecified:
4 This driver category accounts for approximately 60 percent of PG&E
5 Cal/OSHA-recordable injuries and includes:

- 6 a) Strain in twisting/turning;
- 7 b) Bodily reaction and exertion, unspecified;
- 8 c) Overexertion in holding, carrying, turning, or wielding;
- 9 d) Strain in lifting/lowering;
- 10 e) Strain in pulling or pushing;
- 11 f) Repetitive placing, grasping, moving objects, except tools;
- 12 g) Repetitive use of tools; and
- 13 h) Typing or key entry or mousing.

14 Driver Category Six (6) – Violence and Other Injuries by Persons or
15 Animal: This driver category accounts for roughly 4 percent of PG&E
16 Cal/OSHA-recordable injuries and includes:

- 17 a) Assaults and violent acts by person(s);
- 18 b) Assaults by animals; and
- 19 c) Venomous bites, stings, injections.

20 **6. Cross Cutting Factors**

21 A cross-cutting factor is a driver or control that is interrelated to multiple
22 risks. PG&E is presenting eight cross-cutting factors in the 2020 RAMP.
23 The cross-cutting factors that impact the Employee Safety Incident risk are
24 shown in Table 16-3 below. A description of the cross-cutting factors and
25 the mitigations and controls that PG&E is proposing to mitigate the
26 cross-cutting factors are described in Chapter 20.

**TABLE 16-3
CROSS-CUTTING FACTOR SUMMARY**

Line No.	Cross-Cutting Factor	Impacts Likelihood	Impacts Consequence
1	Climate Change	X	
2	Physical Attack	X	
3	Records and Information Management		X
4	Skilled and Qualified Workforce	X	

7. Consequences

The basis for measuring the consequences of the Employee Safety Incident risk are: (1) serious injury according to the Cal/OSHA definition or fatality; or (2) financial. There are no electric or gas reliability consequences.

The outcomes which characterize Employee Safety Incident risk event:

- Overexertion and bodily reaction (60 percent of the Cal/OSHA-recordable injuries; approximately 67 percent of these are field employees).
- Contact with object and equipment (13 percent of the Cal/OSHA-recordable injuries; approximately 92 percent of these are field employees).
- Falls, slips, or trips (12 percent of the Cal/OSHA-recordable injuries; approximately 78 percent of these are field employees)
- Exposure to harmful substances or environments (9 percent of the Cal/OSHA-recordable injuries; approximately 88 percent of these are field employees).
- Violence and other injuries by persons or animal (4 percent of the Cal/OSHA-recordable injuries; approximately 84 percent of these are field employees).
- All other Cal/OSHA-recordable injuries occur approximately 1 percent of the time; approximately 61 percent of these are field employees.
- Fires and explosions Cal/OSHA-recordable injuries occur less than 1 percent of the time; approximately 90 percent of these are field employees.

1 PG&E relied on the PG&E Serious Incidents Reports from 2012 through
2 2019 and previous serious incidents reporting for 2008 through 2011 to
3 analyze the safety consequences of an employee-recordable injury. The
4 Serious Incidents Report provides details on the conditions that led to
5 incidents.

6 PG&E used the PG&E SEMS database in conjunction with the average
7 workers' compensation claim cost from the most recent GRC to evaluate the
8 financial consequences of an employee safety incident. The SEMS
9 database includes the OSHA recordables cases that were classified as
10 Days Away, Restricted or Transferred (DART) cases. Historical data were
11 used to quantify the risk baseline with the RAMP model. These same data
12 were used to assess mitigation effectiveness, along with case studies,
13 benchmarking and PG&E Subject Matter Expert judgment. Greater detail of
14 the mitigation effectiveness methodologies can be found in the workpapers.

15 Table 16-4 shows the consequences of the risk model. Model attributes
16 are described in Chapter 3, "Risk Modeling and Risk Spend Efficiency."

TABLE 16-4
RISK EVENT CONSEQUENCES

	CoRE %Freq %Risk Freq			Natural Units Per Event		CoRE		Natural Units per Year		Attribute Risk Score	
				Safety EF/event	Financial \$M/event	Safety	Financial	Safety EF/yr	Financial \$M/yr	Safety	Financial
Overexertion and bodily reaction	0.14	60%	59%	364	0.0140	0.1380	0.0070	1.0	5.1	50.1	2.5
Falls slips trips	0.16	12%	13%	71	0.0031	0.1543	0.0071	0.2	1.0	11.0	0.5
Contact with object or equipment	0.13	13%	12%	81	0.0025	0.1255	0.0073	0.2	1.2	10.2	0.6
Exposure to harmful substances or environments	0.18	9%	10%	52	0.0034	0.1683	0.0073	0.2	0.8	8.8	0.4
Violence and other injuries by persons or animal	0.17	4%	5%	25	0.0033	0.1635	0.0072	0.1	0.4	4.0	0.2
All Other	0.15	1%	1%	6	0.0028	0.1384	0.0070	0.0	0.1	0.8	0.0
Fires explosions	0.18	1%	1%	4	0.0034	0.1724	0.0073	0.0	0.1	0.6	0.0
Aggregated	0.15	100%	100%	603	0.0142	0.1421	0.0071	1.7	8.5	85.6	4.3

1 **C. Controls and Mitigations**

2 Tables 16-5 and 16-6 list all the controls and mitigations PG&E included in
3 its 2017 RAMP for both the Employee Safety and FFD Program Awareness
4 risks, 2020 GRC, and 2020 RAMP (2020-2022 and 2023-2026). The tables
5 provide a view of the controls that are in place, the mitigations that are
6 continuing implementation, and new mitigations. It also includes controls and
7 mitigations that have been removed. In the following sections PG&E describes
8 the controls in place in 2019 as part of the 2020 RAMP baseline, changes to the
9 2017 RAMP mitigations and controls, and then discusses the 2020 RAMP
10 program which includes new mitigations and mitigations continuing to be
11 implemented during the 2020-2022 and 2023-2026 periods.

12 In the 2017 RAMP PG&E presented two risks related to employee safety:
13 Employee Safety (Chapter 15) and Lack of FFD Program Awareness
14 (Chapter 17). In this 2020 RAMP the FFD controls and mitigations are now
15 incorporated into the Employee Safety Incident risk. This is discussed more fully
16 in the Risk Background and Evolution discussion above.

TABLE 16-5
CONTROLS SUMMARY

Line No.	Control Name and Number (reference)	2017 RAMP Risk Category ^(a)	2017 RAMP	2020-2022 GRC 2017-2020 Controls	2020 RAMP 2020-2022 Controls	2020 RAMP 2023-2026 Controls
1	C1 – PG&E Safety and Health Compliance Standards	Emp. Safety	X	X	X	X
2	C2 –CAP	Emp. Safety	X	X	X	X
3	C3 – Employee Knowledge and Skills Assessments (Including Academy Training)	Emp. Safety	X	X	X	X
4	C4 (inc. Emp. Safety M3)– Safety Observation Program	Emp. Safety	X	X	X	X
5	C5 – Personal Protective Equipment Requirements	Emp. Safety	X	X	Removed (included with C1)	
6	C6 (inc. Emp. Safety M10) – SLD				X	X
7	C7 (inc. Emp. Safety M2) – SIF Incident Investigation Review				X	X
8	C7a (inc. Emp. Safety M2) SIF Incident Investigation Review				X	X
9	C8 (inc. Emp. Safety M9) – Learning Organization				X	X
10	C9 (inc. Emp. Safety M7) – Benchmarking				Removed as foundational	
11	C10 (inc. Emp. Safety M10) – SLD				X	X
12	C11 (inc. Emp. Safety M8) – Enterprise Safety Communication Plan				X	X
13	C12 (inc. Emp. Safety M12) – Employee Wellness (formerly FFD C2)				X	X

**TABLE 16-5
CONTROLS SUMMARY
(CONTINUED)**

Line No.	Control Name and Number (reference)	2017 RAMP Risk Category ^(a)	2017 RAMP	2020-2022 GRC 2017-2020 Controls	2020 RAMP 2020-2022 Controls	2020 RAMP 2023-2026 Controls
14	C13 – Training and Communication (formerly FFD C1)				X	X
15	C14 (inc. FFD M5) – Enhanced FFD Metrics				X	X
16	C15 (inc. FFD M9) – Benefit Plans and Policy (formerly FFD C3)				X	X
17	C16 – Nurse Care Line (NC) (inc. Emp Safety M11)				X	X
18	C17 – Return to Work Task Program (Inc. Emp. Safety M11)				X	X
19	C1 – Training and Communication	FFD	X		Updated to C13	
20	C2 (inc. M12) – Employee Wellness	FFD	X		Updated to C12	
21	C3 – Benefit Plans and Policy	FFD	X		Updated to C15	
<p>(a) “Emp Safety” indicates a control that was listed in the Employee Safety chapter (Chapter 15) in PG&E’s 2017 RAMP. “FFD” indicates a control that was listed in the FFD Awareness chapter (Chapter 17) in PG&E’s 2017 RAMP.</p>						

TABLE 16-6
MITIGATIONS SUMMARY

Line No.	Mitigation Name and Number	2017 RAMP Risk Category ^(a)	2017 RAMP Mitigations	2020 GRC 2020-2022 Mitigations	2020 RAMP 2020-2022 Mitigations	2020 RAMP 2023-2026 Mitigations
1	M1A – Safety Management System (SMS) Planning	Emp. Safety	X	Complete		
2	M1B – ESMS Implementation	Emp. Safety		X	X	
3	M2 – Serious Injury and Fatalities Incident Investigation Review	Emp. Safety	X	X	Becomes control C7	
4	M3 – Safety Observation Tool	Emp. Safety	X	Included with C4		
5	M4 – Job Hazard Analysis	Emp. Safety	X	Removed – included with M1A		
6	M5 – Safety Plan	Emp. Safety	X		X	
7	M6 – Musculoskeletal Disorder (MSD) Program	Emp. Safety	X	X	Now (M6a through M6d)	Now (M6a through M6d)
8	M6a – Office Ergonomics Program				X	X
9	M6b – Industrial Ergonomics Program				X	X
10	M6c – Industrial Athlete Program				X	X
11	M6d Vehicle Ergonomics Program				X	X
12	M7 – Benchmarking	Emp. Safety	X		Becomes control C9	
13	M8 – Enterprise Safety Communication Plan	Emp. Safety	X		Becomes control C11	
14	M9 – Learning Organization	Emp. Safety	X		Becomes control C8	
15	M10 – SLD	Emp. Safety	X	Inc. with C6		
16	M11 – On-Site Clinics	Emp. Safety	X	X	X	X
17	M12 – Health and Wellness	Emp. Safety	X	X	Becomes control C12	

TABLE 16-6
MITIGATIONS SUMMARY
(CONTINUED)

Line No.	Mitigation Name and Number	2017 RAMP Risk Category ^(a)	2017 RAMP Mitigations	2020 GRC 2020-2022 Mitigations	2020 RAMP 2020-2022 Mitigations	2020 RAMP 2023-2026 Mitigations
18	M2 – Identify and Track Population to Receive FFD Training (Knowledge, Mandatory Training)	FFD		X	Included in C14	
19	M3 – Redesign Time-Off Policy, Management and Union Employees	FFD	X	Combined with M9		
20	M4 – Observations – FFD Trained Field Safety Specialists	FFD	X	Removed		
21	M5 – Enhanced FFD Metrics	FFD	X	Becomes a control	Updated to C14	
22	M6 – FFD Data Sources Review	FFD	X	Complete		
23	M7 – Knowledge, Mandatory Training	FFD		X	Updated to C14	
24	M9 – Process Improvements, Redesign Time-Off Policy	FFD		X	Included in Employee Safety Incident C15	
25	M10 – Tools and Technology Kiosks	FFD		X	Discontinued	
26	M11 – Tools and Technology – Clinics	FFD		X (FFD risk chapter)	Now included with Emp. Safety Incident as M11	Now included with Emp. Safety Incident as M11
27	M13 – Enhancing SafetyNet Use				X	X
28	M14 – Industrial Hygiene (IH) Program Compliance Improvements – Phase 1				X	
29	M15 – IH Program Compliance Improvements – Phase 2				RAMP alternative	RAMP alternative

TABLE 16-6
MITIGATIONS SUMMARY
(CONTINUED)

Line No.	Mitigation Name and Number	2017 RAMP Risk Category ^(a)	2017 RAMP 2017-2019 Mitigations	2020 GRC 2020-2022 Mitigations	2020 RAMP 2020-2022 Mitigations	2020 RAMP 2023-2026 Mitigations
30	M16 – Fit4U Pilot				X	
31	M17 – Mobile Medics				X	X
32	M18 – Employee Safety Field Inspections				RAMP alternative	RAMP alternative
<p>(a) “Emp. Safety” indicates a control that was listed in the Employee Safety chapter (Chapter 15) in PG&E’s 2017 RAMP. FFD indicates a control that was listed in the FFD Awareness chapter (Chapter 17) in PG&E’s 2017 RAMP.</p>						

1. 2019 Controls

The controls and mitigations proposed in the 2017 RAMP for the Employee Safety and FFD risks were primarily programmatic in nature and provided the infrastructure to support strengthening the compliance and safety culture. The controls for both risks address each of their respective drivers. The list of controls below reflects the 2019 baseline for the Employee Safety Incident risk. These controls are anticipated to remain in place through 2026.

C1 – PG&E Safety and Health Compliance Standards: Safety and Health Compliance Standards provide an in-depth overview of Cal/OSHA and OSHA compliance requirements. In addition to the compliance requirements, the Standards provide common understanding of the risks across the Company regarding the exposure mitigation. The LOBs use the Standards to develop and/or revise work methods and procedures. In conjunction with this the Safety and Health organization has the responsibility to review required compliance training and provide input to the PG&E Academy on changes needed to the training materials resulting from new or changed Cal/OSHA and OSHA regulatory requirements.

C2 – Corrective Action Program: The CAP is a companywide program that provides employees and contractors a speak-up method to identify and report issues, or ideas, related to gas assets, and processes. The CAP process ensures that issues are categorized, assessed for risk, and assigned to the appropriate owner to resolve issues and implement effective corrective actions to help prevent recurrence. Both employees and contractors have the option of submitting a CAP anonymously.

C3 – Employee Knowledge and Skills Assessments: In conjunction with the PG&E Learning Academy, PG&E's LOBs are developing specific Employee Safety knowledge and skills assessments. The training provides classroom and hands-on instruction by experienced instructors to teach and assess the specialized skills that are critical to field employees executing high risk tasks.

C4 – PG&E Implemented SafetyNet Safety Observations: LOB supervisory and corporate Safety Specialists conduct worksite observations

1 using checklists developed using SafetyNet (PG&E's Safety Observation
2 database tool) as part of the SIF Program implementation.

3 **C6 – Safety Leadership Development:** All PG&E employees in leadership
4 positions, up to and including the Chief Executive Officer, who have union
5 represented employees within their reporting structure/chain of command
6 who work in a capacity that has a SIF potential are automatically profiled to
7 take the revised SLD workshop series which consists of two all-day
8 workshops. The workshops teach and focus on leadership skills and
9 practices that promote and sustain safety performance. The PG&E
10 Academy is responsible delivering, maintaining, and updating the
11 workshops. Workshops are updated annually to address areas of
12 improvement identified by the field safety observation data.

13 **C7 and C7a – PG&E's Serious Injury or Fatality Prevention Program:**

14 The SIF Prevention program focuses on SIFs at PG&E. All injuries and
15 reported near hits are evaluated to determine the hazards classification and
16 if the situation results in a SIF-actual or SIF-potential event. The SIF
17 Strategy and Prevention team conducts or coordinates in-depth cause
18 evaluations for all incidents classified as SIF-potential or SIF-actual. The
19 results of these investigations and the identified corrective actions are
20 monitored through the CAP to ensure timely completion and effectiveness.
21 Focusing its investigative resources on SIF-potential and SIF-actual
22 incidents assists with understanding these situations and the development
23 of corrective actions to eliminate or mitigate recurrence. The SIF program is
24 continuously improved through the review of existing SIF program and
25 processes for enhancements and optimization on an annual basis, ensuring
26 alignment with all LOBs for consistency and continuity enterprise-wide.

27 **C8 – Operational Learning:** PG&E's Operational Learning uses several
28 different methods that are focused on learning about how work is performed.
29 Learning Teams, a critical component of Operational Learning, are
30 facilitated discussions with representative groups of front-line employees,
31 led by a trained facilitator, about how work is performed, what works well,
32 and what are the barriers to success. Learning Teams leverage our
33 employees' extensive expertise and experience to identify best practices
34 and to develop practical and sustainable solutions to improve operating and

1 safety performance. This effort helps PG&E LOBs understand how work is
2 done and to develop approaches and solutions to reduce risk and improve
3 workplace safety. Recommended improvements are entered and evaluated
4 through the CAP.

5 **C10 – PG&E's Leader in the Field:** The Leader in the Field initiative
6 focuses on having leaders spend more time in the field and coaches them
7 on how to provide consistent feedback to workers, engage with them in
8 discussions with how they are working safely, and how to offer specific
9 guidance on how to improve.

10 **C11 – Enterprise Safety Communication Plan:** The enterprise safety
11 communication plan is part of the Corporate Communication Plan to deliver
12 a consistent safety and health communication strategy which helps
13 employees understand the risk factors for their safety and health. This
14 allows employees to understand, engage with, and appreciate the safety
15 and health programs available to them and build credibility with employees
16 and contractors by showing that PG&E is a company committed to
17 worker safety.

18 **C12 – Employee Health and Wellness:** These programs align health and
19 wellness activities with safety prevention efforts to drive better outcomes.
20 Research has shown a direct correlation between the health and well-being
21 of employees and their frequency of being injured on the job. Expanded and
22 enhanced health and wellness services/controls that promote access to
23 medical services and other programs and focus on prevention to assist
24 employees in managing their health. On-site health coaching had been
25 added and a new employee health and wellness portal was implemented
26 with tools and additional self-directed resources. There are two main
27 categories of Health and Wellness controls:

- 28 a) Emotional Health – Employee Assistance Program (EAP) and Peer
29 Volunteer Program.
30 b) Physical Health – Employee Health Screenings and Health Coaching.

31 **C13 – Health and Wellness Training and Communication:** Training and
32 communication controls enhance people leader awareness and
33 effectiveness in detecting behaviors that raise FFD concerns. There are
34 four controls included in this group:

- a) Compliance and Ethics and Code of Conduct training. This Annual mandatory training includes an FFD module to help leaders and employees understand how to identify and react to observed behaviors which may impact the employees' ability to perform their work safely.
- b) FFD Cross Program Manager Training. Resources were identified and cross trained on the program. In addition, a process was established to ensure adequate coverage for the program.
- c) Voluntary FFD situational awareness training for leaders. In addition to mandatory FFD training for all new leaders the FFD Program Manager regularly provides ad hoc FFD training to leaders upon request. These sessions allow for leaders to ask questions and interact directly with the FFD Program Manager.
- d) A quarterly process to communicate new or changing issues during Risk and Compliance Committee (RCC) meetings. Each quarter new or changing regulations involving local, state or federal laws and regulations affecting benefit programs are communicated to the RCC. Reports include the plan in place to incorporate the new requirements.

C14 – Enhanced FFD Metrics: Enhanced FFD data tracking metrics to include risk ranking, late or timely reporting. Mandatory FFD training for people leaders, Directors and below, is tracked through Learning Academy.

C15 – Benefit Plans and Policy: Implemented a third party to administer multiple benefit program offerings, including long-term disability, short-term disability, paid family leave, the PG&E's Voluntary Disability and Paid Family Leave Benefit Plan (offered in lieu of State Plan benefits) and leaves of absence to improve employee access to benefit information. Having a single administrator helps to ensure proper administration of benefits which ensures proper and prompt delivery of benefits. New benefits provide eligible employees with a financial safety net to be able to take the time off needed to seek treatment and help in recovery, thus improving and/or maintaining the health of the workforce and assuring quality of care and fitness to return-to-work.

C16 – Nurse Care Line: This enhanced injury reporting process improves the employee experience when reporting minor injuries. Early intervention is the key to successfully managing physical discomfort or stress. The NCL

allows employees to speak up, without fear, when faced with a work-related health challenge, strengthening the message that employee health is essential. Employees receive medical advice, self-care information and clinic referrals. Using the NCL results in a decrease of injury severity, and a reduction in workers compensation claim costs. While the number of calls to the NCL has increased, the percentage of those calls resulting in OSHA recordables has decreased by 15 percent from 2013-2018. In addition, there was a reduction in average cost per claim of approximately 50 percent in 2018, as compared to 2013. It also identifies training opportunities to further promote a safe working environment.

C17 – Return to Work Task Program: The enhanced return to work task program provides more return to work opportunities for employees with injuries or illnesses (industrial and non-industrial) whose temporary work restrictions cannot be accommodated in their base classification. The Program was launched in 2017. At that time, it was included in 2017 RAMP with the Injury Management mitigation (M11) in the Employee Safety risk. This control provides temporary assignments to help ease the transition from temporary restricted status to full duty. Early return to work helps injured employees recover faster and have better recovery outcomes. The program has resulted in a significant reduction of lost workdays.

2. 2019 Mitigations

a. Employee Safety Risk Mitigations

M1A – Safety Management System Planning: As preparation for implementation of a SMS, perform a gap analysis, prioritize gaps for closure and finalize the SMS policy and guidance for publication. Develop a system for managing job hazards analysis data, which is an integral part of the SMS foundation, and integrate a communication and education plan for hazard awareness and avoidance.

M2 – Serious Injury and Fatalities – Incident Investigation Review: Align the investigations process to improve the quality of the investigations/causal evaluation, documentation, and corrective actions. Improve communications strategies to share learnings.

1 **M3 – Safety Observation Tool:** PG&E is improving the SafetyNet
2 safety observation tool, developed by Predictive Solutions, for use with
3 field employees and contractor safety programs. The benefits of
4 SafetyNet are that it leverages a large and comprehensive database of
5 500 million data points from completed observations throughout the
6 industry and includes algorithms to provide predictive injury analysis,
7 dashboards, and help with improving the quality of the submitted
8 observations. The prior safety observation tool, Guardian, does not
9 have a database of observations from other companies or the capability
10 to use algorithms that provide predictive injury analysis; nor does it
11 provide information regarding the quality of the observations. This
12 mitigation is an enhancement of C4.

13 **M4 – Job Hazard Analysis:** Develop a system for managing job
14 hazards analysis data which is an integral part of the SMS foundation
15 and integrate a communication and education plan for hazard
16 awareness and avoidance.

17 **M5 – Safety Plan:** Publish and implement the One PG&E One Plan to
18 establish shared accountability, ownership and commitment.

19 **M6 – Musculoskeletal Disorder Program:** 64 percent of the injuries
20 from 2014-2017 are MSDs, and sprains and strains. The ergonomics
21 program focuses on office, industrial and vehicle ergonomics by utilizing
22 early intervention activities and ergonomic assessments. The program
23 also establishes systems to utilize injury data and risk assessments to
24 target interventions at the areas of greatest need.

25 **M7 – Benchmarking:** Participation on industry roundtables with peer
26 organizations to share lessons learned and best practices and
27 implement, as applicable, at PG&E. Implementing best practices and
28 help to reduce risk of SIF.

29 **M8 – Enterprise Safety Communication Plan:** Deliver a consistent
30 safety and health communication strategy which helps employees
31 understand the risk factor for their safety and health. This will allow
32 employees to understand, engage with, and appreciate the safety and
33 health programs available to them and build credibility with employees

1 and contractors by showing that PG&E is a company committed to
2 worker safety.

3 **M9 – Learning Organization:** PG&E will use Learning Teams of
4 5-7 front-line employees led by a credible facilitator, who has the respect
5 of both front-line employees and management. These teams build on
6 employees' extensive first-hand experience and skills to develop durable
7 and practical solutions to on-going safety issues. This effort will help
8 PG&E develop approaches and solutions to this risk and ensure that
9 each LOB is accountable for implementing the Learning Teams'
10 recommendations.

11 **M10 – Safety Leadership Development:** In 2017, Corporate Safety
12 expanded the delivery of the SLD workshops under the name *Leading*
13 *Forward: Safety Leadership*. This program provides training to all
14 1,700 crew leads, planned over a 3-year timeframe, and will continue to
15 train new leaders as they are hired into these positions. Training is
16 being developed to teach a group of facilitators how to conduct
17 Learning Teams, as referenced in M9.

18 **M11 – Injury Management:** Enhance the injury reporting process to
19 improve the employee experience when reporting minor injuries.
20 Additionally, enhance the return to work program for injured employees
21 whose temporary work restrictions cannot be accommodated in their
22 base classification. The enhancements will demonstrate to employees
23 that PG&E cares about them and will promote healing and early return
24 to work.

25 **M12 – Health and Wellness:** Align health and wellness activities with
26 safety prevention efforts to drive better outcomes. Research has shown
27 a direct correlation between the health and well-being of employees and
28 their frequency of being injured on the job. Expand and enhance health
29 and wellness services by focusing on prevention and condition
30 management to assist employees in managing their health. Provide
31 additional on-site health coaching and enhance the existing platform
32 with a new user interface and tools and deploy new self-directed
33 resources.

b. FFD Awareness Mitigations

M4 – Observations – Fitness for Duty trained Field Safety

Specialists Observations: Adding FFD awareness to field observations conducted by 65 Safety Specialists in 2018. The checklists are already being revised, therefore no added cost for including the FFD language similar to the recommendation for the driver ride-along checklist. The intent of this mitigation was to improve people leader awareness of the FFD Program. It was later removed as it is training specific to employee supervisors.

M5 – Enhanced FFD Metrics: Enhance FFD data tracking metrics to include risk ranking, late or timely reporting, and a determination of the efficacy of mandatory FFD training for people leaders for all referrals. This was a new mitigation for 2017 and will be continued in subsequent years. This mitigation improves the ability to measure the effectiveness of changes to the FFD Program since it was removed from EAP and thus helps to understand the effectiveness of the program as a control.

M6 – FFD Data Sources Review: Evaluate other sources of employee data for use with risk quantification, validate current results and revise as necessary. This mitigation was completed in 2017 and the data was reviewed during the risk model development process.

D. 2020-2022 Controls and Mitigations

1. Changes to Controls

PG&E will continue to implement the controls described above and shown on Table 16-5.

2. Changes to Mitigations

This list includes updates to mitigations currently being implemented and new mitigations that will become controls during 2020 through 2022.

M1B – Enterprise Safety Management System Implementation: PG&E has committed to implementing an ESMS. The ESMS consists of a series of capabilities (people, process, governance, and technology systems) required to define, plan, implement, and continuously improve workforce safety. The ESMS becomes the way PG&E "delivers the business of safety" and is based on a consistent and comprehensive enterprise safety controls

framework reinforced with system assurance. PG&E's commitment is to implement the system by 2022.

Key components of the system include:

- a) Management of Change (MOC) Capability and MOC Software (program manager and software)
- b) OSHA and Cal OSHA Compliance Baseline and Workforce Safety Control Program Owners Framework
- c) Safety Compliance Register
- d) Hazard Tracking System
- e) Safety Architect for Safety (Controls) Engineering
- f) Safety Certification
- g) Safety Values and Actions – Governance for safety culture improvements including a coordinator, surveys, and training
- h) ESMS implementation (including updates to people, process, technology, and governance documents)

More information about the ESMS is included in workpapers.⁴

M13 – Enhancing SafetyNet use: PG&E is enhancing its use of the SafetyNet safety observation tool, developed by Predictive Solutions, for use with field employees and contractor safety programs. The benefits of SafetyNet are that it leverages a large and comprehensive database of several million completed observations and includes algorithms that have the potential to provide predictive analysis and dashboards regarding unsafe conditions or behaviors enterprise-wide. Safety Observation Tool improvements include observation data improvements and expansion of training and documentation for front-line users to bolster the quality of the data such that reports, and predictive modeling can be utilized by PG&E leadership to improve workplace safety. PG&E anticipates that the tool will be fully optimized in 2021.

M14 – Industrial Hygiene Program Compliance Improvements – Phase 1: Develop and implement overall IH Standard that includes roles and responsibilities (execution and support governance by IH team) for the

⁴ See WP 16-3.

IH program (including the current Safety and Health IH Standards). LOB procedures will align with the current Standards including execution of the compliance programs within their organizations. The compliance function within Enterprise Safety and Health will assess the status of implementation within the LOBs. Implement gap assessment findings including:

- Consolidating monitoring records and compliance recordkeeping, exposure assessments, and medical surveillance program in an IH data management software system that leverages current plan for evaluation of a Safety and Health software solution; and
- Install monitoring equipment for IH team's use and to support program execution.

M16 – Fit4U Pilot: This program focuses on improving the health and well-being of employees who have sustained multiple workers compensation injuries, by providing them with the resources to maintain a healthy lifestyle. Access to health coaching, personal training, meditation/mindfulness, and EAP services should prevent repeat injuries, provide coping skills and accelerate their recovery and return to work. Long term benefits may include a reduction in workers compensation claims, health plan costs, work-related injuries or illnesses increasing DART rate, and health related lost workdays. Analysis of pilot results will determine whether to expand this mitigation past the pilot stage.

PG&E will implement several mitigations between 2020 and 2022 that will become controls in the 2023 through 2026 period:

M6a – Office Ergonomics Program: Continue effort on change management including Supervisor training within the organization for early symptom recognition and action, working with facilities partners to ensure furnishings meet ergonomic design specifications, enhanced reporting moving toward predictive modeling.

M6b – Industrial Ergonomics Program: Continued effort in education about industrial ergonomics risk factors, while making the Velocity software fully operational across enterprise with prevention specialists and industrial ergo teams. The Velocity software is used to assess ergonomics risk factors associated with worker activities and tasks and determine possible risk reduction measures. This mitigation also includes building a business

1 case for a centralized pilot to evaluate potential solutions, increase
2 partnerships with the vendor to receive products to pilot across enterprise
3 needs, robust tracking, reporting, and visibility of impacts and risk reduction
4 from solution implementation.

5 **M6c – Industrial Athlete Program:** The future state is to expand from
6 early symptom intervention to a strategic-based plan to reduce discomfort
7 cases and prevent muscle strains and sprains. Program objectives include
8 targeted interactions with an on-site prevention specialist by focusing on
9 high risk areas identified by Supervisors, Safety Net observations, brief
10 surveys, and biomechanical observations. Industrial Athlete program will
11 consider moving from external third party to internal employee positions with
12 an IT solution.

13 **M6d – Vehicle Ergonomics Program:** All PG&E-owned vehicles included
14 in PG&E's fleet have a design review committee that includes front-line
15 workers, safety, ergonomics, and human factors. The objective is to fully
16 understand the work performed while using the vehicles—such as
17 equipment most frequently used, access, lighting, environmental concerns,
18 smart driving, ease of access, mechanical advantage—and forecast
19 potential future technology impacts, using 5-95 percent anthropometric data
20 and human factors principles.

21 **M11 – On-Site Clinics:** Establish on-site clinics available to PG&E
22 employees. The on-site clinics are expected to provide employees with
23 convenient access to health care services which will lead to a healthier
24 workforce by reducing the duration of Days Away From Work and Restricted
25 Duty cases.

26 **M15 – IH Program Compliance Improvements – Phase 2 (Alternative 1).**
27 Add consultant support and increased staff to expand program and provide
28 additional LOB support with IH Program compliance
29 assurance/implementation including surveillance.

30 **M17 – Mobile Medics:** PG&E will place Emergency Medical Technicians
31 (EMT) throughout seven territories with the highest OSHA-recordable
32 injuries over the last three years. EMTs will be available during regular
33 business hours to respond to injuries and provide immediate care which will
34 mitigate the severity of injuries and reduce OSHA and DART cases.

M18 – Employee Safety Field Inspections: Conduct Cal/OSHA employee safety field inspections across PG&E in alignment with the ESMS and the Safety and Health audit procedure. This supports increased field oversight of Cal/OSHA compliance and safe work.

Table 16-7 below shows the forecast costs for the mitigations planned for the 2020-2022 period.

**TABLE 16-7
FORECAST COSTS
2020-2022
(THOUSANDS OF DOLLARS)**

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	Total
1	M1B	ESMS Implementation	FL	\$1,575	\$1,725	\$925	\$4,225
2	M6a	Office Ergonomics Program	FL, ZC	2,235	2,235	2,235	6,705
3	M6b	Industrial Ergonomics Program	FL, ZC	1,050	1,050	1,050	3,150
4	M6c	Industrial Athlete Program	FL, ZC	4,274	4,274	4,274	12,822
5	M6d	Vehicle Ergonomics Program	FL, ZC	275	275	275	825
6	M11	On-Site Clinics	ZC	1,011	1,505	1,510	4,025
7	M13	Enhancing SafetyNet Use	FL	127	64	–	191
8	M14	IH Program Compliance Improvement-Phase 1	FL	100	100	–	200
9	M16	Fit4U Pilot	ZC	526	–	–	526
10	M17	Mobile Medics	ZC	1,800	1,544	1,323	4,667
11	Total			\$12,973	\$12,771	\$11,592	\$37,336

Note See WP 16-1.

E. 2023-2026 Proposed Mitigation Plan

PG&E will continue implementing the mitigations started in the 2020-2023 period. No new mitigations are planned.

The ESMS, first proposed in the 2017 RAMP, is expected to be in place by year-end 2021 with ongoing refinement of LOBs implementation procedures into 2023.

The four proposed MSD Program mitigations (M6a through M6d in Table 16-6 above) include programs to address overexertion and bodily reaction injuries which comprise 60 percent of the Cal/OSHA recordables on average based on historical data. Approximately 67 percent of the Cal/OSHA recordables are field employees. The Industrial Athlete, Industrial Ergonomics,

1 and Vehicle Ergonomics programs (M6b through M6d) are designed to focus on
2 field personnel.

3 Table 16-8 below shows the forecast cost, RSEs and risk reduction scores
4 for the mitigations planned for the 2023-2026 period.

TABLE 16-8
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026 EXPENSE
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	M1B	ESMS Implementation	FL	\$725	\$725	\$925	\$725	\$3,100	12.99	29.6
2	M6a	Office Ergonomics Program	FL, ZC	2,410	2,410	2,410	2,410	9,640	0.37	2.6
3	M6b	Industrial Ergonomics Program	FL, ZC	1,050	1,050	1,050	1,050	4,200	1.13	3.5
4	M6c	Industrial Athlete Program	FL, ZC	4,402	4,402	4,402	4,402	17,608	0.64	8.4
5	M6d	Vehicle Ergonomics Program	FL, ZC	283	283	283	283	1,133	7.11	5.9
6	M11	On-Site Clinics	ZC	1,789	4,350	2,810	2,810	11,757	2.21	19.0
7	M13	Enhancing SafetyNet Use	FL	—	—	—	—	—	—	—
8	M14	IH Program Compliance Improvement-Phase 1	FL	—	—	—	—	—	—	—
9	M16	Fit4U Pilot	ZC	—	—	—	—	—	—	—
10	M17	Mobile Medics	ZC	1,103	882	882	882	3,749	0.68	1.9
11		Total		\$11,761	\$14,102	\$12,762	\$12,562	\$51,187	—	—

(a) See Mitigation Effectiveness workpapers (MW) included in the source document modeling package for information used to calculate the RSE.
 Note See WP 16-1.

1 Based on the results of the risk modeling analysis shown in Table 16-8
2 above, PG&E is proposing to spend approximately one-third 2023-2026 planned
3 funding on the three programs with the highest RSEs and highest risk reduction
4 scores: MSD Program-Vehicle Ergonomics, ESMS Implementation, and On-Site
5 Clinics.

6 While MSD Program-Office Ergonomics has the lowest RSE and second
7 lowest Risk Reduction score, PG&E supports this program because it helps to
8 minimize the workers compensation injuries and injury severity.

9 **F. Alternative Analysis**

10 In addition to the proposed mitigations described in Section E above, PG&E
11 considered alternative mitigations as well. The mitigations described in Section
12 E constitute the Proposed Plan. The Alternative Plans consist of a combination
13 of all of the proposed mitigations along with the alternative mitigation(s). PG&E
14 describes each of the alternative mitigations it considered below and then
15 provides a table showing the forecast costs, RSEs, and risk reduction scores for
16 each of the Alternative Plans.

17 **1. Alternative Plan 1: IH Program Compliance Improvements – Phase 2**

18 Alternative 1 considers implementing additional IH Program Compliance
19 improvements to expand the program and provide additional LOB support
20 with compliance assurance and program implementation including IH
21 monitoring and surveillance. Field surveillance is an important part of
22 reducing work location exposures to hazardous substances and
23 environments. This alternative was not chosen because it has a lower RSE
24 and lower risk reduction score than the proposed mitigations.

TABLE 16-9
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026 EXPENSE
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	A1	IH Program Compliance Improvements – Phase 2	\$540	\$540	\$540	\$540	\$2,160	–	–
2		Total	\$540	\$540	\$540	\$540	\$2,160	0.14	0.2

(a) See MWs included in the source document modeling package for information used to calculate the RSE.

Note See WP 16-1.

- 1 **2. Alternative Plan 2: Employee Safety Field Inspections for PG&E**
- 2 **Work Locations**
- 3 Alternative 2 considers implementing Employee Safety Field Inspections
- 4 for PG&E employee workplaces and locations. The inspections would be
- 5 compliance focused and in addition to the field safety observations with
- 6 SafetyNet currently taking place. This program would be similar to the
- 7 Contractor Safety Field Inspections and is anticipated to require additional
- 8 resources in order to inspect all PG&E field and office locations. Inspection
- 9 programs are an important part of reducing recordable injuries and fatalities
- 10 as they place increased attention on adhering to safety and health
- 11 compliance requirements and working safely. This alternative was not
- 12 chosen because it has a lower RSE than many of the proposed programs
- 13 and a higher cost.

TABLE 16-10
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026 EXPENSE
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	A2	Employee Safety Field Inspections	\$5,958	\$5,958	\$5,958	\$5,958	\$23,832	–	–
2		Total	\$5,958	\$5,958	\$5,958	\$5,958	\$23,832	0.13	2.3

(a) See MWs included in the source document modeling package for information used to calculate the RSE.

Note See WP 16-1.

1 Table 16-11 compares the proposed and alternative mitigation plans.

TABLE 16-11
MITIGATION PLAN ALTERNATIVES ANALYSIS
(THOUSANDS OF DOLLARS)

Line No.	Risk Mitigation Plan	Plan Components ^(a)	Total Expense (2023-2026)	Total Capital (2023-2026)	Risk Reduction (NPV) ^(b)	Total Spend (NPV) ^(b)	RSE
1	Proposed	M1B, M6a-M6d, M11, M17	\$51,187	–	70.9	\$37,672	1.88
2	Alternative 1	Proposed + A1	\$53,347	–	71.1	\$39,263	1.81
3	Alternative 2	Proposed + A2	\$75,017	–	73.1	\$55,226	1.32

(a) Plan Components refers to the Mitigations presented in Table 16-6.

(b) Information presented in terms of Net Present Value (NPV) to account for the discounting of benefits.

Note See WP 16-2.

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 17
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: CONTRACTOR SAFETY INCIDENT

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 17
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: CONTRACTOR SAFETY INCIDENT

TABLE OF CONTENTS

A. Executive Summary.....	17-3
1. Risk Overview	17-4
2. Risk Definition	17-6
B. Risk Assessment.....	17-6
1. Background and Evolution	17-6
2. Risk Bow Tie	17-7
a. Difference from the 2017 Risk Bow Tie	17-7
3. Exposure to Risk.....	17-7
4. Tranches	17-8
5. Drivers and Associated Frequency	17-9
6. Cross-Cutting Factors	17-10
7. Consequences	17-10
C. Controls and Mitigations	17-11
1. 2019 Controls and Mitigations.....	17-17
a. Controls	17-17
b. Mitigations	17-19
c. 2017 RAMP Update.....	17-21
D. 2020-2022 Controls and Mitigations Plan.....	17-23
1. Changes to Controls	17-23
2. Changes to Mitigations.....	17-24
E. 2023-2026 Proposed Mitigation Plan.....	17-26
F. Alternative Analysis	17-28
1. Alternative Plan 1: Do Not Implement the Contractor Work Management System	17-28

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 17
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: CONTRACTOR SAFETY INCIDENT

TABLE OF CONTENTS
(CONTINUED)

2. Alternative Plan 2: Increased Contractor Safety Field Inspection Resources.....	17-28
---	-------

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 17
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: CONTRACTOR SAFETY INCIDENT

A. Executive Summary

Contractor Safety Incident refers to any event resulting in a contractor Occupational Safety and Health Administration (OSHA) recordable injury or fatality,¹ excluding events resulting from asset failure. Contractors included in the Contractor Safety Incident Risk Assessment and Mitigation Phase (RAMP) are those that perform medium or high-risk work on behalf of PG&E. Events related to asset failure are covered in the asset management risks within Electric Operations, Gas Operations, and Power Generation. The drivers for this risk event are: sprains, strains, tears; cuts and lacerations; bruises and contusions; fractures; back pain, hurt back; abrasions, scratches; animal or insect bites; punctures, except bites; and other. The cross-cutting factor Records and Information Management also impacts this risk.

Exposure to this risk is measured as the approximately 26,000 contractors Pacific Gas and Electric Company (PG&E) employs each year. The risk model includes an annual average of approximately 185 recordable injuries divided into the following workplace injury categories: other; sprains, strains, tears; cuts and lacerations; bruises and contusions; fractures; back pain, hurt back; punctures, except bites; abrasions, scratches; animal or insect bites. Approximately 2 percent of the risk events result in a serious injury or fatality (SIF). The mitigations PG&E will implement from 2020-2026 are designed to address the known risk drivers.

PG&E identified one tranche for this risk which includes contractor high and medium-risk work activities. High-risk work includes activities such as: excavation and trenching beyond four feet; heavy equipment operation; utility tree trimming, clearance work and vegetation management; general construction

¹ An OSHA-recordable-event is defined as work related injuries or illnesses that must be reported to OSHA and that results in any of the following: medical treatment beyond first aid; loss of consciousness; one or more days away from work following the incident; restricted work or transfer to another job; any significant injury or illness diagnosed by a physician; any work-related fatality.

activities; welding and/or hot tapping of gas lines; and fault protection/grounding. Medium-risk work includes activities such as: geotechnical investigation; surveying and field inspection; material handling and compressed natural gas/liquified natural gas handling.

Contractor Safety Incident has the fourth highest 2023 test year (TY) safety score (94) and the seventh highest 2023 TY total score (94) of PG&E's 12 RAMP risks. The 2020 baseline risk score of 121 improves by 41 percent when the planned mitigations are applied: the 2023 TY risk score is 94 and the 2026 post-TY risk score is 72.

PG&E is proposing a series of controls and mitigations to address the Contractor Safety Incident risk. The Work Permits and OSHA Programs Training Requirements mitigations have the highest Risk Spend Efficiency (RSE) scores. The Work Permits, Contractor On-Boarding and Tracking Contract Workers programs have the highest total risk reduction scores.²

**TABLE 17-1
RISK OVERVIEW**

Line No.	Risk Name	Contractor Safety Incident
1	In Scope	An event resulting in a contractor ^(a) recordable injury or fatality, excluding events resulting from asset failure.
2	Out of Scope	PG&E contractor recordable injuries or fatalities resulting from the failure of an asset.
3	Data Quantification Sources ^(b)	ISNetworld (ISN) from 2017 to October 2019. ISN is a vendor that specializes in contractor safety prequalification and supplier management data. ISN's data is based on the contractor's OSHA-recordable injuries and illnesses for PG&E work.
<p>(a) Contractors in scope for this risk are those contractors who perform high risk and medium risk work for PG&E. High risk and medium risk work are defined in Section B.4 below.</p> <p>(b) Source documents will be provided with the workpapers on July 17, 2020.</p>		

1. Risk Overview

In 2019 PG&E employed approximately 2,200 contracting companies, which included approximately 26,000 individuals working more than 44 million hours supporting PG&E's diverse efforts across its lines of

² The information herein is subject to those limitations described in Chapter 2, Section D.

1 business (LOB). PG&E's team of safety and health professionals is focused
2 on preventing illness and injuries for both PG&E team members and the
3 contractors who work with us. Beginning in 2016, PG&E implemented a
4 formal Contractor Safety Program to help our contractor partners reduce
5 illness and injuries when working with PG&E. The program was
6 implemented as required by the Kern Order Instituting Investigation
7 Settlement Agreement with California Public Utilities Commission (CPUC).

8 PG&E's Safety and Health organization develops, enables, and
9 integrates innovative, proactive safety and health solutions, including:
10 strategic planning and trending analysis; expert field safety support;
11 continuous improvement of safety programs; promoting safety culture; and
12 investigation and human factor analysis. This organization establishes the
13 framework for PG&E's safety and health programs, monitors their
14 effectiveness, identifies areas for improvement, and monitors compliance
15 with applicable regulatory requirements.

16 PG&E's Contractor Safety Program is supported by professionals with
17 specific expertise in PG&E's Contractor Safety Program, as well as with the
18 work performed by PG&E's contractors. The Contractor Safety Program
19 Manager and Analysts are responsible for the program governance and
20 mitigation enhancements, while the Field Safety Managers and Safety
21 Specialists conduct LOB and contractor assessments, observe contractor
22 work for OSHA compliance, provide feedback to contractors, and coach and
23 support LOB resources to improve safety performance.

24 PG&E's Contractor Safety Program includes all contractors and
25 subcontractors performing medium- and high-risk work on PG&E facilities
26 and assets.³ The Contractor Safety Program includes: contractor and
27 subcontractor pre-qualification prior to executing contracts and beginning
28 work; safety planning integrated into the overall job plan; oversight
29 procedures to monitor safe planning and work execution; and post-job
30 evaluations to capture contractor safety performance including lessons
31 learned, identifying quality safety programs and pursuing continuous
32 improvement.

³ High risk and medium risk work are described in Section B.4 below.

In 2018, PG&E strengthened the contractor pre-qualification criteria to evaluate contractors that experience a significant increase in worker headcount for PG&E-related work and for contractors that have been in business less than three years. PG&E conducts additional evaluations of these contractors' safety management systems. Contractors that are not approved can no longer work for PG&E.

2. Risk Definition

The risk is defined as any event resulting in a contractor recordable injury or fatality, excluding events resulting from asset failure. Events related to asset failure are covered in the asset management risks within Electric Operations, Gas Operations, and Power Generation.

B. Risk Assessment

1. Background and Evolution


The Contractor Safety risk was included in PG&E's 2017 RAMP⁴ and was defined as "the failure to identify and mitigate occupational exposures that may result in a contractor injury or illness that is fatal, life threatening or life altering." In the 2020 RAMP the contractor safety risk name has changed to Contractor Safety Incident and the risk definition was changed to align with an event-based risk register.

The risk drivers in the 2020 RAMP have also evolved. In the 2017 RAMP the drivers were categorized according to the Bureau of Labor Statistics Occupational Injury and Illness Classification Manual and were supported by PG&E employee data. In the 2020 RAMP the risk drivers are based on OSHA injury classifications and supported by PG&E-specific contractor ISN data. PG&E determined that the ISN classification is a better way to both measure risk exposure and to define the risk drivers because the ISN classification is aligned to the contractor's OSHA-recordable injuries and illnesses for PG&E work. The risk drivers use the same classification categories as OSHA defines for reporting.

⁴ PG&E's RAMP Report, Investigation 17-11-003, Nov. 30, 2017 (PG&E's 2017 RAMP Report), Chapter 14.

2. Risk Bow Tie

**FIGURE 17-1
RISK BOW TIE – 2023 TY**



a. Difference from the 2017 Risk Bow Tie

The risk exposure in the 2017 RAMP bow tie and the 2020 RAMP bow tie are generally the same, however for 2020 the number of contractors is used to measure exposure rather than contractor hours. In the 2020 RAMP, consequences are measured in terms of serious injuries or fatalities whereas in the 2017 RAMP consequences were California Occupational Safety and Health Administration (Cal/OSHA)-recordable injuries and fatalities.

3. Exposure to Risk

Exposure to the risk is measured as number of contract employees performing high and medium risk work. The total exposure in the risk bow tie is based on an annual average of 25,840 contract employees. PG&E contractors conduct a wide variety of activities for PG&E across its LOBs. From 2018-2019 the contractor workforce population increased by

1 11 percent. In 2019 PG&E contractors self-reported more than 44 million
2 hours for PG&E specific work.

3 The scope of this risk includes PG&E contractors who perform medium
4 and high-risk activities such as digging and trenching, vegetation
5 management or material handling that can result in a contractor safety
6 incident. Designing and implementing mitigations and controls focused on
7 the most serious and most often occurring safety events will help to reduce
8 contractor safety events and contractor safety risk.

9 PG&E relies on ISN data for developing the risk analysis. Exposure to
10 risk was modeled using data in the ISN Site Tracker reports that include
11 PG&E specific data for; OSHA-recordable injuries and contractor workplace
12 injury types, and number of PG&E contract employees in scope for the risk.

13 **4. Tranches**

14 PG&E identified one tranche for the Contractor Safety Incident risk
15 based on a review of contractor safety data. This tranche includes high- and
16 medium-risk work activities as described in the PG&E Contractor Safety
17 Program Risk Matrix that is aligned to the PG&E Utility Standard,
18 SAFE-3001S.

19 High-risk work includes activities such as: excavation and trenching
20 beyond four feet; heavy equipment operation; utility tree trimming, clearance
21 work and vegetation management; general construction activities; welding
22 and/or hot tapping of gas lines; and fault protection/grounding.

23 Medium-risk work includes activities such as: geotechnical
24 investigation; surveying and field inspection; material handling and
25 compressed natural gas/liquified natural gas handling.

26 At this time, PG&E tracks contractors by prime contractors (primes),
27 those contractors who work directly for PG&E, and sub-contractors (subs),
28 those contractors that have been retained by a prime contractor to provide
29 services on behalf of PG&E. Going forward, PG&E will consider whether
30 the collection of PG&E contractor incident information specific to the LOBs
31 will provide further insight into where Contractor Safety mitigation programs
32 should be focused.

5. Drivers and Associated Frequency

PG&E identified nine drivers for the Contractor Safety Incident risk. Each driver and its associated 2023 TY baseline frequency is discussed below. There are no sub-drivers for the Contractor Safety Incident risk. The nine risk drivers are based on the OSHA-recordable classifications in ISN that are aligned to the contractor's OSHA-recordable injuries and illnesses for PG&E work.

D1 – Other: Refers to a contractor safety incident other than those addressed by drivers D2 through D9. Other contractor safety events accounted for 57 (31 percent) of the 185 expected annual number of events reportable to the Cal/OSHA.

D2 – Sprains, Strains and Tears: Refers to a contractor safety incident that results in soft tissue injury such as a muscle, ligament or tendon sprain, strain or tear that is reportable to Cal/OSHA. Sprain, strain or tear events accounted for 35 (19 percent) of the 185 expected annual number of events.

D3 – Cuts and Lacerations: Refers to a contractor safety incident that results in a cut or laceration that is reportable to Cal/OSHA. Cuts and lacerations accounted for 29 (16 percent) of the 185 expected annual number of events.

D4 – Bruises and Contusions: Refers to a contractor safety incident that results in a bruise or contusion that is reportable to Cal/OSHA. Bruises and contusions accounted for 22 (12 percent) of the 185 expected annual number of events.

D5 – Fractures: Refers to a contractor safety incident resulting in a broken bone that is reportable to Cal/OSHA. Fractures accounted for 16 (9 percent) of the 185 expected annual number of events.

D6 – Abrasions and Scratches: Refers to a contractor safety incident resulting in abrasions or scratches that is reportable to Cal/OSHA. Abrasions and Scratches events accounted for 8 (4 percent) of the 185 expected annual number of events.

D7 – Back Pain, Hurt Back: Refers to a contractor safety incident resulting in back pain or a hurt back that is reportable to Cal/OSHA. Back pain or hurt back events accounted for 10 (5 percent) of the 185 expected annual number of events.

D8 – Animal or Insect Bites: Refers to a contractor safety incident due to an animal or insect bite that is reportable to Cal/OSHA. Animal or insect bite events accounted for 5 (3 percent) of the 185 expected annual number of events.

D9 – Punctures (Except Bites): Refers to a contractor safety incident due to a puncture wound, excluding bites, that is reportable to Cal/OSHA. Puncture events accounted for 3 (2 percent) of the 185 expected annual number of events.

6. Cross-Cutting Factors

A cross-cutting factor is a driver or control that is interrelated to multiple risks. PG&E is presenting eight cross-cutting factors in the 2020 RAMP. The cross-cutting factors that impact the Contractor Safety Incident risk are shown in Table 17-2 below. A description of the cross-cutting factors and the mitigations and controls that PG&E is proposing to mitigate the cross-cutting factors are described in Chapter 20.

**TABLE 17-2
CROSS-CUTTING FACTOR SUMMARY**

Line No.	Cross-Cutting Factor	Impacts Likelihood	Impacts Consequence
1	Records Information Management		X

PG&E is continuing to evaluate the impact that Physical Attack has on RAMP risks and expects to present Physical Attack as a cross-cutting factor relative to additional RAMP risks in the 2023 General Rate Case (GRC).

7. Consequences

The basis for measuring the consequences of the Contractor Safety Incident risk are a serious injury (Cal/OSHA definition) or fatality.

The consequences of a Contractor Safety Incident risk event occurring are:

- A serious injury⁵ or fatality occurs 2 percent of the time and accounts for 100 percent of the risk consequences; and
- An OSHA-recordable event occurs 98 percent of the time but does not account for any of the risk consequences.

PG&E relied on the PG&E Serious Incidents Reports from 2012 through 2019 to analyze the safety consequences of a contractor safety incident. The Serious Incidents Report provides the details of the incident including injury type, actions taken, and the date that injury occurred consistent with Cal/OSHA reporting requirements. The review and analysis of the data was supported by PG&E Subject Matter Expert (SME) judgement to confirm the initial the incident information.

Table 17-3 below shows the risk event consequences. Model attributes are described in Chapter 3, “Risk Modeling and Risk Spend Efficiency.”

**TABLE 17-3
RISK EVENT CONSEQUENCES**

					Natural Units Per Event	CoRE	Natural Units per Year	Attribute Risk Score
	CoRE	%Freq	%Risk	Freq	Safety EF/event	Safety	Safety EF/yr	Safety
OSHA Recordable	-	98%	-	182.4	-	-	-	-
Serious Injury or Fatality	32.2	2%	100%	2.9	0.64	32.2	1.88	94
Aggregated	0.5	100%	100%	185.3	0.01	0.5	1.88	94

C. Controls and Mitigations

Tables 17-3 and 17-4 list all the controls and mitigations. PG&E included in its 2017 RAMP, 2020 GRC and 2020 RAMP (2020-2022 and 2023-2026). The tables provide a view as to those controls and mitigations that are on-going, those that are no longer in place, and new mitigations. In the following sections

⁵ A significant injury or illness is diagnosed by a physician or other licensed health care professional. OSHA believes that most significant injuries and illnesses will result in one of the criteria listed in § 1904.7(a): death, days away from work, restricted work or job transfer, medical treatment beyond first aid or loss of consciousness. OSHA believes that cancer, chronic irreversible diseases, fractured or cracked bones, and punctured eardrums are generally considered significant injuries and illnesses. . . even if medical treatment or work restrictions are not recommended, or are postponed, in a particular case. United States Department of Labor, Occupational Safety and health Administration, Standard Number 1904.7, Note to § 1904.7.

1 PG&E describes the controls in place in 2019 as part of the 2020 RAMP
2 baseline, changes to the mitigations and controls presented in the 2017 RAMP,
3 and then discusses new mitigations and mitigations continuing to be
4 implemented during the 2020-2022 and 2023-2026 periods.

**TABLE 17-4
CONTROLS SUMMARY**

Line No.	Control Name and Number	2017 RAMP 2017-2019	2020-2022 GRC 2017-2020	2020 RAMP 2020-2022	2020 RAMP 2023-2026
1	C1 – Enhanced Standard Contract Terms and Conditions	X	X	X	X
2	C2 – Contractor Safety Pre-Qualifications	X	X	X	X
3	C3 – Contractor Safety Standard and LOB Contractor Oversight Procedures	X	X	X	X
4	C4 – Contractor Safety Plans	X	X	X	X
5	C5 – Contractor Hazard Analysis	X	X	X	X
6	C6 – LOB Contractor Safety Oversight	X	X	X	X
7	C7 – LOB Compliance Assessments	X	X	X	X
8	C8 – Corrective Action Program (CAP) for Contractor Issues	X	X	X	X
9	C9 – Contractor Post-Job Safety Performance Review	X	X	X	X
10	C10 (M1B) – SIF Incident Governance and Oversight		X	X	X
11	C11 (M2) – Contractor Safety Officer Criteria		X	Being Enhanced as M18	X
12	C12 (M3) – CAP Issues Criteria		X	Removed as Ineffective	
13	C13 (M4) – ISN Rapid Growth Tracking		X	X	X
14	C14 (M6) – OSHA Program Training Requirements		X	Being Enhanced as M17	
15	C15 (M7) – Standardized Safety Plan and Job Safety Analysis (JSA) Templates		X	X	X
16	C16 (M8) – PG&E Specific Hazards Communication Process		X	Removed as Duplicative	
17	C17(M12) – Tools and Technology		Mitigation Bundle	Unbundled – Removed	

TABLE 17-4
CONTROLS SUMMARY
(CONTINUED)

Line No.	Control Name and Number	2017 RAMP 2017-2019	2020-2022 GRC 2017-2020	2020 RAMP 2020-2022	2020 RAMP 2023-2026
18	C18 (M9 – Contractor Governance) LOB to Conduct Contractor Forums			X	X
19	C19 (M10 Contractor Knowledge bundle) – All impacted PG&E Employees Bi-Annual Program Compliance Training			X	X
20	C20 (M9 – Contractor Governance) Enhance Contractor Post-Job Performance Evaluation			X	X
21	C21 (M9 – Contractor Governance) Automated System for Improving Processes through ISN			X	X

**TABLE 17-5
MITIGATIONS SUMMARY**

Line No.	Mitigation Name and Number	2017 RAMP 2017-2019 Mitigations	2020 GRC 2020-2022 Mitigations	2020 RAMP 2020-2022 Mitigations	2020 RAMP 2023-2026 Mitigations
1	M1B – SIF Incident Governance and Oversight	X	Becomes a Control C10		
2	M2 – Contractor Knowledge: Contractor Safety Officer Criteria	X	Becomes a Control C11	Being Enhanced as M18	
3	M3 – CAP Issues Criteria	X	Becomes a Control	Removed as Ineffective	
4	M4 – ISN Company Rapid Growth Tracking	X	Becomes a Control C13		
5	M5 – Contractor Blocking Automation	X	Removed as infeasible		
6	M6 – Contractor Knowledge: OSHA Program Training Requirements	X	Becomes a Control	Being Enhanced as M17	
7	M7 – Standardized Safety Plan and JSA Templates	X	Becomes a Control C15		
8	M8 – PG&E Specific Hazards Communication Process	X	Becomes a Control	Removed as duplicative	
9	M9 – Contractor Governance		Mitigation Bundle	Unbundled – now C18, C19, C20	
10	M10 – Contractor Knowledge		Mitigation Bundle	Unbundled – now C10	

**TABLE 17-5
MITIGATIONS SUMMARY
(CONTINUED)**

Line No.	Mitigation Name and Number	2017 RAMP 2017-2019 Mitigations	2020 GRC 2020-2022 Mitigations	2020 RAMP 2020-2022 Mitigations	2020 RAMP 2023-2026 Mitigations
11	M11 – Contractor Process Improvements (PI)		Mitigation Bundle `	Unbundled – now M11a and M11b	
12	M11A - Safety Scorecard		X (Inc. in M11)	X	Becomes a Control
13	M11B – Work Permits		X (Inc. in M11)		X
14	M12 – Tools and Technology		Mitigation Bundle	Unbundled – now M12a and M12b	
15	M12a – ISN's Individual Badge Feature			X	Becomes a Control
16	M12b – Establish Tool for Capturing Contractor Near-Hits and Good-Catches			X	Becomes a Control
17	M13 – Contractor On-Boarding Requirements			X	X
18	M14 – Contractor Safety Field Inspections			X	X
19	M15 – Contractor Safety Handbook			X	Becomes a Control
20	M16 – Tracking Contractor Workers				X
21	M17 (enhancement to C14) –OSHA Programs Training Requirements			X	X
22	M18 (enhancement to C11) – Contractor Safety Officer Criteria			X	Becomes a Control

1. 2019 Controls and Mitigations

a. Controls

PG&E identified nine controls in its 2017 RAMP that are anticipated to remain in place through 2026.

C1 – Enhanced Standard Contract Terms and Conditions: The enhanced Standard Contract Terms and Conditions, which are inserted into each of the prime contractors' contracts, are specific safety-related expectations and conditions based on the Contractor Safety Program Standard SAFE-3001S. Ongoing evaluations are conducted through the LOB compliance assessment process to assess effectiveness and identify any gaps.

C2 – Contractor Safety Pre-Qualification: The Contractor Safety program's pre-qualification process establishes criteria for contractors to qualify in order to perform work for PG&E. The criteria include total recordable injury and days away/restricted duty/transferred rates, number of fatalities, and confirmed OSHA citations. Ongoing evaluations are conducted through the LOB compliance assessment process to assess effectiveness and identify any gaps.

C3 – Contractor Safety Standard and LOB Contractor Oversight Procedures: The Contractor Safety Standard and the associated LOB contractor safety oversight procedures set requirements for managing medium and/or high risk contract work, including procedural steps for each LOB in providing work oversight and management for their contractors. These procedures include providing post-job safety performance evaluation of contractor work and sharing lessons learned resulting from safety incidents. Ongoing evaluations are conducted through the LOB compliance assessment process to assess effectiveness and identify any gaps in procedure implementation. Corporate Contractor Safety has established a formal review and approval process in 2019 for any new or revised procedures and included an approval requirement in the Contractor Safety Standard SAFE-3001S.

1 **C4 – Contractor Safety Plans:** Safety plans are developed by the
2 contractor and are reviewed and approved by PG&E prior to
3 commencing high risk work. These plans are required to address the
4 Scope of Work (SOW) to be performed and identify specific site or task
5 hazards, and mitigations of those hazards prior to beginning work.
6 Additionally, these plans include a requirement to perform a hazard
7 analysis (Refer to C5 for Job Hazard Analysis/tailboard requirements)
8 prior to beginning medium and/or high-risk work activities. Ongoing
9 evaluations are conducted through the LOB compliance assessment
10 process to assess effectiveness and identify any gaps. In 2019, this
11 process was strengthened by establishing minimum safety training
12 requirements and qualifications for safety plan approvers.

13 **C5 – Contractor Hazard Analysis:** Contractors perform a job hazard
14 analysis as part of their daily tailboard process as a method of
15 identifying, mitigating and communicating known or potential hazards to
16 their employees and subcontractors prior to commencing work. These
17 analyses are required prior to the execution of work and re-enforce the
18 requirements established in the approved safety plans (refer to C4 for
19 Contractor Safety Plans). Ongoing evaluations are conducted through
20 the LOB compliance assessment process to assess effectiveness and
21 identify any gaps.

22 **C6 – LOB Contractor Safety Oversight:** The LOBs and Corporate
23 Field Safety provide oversight of contractors by conducting field safety
24 observations of crews, using observation software, to validate
25 compliance with PG&E and regulatory safety requirements, while
26 identifying safe/unsafe behavior and/or conditions. SafetyNet® is a
27 software tool that was made available across the enterprise in 2019 to
28 capture contractor safety observations performed by the LOB. This
29 allows PG&E to aggregate large quantities of data from observed at-risk
30 behaviors and/or conditions from multiple job sites and projects.
31 Analysis of this data allows each LOB to better understand the specific
32 areas of risk exposure and to target mitigation resources to those
33 specific risks.

C7 – LOB Compliance Assessments: These assessments focus on compliance with the requirements outlined in the LOB procedures, including identifying any nonconformance and correcting them through PG&E's CAP. The assessments also focus on PG&E work that utilizes contractors performing medium and/or high-risk activities and are conducted across all LOBs by members of the Corporate Contractor Safety team. The assessment results, including any related findings, are reported out post-assessment at the LOB level and also quarterly at an enterprise level. PG&E has completed 208 Contractor Safety Program LOB Compliance Assessments across the enterprise in 2019. 10.3 percent of these assessments resulted in one or more identified non-conformances.

C8 – CAP for Contractor Issues: CAP continues to be used for contractor LOB assessment non-conformances issues. CAP provides a process to document non-conformances identified from the LOB compliance assessments (Refer to C7 for LOB Compliance Assessment Control) and track issues to closure. To enhance the visibility into the issues being identified from these assessments, PG&E created a dashboard in 2019 that displays all assessment findings by LOB that can be accessed by any PG&E employee.

C9 – Contractor Post Job Safety Performance Review: LOBs complete safety performance evaluations for contractors at the end of project work or at least annually for multi-year projects. Post-job performance evaluations are entered into each contractor's ISN account and factor into each contractor's pre-qualification status. Ongoing evaluations are conducted through the LOB compliance assessment process to assess effectiveness and identify any gaps.

b. Mitigations

PG&E identified 8 mitigations in the 2017 RAMP for the 2017 to 2019 period.

M1B – SIF Incident Governance and Oversight: This mitigation is broken up into three sub-mitigations and is performed by a cross-functional team of PG&E SMEs. By doing this work, PG&E will be able to establish a standardized framework for effectively on-boarding

contractors, improve identification and mitigations of hazards and investigate and respond to serious injury and fatality events. The sub-mitigations are:

- Implementation of an agreed-upon Safety and Health oversight structure to assist in the identification and controls of hazardous conditions;
- Perform end-to-end process review as part of contractor fatality investigation and implement corrective actions; and
- Design the framework for a contractor on-boarding program (5-year plan, contractor training requirements, and PG&E criteria for on-boarding).

M2 – Contractor Safety Officer Criteria: Develop and implement criteria for when contractors are required to provide a Safety Officer, or a designated safety representative. This mitigation is an enhancement of C6 (LOB Contractor Safety Oversight) noted in Section III above. By implementing this requirement, the contractor will provide additional safety oversight during the execution of work.

M3 – Corrective Action Program Issues Criteria: This mitigation will provide contractors with the ability to use CAP. The program had previously been available only to PG&E employees. This mitigation will allow PG&E to efficiently track and review the contractor's progress on closure of corrective actions. This also includes the development and implementation of criteria for requiring CAP issues to be reported when there are contractor safety identified findings and/or corrective actions from safety incident investigations. This mitigation is an enhancement of C8 (CAP for contractor issues).

M4 – ISN Company Rapid Growth Tracking: Utilize ISN to track the rapid growth of contractors that have expanded their Company employee count by 20 percent or greater in a single quarter. This will enable PG&E to perform a review of the contractors' safety management systems in place to support the workforce expansion. This mitigation is an enhancement of C2 (Contractor Safety – Pre-Qualifications).

M5 – Contractor Blocking Automation: Automate the ability to block contractors who do not meet PG&Es pre-qualification requirements in SAP. Implement a daily a direct feed from ISN to SAP that will block contractors based on their pre-qualification status in ISN. The SAP block will not allow a new contract to be executed with the contractor. This will lead to a reduction in the risk associated with executing a contract with an unqualified contractor. This mitigation is an enhancement of C2 (Contractor Safety – Pre-Qualifications).

M6 – (Contractor Knowledge) OSHA Programs Training Requirements: Identify safety training for contractors and PG&E employees overseeing contractors to ensure they have the appropriate qualifications and training required to oversee the work from a safety perspective. This is in addition to any required OSHA training. This mitigation is an enhancement of C6 (LOB Contractor Safety Oversight).

M7 – Standardized Safety Plan and JSA Templates: Standard templates for safety plans and JSAs will allow PG&E to establish baseline requirements across all LOBs. This mitigation is an enhancement of C4 (Contractor Safety Plans) and C5 (Contractor Hazard Analysis).

M8 – PG&E Specific Hazards Communication Process: Develop a process for communicating PG&E specific hazards to enable contractors to better identify and plan to mitigate those hazards associated with sites, assets and facilities prior to commencing work. This mitigation is an enhancement of C4 (Contractor Safety Plans) and C5 (Contractor Hazard Analysis).

c. 2017 RAMP Update

PG&E concluded in the 2017 RAMP that the best way to mitigate contractor safety risks was through mitigation bundles that focused on key Contractor Safety Program objectives: Contractor Safety Program PI; Governance; Knowledge; and Tools and Technology. PG&E also designed and implemented controls to comply with PG&E's internal contractor safety program and with applicable OSHA and CPUC requirements.

1 In addition, PG&E presented eight mitigations (M1B through M8)⁶ in
 2 the 2017 RAMP to further manage risk by enhancing the
 3 pre-qualification contractor management process and by improving
 4 contractor safety planning, training and oversight. The mitigations were
 5 developed based on the results of a Contractor Safety Program gap
 6 analysis that PG&E conducted. Of those eight mitigations:

- 7 • As shown in Table 17-5 above, seven mitigations (M1, M2, M3, M4,
 8 M6, M7, and M8) are now controls in the 2020 RAMP and the SOW
 9 presented in the 2017 RAMP remains the same; and
- 10 • One mitigation (M5) was removed because it is not possible to feed
 11 data directly from ISN into PG&E's SAP.

12 In the 2020 GRC PG&E provided an update as to the state of
 13 managing the Contractor Safety risk.⁷ In the 2020 GRC PG&E
 14 identified three remaining mitigation bundles: Contractor Governance;
 15 Contractor Knowledge; and Contractor PIs. While the individual
 16 mitigations have changed, the three new mitigations proposed in the
 17 2020 GRC are closely aligned to the key Contractor Safety Program
 18 objectives set forth in the 2017 RAMP. The mitigations PG&E
 19 presented in the 2017 RAMP became controls in the 2020 GRC as the
 20 mitigations matured and became established, on-going processes for
 21 managing risk.⁸

22 In the 2017 RAMP PG&E presented nine controls (C1-C9)⁹ that
 23 were on-going activities for managing the risk drivers for Contractor
 24 Safety risk. These same nine controls were included in PG&E's 2020
 25 GRC and are again presented in the 2020 RAMP, though the scope of
 26 many of the controls has been updated.

27 In the 2020 GRC identified eight new controls, most of which
 28 continue into the 2020 RAMP. The additional controls and changes to
 29 controls are included in Table 17-4 above.

6 PG&E's 2017 RAMP Report, p. 14-11.

7 Application (A.) 18-12-009, Exhibit (PG&E-7), Chapter 1.

8 A.18-12-009, Exhibit (PG&E-7), Table 1-4, p. 1-30.

9 PG&E's 2017 RAMP Report, p. 14-9.

For the 2020 RAMP, the three mitigation bundles remaining from the 2020 GRC; M9 (Contractor Governance), M10 (Contractor Knowledge), and M11 (Contractor PI) have been removed and updated as individual mitigations

D. 2020-2022 Controls and Mitigations Plan

1. Changes to Controls

In the 2020 RAMP PG&E continues to implement the nine controls included in the 2017 RAMP and adds seven new controls that are described below. Changes to controls included in PG&E's 2020 GRC are shown in Table 17-4 above.

C10 –SIF Incident Governance and Oversight. PG&E has two established procedures to address this: (1) The SIF Manual, SAFE-1100M, that outlines the process for after a SIF occurs (PG&E employee or contractor) from the necessary notifications through the full investigation process; and (2) The procedure for non-SIF incidents involving contractors, SAFE-1100P-2, that provides a structure for evaluating the quality of the required contractor investigation and associated corrective actions, determining the extent of condition throughout PG&E, and developing and implementing corrective actions based on the extent of condition. Both procedures have processes required for entering issues into CAP for evaluation and corrective actions that were previously identified in C12 (CAP Issue Criteria), which has now been removed and incorporated into this control.

C13 – ISN Rapid Growth Tracking and Contractor Evaluations. Utilize ISN to track the rapid growth of contractors that have increased their headcount significantly for PG&E work. PG&E's Corporate Contractor Safety team performs Management and Organizations reviews of the contractor's safety management systems in place to support the workforce expansion. In 2019, 52 evaluations were completed resulting in 44 approved contractors. This control is an enhancement of C2 (Contractor Safety Prequalification).

C15 – Standardized Safety Plan and JSA Templates. Standard templates for safety plans and JSAs will allow PG&E to establish baseline

requirements across all LOBs. In 2018, PG&E established minimum requirements for Job Hazard Analysis templates and included these requirements in the contract terms and conditions. This program is an enhancement of control for C4 (Contractor Safety Plans) and C5 (Contractor Hazard Analysis/Daily Tailboards). Ongoing evaluations are conducted through the LOB compliance assessment process to assess effectiveness and identify any gaps.

C18 – LOBs to Conduct Contractor Forums. LOBs conduct safety forums with contractors to partner on safety topics, lessons learned and performance feedback. Ongoing evaluations are conducted through the LOB compliance assessment process to assess effectiveness and identify any gaps.

C19 – Contractor Safety Program Orientation. The Contractor Safety Program Orientation SAFE-0102 web-based training (WBT), was created for PG&E employees who oversee contractors. This WBT was approved in 2018 by the Learning Academy as an optional course and does not require mandatory enrollment. PG&E will re-evaluate in 2020 if this WBT needs to be required and assigned to employees who oversee contracted work. This control was Mitigation M9 in the 2020 GRC.

C20 – Enhance Contractor Post-Job Performance Evaluation.

Contractor post-job performance evaluation scorecard criteria have been in place as a control since 2018. This control was Mitigation M9 in the 2020 GRC.

C21 – Automated System for Improving Processes through ISN. An automated system for tracking, trending and generating reports to improve processes through ISN has been in place as a control since 2018. This control was Mitigation M9 in the 2020 GRC.

2. Changes to Mitigations

PG&E will implement eight new mitigations in the 2020-2022 period. Certain mitigations will continue into the 2023-2026 period as well.

M11a – Safety Scorecard. Implement a safety performance evaluation scorecard to determine whether contractors need improvement in their performance or if they need a probationary period with a possible safety improvement plan or a deep-dive safety assessment. The results may be

used in determining future work awards. Expected implementation year-end 2021 with integration into contractor work activities through 2023 transitioning to a control and in place through 2026 (RAMP 2020 timeline)

M12a – Use ISN’s Individual Badge Feature. Use ISN’s individual badge feature to verify contractor employee training and qualifications at the job site. Year end 2020 completion is estimated.

M12b – Contractor Near-hits/Good-Catches. Establish a method for capturing both PG&E employee and contractor near-hits/good-catches in one platform. This mitigation is expected to be implemented in 2021.

M13 – Contractor Onboarding. This is a new mitigation and an enhancement related to C10 (SIF Incident Governance and Oversight). This mitigation will include minimum criteria for requirements for consistently onboarding contractors throughout the enterprise.

M14 – Contractor Safety Field Inspections. Corporate Safety will perform unannounced field visits. This is a new mitigation and an enhancement related to C6 (LOB Contractor Safety Oversight) and C7 (LOB Compliance Assessments). The Contractor Safety Standard SAFE-3001S requires the LOBs to perform safety observations of their contractors. Additionally, the Corporate Contractor Safety team conducts LOB compliance assessment of the LOBs adherence to their approved contractor oversight procedures (refer to C3 Contractor Safety Standard and LOB Contractor Oversight Procedures). This is an expansion to focus on contractor adherence to OSHA compliance.

M15 – Contractor Safety Handbook. This mitigation is an enhancement of C1 (Enhanced Standard Contract Terms and Conditions). Develop a comprehensive Environmental and Health and Safety (EHS) handbook to includes policies, programs, procedures, and other documents that explain PG&E's requirements and expectations to provide consistent guidance to contractors. Integrate the EHS Handbook into contractor work activities. This mitigation will be implemented 2022.

M17 – OSHA Programs Training Requirements. Identify safety training for contractors and PG&E employees overseeing contractors to ensure they have the appropriate qualifications and training required to oversee the work

from a safety perspective. This is in addition to any required OSHA training. This mitigation is an enhancement of C6 (LOB Contractor Safety Oversight). **M18 – Contractor Safety Officer Criteria (enhancement to C11).** Develop and implement criteria for when contractors are required to provide a Safety Officer, or a designated safety representative. This mitigation is an enhancement of C6 (LOB Contractor Safety Oversight). By implementing this requirement, the contractor will provide additional safety oversight during the execution of work. This mitigation will be evaluated in 2020 for 2021 implementation.

Table 17-6 below shows the forecast costs for the mitigation work planned for the 2020-2022 period.

**TABLE 17-6
FORECAST COSTS
2020-2022 EXPENSE
(THOUSANDS OF DOLLARS)**

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	Total
1	M11a	Safety Scorecard	FL	–	\$181	–	\$181
2	M11b	Work Permits	FL	–	–	–	–
3	M13	Contractor On-Boarding	FL	–	–	\$1,625	1,625
4	M14	Contractor Safety Field Inspections	FL	–	3,740	3,740	7,480
5	M15	Contractor Safety Handbook	FL	–	216	–	216
6	M16	Tracking Contractor Workers	FL	–	–	–	–
7	M17	OSHA Programs Training Requirements	FL	–	492	148	640
8	M18	Contractor Safety Officer Criteria	FL	–	17	17	34
9		Total		–	\$4,646	\$5,530	\$10,176

Notes See WP 17-1.

E. 2023-2026 Proposed Mitigation Plan

PG&E is proposing two new mitigations between 2023 and 2026 that are described below. In addition, three mitigations started in the 2020-2022 period continue (M13, M14 and M17) and five mitigations started in the 2020-2022 period become controls (M11A, M12A, M12B, M15, and M18).

M11b – Work Permits: Establish a process for PG&E to evaluate critical high-risk work activities and ensure all safety controls are in place before commencement.

M16 – Tracking Contractor Workers: Establish a platform for tracking contractor work status and crew locations. The proposed system will enhance existing processes to allow tracking of work schedules and locations. PG&E expects implementation year-end 2023 with transition to control through the RAMP 2020 timeline of 2026.

Table 17-7 below shows the forecast costs, RSEs and risk reduction scores for the mitigation work planned for the 2023-2026 period.

TABLE 17-7
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	M11a	Safety Scorecard	FL	—	—	—	—	—	—	—
2	M11b	Work Permits	FL	\$58	\$17	\$17	\$17	\$109	215.9	18.0
3	M13	Contractor On-Boarding	FL	1,625	1,625	1,625	1,625	6,500	3.8	18.0
4	M14	Contractor Safety Field Inspections	FL	3,740	3,740	3,740	3,740	14,960	1.3	14.4
5	M15	Contractor Safety Handbook	FL	—	—	—	—	—	—	—
6	M16	Tracking Contractor Workers	FL	1,501	1,501	1,501	1,501	6,005	4.1	18.0
7	M17	OSHA Programs Training Requirements	FL	148	148	148	148	591	33.0	14.4
8	M18	Contractor Safety Officer Criteria	FL	—	—	—	—	—	—	—
9		Total	—	\$7,071	\$7,031	\$7,031	\$7,031	\$28,164		

(a) See Mitigation Effectiveness workpapers (MW) included in the source document modeling package for information used to calculate the RSE.

Note See WP 17-1.

Based on the results of the risk modeling analysis shown in Table 17-7 above, PG&E is proposing to spend approximately half of its 2023-2026 funds on the Contractor Safety Field Inspections program even though it has one of the lower RSEs. The Contractor Safety Field Inspections Program is critical because it allows PG&E to confirm that its Contractors are executing high and medium risk work safely. It is the way to verify that Contractors are complying with OSHA and PG&E safety requirements and that they are adhering to the project specific safety plans approved by PG&E.

1 The proposed Work Permits mitigation has the highest RSE though PG&E is
2 proposing to spend less than one percent of its budget on it. The program is
3 available through ISN and allows for permit management on the move, through
4 phones and tablets. PG&E will look for opportunities to expand this program.

5 **F. Alternative Analysis**

6 In addition to the proposed mitigations described in Section E above,
7 PG&E considered alternative mitigations as well. The mitigations described in
8 Section E constitute the Proposed Plan. The Alternative Plans consist of a
9 combination of some or all of the proposed mitigations along with the alternative
10 mitigation(s). PG&E describes each of the alternative mitigations it considered
11 below and then provides a table showing the forecast costs, RSEs and risk
12 reduction scores for each of the Alternative Plans.

13 **1. Alternative Plan 1: Do Not Implement the Contractor Work** 14 **Management System**

15 This alternative considers removal of the Contractor Work Management
16 System for tracking contractor work status and crew locations. Because the
17 Contractor Work Management System supports increased oversight and is
18 critical to the success of the Contractor Safety Program PG&E will proceed
19 with its proposal to implement the system. This alternative was not chosen
20 because it could reduce contractor safety.

21 **2. Alternative Plan 2: Increased Contractor Safety Field Inspection** 22 **Resources**

23 This alternative would expand the Contractor Safety Field Inspections
24 program by increasing the number of PG&E resources assigned to the
25 program. As shown in Table 17-8, expanding this program would
26 significantly increase the cost without a commensurate increase in safety
27 risk reduction. PG&E chose not to pursue this alternative due to the
28 high cost.

TABLE 17-8
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026 EXPENSE
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	A2	Increased Contractor Safety Field Inspections	\$3,740	\$3,740	\$3,740	\$3,740	\$14,960		
2		Total	\$3,740	\$3,740	\$3,740	\$3,740	\$14,960	0.9	9.8

(a) See MW included in the source document modeling package for information used to calculate the RSE.

Note: See WP 17-1.

1 Table 17-9 compares the proposed and alternative mitigation plans.

TABLE 17-9
MITIGATION PLAN ALTERNATIVES ANALYSIS
(THOUSAND OF DOLLARS)

Line No.	Risk Mitigation Plan	Plan Components ^(a)	Total Expense (2023-2026)	Total Capital (2023-2026)	Risk Reduction (NPV) ^(b)	Total Spend (NPV) ^(b)	RSE
1	Proposed	M11b, M13, M14, M16, M17	\$28,165	—	82.9	\$20,749	4.0
2	Alternative 1	M11b, M13, M14, M17	\$22,160	—	68.2	\$16,326	4.2
3	Alternative 2	Proposed +A2	\$43,125	—	90.5	\$31,768	2.8

(a) Plan Components refers to the Mitigations presented in Table 17-4.

(b) Information presented in terms of Net Present Value (NPV) to account for the discounting of benefits.

Note: See WP 17-2.

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 18
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: MOTOR VEHICLE SAFETY INCIDENT

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 18
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: MOTOR VEHICLE SAFETY INCIDENT

TABLE OF CONTENTS

A. Executive Summary.....	18-1
1. Risk Overview	18-2
2. Risk Definition	18-3
B. Risk Assessment.....	18-3
1. Background and Evolution	18-3
2. Risk Bow Tie	18-5
3. Exposure to Risk.....	18-5
4. Tranches	18-5
5. Drivers and Associated Frequency	18-6
6. Cross Cutting Factors	18-7
7. Consequences	18-8
8. Next Steps in Modeling the Motor Vehicle Safety Incident Risk.....	18-10
C. Controls and Mitigations	18-10
1. 2019 Controls and Mitigations.....	18-14
a. Controls	18-14
b. Mitigations	18-17
c. 2017 RAMP Update.....	18-17
D. 2020–2022 Controls and Mitigation Plan.....	18-18
1. Changes to Controls	18-18
2. Changes to Mitigations.....	18-20
E. 2023-2026 Proposed Mitigation Plan.....	18-21
F. Alternative Analysis	18-23
1. Alternative Plan 1: A1 (M10) Driver Selection Program	18-23

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 18
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: MOTOR VEHICLE SAFETY INCIDENT

TABLE OF CONTENTS
(CONTINUED)

2. Alternative Plan 2: A2 (M20) Enhancement to Pool Vehicle Reservation System	18-23
3. Alternative Plan 3: A3 (M21) In-Cab Camera Technology	18-24
4. Alternative Plan 4: Smith Driving (M22)	18-24

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 18
RISK ASSESSMENT AND MITIGATION PHASE
RISK MITIGATION PLAN: MOTOR VEHICLE SAFETY INCIDENT

A. Executive Summary

Motor Vehicle Safety Incident (MVSII) risk includes any motor vehicle accident involving a Pacific Gas and Electric Company (PG&E or the Company) vehicle (or a personal vehicle being operated on company business) resulting in injuries or fatalities to, either PG&E employees or the public, and/or property damage. However, certain PG&E vehicles such as off-road vehicles and unique or specialized vehicles are out of scope for this risk. The drivers for this risk event are: non-preventable motor vehicle incident (NPMVI); preventable motor vehicle incident (PMVI) – PG&E hit stationary object; PMVI – PG&E backing; PMVI – PG&E struck third party; PMVI – rear ended third party; PMVI – PG&E initiated (all others); and PMVI – PG&E hit PG&E equipment. The cross-cutting factor Records and Information Management also impacts this risk.

Exposure to this risk is based on the approximately 141 million miles driven each year. The risk model includes an Average Annual Frequency of approximately 914 risk events each year. NPMVI accounts for 523 events/incidents or 57 percent of the risk events and 57 percent of the risk. PMVI accounts for 43 percent of the risk events and 43 percent of the risk.

PG&E identified eight tranches for 2020 based on a review of motor vehicle types and weight classes between 2016 and 2019. PG&E-owned trucks less than 10,000 pounds and PG&E-owned trucks 10,000 to 26,000 pounds account for 594 of the 914 risk events or 65 percent of the tranche-level risk for both Preventable and Non-Preventable incidents.

MVSI has the tenth highest 2023 test year baseline safety score (16.0) and the tenth highest 2023 test year baseline total risk score (16.6) of PG&E's 12 RAMP risks. The 2020 baseline total risk score of 21.4, improves by 24 percent when the planned mitigations are applied: the 2023 test year baseline total risk score is 16.6 and the 2026 post-mitigation risk score is 16.2.

PG&E is proposing a series of controls and mitigations to address MVSII risk. The Cell Phone Activity Blocking mitigation is PG&E's proposed mitigation.

1 It will be subject to further review as part of the General Rate Case (GRC)
 2 mitigation analysis using a third-party consultant (University of California, Los
 3 Angeles (UCLA)) who will incorporate the use of Bayesian Belief Networks to
 4 perform calculations considering the joint effect of factors in human error in
 5 PMVIs. Based on the current RAMP analysis, the Smith Driving and Driver
 6 Selection Program mitigations have highest risk reduction score.¹

**TABLE 18-1
RISK OVERVIEW**

Line No.	Risk Name	Motor Vehicle Safety Incident
1	In Scope	Any recordable MVI, both preventable and non-preventable involving a PG&E vehicle (or operated on behalf of PG&E). A recordable incident requires PG&E line of business filing a report on the incident. Non-preventable motor vehicle incidents involving third party interaction are in scope.
2	Out of Scope	Motorized equipment, off-road vehicles, off-road driving, and unique or specialized vehicles (included in the Employee Safety Incident risk), as well non-staff augmentation contractors, and other drivers. ^(a)
3	Data Quantification Sources	PG&E fleet data and MVI data, from January 2016 to December 2019 ^(b)
<p>(a) Incidents associated with motorized equipment, off-road vehicles, off-road driving, and unique or specialized vehicles that are not in scope for this risk are included in the Employee Safety Incident risk, Chapter 16.</p> <p>(b) Source documents will be provided with the workpapers on July 17, 2020.</p>		

7 **1. Risk Overview**

8 PG&E's Transportation Services (TS) organization supports more than
 9 13,800 vehicles and related equipment including construction equipment,
 10 trailers and aircraft. Annually, PG&E employees drive more than 141 million
 11 miles in PG&E vehicles to provide service to customers.

12 PG&E's Transportation Safety organization ensures compliance with
 13 federal Department of Transportation (DOT) regulations and state
 14 requirements. The Transportation Safety team manages a centralized
 15 compliance system of driver profiles (i.e., Commercial Driver's License
 16 (CDL), medical, drug, alcohol, clearinghouse and other compliance testing
 17 requirements) that provides PG&E with the ability to view and pair qualified

¹ The information herein is subject to those limitations described in Chapter 2, Section D.

drivers to vehicles they are qualified to drive and to track Drug and Alcohol Program enrollment and compliance. The department also tracks DOT-covered positions for the Pipeline and Hazardous Materials Safety Administration drug testing pool, for the Gas Operations.

The TS organization requires adherence to the MVSI controls, including safe driving programs, to reduce preventable motor vehicle incidents.

2. Risk Definition

Any motor vehicle accident involving a PG&E vehicle (or a personal vehicle being operated on company business) resulting in injuries or fatalities to, either PG&E employees or the public, and/or property damage. Certain PG&E vehicles such as off-road vehicles and unique or specialized vehicles are out of scope for this risk and are included in the Employee Safety Incident risk as part of the Serious Injury or Fatality (SIF) Prevention program.

B. Risk Assessment

1. Background and Evolution

MVSI is an updated risk in the 2020 RAMP. PG&E's 2017 RAMP included a motor vehicle risk, Motor Vehicle Safety.² For both the 2017 RAMP Motor Vehicle Safety and the 2020 RAMP MVSI risks, the risk event is the same—MVI both preventable (43 percent of the time) and non-preventable (57 percent of the time).

The MVSI risk definition has been updated since 2017. In the 2017 RAMP, this risk was defined as the failure to identify and mitigate motor vehicle incident exposures that may result in serious injuries or fatalities for employees or the public, property damage, and other consequences. The new risk definition aligns to PG&E's transition to an event-based risk register.

In the 2017 RAMP, PG&E identified three MVSI drivers: Equipment; Human Errors; and Outside Forces. Human errors, i.e., incidents resulting from human mistakes, accounted for 94 percent of the 2,256 events.³

² PG&E's RAMP Report, Investigation (I.) 17-11-003 (Nov. 30, 2017) (PG&E's 2017 RAMP Report), Chapter 16.

³ PG&E's 2017 RAMP Report, p. 16-4.


1 The seven drivers for MVSIs 2020 RAMP are classified into two groups:
2 non-preventable incidents—where the PG&E driver could not have
3 reasonably prevented the incident from occurring (which accounts for
4 57 percent of the incidents); and, preventable incidents—where the PG&E
5 driver could have reasonably prevented the incident from occurring (which
6 accounts for 43 percent of the incidents). As part of the UCLA risk analysis
7 planned for later this year (discussed in greater detail in Section 8), PG&E
8 will revisit the tranches and the data to better understand and illustrate the
9 risk areas. Two of the 2017 drivers (Equipment and Outside Forces) are no
10 longer drivers in 2020 because the data associated with these drivers did
11 not reasonably represent factors leading to MVSIs.

12 PG&E's 2017 RAMP relied on both PG&E and national data (from DOT)
13 to develop weightings for each risk driver.⁴ In 2020, PG&E is relying
14 exclusively on PG&E data to develop weightings for each risk driver. PG&E
15 will review the data again in 2021 and may further revise the weightings for
16 the risk drivers. The new drivers and new risk definition, which resulted from
17 the transition to using PG&E data instead of national data, provide a more
18 focused approach to PG&E-specific risk because it takes into account
19 controls that are already in place but that may not be accounted for in other
20 fleets and statistics.

⁴ PG&E's 2017 RAMP Report, p. 16-4.

2. Risk Bow Tie

**FIGURE 18-1
RISK BOW TIE – 2023 TEST YEAR BASELINE**



3. Exposure to Risk

Driving or riding in a PG&E vehicle or vehicle operated on behalf of PG&E creates exposure to the MVSI risk. PG&E uses miles driven as the measure of risk relative to exposure and the number of events per vehicle miles driven as the measure of risk relative to exposure.

PG&E's exposure for this risk is 141.3 million miles driven per year, which is based on PG&E Transportation Services data.

4. Tranches

PG&E identified eight tranches for MVSI risk, based on a review of motor vehicle types and weight classes for 2020. PG&E anticipates that the number of tranches will change in 2021.

- PG&E owned – trucks weighing less than 10,000 pounds;
- PG&E owned – trucks weighing between 10,000 and 26,000 pounds;
- PG&E owned – trucks weighing more than 26,000 pounds;
- PG&E owned – passenger vehicles;
- PG&E owned – trailers (will not apply in 2021 because trailers do not operate under their own power);

- 1 • PG&E owned – carpool vans (will not apply in 2021 because PG&E
- 2 does not own carpool vans);
- 3 • Employee owned vehicles; and
- 4 • Rental vehicles.

TABLE 18-2
RISK EXPOSURE AND PERCENT RISK BY TRANCHE

Line No.	Tranche	Annualized Mileage	Percent Exposure	Safety Risk Score	Financial Risk Score	Total Risk Score	Percent Risk ^(a)
1	PG&E-Owned – Trucks Less Than 10,000 lbs.	66.5	47%	6.7	0.28	6.9	42%
2	Employee-Owned Vehicles	30.0	21	1.6	0.07	1.7	10
3	PG&E-Owned – Trucks 10,000 – 26,000 lbs.	25.0	18	3.3	0.14	3.5	21
4	PG&E-Owned – Trucks Greater Than 26,000 lbs.	11.0	8	1.2	0.05	1.2	7
5	Rental Vehicles	7.4	5	1.2	0.05	1.3	8
6	PG&E-Owned – Passenger Vehicles	1.3	1	1.8	0.07	1.9	11
7	PG&E-Owned – Trailers	0.0	0	0.1	0.01	0.1	1
8	PG&E-Owned – Carpool Vans	0.0	0	0.0	0.00	0.0	0
9	Total ^(b)	141.3	100%	16.0	0.66	16.6	100%

(a) Percent risk is calculated risk based on frequency and consequence. The percent risk is the contribution of risk for each tranche to the overall risk.

(b) Differences due to rounding.

5. Drivers and Associated Frequency

PG&E identified seven drivers and six sub-drivers for the MVSII risk.

Each driver and its associated historical frequency, and key sub-drivers are discussed below.

D1 – NPMVI: Refers to a recordable MVI wherein the PG&E driver is not at fault. NPMVI events accounted for 523 (57 percent) of the 914 average annual number of events. PG&E identified six sub-drivers NPMVI sub-drivers: (1) third-party struck PG&E from behind; (2) all other; (3) third-party struck PG&E; (4) third-party struck PG&E property, parked; (5) third-party struck stopped PG&E; and (6) rock/road debris struck PG&E.

D2 – PMVI: PG&E Hit Stationary Object: Refers to a recordable MVI wherein the PG&E driver hit a stationary object. PG&E Hit Stationary Object

events accounted for 107 (12 percent) of the 914 average annual number of events.

D3 – PMVI, PG&E Backing: Refers to a recordable MVI wherein the PG&E driver backed their vehicle into an object. PG&E Backing events accounted for 98 (11 percent) of the 914 average annual number of events.

D4 – PMVI, PG&E Struck Third-Party: Refers to a recordable MVI wherein the PG&E driver struck a third-party vehicle. PG&E Struck Third-Party events accounted for 78 (8 percent) of the 914 average annual number of events.

D5 – PMVI, PG&E Rear-Ended Third-Party: Refers to a recordable MVI wherein the PG&E driver struck the rear end of a third-party vehicle. PG&E Rear-Ended Third-Party events accounted for 64 (7 percent) of the 914 average annual number of events.

D6 – PMVI, PG&E Initiated (all others): Refers to a recordable MVI wherein the PG&E driver is at fault (other than as described by the PMVI drivers). PG&E Initiated events accounted for 35 (4 percent) of the 914 average annual number of events.

D7 – PMVI, PG&E Hit PG&E Equipment: Refers to a recordable MVI wherein the PG&E driver struck PG&E equipment. PG&E Hit PG&E Equipment events accounted for 11 (1 percent) of the 914 average annual number of events.

6. Cross Cutting Factors

A cross-cutting factor is a driver or control that is interrelated to multiple risks. PG&E is presenting eight cross-cutting factors in the 2020 RAMP. The cross-cutting factor that impacts the MVSI risk are shown in Table 18-3 below. A description of the cross-cutting factors and the mitigations and controls that PG&E is proposing to mitigate the cross-cutting factors are described in Chapter 20.

**TABLE 18-3
CROSS-CUTTING FACTOR SUMMARY**

Line No.	Cross-Cutting Factor	Impacts Likelihood	Impacts Consequence
1	Records and Information Management		X

When analyzing this risk PG&E considered the cross-cutting risk Climate Change even though it is not listed in the table above. Climate change presents ongoing and future risks to PG&E's assets, operations, employees, customers, and the communities it serves. During this RAMP period PG&E will conduct a Climate Vulnerability Assessment (CVA) to further assess how its assets, operations, and employees are vulnerable to the projected impacts of climate change. PG&E intends to use findings from the CVA as well as developments in climate science and internal data gathering to continue to advance the quantification of all event-based risks, including RAMP risks, over this RAMP period.

7. Consequences

The basis for measuring the consequences of the MVSI risk is the finding that a PG&E driver in a recordable MVI is either at fault or not at fault.

The consequences of a MVSI risk event occurring are:

- An NPMVI occurs 73 percent of the time, and accounts for 73 percent of the safety risk; and
- A PMVI occurs 27 percent of the time and accounts for 27 percent of the safety risk.

Both PG&E employees and the public can be impacted by a PMVI or NPMVI. There is a financial consequence for both PMVI and NPMVI.

To analyze the safety consequences of the MVSI risk, PG&E relied on the PG&E Serious Injuries Report or the years of 2012-2019 using Fleet information data. PG&E focused on the period 2016-2019 for MVS incident reporting. The Serious Injuries Report provides information on serious injuries and fatalities for Employee, Contractor and Third-Party Public. SIF reporting incorporates a defined set of injuries that meets or exceeds Cal/OSHA reporting. Incident fault is not defined in the data.

PG&E relied on the PG&E GRC and Cal/OSHA recorded days away from work/restricted/transferred (DART) cases to analyze the financial consequences of the MVSI risk. The data used to evaluate this risk was supported by PG&E subject matter expertise best judgment.

Table 18-4 shows the consequences of the risk event. Model attributes are described in Chapter 3, Risk Modeling and Risk Spend Efficiency (RSE).

TABLE 18-4
RISK EVENT CONSEQUENCES

	CoRE %Freq %Risk Freq				Natural Units Per Event		CoRE		Natural Units per Year		Attribute Risk Score	
					Safety EF/event	Financial \$/M/event	Safety	Financial	Safety EF/yr	Financial \$/M/yr	Safety	Financial
Non-Preventable Motor Vehicle Incident	0.02	73%	73%	523	0.0004	0.002	0.0223	0.001	0.2	1.0	11.7	0.5
Preventable Motor Vehicle Incident	0.02	27%	27%	190	0.0004	0.002	0.0226	0.001	0.1	0.4	4.3	0.2
Aggregated	0.02	100%	100%	713	0.0004	0.002	0.0224	0.001	0.3	1.3	16.0	0.7

8. Next Steps in Modeling the Motor Vehicle Safety Incident Risk

PG&E has contracted with the B. John Garrick Institute for the Risk Sciences at UCLA to do an assessment that will lead to PG&E's updating its risk analysis so that the MVI risk drivers are expressed as accident causes (distraction, fatigue, etc.) as opposed to accident types.

PG&E is working with UCLA to study the causes of PG&E MVIs and assist in developing recommendations for mitigations. The first step in the UCLA/PG&E work was to identify and understand the relative contribution of causes to MVIs. The team analyzed PG&E preventable MVI investigation narrative records in order to identify the primary causes of the accident. Identified causes include fatigue, distraction, cellphone usage, and eating/drinking. In many cases, multiple causes were contributors to a single MVI. The causal analysis was performed globally and at a tranche level for each of the different accident types (e.g., PG&E strikes road hazard, PG&E backing etc.).

The second aspect of the UCLA/PG&E MVI study was to understand how important each of the causes was in the likelihood and severity of MVIs. This part of the study used the results from the investigative narrative causal analysis to rank the importance of causes for different accidents. Results from the cause ranking along with national data on MVIs was used to develop some initial recommendations for risk reduction.

Going forward, PG&E is considering an improvement to the MVI risk model such as developing event sequence models for each of the different accident types. This will lead to expressing the risk drivers as accident causes as opposed to accident types. Reconfiguring the bowtie in this manner will improve PG&E's ability to focus mitigation efforts on the actual causes of accidents. PG&E expects to update its model and include the findings in the upcoming 2023 GRC.

C. Controls and Mitigations

Tables 18-5 and 18-6 list all the controls and mitigations PG&E included in its 2017 RAMP, 2020 GRC and 2020 RAMP (2020-2022 and 2023-2026). The tables provide a view as to those controls and mitigations that are on-going, those that are no longer in place, and new mitigations. In the following sections

1 PG&E describes the controls and mitigations in place in 2019, changes to the
2 2019 mitigations and controls presented in the 2017 RAMP, and then discusses
3 new mitigations and/or significant changes to mitigations and/or controls during
4 the 2020-2022 and 2023-2026 periods.

**TABLE 18-5
CONTROLS SUMMARY**

Line No.	Control Name and Number	2017 RAMP	2020 GRC 2020-2022 Controls	2020 RAMP 2020-2022 Controls	2020 RAMP 2023-2026 Controls
1	C1 – Commercial Driving School	X	X	X	X
2	C2 – Driver Qualification	X	X	X	X
3	C3 – Smith Driving Courses	X	X	X	X
4	C4 – Distracted Driving	X	X	X	X
5	C5 – Smith Driving Course	X	X	Mitigation – M22	X (Alternative)
6	C6 – Defensive Driving, the Critical 5	X	X	X	X
7	C7 – Vehicle Tie Down Equipment Training	X	X	X	X
8	C8 – Reasonable Suspicion Supervisor Training	X	X	X	X
9	C9 – DMV Employee Pull Notice Program	X	X	X	X
10	C10 – Fitness for Duty Training	X	X	X	X
11	C11 – Phone Free Driving Standard	X	X	X	X
12	C12 – Company Pool Vehicle Standard	X	X	X	X
13	C13 – Commercial Driver’s Fatigue Management Procedure	X	X	X	X
14	C14 – Drug/Alcohol Testing Program (DOT and Gas Employees)	X	X	X	X
15	C15 – “How am I Driving” Hotline Reporting and Supervisor’s Review	X	X	X	X
16	C16 – Preventive Maintenance On Time Performance and Monitoring	X	X	X	X
17	C17 – Driver Visual Inspection Report (DVIR) and Audit	X	X	X	X
18	C18 (M1) – MVS Standard			X	X
19	C19 (M2A and M3)– Vehicle Safety Technology (VST) Program			X	X
20	C20 (M4) – TECH-0081WBT: Driving Expectations and New Laws			X	X
21	C21 (M5) – Standardized Employee MV Training Requirements			X	X
22	C22 (M6) – Training Acknowledgement for Valid License			X	X
23	C23 (M7) – Implement Driver Accountability			X	X

**TABLE 18-6
MITIGATIONS SUMMARY**

Line No.	Mitigation Name and Number	2017 RAMP 2017-2019 Mitigations	2020 GRC 2020-2022 Mitigations	2020 RAMP 2020-2022 Mitigation	2020 RAMP 2023-2026 Mitigations
1	M1 – MVS Standard	X	X	Becomes a control	
2	M2A – VST Program		X	Becomes a control	
3	M2B – 2017 and 2018 Vehicle Safety Technology Install and Activate	X		X	
4	M3 – VST Program Standardized Reporting	X			
5	M4 – Driving Expectations and New Laws		X	Becomes a control	
6	M5 – Standardized Employee MV Training Requirements		X	Becomes a control	
7	M6 – Training Acknowledgement for Valid License	X	X	Becomes a control	
8	M7 – Implement Driver Accountability	X	X	Becomes a control	
9	M8 – Revise License Verification Processes for Non-DOT Covered Drivers	X	X		
10	M9 – Deploy Vehicle Safety Technology in Personal Vehicles:			Removed as infeasible	
11	M10 – Driver Selection Program:				X (Alternative)
12	M13 – Motor Vehicle Safety Management System:			Removed – integrated into ESMS	
13	M14 – Post Incident Review			X	
14	M15 – 360 Walk Around App			X	
15	M16 – UCLA Study and Risk Analysis			X	
16	M17 – Data Enhancement/Improvement Plan				X
17	M18 – Safe Backing Training (TECH-9161)			X	

**TABLE 18-6
MITIGATIONS SUMMARY
(CONTINUED)**

Line No.	Mitigation Name and Number	2017 RAMP 2017-2019 Mitigations	2020 GRC 2020-2022 Mitigations	2020 RAMP 2020-2022 Mitigation	2020 RAMP 2023-2026 Mitigations
18	M19 – Cell Phone Activity Blocking				X
19	M20 – Enhancement to Pool Vehicle Reservation System				X (Alternative)
20	M21 – In-Cab camera technology				X (Alternative)
21	M22 – Smith Driving Course				X (Alternative)

1. 2019 Controls and Mitigations

a. Controls

C1 – Commercial Driving School: This course (EQIP-0006) is recommended for those employees that are required to obtain a CDL. The Commercial Driver School will prepare successful candidates to obtain a CDL. The course also includes practice on backing skills, proper shifting and various driving scenarios and road conditions.

C2 – Driver Qualification: This course (EQIP-0034) is required for employees that have their CDL and need to drive Commercial vehicles for PG&E. The driver must demonstrate safety, knowledge of laws, six step air brake check, and pre-trip inspection. The driver must also demonstrate skills driving with a trailer, under various conditions and scenarios. This is a three-day course.

C3 – Smith Driving Courses: These courses are designed for any PG&E employee who drives a Company vehicle as part of their job function. The focus of the course is to present the proper methods for safe, defensive driving and provide the skills (reinforced through practical application) to help the driver avoid (or reduce the severity of) MVIs.

C4 – Distracted Driving: This course (TECH-9164WBT) is designed to deter drivers from using cell phones and other hand-held devices while driving. The course explains the effects of four types of distractions,

1 including cognitive, physical, visual, and auditory, in order to mitigate the
2 impact of these distractions on drivers.

3 **C5 – Smith Driving Course:** This course (TECH-0089) is for those
4 who drive a personal vehicle for work. Training is conducted with the
5 employees' personal vehicle.

6 **C6 – Defensive Driving – The Critical 5:** This course
7 (TECH-9162WBT) discusses common driving patterns that expose
8 motorists to unnecessary risks.

9 **C7 – Vehicle Tie-Down Equipment Training:** This course
10 (EQIP-0062) instructs participants on how to perform safe equipment
11 tie-down procedures.

12 **C8 – Reasonable Suspicion Supervisor Training:** This course
13 (TECH-0049) is designed to qualify supervisors: to recognize the
14 warning signs of alcohol abuse or drug use; to know how to handle the
15 substance abusing employee; and to follow proper procedures for
16 reasonable suspicion drug and/or alcohol testing, documentation, and
17 reporting as required by current federal regulations and Company policy.

18 **C9 – Department of Motor Vehicle (DMV) Employer Pull Notice**
19 **Program:** This control confirms PG&E commercial drivers are in good
20 standing.

21 **C10 – Fitness for Duty Training:** This training (CORP-9134 VL) will
22 help supervisors recognize when they may have reason to question
23 whether or not an employee is physically or mentally able to perform
24 their work.

25 **C11 – Phone Free Driving Standard:** This standard (SAFE-1018S)
26 describes the requirements and prohibitions for using cellular phones
27 and Bluetooth® devices while driving on Company business, or while
28 driving a Company owned, leased or rented vehicle. The purpose of
29 this standard is to reduce the potential for distraction and promote
30 employee and public safety.

31 **C12 – Company Pool Vehicle Standard:** This standard
32 (TRAN-1012S) establishes requirements and responsibilities for
33 checking-out, operating, fueling performing repairs or maintenance
34 work, and returning PG&E pool vehicles. The standard requires the

1 presentation of a valid driver's license prior to rental of Company pool
2 vehicles.

3 **C13 – Commercial Driver's Fatigue Management Procedure:** This
4 procedure (TRAN- 2001P-01) provides instructions for managing driver
5 fatigue for commercial drivers.

6 **C14 – Drug/Alcohol Testing Program (DOT and Gas Employees):**

7 All DOT-covered employees are subject to drug testing managed by the
8 DOT Compliance Team (49 CFR parts 40, 199 and 382), including:
9 Pre-employment Drug Testing; Post-accident Drug Testing; Random
10 Drug Testing; Drug Testing resulting from Reasonable Suspicion and/or
11 Reasonable Cause; Return to Duty Drug Testing; and Follow-up Drug
12 Testing. The Drug and Alcohol Clearinghouse affects only CDL drivers.

13 **C15 – “How Am I Driving” Hotline Reporting and Supervisor**

14 **Review:** Driver complaints are received from the “How Am I Driving”
15 hotline. Supervisors are required to investigate, take corrective
16 measures and submit the investigation report for “How Am I Driving”
17 notifications within 15 days.

18 **C16 – Preventive Maintenance On-Time Performance and**

19 **Monitoring:** Garage mechanics perform preventive maintenance and
20 inspections and record the work via work orders entered in the Fleet
21 Anywhere application. Mechanics use preventive maintenance
22 checklists as guidelines for performing maintenance and inspections.
23 Garage Supervisors run daily and monthly reports to review preventive
24 maintenance and inspections coming due and on-time rates. The target
25 is 95 percent or greater for on-time completion rates. The PM On-time
26 Performance metric is reported monthly.

27 **C17 – DVIR and Audit:** Drivers perform an inspection of their vehicles
28 at the end of the day. Any issue identified with the vehicle results in the
29 vehicle being pulled out of service until the necessary repairs are
30 completed. PG&E performs audits of these reports to ensure drivers are
31 completing them, and that repairs are completed when identified. This
32 addresses potential equipment failures that may arise between
33 scheduled preventive maintenance work.

1 **b. Mitigations**

2 **M6 – Training Acknowledgement for Valid License:** Revise all
 3 employee web based training to include an acknowledgement statement
 4 for positive confirmation that the employee must have a valid license for
 5 the class of vehicle they drive on company business and are aware that
 6 they must notify their supervisor if their license status changes for any
 7 reason. The expected impact is to reduce the number of drivers
 8 operating vehicles without the necessary qualifications, and out of
 9 compliance.

10 **M7 – Implement Driver Accountability:** Use Vehicle Safety
 11 Technology (VST) and How's My Driving program to identify risky
 12 drivers and build an automated accountability structure. The impact of
 13 this mitigation is to identify risky drivers and take the appropriate
 14 measures to address performance.

15 **M2B – 2017 and 2018 Vehicle Safety Technology (VST) Install and**
 16 **Activate:** VST is Global Positioning System (GPS) – based, and the
 17 tool provides real-time, audible feedback to the driver when risky
 18 behaviors occur, such as speeding, hard acceleration and hard braking.

19 **M8 – Revise License Verification Process for Non-DOT Covered**
 20 **Drivers:** Implement license and insurance verification plan for
 21 employees who are not a part of the commercial driver pool. This
 22 mitigation is an expansion of C9 – DMV Employer Pull Notice Program.
 23 The expected impact is to ensure that drivers on the road have the
 24 appropriate licenses and are compliant with California laws.

25 **c. 2017 RAMP Update**

26 In the 2017 RAMP, PG&E outlined its 2017-2019 mitigation plan
 27 which focused on mitigating human error, a risk driver that was the
 28 source of 94 percent of motor vehicles incidents. PG&E proposed four
 29 mitigations, three of which (M2B, M6, and M7) expand on the Vehicle
 30 Safety Technology Program, a tool that provides real-time, audible
 31 feedback to the driver when it senses risky behavior such as hard
 32 braking, speeding and hard acceleration. The other mitigation related to
 33 further ensuring that drivers have the minimum qualifications for safely
 34 operating a PG&E or personal vehicle used for PG&E business (M8).

M2B, Vehicle Safety Technology (VST) Installation and Activation, is an on-going mitigation. Since the 2017 RAMP PG&E has installed VST in 8000 vehicles, approximately 85 percent of PG&E's fleet. By the end of 2023 PG&E plans to install VST in all on-road PG&E owned vehicles, approximately 10,000 vehicles, and updated to a new VST vendor solution.

M6, Training Acknowledgement for Valid License, involved updating all web-based training to include an acknowledgement by employees to acknowledge that they had a valid license for the class of vehicle they drive on company business or notify their supervisor if their license status changes. PG&E completed this mitigation by updating the web-based training to include this acknowledgement. This mitigation becomes a control in the 2020 RAMP.

M7, Implement Driver Accountability, used VST and 1-800-How's My Driving Program to identify risky drivers and build an automated accountability structure. PG&E completed this mitigation by building the automated accountability structure report. This mitigation becomes a control in the 2020 RAMP.

PG&E removed M8, Revise License Verification Process for Non-DOT Covered Drivers, because it is not currently desired by the TS organization. This mitigation is still being considered as a future RAMP mitigation and is part of Alternative 1 described in Section D below.

D. 2020–2022 Controls and Mitigation Plan

1. Changes to Controls

The scope of the following controls has been updated since they were first included in the 2017 RAMP:

C2 – Driver Qualification: An additional course is available (EQUIP-0059) for Class A Commercial Driver's License (CDLA) drivers who have a CDL but require more training.

C9 – Department of Motor Vehicle (DMV) Employer Pull Notice

Program: This program provides timely motor vehicle records and includes reports of accidents or tickets associated with any PG&E CDL drivers licenses. These accidents or tickets are documented and letters sent to the

employee and their leadership. This program is a requirement under California Code, CVC § 1801.1.

C15 – “How Am I Driving” Hotline Reporting and Supervisor Review:

Driver complaint reports fed into the Safe Driver Coaching Program.

C16 – Preventive Maintenance On-Time Performance and Monitoring:

Garage mechanics perform preventive maintenance and inspections and record the work via work orders entered in the Fleet Anywhere application.

Mechanics use preventive maintenance checklists as guidelines for performing maintenance and inspections. Garage Supervisors run daily and monthly reports to review preventive maintenance and inspections coming due and on-time rates. The Preventive Maintenance On-time Performance metric is reported monthly.

In the 2020 RAMP, six 2017 RAMP mitigations are now controls: M1, M2A, M4, M5, M6, and M7. The descriptions of the former mitigations, now controls, follow:

C18 – Motor Vehicle Safety Standard: This standard (SAFE-1002S) describes PG&E’s MVS program, the intent of which is to minimize injuries to employees and members of the public, to prevent property damage and to control risks that may be caused by the operation of a motor vehicle. The mitigation was completed in 2016, and the standard was most recently updated in 2017.

C19 – Vehicle Safety Technology Program Standardized Reporting (hard brake, hard acceleration and speed indicators): Data feed from vendor is used to develop a rate (by vehicle) per 1,000 miles of hard brakes, hard acceleration, and max speed.

C20 – TECH-0081WBT Driving Expectations and New Laws: This annual training updates employees regarding new driving regulations and requires employees who drive for business to certify they have a valid driver’s license. This training began in 2017.

C21 – Standardized Employee Motor Vehicle Training Requirements: This mitigation established standard training requirements for drivers and was published as an appendix to SAFE-1002S. This mitigation provides structure for several training requirements and was completed in 2016.

C22 – Training Acknowledgement for Valid License: Revise all employee web-based training to include an acknowledgement statement for positive confirmation that the employee must have a valid license for the class of vehicle they drive on company business and are aware that they must notify their supervisor if their license status changes for any reason. If employee response is to decline the validation, the training will remain as incomplete, Supervisor must take appropriate action.

C23 – Safe Driver Coaching Program (SAFE -1002P): Use VST and How's My Driving Program to identify risky drivers and build an automated accountability structure. Utilize the How's My Driving (vendor – Driver's Alert) observation system and process to address VST data for vehicles that are over the threshold for HB, HA and Excessive Speed. VST data is fed into the system.

2. Changes to Mitigations

PG&E is including six new mitigations in the 2020 RAMP.
(This includes M17.)

M14 – Post Incident Review: This procedure outlines leadership requirements to perform a consistent document review and corrective actions for an employee following an MVI. This procedure is designed to provide employees with timely coaching and to reduce overall risk. The procedure will be rolled out enterprise-wide, with a dashboard for leaders to have access to a single source containing multiple data points related to driver/vehicle risk.

M15 – 360 Walk Around App: Mobile application designed to require 360 degree walkaround prior to driving. Developed for non-regulated company drivers.

M16 – UCLA Study and Risk Analysis: The TS and Transportation Safety organizations are partnering with UCLA to conduct risk assessment of Motor Vehicle Safety Program. Desired outcomes are to identify gaps, inform future mitigations, alternatives, and develop program recommendations.

M18 – Safe Backing Training (TECH-9161): This course is for all company drivers. This course reviews safe backing principles, company policies and proper use of spotter/backers. Available to all PG&E employees.

One mitigation – M8, Revise License Verification Process for Non-DOT Covered Drivers – was removed because this action is not currently part of Transportations Services' plans.

Table 18-7 below shows the estimated costs for the mitigation work planned for the 2020-2022 period.

**TABLE 18-7
FORECAST COSTS
2020-2022
(THOUSANDS OF DOLLARS)**

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	Total
1	M2B	Update VST Installation and Activation	FL	\$2,570	\$2,570	\$2,570	\$7,710
2	M14	Post Incident Review	FL	68	68	–	136
3	M15	360 Walk Around App	FL	63	–	–	63
4	M18	Safe Backing Training TECH-9161	FL	36	–	–	36
5	M19	Cell Phone Activity Blocking	FL	–	–	–	–
6		Total		\$2,737	\$2,638	\$2,570	\$7,945

Note: See WP 18-1.

E. 2023-2026 Proposed Mitigation Plan

M17 – Data enhancement/improvement plan for improved collection and usage of data: Informed by UCLA Risk Assessment Study recommendations.

M19 – Cell Phone Activity Blocking – Enhanced Control for Phone Free Driving Policy: An engineering control to block phone activity and use while driving. The technology will not block emergency cell phone features. This mitigation is in the initial proposal phase and will be informed by information developed in the proposed UCLA analysis.

Table 18-8 below shows the estimated costs, RSE and risk reduction score for the mitigation work planned for the 2023-2026 period.

TABLE 18-8
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	M14	Post Incident Review	FL	-	-	-	-	-	-	
2	M15	360 Walk Around App	FL	-	-	-	-	-	-	
3	M18	Safe Backing Training TECH-9161	FL	-	-	-	-	-	-	
4	M19	Cell Phone Activity Blocking	FL	\$1,035	\$2,070	\$3,050	\$4,140	\$10,295	0.42	3.1
5	M2B	Update VST Installation and Activation	FL	-	-	-	-	-	-	
6		Total		\$1,035	\$2,070	\$3,050	\$4,140	\$10,295		

(a) See Mitigation Effectiveness worksheets (MW) included in the source document modeling package for information used to calculate the RSE.
 Note See WP 18-1.

F. Alternative Analysis

In addition to the proposed mitigation described in Section E above, PG&E considered alternative mitigations as well. The mitigation described in Section E constitute the Proposed Plan. The Alternative Plans consist of a combination of some or all of the proposed mitigations along with the alternative mitigation(s). PG&E describes each of the alternative mitigations it considered below and then provides a table showing the forecast costs, RSEs and risk reduction scores for each of the Alternative Plans. Each of the alternatives is in the initial proposal phase. Initial risk reduction estimates and RSE calculations will be subject to further review with the proposed UCLA analysis

1. Alternative Plan 1: A1 (M10) Driver Selection Program

As a part of PG&E's driver selection process, PG&E will integrate all sources of information with respect to the driver in order to create a holistic assessment of individual driver risk. This mitigation is an expansion of the previous mitigation M8: Revise License Verification Process for Non-DOT Covered Drivers. This mitigation would include a license and insurance verification plan for employees who are not a part of the commercial driver pool.

**TABLE 18-9
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026 EXPENSE
(THOUSANDS OF DOLLARS)**

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	A1	Driver Selection Program	\$81	\$81	\$81	\$81	\$324		
2		Total	\$81	\$81	\$81	\$81	\$324	15.89	3.8

(a) See MWs included in the source document modeling package for information used to calculate the RSE.
Note See WP 18-1.

2. Alternative Plan 2: A2 (M20) Enhancement to Pool Vehicle Reservation System

Enhancement to existing control C12, requiring electronic proof of valid license prior to reserving pool vehicles. This mitigation is contingent on M8.

TABLE 18-10
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026 EXPENSE
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	A2	Enhancement to Pool Vehicle Reservation System	\$25	\$25	\$25	\$25	\$100	N/A	N/A
2		Total	\$25	\$25	\$25	\$25	\$100		

(a) See MWs included in the source document modeling package for information used to calculate the RSE.
 Note See WP 18-1.

1 **3. Alternative Plan 3: A3 (M21) In-Cab Camera Technology**

2 This mitigation would install an in-cab camera that monitors both
 3 external and in-cab activities and is triggered off of specific parameters and
 4 operation of the vehicle (i.e., braking, cornering, acceleration, speeding).

TABLE 18-11
FORECAST COSTS, RSE, AND RISK REDUCTION
2023-2026 EXPENSE
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	2023	2024	2025	2026	Total	RSE ^(a)	Risk Reduction
1	A3	In – Cab Camera Technology	\$100	\$100	\$100	\$100	\$400		
2		Total	\$100	\$100	\$100	\$100	\$400	19.08	5.6

(a) See MWs included in the source document modeling package for information used to calculate the RSE.

5 **4. Alternative Plan 4: Smith Driving (M22)**

6 This Alternative is the Smith Driving course (TECH-0089) for those who
 7 drive a personal vehicle for work. Training is conducted in the employee's
 8 personal vehicle. PG&E is not forecasting any costs for this work. The risk
 9 reduction value for this Alternative Mitigation is 3.8.

10 Table 18-12 compares the proposed and alternative mitigation plans.

TABLE 18-12
MITIGATION PLAN ALTERNATIVES ANALYSIS
(THOUSANDS OF DOLLARS)

Line No.	Risk Mitigation Plan	Plan Components ^(a)	Total Expense (2023-2026)	Total Capital (2023-2026)	Risk Reduction (NPV) ^(b)	Total Spend (NPV)	RSE
1	Proposed	M19	\$10,295	—	3.11	\$7,324	0.42
2	Alternative 1	A1	\$324	—	3.79	\$239	15.89
3	Alternative 2	A2B	—	—	—	—	—
4	Alternative 3	A3	\$400	—	5.62	\$295	19.08
5	Alternative 4	A4	—	—	3.79	—	—

(a) Plan Components refers to the Mitigations presented in Table 18-6.

(b) Information presented in terms of NPV to account for the discounting of benefits.

Note See WP 18-2.

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 19
RISK ASSESSMENT AND MITIGATION PHASE
OTHER SAFETY RISKS

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 19
RISK ASSESSMENT AND MITIGATION PHASE
OTHER SAFETY RISKS

TABLE OF CONTENTS

A. Introduction.....	19-1
1. Identifying the 2020 RAMP Risks.....	19-1
2. PG&E's 2020 RAMP Risks – Responding to Stakeholder Feedback.....	19-2
B. Aviation – Fixed Wing Incident	19-3
1. Risk Overview	19-3
2. Changes Since the 2017 RAMP	19-3
3. Risk Mitigations.....	19-3
4. Responding to Stakeholder Feedback	19-4
C. Aviation – Helicopter Incident	19-4
1. Risk Overview	19-4
2. Changes Since the 2017 RAMP	19-4
3. Risk Mitigations.....	19-4
4. Responding to Stakeholder Feedback	19-5
D. Failure of Electric Distribution Underground Assets	19-5
1. Risk Overview	19-5
2. Changes Since the 2017 RAMP	19-6
3. Risk Mitigations.....	19-6
4. Responding to Stakeholder Feedback	19-8
E. Failure of Substation Assets.....	19-8
1. Risk Overview	19-8
2. Changes Since the 2017 RAMP	19-8
3. Risk Mitigations.....	19-9
4. Responding to Stakeholder Feedback	19-9

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 19
RISK ASSESSMENT AND MITIGATION PHASE
OTHER SAFETY RISKS

TABLE OF CONTENTS
(CONTINUED)

F. Failure of Electric Transmission Overhead Assets	19-10
1. Risk Overview	19-10
2. Changes Since the 2017 RAMP	19-10
3. Risk Mitigations	19-11
4. Responding to Stakeholder Feedback	19-12
G. Failure of Electric Transmission Underground Assets	19-12
1. Risk Overview	19-12
2. Changes Since the 2017 RAMP	19-13
3. Risk Mitigations	19-13
4. Responding to Stakeholder Feedback	19-13
H. Hazardous Materials Release	19-14
1. Risk Overview	19-14
2. Changes Since the 2017 RAMP	19-14
3. Risk Mitigations	19-14
4. Responding to Stakeholder Feedback	19-14
I. Loss of Containment on Compressed Natural Gas Station Equipment	19-15
1. Risk Overview	19-15
2. Changes Since the 2017 RAMP	19-15
3. Risk Mitigations	19-15
4. Responding to Stakeholder Feedback	19-16
J. Loss of Containment on Gas Customer Connected Equipment	19-16
1. Risk Overview	19-16
2. Changes Since the 2017 RAMP	19-17

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 19
RISK ASSESSMENT AND MITIGATION PHASE
OTHER SAFETY RISKS

TABLE OF CONTENTS
(CONTINUED)

3. Risk Mitigations	19-17
4. Responding to Stakeholder Feedback	19-17
K. Loss of Containment at Gas Measurement and Control or Compression and Processing Facility.....	19-17
1. Risk Overview	19-17
2. Changes Since the 2017 RAMP	19-19
3. Risk Mitigations	19-19
a. Measurement and Control Failure – Release of Gas with Ignition at Measurement and Control Facility	19-19
b. Compression and Processing Failure – Release of Gas with Ignition at Manned Processing Facility	19-21
4. Responding to Stakeholder Feedback	19-21
L. Loss of Containment at Natural Gas Storage Well or Reservoir.....	19-22
1. Risk Overview	19-22
2. Changes Since the 2017 RAMP	19-23
3. Risk Mitigations	19-23
4. Responding to Stakeholder Feedback	19-24
M. Loss of Containment on LNG/CNG Portable Equipment.....	19-24
1. Risk Overview	19-24
2. Changes Since the 2017 RAMP	19-25
3. Risk Mitigations	19-25
4. Responding to Stakeholder Feedback	19-25
N. Nuclear Core Damaging Event.....	19-25
1. Risk Overview	19-25

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 19
RISK ASSESSMENT AND MITIGATION PHASE
OTHER SAFETY RISKS

TABLE OF CONTENTS
(CONTINUED)

2. Changes Since the 2017 RAMP	19-28
3. Risk Mitigations	19-28
4. Responding to Stakeholder Feedback	19-29

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 19
RISK ASSESSMENT AND MITIGATION PHASE
OTHER SAFETY RISKS

A. Introduction

1. Identifying the 2020 RAMP Risks

Pacific Gas and Electric Company's (PG&E or the Utility) 2019 Corporate Risk Register (CRR) includes 25 safety risks.¹ PG&E is presenting 13 of those safety risks² in its 2020 Risk Assessment and Mitigation Phase (RAMP) filing consistent with the requirements set forth in the Phase Two Safety Model Assessment Proceeding Settlement Agreement (the Agreement).³

As prescribed by the Agreement, PG&E evaluated all of the risks on its CRR, identified the safety risks and computed a Safety Risk Score for each risk. PG&E sorted the CRR list by the Safety Risk Score and selected the top 40 percent of the CRR risks with a safety risk score greater than zero.⁴ PG&E also selected risks for inclusion in RAMP where the Safety Risk Score was within 20 percent of the lowest top 40 percent Safety Risk Score.

PG&E considers all its safety risks important and, as such, monitors and manages them through its normal course of business. While 13 of the 25 risks on the CRR are not being assessed as a 2020 RAMP risk, PG&E will provide information about them in this chapter including an overview of the risk, changes in the risk since the 2017 RAMP, risk mitigation efforts and responses to stakeholder feedback (including feedback received at the PG&E 2020 RAMP Workshop #3, held February 4, 2020, "Workshop #3").

The 13 safety risks presented in this chapter are:

-
- ¹ PG&E recently changed the name of its risk register to CRR. It was previously known as the Enterprise Risk Register. See Chapter 2.
 - ² Two individual risks – LOC, Gas Distribution Pipeline, Non-Cross Bore and LOC, Gas Distribution, Cross Bore – are presented as a single risk in the 2020 RAMP filing. The name of the combined risk is LOC on Distribution Main or Service
 - ³ Decision (D.)18-12-014.
 - ⁴ D.18-12-104, Attachment A, Settlement Agreement, Step 2A, Item 9.

- 1) Aviation – Fixed Wing Incident;
- 2) Aviation – Helicopter Incident;
- 3) Failure of Electric Distribution Underground Assets;
- 4) Failure of Substation Assets;
- 5) Failure of Electric Transmission Overhead Assets;
- 6) Failure of Electric Transmission Underground Assets;
- 7) Hazardous Materials Release;
- 8) Loss of Containment (LOC) on Compressed Natural Gas (CNG) Station Equipment;
- 9) LOC on Gas Customer Connected Equipment;
- 10) LOC at Gas Measurement and Control (M&C) or Compression and Processing (C&P) Facility;
- 11) LOC at Natural Gas Storage Well or Reservoir;
- 12) LOC on Liquefied Natural Gas (LNG)/CNG Portable Equipment; and
- 13) Nuclear Core Damaging Event.

2. PG&E's 2020 RAMP Risks – Responding to Stakeholder Feedback

At Workshop #3 PG&E presented its proposed list of 12 safety risks that would be included in the 2020 RAMP. The California Public Utilities Commission (CPUC) Safety Enforcement Division, the CPUC Public Advocates Office and other parties were concerned that important safety risks (such as Nuclear Core Damaging Event, and LOC, Distribution Pipeline, Cross Bore) were not included in the proposed list of risks that PG&E would include in its 2020 RAMP.

PG&E considered this feedback and agrees that all of the CRR safety risks should be presented in some way in the 2020 RAMP. To address this feedback PG&E decided to:

- Incorporate the LOC, Distribution Pipeline, Cross Bore risk into the LOC, Distribution Main or Service risk, as one of the 12 RAMP risks evaluated in this Report. The cross bore risk is incorporated as a sub-driver of the gas distribution risk that is now called, “Loss of Containment – Distribution Main and Service” risk; and
- Provide a description of the remaining 13 CRR safety risks that are not designated as one of the 12 RAMP risks. We describe these risks and the mitigations proposed or underway.

B. Aviation – Fixed Wing Incident

1. Risk Overview

Aviation – Fixed Wing Incident is defined as an accident associated with the operation of fixed wing aircraft during the time any person boards the aircraft with the intention of flight, and until all persons have disembarked. This risk includes fixed wing aircraft owned or operated by PG&E that meets Title 49 Code of Federal Regulations (CFR) 830.

PG&E's Aviation Services organization is responsible for its fixed wing aircraft which consists of four Cessna aircraft (that regularly survey electric and gas infrastructure). Aviation Services also provides the fixed wing patrol aircraft equipped with Electro-Optical/Infra-Red capable camera systems, for monitoring gas transmission pipeline rights-of-way, or for potential encroachment hazards.

2. Changes Since the 2017 RAMP

Aviation Fixed Wing Incident was not a 2017 RAMP risk.

3. Risk Mitigations

The fixed wing aircraft are maintained and operated under 14 CFR Part 91 General Aviation. The fixed wing pilots have Federal Aviation Administration (FAA) pilots' licenses and use a Flight Operations Manual. A flight hazard assessment process and fatigue risk management program are in place. Pilots undergo annual simulator training for normal and emergency procedures and require upset prevention and recovery techniques training every 24 months.

The pilots use FAA certified dispatches in Helicopter Operations and have an onboard GPS tracking tool for flight following. All aircraft maintenance, inspections and repairs are performed under 14 CFR Part 43 Maintenance and Repair by PG&E FAA certified Aviation Maintenance Technicians or approved FAA certified contract technicians or an approved aircraft maintenance organization under 14 CFR Part 145 Repair Station Certification. PG&E aircraft maintenance uses a computerized maintenance tracking tool and a General Maintenance Manual as parts of the maintenance program. All maintenance, inspection, service and scheduled overhaul, replacement of time-controlled components/life-limited parts are

1 accomplished with timeframes established by the manufacturer and
2 approved by applicable regulatory authorities.

3 **4. Responding to Stakeholder Feedback**

4 Stakeholders have not provided any specific feedback about the
5 Aviation – Fixed Wing Incident risk. Stakeholder feedback related to
6 PG&E's exclusion of certain safety risks in the 2020 RAMP is addressed in
7 Section A.2. above.

8 **C. Aviation – Helicopter Incident**

9 **1. Risk Overview**

10 Aviation – Helicopter Incident is an accident associated with the
11 operation of rotary wing aircraft, during the time any person boards the
12 aircraft with the intention of flight, and until all persons have disembarked.
13 This risk includes those rotary wing aircraft owned or operated by PG&E that
14 meet the definition of Title 49 CFR 830.

15 In 2018 PG&E purchased four heavy lift helicopters to support service
16 restoration work and emergency response to wildfire threats. During the fire
17 season, the helicopters will be available for use by both PG&E and the
18 California Department of Forestry and Fire Protection for emergency
19 response. Outside of fire season, they will be available to support internal
20 PG&E heavy lift maintenance and construction work.

21 **2. Changes Since the 2017 RAMP**

22 Aviation – Helicopter Incident was not a 2017 RAMP risk.

23 **3. Risk Mitigations**

24 PG&E's Helicopter Operations department is responsible for managing
25 the helicopter contractor portfolio, which includes overseeing all helicopter
26 vendors, pilots and ISNetworld qualification. The department is also
27 responsible for maintaining safe helicopter operations by ensuring that
28 vendor audits, health checks and flight safety reviews are completed.
29 PG&E's Helicopter Operations department is also responsible for leading
30 Aviation Incident/Accident Investigations. The investigation process uses
31 the Enterprise Corrective Action Program to document and manage
32 corrective actions identified as part of the investigation.

1 All PG&E lines of business and contractors are required to use the
2 Helicopter Operations Field Manual. This manual provides detailed
3 instructions for required training, procedures and critical tasks for helicopter
4 operations. All helicopter vendors are required to have a 14 CFR Part 135
5 Air Carrier Operating Certificate and if they are lifting external loads, a
6 Part 133 External Load Certificate as well. These certificates cover pilots,
7 flight and maintenance operations. In addition, Helicopter Operations
8 requires a pilot training validation and an external loads skill assessment.
9 Helicopter Operations uses flight scheduling software and a work request
10 review process to manage operations and employs FAA certified
11 dispatchers to oversee and monitor flights. Each flight completes a Flight
12 Risk Assessment and an operations briefing with the Helicopter Dispatcher
13 in addition to preflight briefings and tailboard safety meetings at work
14 locations. Operating helicopters carry a GPS tracker onboard to support
15 flight following. Employees and Contractors who are qualified for specified
16 tasks are tracked and identified through an identification card system.

17 **4. Responding to Stakeholder Feedback**

18 Stakeholders have not provided any specific feedback about the
19 Aviation – Helicopter Incident risk. Stakeholder feedback related to PG&E's
20 exclusion of certain safety risks in the 2020 RAMP is addressed in
21 Section A.2. above.

22 **D. Failure of Electric Distribution Underground Assets**

23 **1. Risk Overview**

24 Failure of Electric Distribution Underground (UG) Assets is defined as a
25 failure of distribution UG assets or lack of remote operation functionality that
26 may result in public or employee safety issues, property damage,
27 environmental damage or an inability for PG&E to deliver power to
28 its customers.

29 PG&E manages its UG distribution assets in its Underground Asset
30 Management (UAM) Program. PG&E's UG assets include over
31 26,000 circuit miles of UG primary distribution cable. Most of the UG cables
32 are installed in urban and suburban areas.

The scope of this risk includes a failure of assets associated with the UG electrical distribution system including primary and secondary UG cables, line equipment, subsurface and pad-mount transformers.

2. Changes Since the 2017 RAMP

Failure of Electric Distribution UG Assets was not a 2017 RAMP risk. Since 2017 Electric Operations (EO) has consolidated certain risks on the EOs risk register and is now presenting two underground asset related risks: Failure of Electric UG Assets in this Other Safety Risk Chapter and Failure of Electric Distribution Network Assets in Chapter 12, one of the 12 RAMP risks.

3. Risk Mitigations

The UAM Program generally manages risk by replacing primary distribution cables and components due to reliability performance, asset age and condition, compliance, and potential safety risk to the public and employees.

PG&E has several controls in place to manage risk associated with UG cable and line equipment, including: equipment replacement; equipment diagnostics, testing and rejuvenation; engineering equipment standards and specifications; public awareness programs such as locate and mark; 811 public awareness; and, inspection and maintenance programs.

Summarized below are the programs included in PG&E's 2020 General Rate Case (GRC) designed to manage electric distribution system UG asset risk.⁵

- a) Reliability Related Cable Replacement: Proactive replacement of cable based on age and type, reliability performance or a combination of these factors and other influences. UG primary distribution failures that impact reliability performance and safety issues can occur as UG cables deteriorate.
- b) Cable Rejuvenation and Testing: Cable testing helps identify specific cables that are problematic so that they can be targeted for replacement and provides a baseline of the cable's condition that is used for future condition assessments. Cable rejuvenation involves injecting silicon

⁵ Application (A.)18-12-009, Exhibit (PG&E-4), Chapter 11.

fluid into certain types of cables under certain conditions with the goal of extending operating life.

c) Critical Operating Equipment (COE) Cable Replacement: When failures occur on primary cable UG systems with looped designs, the faulted section of line is isolated and de-energized until an evaluation of its operating condition and repair scope is determined. Upon evaluation the failed cable sections becomes a COE Cable Replacement project.

d) Load Break Oil Rotary (LBOR) Switch Replacement: PG&E is proactively replacing LBOR switches. LBOR switches lack oil inspection sight glasses which poses a greater safety risk than other types of switches because crews cannot visually verify the oil level and condition of an LBOR switch before operating it. Recognizing the importance of replacing LBOR switches, PG&E proposed replacing 90 pre-1975 switches per year for the 2020 GRC period as part of the 2020 GRC settlement.⁶

e) Underground Patrols and Inspections: PG&E patrols its underground facilities on a regular basis and conducts a more detailed examination of each underground enclosure and associated facilities every three years. Compliance inspectors perform minor repair and maintenance work during underground inspections and patrols.

f) Underground Preventive Maintenance and Equipment Repair: PG&E's Underground Notifications program is the program designed to improve system reliability, improve safety and ensure regulatory compliance by correcting abnormal maintenance conditions related to PG&E's underground facilities.

g) Venting Manhole Cover Replacements: This is an ongoing program to replace existing solid and grated manhole covers on vaults with hinged venting manhole covers designed to stay in place in the event of a vault explosion. A venting cover that stays in place during a vault explosion reduces the potential for exposure to hot gasses from the vault,

⁶ A.18-12-009, Joint Motion for Approval of Settlement Agreement, (Dec. 20, 2019), p. 48.

eliminates the risk of a projectile manhole cover, and reduces the force of the explosion.

- h) Design Standards Review: Supports electric designs including UG assets are on a five year review process. These reviews address evolving risks and issues associated with such items as supplier quality, field conditions, new products, and trends in the industry.

4. Responding to Stakeholder Feedback

Stakeholders have not provided any specific feedback about the Failure of Electric Distribution UG Assets risk. Stakeholder feedback related to PG&E's exclusion of certain safety risks in the 2020 RAMP is addressed in Section A.2. above.

E. Failure of Substation Assets

1. Risk Overview

Failure of Substation Assets is defined as the failure of substation assets or lack of remote operation functionality that may result in public or employee safety issues, property damage, environmental damage, disruption of major generation sources or inability to deliver energy.

PG&E has 945 transmission and distribution substations, consisting of power transformers, circuit breakers, switchgears, protective relays, bus structures, and voltage regulation equipment. Each substation transforms high voltage electricity from PG&E's electric transmission system to lower voltage for delivery to PG&E's customers.

The drivers of substation risk are: equipment failure; work procedure error; animal; weather; cyber attack; geomagnetic storm;⁷ sabotage; seismic; and gas collocation.

2. Changes Since the 2017 RAMP

In 2017 PG&E did not consider risks associated with substations to be a top safety-related risk and, as such, they were not identified as a RAMP risk. PG&E did, however, discuss its risk methodology and mitigation approach to substation risks in Appendix 1. Since 2017 PG&E has formally consolidated

⁷ A geomagnetic storm, or solar storm, is a temporary disturbance of the Earth's magnetosphere caused by a solar wind shock wave and/or cloud of magnetic field that interacts with the Earth's magnetic field.

1 the risks associated with individual substation asset categories into the
2 single Failure of Substation Asset risk. Consolidating the risk enables
3 PG&E to better analyze how the different types of substation risks interact
4 with one another and enables PG&E to compare and weigh the overall
5 contributions of each for the former risks towards a single substation failure
6 risk event.

7 **3. Risk Mitigations**

8 PG&E employs two primary mitigations to address substation asset risk.
9 The first mitigation, the Bus Reliability and Upgrade Program, includes work
10 to modify and/or replace substation buses to reduce the likelihood of bus
11 level outages that could lead to larger and prolonged substation outages.

12 The second mitigation includes projects to reduce the risk of substation
13 outages caused by potential failure of gas pipelines collocated with PG&E
14 substations. This program involves reviewing studies on collocated
15 pipelines and performing work such as pipeline/substation equipment
16 relocation, ground grid modifications, and/or fencing replacement to reduce
17 the risk and impacts of collocated pipeline failure if it were to occur.

18 Along with these two mitigations, PG&E uses controls to manage
19 substation asset risk including: proactive asset replacement; perimeter
20 vegetation clearance; lightning protection; design criteria; drawings and
21 facility markings; damage modelling and; grounding systems. PG&E also
22 employs inspection and maintenance controls (e.g., substation inspections,
23 intrusion detection, on-site security guards and gas line corrosion protection)
24 and controls to reduce the consequences of substation failure (e.g., fire
25 protection systems, oil containment/spill prevention and community outreach
26 and outage communications).

27 **4. Responding to Stakeholder Feedback**

28 Stakeholders have not provided any specific feedback about the Failure
29 of Substation Assets risk. Stakeholder feedback related to PG&E's
30 exclusion of certain safety risks in the 2020 RAMP is addressed in
31 Section A.2. above.

F. Failure of Electric Transmission Overhead Assets

1. Risk Overview

Failure of Electric Transmission Overhead Assets risk is defined as a failure of transmission overhead assets or lack of remote operation functionality that may result in public or employee safety issues, property damage, environmental damage, disruption of major generation sources and inability to deliver energy. The risk includes failure of assets associated with transmission overhead lines including conductor, steel structure, non-steel structures, and other components such as insulators, switches and other hardware that form the electric transmission network.

Wildfire impacts from the overhead transmission assets are not included in the Failure of Transmission Overhead Assets risk but are incorporated into the Wildfire risk (Chapter 10).

Overhead transmission lines are energized at high voltages, and form the backbone of PG&E's electrical system. PG&E's transmission system includes approximately 18,000 circuit miles of overhead transmission lines and related equipment.

The drivers of transmission overhead asset risk are: transmission line equipment failure; natural hazard; vegetation; animal; human performance; environmental factors; and other. In addition to wires down, key areas of exposure include wildfire, environmental factors such as corrosion and wind as well as aging infrastructure.

2. Changes Since the 2017 RAMP

The 2017 RAMP included a Transmission Overhead Conductor risk.⁸ As discussed in Section A.1, this risk did not score in the top 40 percent of PG&E's enterprise safety risks in 2020 and, therefore, is not included as a 2020 RAMP risk.

PG&E has made significant progress understanding failure modes for Transmission overhead assets, enhancing inspection methods to look for these failure modes and prioritizing these enhanced inspections, repairs, projects, and programs in the High Fire-Threat District (HFTD) areas.

⁸ PG&E's RAMP Report, Investigation (I.) 17-11-003 (Nov. 30, 2017), Chapter 10.

In the 2017 RAMP PG&E described a group of ten controls that were designed to help control the frequency or consequence of one or more drivers of the Transmission Overhead Conductor risk.⁹ PG&E plans to continue implementing similar controls during the 2020 RAMP period and thereafter as applicable.

In the 2017 RAMP PG&E listed four mitigations that it planned to undertake between 2017 and 2019: overhead conductor replacement; insulator replacement; Right-of-Way (ROW) expansion; and public awareness outreach.¹⁰ PG&E completed work in each of those mitigation programs between 2017 and 2019.

3. Risk Mitigations

PG&E is implementing several mitigations to reduce overhead transmission asset failure risk including: enhanced maintenance program (inspections and repairs), Public Safety Power Shutoff (PSPS), asset replacement and retirements; enhanced vegetation management; system configuration design (sectionalizing); seasonal insulator washing; animal abatement; anti-climbing guards; bridging on underbuild; FAA line markers; and tower coating.

- PG&E implemented its Wildfire Safety Inspection Program in 2019 and plans to complete maintenance repair notifications generated through the program during the next three years. This enhanced inspection method is expected to continue going forward to drive condition-based asset management decisions. Maintenance repairs can extend the lifespan and ensure the safety of transmission line overhead assets. Examples of repairs include structure replacement, hardware replacement, and foundation crack sealing.
- The Transmission Vegetation Management Reliability (TVMR) program, also known as the ROW Expansion program, focuses on circuits involved in the most tree-related outages and will also help potentially reduce the scope of future Public Safety Power Shutoff events. The TVMR program aims to increase transmission line vegetation

⁹ PG&E's 2017 RAMP Report, p. 10-12, Table 10-1.

¹⁰ PG&E's 2017 RAMP Report, p. 10-15, Table 10-2.

clearances by voltage. This increased clearing improves reliability and can reduce potential wildfire ignitions in HFTD areas.

- PG&E evaluates as applicable the possibility of replacement alternatives as lines are identified for mitigation. These alternatives go beyond standard like-for-like replacement of assets and can include UG, microgrid/battery storage, line removal, and line relocation. Evaluating alternate paths, redundant paths, or reduction of paths can alleviate capacity, vegetation, fire spread, compliance, and reliability concerns.

PG&E also implements controls to manage overhead transmission asset risk including: asset inventory; asset health; cathodic protection; design standards; ground, climbing and aerial enhanced inspections; ground/non-routine air patrols; infrared inspections; planning, simulation and capacity program; product inspection; routine air patrols; routine vegetation management; and wood pole intrusive inspection.

4. Responding to Stakeholder Feedback

Stakeholders have not provided any specific feedback about the Failure of Transmission Overhead Asset risk. Stakeholder feedback related to PG&E's exclusion of certain safety risks in the 2020 RAMP is addressed in Section A.2. above.

G. Failure of Electric Transmission Underground Assets

1. Risk Overview

Failure of Electric Transmission UG Assets is defined as the failure of transmission UG assets or lack of remote operational functionality that may result in public or employee safety issues, property damage, environmental damage, reduced operational redundancy in critical urban centers, or large-scale prolonged outages. This risk includes failure of assets associated with pipe type cable, including cable carrier, cross-line polyethylene cable, cable terminations, pumping plant, vaults, splices, low pressure tripping system and SCADA systems.

The transmission UG asset risk drivers are: other PG&E assets or processes (e.g., substation causes, system design, etc.); PG&E activity (e.g., safety clearance); human performance; other (e.g., unknown outage causes); and transmission UG line equipment.

2. Changes Since the 2017 RAMP

Failure of Transmission UG Assets was not a 2017 RAMP risk.

3. Risk Mitigations

PG&E is executing several mitigations to reduce the risk to transmission UG assets:

- Cathodic protection assessments to critical pipe type cable circuits. The carrier pipe of the pipe type cable is made of carbon steel and can corrode if the cathodic protection is not in place. The substance inside the cable and the carrier pipe can leak out to the soil potentially damaging the environment and harming the cable by keeping it from properly cooling.
- Developing solutions to ensure proper inventory of pipe type cable is available in case of a major disaster. Two of these solutions are:
 - (1) investigating a new design for pipe type cable systems as the manufacturer of certain cable types no longer produces it; and
 - (2) ensuring the availability of cable reels and equivalent overhead equipment for emergency response preparedness. This mitigation is designed to ensure spare material is available for repairs to enable restoration of transmission paths via both UG and/or temporary overhead.
- Repairing or replacing transmission UG cables and associated components as part of routine and detail inspections of UG assets. These actions can reduce potential public and employee safety hazards due to equipment failures, can lessen environmental impact by reducing potential oil spills, and can help to maintain adequate reliability performance.

4. Responding to Stakeholder Feedback

Stakeholders have not provided any specific feedback about the Failure of Transmission UG Assets risk. Stakeholder feedback related to PG&E's exclusion of certain safety risks in the 2020 RAMP is addressed in Section A(2) above.

H. Hazardous Materials Release

1. Risk Overview

The Hazardous Materials Release risk is defined as the release of hazardous materials (excluding natural gas) by PG&E or by an agent acting on behalf of PG&E or under PG&E's authority. This risk excludes transport events, asset failure outcomes, and employee safety events addressed in other event based risk assessments. The Environmental Management and Remediation group within PG&E's Shared Services organization is responsible for managing this. This risk encompasses all the stages of the hazardous materials' lifecycle at PG&E from procurement to disposal. It includes spills and air release as well as events that occurred in the past and for which PG&E is now responsible for remediating.

2. Changes Since the 2017 RAMP

Hazardous Materials Release was not a 2017 RAMP risk.

3. Risk Mitigations

PG&E manages Hazardous Materials Release through a series of existing controls that consist of:

- Engineering controls such use of proper storage containers and containment to prevent the spread of a hazardous material if it is released;
- Detective controls including remote monitoring and inspections; and
- Administrative controls including handling and storage procedures, spill prevention, control and countermeasure plans, personnel training, and procurement management to reduce or eliminate the use of hazardous substances.

Risk control and mitigations for hazardous materials are closely aligned with PG&E's compliance program for regulatory requirements at the Federal, State and Local level which specify preventive measures to be taken to minimize the risk of hazardous materials release, and to assure rapid and effective control should a release occur.

4. Responding to Stakeholder Feedback

Stakeholders have not provided any specific feedback about the Hazardous Materials Release risk. Stakeholder feedback related to PG&E's

1 exclusion of certain safety risks in the 2020 RAMP is addressed in
2 Section A.2. above.

3 **I. Loss of Containment on Compressed Natural Gas Station Equipment**

4 **1. Risk Overview**

5 LOC on CNG Station Equipment is defined as any LOC during
6 operations at a PG&E owned CNG station that can lead to significant impact
7 on public safety, employee safety, contractor safety, financial losses, and/or
8 the inability to deliver natural gas to customers.

9 The LNG/CNG asset family includes both CNG stations (defined as gas
10 distribution assets for rate case purposes) and LNG/CNG portable assets
11 (defined as gas transmission assets for rate case purposes). The LNG/CNG
12 portable equipment risk is described in Section M below.

13 PG&E's CNG Stations Program includes 32 PG&E-owned CNG
14 stations, 24 of which are accessible by third-party customers. CNG stations
15 provide fuel to over 6,500 third-party customer vehicles and more than
16 100 CNG vehicles in PG&E's fleet and are used to refill portable CNG
17 trailers.

18 PG&E also has several mobile compressor units that provide backup
19 compression for CNG stations during outages of CNG station compressors
20 and provide compression to fill portable CNG trailers.

21 The top asset-related risks identified for the CNG station assets are
22 equipment-related and are primarily associated with obsolescence and end-
23 of-service-life conditions, and in particular, third-party customer equipment
24 integrity shortfalls and code non-compliance that can result in LOC events
25 while in PG&E's stations.

26 **2. Changes Since the 2017 RAMP**

27 LOC on CNG Station Equipment was not a 2017 RAMP risk.

28 **3. Risk Mitigations**

29 CNG station risks are primarily monitored via information collected
30 during regular maintenance and operation, through subject matter expert
31 (SME) knowledge, and through processes designed to minimize the
32 likelihood of customers in PG&E stations with higher risk vehicles and CNG
33 system condition. PG&E complies with federal and state codes that require

1 periodic maintenance to minimize safety risks by confirming or correcting the
2 condition and function of station components and incorporates best
3 practices to manage risks that sometimes go beyond code requirements.
4 PG&E also performs station capital investment rebuild and replacement
5 work to address safety, reliability, and economic risks that typically includes
6 replacement of equipment that is assessed to involve higher performance
7 risks or that is obsolete.

8 **4. Responding to Stakeholder Feedback**

9 Stakeholders have not provided any specific feedback about the LOC on
10 CNG Station Equipment risk. Stakeholder feedback related to PG&E's
11 exclusion of certain safety risks in the 2020 RAMP is addressed in
12 Section A.2. above.

13 **J. Loss of Containment on Gas Customer Connected Equipment**

14 **1. Risk Overview**

15 LOC on Gas Customer Connected Equipment is defined as a LOC from
16 a leak or rupture, with or without ignition, that can result in significant
17 impacts to public safety, employee safety, contractor safety, property
18 damage, financial loss, and/or the inability to deliver natural gas to PG&E
19 customers.

20 Customer connected equipment includes gas meter set assemblies
21 (including regulators, valves, piping and meters). There are approximately
22 4.6 million gas meters in service in PG&E's service territory, the majority of
23 which are located above ground and outside of the facility being served.
24 The top risks related to customer connected equipment assets are:
25 (1) incorrect operation and use of unapproved materials; (2) material
26 traceability issues that would prevent accurately locating and eliminating
27 known defective material; (3) failure of indoor meter sets; (4) and equipment
28 failure due to outside forces, such as building meter interaction during an
29 earthquake.

30 The scope of this risk includes a failure of assets associated with
31 customer connected equipment, leading to a LOC.

2. Changes Since the 2017 RAMP

LOC on Gas Customer Connected Equipment was not a 2017 RAMP risk.

3. Risk Mitigations

PG&E conducts a 3-year compliance gas leak survey, along with special leak surveys and leak rechecks, that covers gas distribution pipeline systems, including services, mains and other gas assets. Once a leak is verified and graded, PG&E schedules repair or replacement work to remediate the leak. PG&E also responds to emergencies by replacing or repairing damaged facilities, due to external forces.

4. Responding to Stakeholder Feedback

Stakeholders have not provided any specific feedback about the LOC on Gas Customer Connected Equipment risk. Stakeholder feedback related to PG&E's exclusion of certain safety risks in the 2020 RAMP is addressed in Section A.2. above.

K. Loss of Containment at Gas Measurement and Control or Compression and Processing Facility

1. Risk Overview

The Loss of Containment at Gas Measurement and Control or Compression and Processing Facility ("LOC at Gas M&C or C&P Facility") risk is defined as failure at a gas M&C or C&P facility resulting in a loss of containment that can lead to significant impact on public safety, employee safety, contractor safety, property damages, financial losses, and/or the inability to deliver natural gas to customers.

The M&C assets include gas transmission and distribution regulating and metering stations and associated equipment. The M&C assets also include transmission large volume customer regulating and metering stations, selected large customer meter sets, and equipment for monitoring gas quality. The M&C assets monitor, measure, and control pressure and flow within the gas transmission and distribution systems. There is significant diversity in terms of design and equipment installed at these stations. The age and condition of the M&C assets also varies across the asset population. Condition of the assets is assessed based on age,

1 obsolescence, physical condition, functional performance, maintenance
2 history, and SME input.

3 The C&P assets include compressor units and associated equipment
4 installed at PG&E's nine compressor stations. Also included in the C&P
5 asset family are compressor units and gas processing equipment installed at
6 PG&E's three underground storage facilities. The purpose of the C&P
7 facilities is to meet customer demands by moving gas from receipt points to
8 customer delivery locations as well as providing for injection and withdrawal
9 of gas at PG&E's underground storage facilities. Gas processing equipment
10 provides gas that is free from particulates and is sufficiently dehydrated and
11 odorized to meet gas quality requirements on the transmission and
12 distribution pipeline systems. Most of the compressor and underground gas
13 storage facilities were put into service between the early 1950s and the early
14 1970s. Much of the equipment, controls and systems at these facilities
15 systemwide are more than 40 years old and are showing signs of wear and
16 deterioration.

17 Threats identified for the M&C and C&P assets include: equipment-
18 related; incorrect operations; manufacturing-related; welding/fabrication
19 defects; corrosion; weather-related and outside forces; and third-party
20 damage. The ongoing evaluation of threats and risks associated with M&C
21 and C&P assets and the identification of mitigation measures are largely
22 based on the experience and judgment of PG&E SMEs. PG&E has
23 conducted studies to collect information for monitoring threat status and
24 asset health, including: benchmarking studies to identify potential new
25 threats and assess PG&E's current performance; process safety
26 assessments to understand hazards that may apply to stations; and, causal
27 analysis for significant events to understand the underlying causes of the
28 event and to define actions to prevent recurrence. Relative to the evaluation
29 of asset health, PG&E has conducted: control assessments to assess
30 proper regulation function and identify necessary maintenance and
31 equipment replacement; reliability centered maintenance; condition
32 assessments based on age, functional performance, physical condition and
33 other metrics to assess component and overall station health.

2. Changes Since the 2017 RAMP

PG&E's 2017 RAMP included two risks related to M&C failure and one risk related to C&P failure. The two M&C risks were: M&C Failure – Release of Gas with Ignition Downstream;¹¹ and, M&C Failure – Release of Gas with Ignition at M&C Facility.¹² The one C&P risk was C&P Failure – Release of Gas with Ignition at Manned Processing Facility.¹³

The M&C and C&P risks identified as 2020 RAMP risks have changed. In the 2020 RAMP:

- Large Overpressure Event Downstream of Gas M&C Facility is a RAMP risk (Chapter 9); and
- LOC at Gas M&C or C&P Facility is not one of the 2020 RAMP risks but is included in this “Other Safety Risk” chapter.

3. Risk Mitigations

a. Measurement and Control Failure – Release of Gas with Ignition at Measurement and Control Facility

For the M&C Failure – Release of Gas with Ignition at M&C Facility risk, the 2017 RAMP included six mitigations: The current status of each mitigation is provided below.

M1B – Critical Documents Program: The Critical Documents Program was proposed as a mitigation in the 2017 RAMP. This is a non-unitized program. To incorporate this mitigation into the 2017 RAMP model, PG&E developed representative units of work (number of stations) for the years 2017, 2018 and 2019.¹⁴ The Critical Documents program was also forecast as a non-unitized program in the 2019 Gas Transmission and Storage (GT&S) Rate Case with a targeted program completion date in 2021. The program is on track to complete all site visits by end of 2021 with the close out of some projects extending into 2022.

¹¹ PG&E's 2017 RAMP Report, Chapter 3.

¹² PG&E's 2017 RAMP Report, Chapter 4.

¹³ PG&E's 2017 RAMP Report, Chapter 6.

¹⁴ See I.17-11-003, WP 3-3, footnote (fn.) 1 that describes how PG&E developed its units of work estimates.

M2B – Engineering Critical Assessment (ECA) Phase 1: This program was forecast in the 2019 GT&S rate case as a non-unitized program with a targeted completion in 2021. To incorporate this mitigation into the 2017 RAMP model, PG&E developed representative units of work (number of stations) for the years 2017, 2018 and 2019.¹⁵ This program is on pace to be completed by the end of 2021.

M3B –ECA Phase 2: This program was forecast in the 2019 GT&S rate case as a non-unitized program with targeted completion in 2033. To incorporate this mitigation into the 2017 RAMP model, PG&E developed representative units of work (number of stations) for the years 2017, 2018 and 2019.¹⁶ PG&E has advanced the program development by working with industry leaders to solidify engineering-based maximum allowable operating pressure reconfirmation methods by: evaluating non-destructive technologies for flaw detection and material property verification; setting up a database to host the data received from the inspections; developing data analysis methods; and, creating program processes and procedures. This program is still on pace to be complete by the end of 2033.

M4B – Physical Security Upgrades: PG&E's 2017 RAMP forecast included representative units of work (number of stations) of one M&C station and one C&P station per year in the 2017 RAMP. PG&E has completed a total of 6 physical security upgrades at both M&C and C&P facilities between 2017 and 2019 which is consistent with the 2019 GT&S forecasted units.

M5B – SCADA Visibility, Transmission and Distribution: PG&E committed to implementing SCADA visibility at 530 distribution stations and 24 transmission stations between 2017 and 2019. PG&E is on pace to complete the SCADA Visibility program by 2025.

M6A –Station Strength Testing: The Station Strength Testing Program is designed to address components that cannot be addressed

¹⁵ I.17-11-003, WP 4-6, fn. 2 that describes how PG&E developed its units of work estimates.

¹⁶ I.17-11-003, WP 4-9, fn. 1 that describes how PG&E developed its units of work estimates.

via the non-destructive alternatives from the ECA 2 program. This program was forecasted as a non-unitized program in the 2019 GT&S rate case with a targeted completion in 2033. To incorporate this mitigation into the 2017 RAMP model, PG&E developed representative units of work (number of stations) for the years 2018 and 2019.¹⁷ PG&E did not perform any station strength testing during 2017-2019 period. Depending on the findings from the stations that are currently being assessed in the ECA2 program, PG&E will perform station strength testing beyond 2021.

PG&E will continue to implement the six mitigations described above during the 2020-2022 period.

b. Compression and Processing Failure – Release of Gas with Ignition at Manned Processing Facility

For the Compression and Processing Failure – Release of Gas with Ignition at Manned Processing Facility risk, the 2017 RAMP included five mitigations: The current status of each mitigation is provided below.

M1B – Critical Documents Program: This mitigation is described in Section G.3.a above.

M2B – ECA Phase 1: This mitigation is described in Section G.3.a above.

M3B – ECA Phase 2: This mitigation is described in Section G.3.a above.

M4B – Physical Security Upgrades: This mitigation is described in Section G.3.a above.

M5A – Station Strength Testing: This mitigation is the same as M6A in Section G.3.a above.

PG&E will continue to implement the five mitigations described above during the 2020-2022 time period.

4. Responding to Stakeholder Feedback

Stakeholders have not provided any specific feedback about the Loss of Containment at Gas Measurement and Control or Compression and

¹⁷ I.17-11-003, WP 4-20, fn. 1 that describes how PG&E developed its units of work estimates.

1 Processing Facility risk. Stakeholder feedback related to PG&E's exclusion
2 of certain safety risks in the 2020 RAMP is addressed in Section A.2. above.

3 **L. Loss of Containment at Natural Gas Storage Well or Reservoir**

4 **1. Risk Overview**

5 LOC at Natural Gas Storage Well or Reservoir is defined as a LOC, with
6 or without an unplanned ignition, at a gas storage well or reservoir that can
7 lead to significant impact on public safety, employee safety, contractor
8 safety, financial losses, environmental consequences, and in rare cases, the
9 inability to deliver natural gas to customers.

10 As of the end of 2019, PG&E's gas storage assets consisted of
11 three storage fields that included 111 storage wells, of which 86 wells were
12 equipped with downhole safety valves, more than 200 miles of casing and
13 tubing; approximately 14 miles of transmission pipe and ancillary equipment;
14 204 surface safety valves for pipeline isolation; and, 152 well measurement
15 meters, wellhead separators and flow controls.

16 As discussed in Section E.2. below, the gas storage assets that PG&E
17 owns and operates will be changing as set forth in D.19-09-025, in P&GE's
18 2019 GT&S Rate Case.¹⁸

19 The threats and risks to gas storage assets include: internal and
20 external corrosion and erosion; construction/fabrication threats resulting
21 from an improperly completed and poorly constructed well; equipment failure
22 or incorrect operation of one of the components.

23 PG&E manages gas storage risk through its UG Storage Risk and
24 Integrity Management Plan (referred to as WELL). PG&E's WELL provides
25 coordinated management and operation of PG&E's gas storage assets
26 consistent with the integrity management approach for other natural gas
27 assets. WELL includes several mitigation projects and programs, including:
28 reworks and retrofits; integrity inspections and surveys; engineering studies,
29 data analysis and development of gas storage emergency plans; control and
30 continuous monitoring; and, repair and replace non-storage assets.

18 A.17-11-009.

2. Changes Since the 2017 RAMP

In the 2017 RAMP, PG&E outlined its proposed Natural Gas Storage Strategy (NGSS).¹⁹ The proposed NGSS was developed in response to several new regulations that were enacted because of the October 2015 leak at the Aliso Canyon Natural Gas Storage Facility.

PG&E evaluated the new regulations and determined that complying with them would significantly increase the scope of work and cost to maintain and operate gas storage wells. In response, PG&E developed its NGSS and presented its proposal to change its storage assets portfolio in the 2019 GT&S Rate Case. PG&E's NGSS reduced PG&E's storage risk by ceasing certain operations and implementing risk mitigation efforts as required by the new regulations.

The 2017 RAMP outlined three proposals (the proposed NGSS and two alternatives). In September 2019, the CPUC issued its final decision (D.19-09-025) in PG&E's 2019 GT&S Rate Case. The CPUC adopted the NGSS with conditions, a two-way balancing account and reduction of the storage holdings to the amount necessary to provide reliability services. This involves the sale or decommissioning of the Los Medanos and Pleasant Creek storage fields.²⁰

3. Risk Mitigations

In the 2017 RAMP PG&E identified one risk mitigation, M1B - Storage Well Inspection Program. Between 2017 and 2019, PG&E planned to complete baseline inspections of 64 wells (8 in 2017, 12 in 2018 and 44 in 2019), PG&E projected completing the baseline assessments as part of its plan to mitigate the single point of failure in all storage wells by 2020 to comply with proposed California Geological Energy Management (CalGEM)²¹ regulations. CalGEM adopted regulations effective October 1, 2018 that extended the timeline for the baseline casing assessments and the elimination of the single point of failure. The new regulations require this

¹⁹ PG&E's 2017 RAMP Report, Chapter 8.

²⁰ D.19-09-025, pp. 327-328, 330, Ordering Paragraphs 40, 42, 43, 44, 45, 48, 49 and 59.

²¹ CalGEM was formerly known as the California Division of Oil, Gas and Geothermal Resources.

1 work be completed by 2025. In 2017-2019, PG&E completed 31 baseline
2 assessments bringing the total to 57 (2013-2019) or 49 percent of its well
3 population. The federal PHMSA issued its final rules on January 2020 that
4 requires completing the baseline casing inspections of all the wells by 2027.
5 PG&E is on track to meet this deadline.

6 **4. Responding to Stakeholder Feedback**

7 Stakeholders have not provided any specific feedback about the LOC at
8 Natural Gas Storage Well or Reservoir risk. Stakeholder feedback related to
9 PG&E's exclusion of certain safety risks in the 2020 RAMP is addressed in
10 Section A.2. above.

11 **M. Loss of Containment on LNG/CNG Portable Equipment**

12 **1. Risk Overview**

13 LOC on LNG/CNG Portable Equipment is defined as a LOC during
14 operations that can lead to significant impact on public safety, employee
15 safety, contractor safety, financial losses, and/or the inability to deliver
16 natural gas to customers.

17 The LNG/CNG asset family includes both CNG stations (defined as gas
18 distribution assets for rate case purposes) and LNG/CNG portable assets
19 (defined as gas transmission assets for rate case purposes). CNG station
20 risk is described in Section I above.

21 Portable LNG/CNG equipment provides gas service to customers while
22 pipelines are out of service during strength testing, upgrade or repair work,
23 or emergency unplanned outages, and supplements pipeline flowing supply
24 during peak winter demand periods.

25 This equipment consists of trailers that store and transport LNG and
26 CNG, trailers that deliver portable supplies back into the pipeline system or
27 directly to customers, and portable compression equipment (and associated
28 portable electric generation) that is used to evacuate pipelines prior to
29 construction work as an environmentally preferable alternative to blowing
30 gas to atmosphere (blowdowns result in undesirable adverse environmental
31 impact).

2. Changes Since the 2017 RAMP

Loss of Containment on LNG/CNG Portable Equipment was not a 2017 RAMP risk.

3. Risk Mitigations

LNG/CNG portable risk is primarily monitored via information collected during regular maintenance and operation and through SME knowledge. PG&E complies with federal and state codes that require periodic maintenance to minimize safety risks by confirming or correcting the condition and function of portable system components and incorporates best practices to manage risks that sometimes go beyond code requirements. PG&E also makes portable equipment capital investment rebuilds and replacements to manage safety, reliability and economic risks, that typically include replacement of equipment that is assessed to involve higher performance risks or that is obsolete.

4. Responding to Stakeholder Feedback

Stakeholders have not provided any specific feedback about the Loss of Containment on LNG/CNG Portable Equipment risk. Stakeholder feedback related to PG&E's exclusion of certain safety risks in the 2020 RAMP is addressed in Section A.2. above.

N. Nuclear Core Damaging Event

1. Risk Overview

The Nuclear Core Damaging Event risk is defined as a nuclear reactor core-damaging event with the potential for radiological release at the Diablo Canyon Power Plant (DCPP) due to equipment failure, natural disaster or some other significant event. The scope of this risk includes events caused by equipment failure, seismic events, internal fires or floods that lead to core damage at Diablo Canyon Units 1 and 2. This risk excludes events outside of the DCPP licensing basis not caused by equipment failure, seismic events, internal fires and floods that lead to core damage and events that do not lead to core damage.

DCPP Units 1 and 2 have a combined capacity of 2,240 megawatts and each year safely and reliably generate approximately 18,000 gigawatt-hours of clean electricity without greenhouse gas emissions. PG&E generates

1 power safely and operates reliably by maintaining high safety standards and
2 continuously improving its operations. DCPD has an excellent operating
3 record in its 32 years of operation. PG&E's Nuclear Generation organization
4 is responsible for the overall safe and efficient operation of DCPD.

5 DCPD relies on key measures and metrics to monitor safety and
6 reliability. Safe operations are the number one priority for DCPD. Nuclear
7 Regulatory Commission (NRC) inspectors are assigned to and provide daily
8 inspection activities for all nuclear activities. The NRC's Reactor Oversight
9 Process is the program through which the NRC measures nuclear safety,
10 regulatory compliance and recognizes compliance with safety requirements.

11 In addition to public safety, PG&E is also focused on the safety of the
12 PG&E employees and contractors working at DCPD. PG&E measures
13 personal safety at DCPD by the Occupational Safety and Health
14 Administration lost work day rate.

15 PG&E measures collective radiation exposure at DCPD by Person-REM
16 (Roentgen Equivalent Man), a unit of absorbed doses of radiation or the
17 collective radiation exposure when summed across all site personnel.
18 PG&E's collective Person-REM exposure has been on the decline
19 since 2016.

20 DCPD fulfills the federal requirements of all nuclear power facilities by
21 maintaining a physical security program committed to preventing radiological
22 sabotage and the theft of special nuclear material. The DCPD security
23 program and security features are periodically inspected by the NRC to
24 confirm compliance.

25 Nuclear Generation identifies, manages and mitigates risk through
26 several programs and processes including:

- 27 • Probabilistic Risk Assessment (PRA): Based on NRC endorsed
28 regulatory guidelines, the PRA is a quantified operational risk
29 management model used to obtain insights and trends based on actual
30 plant performance that provides a more accurate assessment and
31 identification of risks;
- 32 • Risk-Informed Work Management Program: A program that manages
33 risk to plant operations during maintenance activities and monitors the
34 implementation of the risk management program. This program

1 involves use of the PRA model to assess maintenance related risk.

2 Maintenance schedules are adjusted to minimize risk impact.

- 3 • Accredited and Non-Accredited Training Programs: Accredited training
4 programs are performance-based programs that are highly integrated
5 processes involving the participation and support of line management,
6 training leaders, instructors and students. Operations, Maintenance,
7 Engineering and emergency response personnel are trained to
8 implement procedures for mitigating natural phenomena and external
9 events within the current design basis.
- 10 • Corrective Action Program (CAP): The CAP is required by NRC
11 regulation and it is the main process DCPD uses to identify, analyze,
12 and resolve plant problems. The CAP process includes identifying
13 issues, conducting significant issue reviews, causal analysis, develop
14 and implement corrective actions and performance trending and
15 monitoring. The program is used to develop corrective actions to
16 prevent recurrence of problems.
- 17 • Operating Experience Program: The purpose of the Operating
18 Experience Program is to share operating experience among nuclear
19 power plants to evaluate event precursors so actions can be
20 implemented to eliminate vulnerabilities.
- 21 • Design Control Processes: Nuclear Generation design activities are
22 controlled per NRC regulations to ensure that design, technical and
23 quality requirements are correctly translated into design documents and
24 that changes to design are properly controlled.
- 25 • Security Program: DCPD operates physical security and cyber security
26 programs based on NRC regulatory requirements.
- 27 • Long-Term Seismic Program: DCPD complies with an NRC
28 commitment to continuously study and update the state of knowledge
29 regarding seismic hazards impacting DCPD.
- 30 • Emergency Preparedness – The DCPD Emergency Planning
31 Department administers the Emergency Plan which is a condition of the
32 DCPD operating license and is heavily regulated by the NRC and the
33 United States (U.S.) CFR. The Emergency Plan includes plans,
34 processes, procedures, facilities, equipment, training and drills all in

support of protecting the health and safety of the public in the event of a radiological emergency.

2. Changes Since the 2017 RAMP

Nuclear Core Damaging Event was a 2017 RAMP risk.²² PG&E performed an updated risk evaluation in 2019 to review the key risk drivers and evaluate their potential impact and to evaluate the effectiveness of existing mitigations to maintain the overall level of risk within NRC requirements. Through this risk evaluation process PG&E determined that this risk is well below the required regulatory threshold of one event for every 10,000 reactor years. The PRA modeling PG&E performed resulted in one event for every 11,299 reactor years.

PG&E will continue conducting seismic evaluations to evaluate the core damaging event risk. The NRC is evaluating if additional actions may be needed based on lessons learned from the 2011 Fukushima Nuclear accident.

Due to the impending shutdown of both DCPD Units in 2024 and 2025, a new enterprise risk associated with decommissioning activities is under development.

3. Risk Mitigations

PG&E did not propose mitigations for this risk for the 2017-2019 period in the 2017 RAMP. In the 2020 GRC PG&E identified certain projects and equipment purchases to mitigate risk as part of the Enterprise and Operational Risk Management process. PG&E has completed: Beyond Design Basis (BDB) regulatory requirements; seismic, flooding and tsunami studies; portable equipment procurement used in case of a BDB event with extended loss of power; staffing and communication studies to support BDB strategies; upgrade spent fuel pool instrumentation; and upgrade reactor cooling pump seals to prevent loss of reactor coolant.

PG&E will maintain current risk controls until the DCPD nuclear units are closed at the end of their respective NRC licenses.²³ These controls were

²² PG&E's 2017 RAMP Report, Chapter 12.

²³ In D.18-01-022, the CPUC approve the retirement of DCPD when its NRC operating licenses expire in November 2024 for Unit 1 and August 2025 for Unit 2.

1 listed in the 2017 RAMP and the 2020 GRC. Current risk controls include:
2 maintaining plant systems; operating the facility; plant and system
3 configurations; security from external and internal threats and emergency
4 response; independent oversight and training; and regulatory requirement
5 improvements and ongoing seismic evaluations.

6 **4. Responding to Stakeholder Feedback**

7 At Workshop #3 stakeholders provided feedback about PG&E's
8 proposed list of RAMP risks. Both the Safety and Policy Division and The
9 Utility Reform Network questioned the safety score assigned to the Nuclear
10 Core Damaging Event risk and recommended that PG&E reconsider the list
11 of risks to be included in the 2020 RAMP. In particular, these groups raised
12 concerns regarding the low Safety CoRE value.

13 PG&E's first approach to estimate the safety consequences of a
14 worst-case nuclear accident at Diablo Canyon was to review safety impacts
15 from historical events and to use this data in the PG&E estimate. Data from
16 the accidents at Three Mile Island, Fukushima and Chernobyl was reviewed.
17 Ultimately, the Fukushima accident was determined to be the most closely
18 aligned when Emergency Preparedness, Radioactive source term and
19 accident severity were considered. Based on this comparison, the safety
20 consequences from a direct impact of radiation were estimated to be
21 very low.

22 Subsequent to this initial empirical approach, PG&E reviewed the results
23 of analytical studies that were performed both for Diablo Canyon and other
24 representative nuclear power plants including those performed by the U.S.
25 NRC. Two studies were assessed to determine if they would provide a
26 more accurate estimate of a severe accident. Ultimately, PG&E decided to
27 rely on the DCCP specific Severe Accident Mitigations Alternatives (SAMA)
28 analysis that is based on site specific meteorology, radiation source terms
29 and population distribution/density.

30 PG&E performed the SAMA for DCCP license renewal purposes. This
31 study includes conservative assumptions such as linear no dose threshold

1 health impacts²⁴ and does not credit beyond design basis mitigation actions
2 but was considered the most representative because of its specificity to
3 Diablo Canyon. The published results from the SAMA study did not include
4 per event safety impact numbers, rather the SAMA report included a safety
5 risk metric²⁵ that incorporated the extremely low likelihood that an event like
6 this could occur.

7 Additional information about PG&E's analysis is included in supporting
8 workpapers.²⁶

24 Linear no-threshold model is a dose-response model used in radiation protection to estimate stochastic (random) health effects such due to exposure to ionizing radiation. This model assumes that any dose greater than zero will increase risk in a linear fashion.

25 This safety risk metric is a probabilistic evaluation of the potential safety impact wherein the consequence of an event is multiplied by the frequency of event. The result of the safety risk metric is provided in safety events per year.

26 See WP 19-1, MAVF Nuclear Safety Consequence Position Paper.

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 20
RISK ASSESSMENT AND MITIGATION PHASE
CROSS-CUTTING FACTORS

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 20
RISK ASSESSMENT AND MITIGATION PHASE
CROSS-CUTTING FACTORS

TABLE OF CONTENTS

A. Introduction.....	20-2
1. Identifying the 2020 Risk Assessment and Mitigation Phase Cross-Cutting Factors	20-2
2. Presenting the Cross-Cutting Factors in the 2020 RAMP	20-3
3. Changes Since the 2017 RAMP	20-4
B. Mapping the Cross-Cutting Factors to the 2020 RAMP Risks	20-4
C. Modeling the Cross-Cutting Factors	20-8
1. Incorporating Cross-Cutting Factors Into the RAMP Risk Bowties.....	20-8
2. Calculating a RSE	20-10
D. Introduction to the 2020 RAMP Cross-Cutting Factors.....	20-10
1. Climate Change	20-11
2. Cyber Attack	20-12
3. Emergency Preparedness and Response.....	20-12
4. IT Asset Failure	20-13
5. Physical Attack.....	20-13
6. Records and Information Management.....	20-14
7. Seismic	20-14
8. Skilled and Qualified Workforce	20-14

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 20
RISK ASSESSMENT AND MITIGATION PHASE
CROSS-CUTTING FACTORS

A. Introduction

**1. Identifying the 2020 Risk Assessment and Mitigation Phase
Cross-Cutting Factors**

To develop its list of 2020 Risk Assessment and Mitigation Phase (RAMP) cross-cutting factors, Pacific Gas and Electric Company (PG&E or the Company) evaluated all the risks on its Corporate Risk Register (CRR).¹ As PG&E analyzed its CRR it identified items that were not risk events themselves, but rather impacted either the likelihood or consequence of other items on the CRR. Those items that were not risks themselves, but impacted other risks were identified as the cross-cutting factors in this 2020 RAMP.

The eight cross-cutting factors PG&E identified and is presenting in this report are:

- 1) Climate Change;
- 2) Cyber Attack;
- 3) Emergency Preparedness and Response (EP&R);
- 4) Information Technology (IT) Asset Failure;
- 5) Physical Attack;
- 6) Records and Information Management (RIM);
- 7) Seismic; and
- 8) Skilled and Qualified Workforce (SQWF).

Cross-cutting factors can impact RAMP risks in several ways. A cross-cutting factor can be a unique risk driver or a component of an existing driver, therefore impacting the likelihood of an event. It can also impact the consequence of an event, increasing the impact of potential outcomes.

¹ PG&E recently changed the name of its Enterprise Risk Register to the Corporate Risk Register. See Chapter 2 of this report.

Unique Driver: The Seismic cross-cutting factor is a unique driver of the Large Uncontrolled Water Release (Dam Failure) risk. A dam failure risk event can occur as a result of a seismic event.

Component of an Existing Driver: The RIM cross-cutting factor does not cause risk events on its own but can contribute to a risk event and; therefore, is represented as a component of another driver. For example, the absence of important records and information or the inability to access that information quickly cannot cause a Loss of Containment on Gas Transmission Pipeline risk event on its own, but can contribute to the likelihood of this risk event occurring through either of two risk drivers—Incorrect Operations or Coordination Failure—if information is not readily available. RIM is represented as a separate driver in the Loss of Containment on Gas Transmission Pipeline Risk Bow Tie for visibility but is essentially a component of the Incorrect Operations risk driver.

Consequence: PG&E's planning for and response to emergencies, included in the EP&R cross-cutting factor, impacts the consequence of a risk event. If a Loss of Containment Gas Distribution Main or Service risk event occurred, initiating emergency response activities could reduce the consequence of the event.

2. Presenting the Cross-Cutting Factors in the 2020 RAMP

The cross-cutting factors appear in several locations in the 2020 RAMP report.

- In this chapter (Chapter 20, "Cross-Cutting Factors"), PG&E shows how the cross-cutting factors map to the RAMP risks, summarizes each cross-cutting factor, and briefly discusses how the cross-cutting factors impact the RAMP risks.
- In Chapter 20, Attachment A, PG&E describes each cross-cutting factor in more detail, explains how it impacts the 2020 RAMP risks, discusses any changes since the 2017 RAMP, describes the mitigations and controls planned for the 2020 through 2026 period, and provides the Risk Spend Efficiency (RSE) scores.
- In the 12 RAMP risk chapters (Chapter 7 to Chapter 18) PG&E lists the cross-cutting factors that impact that RAMP risk.

- In workpapers, PG&E provides a mitigation effectiveness analysis and the forecast costs for those cross-cutting factors where PG&E calculated an RSE.

3. Changes Since the 2017 RAMP

In PG&E's 2017 RAMP, the three cross-cutting factors (RIM, SQWF, and Climate Resilience, (now Climate Change)) were aggregated across individual risk models. PG&E had developed a cross-cutting model that was dependent on the outputs from the other stand-alone risk models. The cross-cutting models were not specific risk events, but an aggregation of the associated stand-alone model. For example, for the RIM cross-cutting factor, each of the stand-alone risks estimated what portion of the risk could be attributed to a records issue. The portion attributed to records issues was an input into the RIM cross-cutting model.

For the 2020 RAMP PG&E is using a new approach for presenting and modeling cross-cutting factors. This new approach is responsive to feedback from the Safety Policy Division, formerly the Safety Enforcement Division (SED), that PG&E's approach to modelling cross-cutting factors in the RAMP lacked specificity and transparency into the impact of the drivers and how they are causally linked to the risk event.² In the 2020 RAMP, PG&E is now integrating each applicable cross-cutting factor into the appropriate RAMP risk models as a driver, driver component, or consequence of that specific risk. This new approach increases transparency and better shows how the cross-cutting factors contribute to the frequency and/or consequence of the RAMP risk events.

B. Mapping the Cross-Cutting Factors to the 2020 RAMP Risks

Tables 20-1 and 20-2 below map the eight cross-cutting factors to the 12 RAMP risks. Table 20-1 shows how the cross-cutting factors impact the likelihood of a risk event while Table 20-2 shows how the cross-cutting factor

² SED noted that PG&E's 2017 approach to modelling cross-cutting risks lacked the specificity and transparency into the impact of the drivers and how they are causally linked to the risk event. SED noted that it might be best to include the cross-cutting drivers in the appropriate stand-alone risk chapter to prevent duplication and better show how these components of risk contribute to the frequency of the risk event. (PG&E, Risk and Safety Aspects of RAMP Report I.17-11-003 (Mar. 30, 2018), p. 24).

1 impacts the consequence of a risk event. PG&E also provides an individual
2 table for each of the cross-cutting factors in Attachment A that maps the
3 cross-cutting factor to the applicable RAMP risks.

4 The risk bowties in each RAMP risk chapter show the applicable
5 cross-cutting factors on both the frequency and consequences sides. Certain
6 cross-cutting factors that impact the consequences of the risk event (right side
7 of the bow tie) will not appear on the bow tie because the cross-cutting factor
8 does not make a separate contribution to the outcome of the risk event. These
9 cross-cutting factors are considered foundational because they support other
10 mitigations rather than directly reducing the risk itself. For example, for the
11 cross-cutting factor EP&R, if a risk event occurs such as Loss of Containment
12 on Gas Transmission Pipeline and PG&E implements EP&R activities (PG&E
13 activates the Emergency Operations Center (EOC)), the EOC activities will
14 reduce the consequence of the risk event (e.g., enhanced coordination with first
15 responders), but those EOC activities do not themselves directly reduce the risk
16 associated with the loss of containment event.

TABLE 20-1
MAPPING THE CROSS-CUTTING FACTORS TO THE RAMP RISKS
CROSS-CUTTING FACTORS IMPACT THE LIKELIHOOD OF THE RISK EVENT

Line No.	RAMP Risk	Cross-Cutting Factor							
		Climate Change	Cyber Attack	EP&R	IT Asset Failure	Physical Attack	RIM	Seismic	SQWF
1	Contractor Safety Incident								
2	Employee Safety Incident	(b)				X	X		X
3	Failure of Electric Distribution Overhead Assets	X				X	X	X	X
4	Failure of Electric Distribution Network Assets	(b)				X	X	X	X
5	Large Overpressure Event Downstream of Gas Measurement and Control Facility						X		X
6	Large Uncontrolled Water Release (Dam Failure)	(b)	X		X	X		X	
7	Loss of Containment on Gas Distribution Main or Service	(b)				X	X	X	X
8	Loss of Containment on Gas Transmission Pipeline	(b)				X	X	X	X
9	Motor Vehicle Safety (MVS) Incident								
10	Real Estate and Facilities Failure	(b)				X		X	
11	Third-Party Safety Incident								
12	Wildfire	(b)						X	

(a) Given historical data, this cross-cutting factor impacts the RAMP risk, but was not extracted from the data and considered or modeled separately. This is referred to in Section B.1 as “Embedded.”

(b) This cross-cutting factor is considered by PG&E to impact the RAMP risk, but data limitations precluded a statistically meaningful quantification of its impact. See Attachment A, Section A for more information.

TABLE 20-2
MAPPING THE CROSS-CUTTING FACTORS TO THE RAMP RISKS
CROSS-CUTTING FACTOR IMPACT THE CONSEQUENCE OF THE RISK EVENT

Line No.	RAMP Risk	Cross-Cutting Factor								Seismic	SQWF
		Climate Change	Cyber Attack	EP&R	IT Asset Failure	Physical Attack	RIM				
1	Contractor Safety Incident										
2	Employee Safety Incident						X				
3	Failure of Electric Distribution Overhead Assets			(a)	X		X		X		
4	Failure of Electric Distribution Network Assets			(a)			X		X		
5	Large Overpressure Event Downstream of Gas Measurement and Control Facility		X	(a)	X		X				
6	Large Uncontrolled Water Release (Dam Failure)			(a)			X				
7	Loss of Containment on Gas Distribution Main or Service			(a)			X				
8	Loss of Containment on Gas Transmission Pipeline		X	(a)	X		X				
9	Motor Vehicle Safety (MVS) Incident						X				
10	Real Estate and Facilities Failure			(a)			X		X		
11	Third-Party Safety Incident										
12	Wildfire	X		(a)			X		X		
(a) Given historical data, this cross-cutting factor impacts the RAMP risk, but was not extracted from the data and considered or modeled separately. This is referred to in Section B.1 as "Embedded."											

1 C. Modeling the Cross-Cutting Factors

2 1. Incorporating Cross-Cutting Factors Into the RAMP Risk Bowties

3 PG&E describes its RAMP risk model in Chapter 3, "Risk Modeling and
4 Risk Spend Efficiency." As described in Chapter 3, the eight cross-cutting
5 factors are incorporated into the applicable RAMP risks.

6 Since the cross-cutting factors impact the RAMP risks in different ways,
7 PG&E used seven different modeling methods to incorporate them into the
8 RAMP risk models. These methods are described below and are shown in
9 the individual cross-cutting factor tables in Attachment A.

10 a) Drivers: To determine the likelihood of an event, PG&E modeled the
11 cross-cutting drivers using two methods.

- 12 • Extracted from Existing: PG&E reviewed the historical causal data
13 related to risk incidents and identified cross-cutting events that
14 impacted the RAMP risk. The cross-cutting factor events were not
15 extracted from the historical data and modeled or considered
16 separately. Extracted from Existing generally represents the impact
17 of cross-cutting factors considering the current application of
18 controls. For example, when modelling the effect of the Physical
19 Attack cross-cutting factor on the Employee Safety Incident risk,
20 PG&E relied on and applied historical data related to the different
21 types of employee safety incidents assuming the data incorporates
22 existing controls to reduce the likelihood of physical attack.
- 23 • Added Frequency: PG&E added frequencies (risk events) based on
24 separate quantification efforts. This method was generally used to
25 represent low frequency events where additional quantification was
26 added to the model to represent the potential impact of the
27 cross-cutting factor. For example, for the Failure of Electric
28 Distribution Network Assets risk, PG&E has no historical data on
29 how major seismic events impact those assets, so to model the
30 Seismic cross-cutting factor, PG&E used seismic model output
31 rather than historical observations to characterize Seismic risk.

32 b) Consequence Multiplier: Reflects an adjustment to the Consequence of
33 Risk Event, due to the impact of the cross-cutting factor. This method

was generally used to represent the cumulative effect of the concurrent occurrence of the RAMP risk event and the cross-cutting factor. For example, RIM is a consequence multiplier to several risk events. The model considers that the lack of access or lack of timely access to records and information can impact a risk event. This impact is expressed in the model by adding a multiplying factor to an outcome. The impact of RIM is modeled by adding a factor that increases the financial outcome (costs) of an event.

- c) Outcome: if an outcome of a Risk Event has different relationships to drivers than the non-cross cutting factor outcomes (e.g., the severe Seismic outcome is driven only by the Seismic driver).
- d) Unique Driver/Outcome Combination: In certain instances PG&E recognizes a Unique Driver/Outcome Combination for the cross-cutting factors and the model introduces a unique combination of outcomes. For example, for the Loss of Containment on Gas Transmission Pipeline risk, if an IT asset failure occurs coincidently or immediately following a risk event, it could cause loss of visibility of the system and delayed response capability, resulting in a greater consequence of the risk event. The model expresses this unique event by adding two outcomes related to the coincident occurrence of the risk event and cross-cutting factor: Transmission Pipeline Rupture Coincident with IT Asset Failure; and Transmission Pipeline Leak Coincident with IT Asset Failure.
- e) Escalating Frequency: Adjustment to driver frequency. This method is generally used to represent a cross-cutting factor that is expected to lead to an increase in the frequency of a risk event occurring. For example, for the Distribution Overhead Asset Failure risk, the model assumes that climate changes (cross-cutting factor: Climate Change) will increase the frequency of events in the Natural Hazard sub-driver category (like heatwave occurrence, lightening, fire, and flooding) over time and, as such, an escalating frequency multiplier is applied to the risk driver.
- f) Embedded: The impact of the cross-cutting factor is already accounted for in the assessment of frequency and consequence of a risk event as control. For example, the model assumes that the impacts of the EP&R

cross-cutting factor are already accounted for in the current Loss of Containment – Distribution Main or Service bowtie and no additional EP&R data is added to the baseline risk assessments.

2. Calculating a RSE

PG&E describes the basic process by which each of the cross-cutting factors is represented in the risk model in Attachment A. The source documents used in each of the cross-cutting factor models is included in supporting workpapers.³

Calculating the RSE incorporates cost estimates and the perceived effectiveness of each mitigation. PG&E discusses RSEs in Chapter 3, “Risk Modeling and Risk Spend Efficiency.” The cost estimates for the mitigations are included in Attachment A for each cross-cutting factor and in supporting workpapers.⁴ The effectiveness of each mitigation is described in the Mitigation Effectiveness workpapers.⁵

In Attachment A PG&E describes the mitigation and control programs it is proposing for each cross-cutting factor during the RAMP period. Most of these programs apply to multiple risks, multiple drivers, multiple tranches, and multiple outcomes. Given the number of potential combinations of risks, drivers, tranches and outcomes, PG&E calculated one RSE for a cross-cutting factor as opposed to an RSE for each cross-cutting factor mitigation. For example, PG&E is proposing seven mitigations to address RIM risks but has calculated one RSE for RIM (all mitigations).

D. Introduction to the 2020 RAMP Cross-Cutting Factors

In this Section PG&E introduces the eight cross-cutting factors. Additional information about each one, including a discussion of the applicable risk modeling, impacts to the 2020 RAMP risks, changes since the 2017 RAMP, planned work and the RSE score is included in Attachment A.

³ PG&E will provide all risk model workpapers on July 17, 2020.

⁴ References to the financial workpaper are provided in Attachment A.

⁵ Chapter 3 workpapers include the mitigation effectiveness workpapers for each cross-cutting risk for which PG&E calculated a RSE value.

1. Climate Change

Climate change presents ongoing and future risks to PG&E's assets, operations, employees, customers, and infrastructure adjacent communities. In the face of these risks, the California Public Utilities Commission (CPUC) has defined climate adaptation for energy utilities as an adjustment in utility systems using strategic and data-driven consideration of actual or expected climatic impacts and stimuli or their effects on utility planning, facilities maintenance and construction, and communications, to maintain safe, reliable, affordable, and resilient operations.⁶

PG&E recognizes that adapting to and becoming resilient in the face of climate change is a critical responsibility and that integrating climate change into the Company's risk approach is a key step in understanding and preparing for projected climate-driven natural hazards. PG&E evaluated all RAMP risks for vulnerability to climate impacts. PG&E integrated available climate projections into the risk bowties for Wildfire and Failure of Electric Distribution Overhead Asset risks. Integrating the projected, quantitative impact of climate change into the other RAMP risk models was not possible for this report due to: the need for more data about the relationship between climate-driven natural hazards and risk events and the need for more or more specific PG&E data.

PG&E considers that most RAMP Risks are impacted by the climate change cross-cutting factor and intends to further integrate forward-looking climate data into risk analysis in future reports.

Because PG&E expects climate change to impact most RAMP risks additional risk assessment is prudent. A key mitigation planned for the 2020 to 2026 period is to conduct a Climate Vulnerability Assessment (CVA). PG&E will undertake a CVA to assess how its assets, operations, and employees are vulnerable to the projected impacts of climate change and consider how climate impacts to PG&E assets may impact customers and infrastructure adjacent communities. The final scope of the CVA will be determined by the forthcoming decision in Rulemaking (R.) 18-04-019.

Climate Change is discussed in more detail in Attachment A, Section A.

⁶ CPUC's Climate Adaptation Order Instituting Rulemaking (R.)18-04-019, (May 7, 2018).

2. Cyber Attack

Cyber Attack is a coordinated malicious attack purposefully targeting PG&E's core business functions and resulting in a loss of control of Company information or systems used for gas, electric or business operations. The consequences of a cyber attack are potentially catastrophic and could impact the safety and reliability of PG&E's operational systems. The Cyber Attack risk includes attacks on IT to obtain unauthorized access to PG&E's data, and attacks on operational technology to impact PG&E's ability to control the delivery of natural gas and/or electricity.

In the 2020 RAMP, PG&E is proposing a series of mitigations aligned to the four pillars of the National Institute of Standards and Technology (NIST) Cybersecurity Framework (CSF): (1) Identify – Activities that develop organizational understanding in managing security risks to systems assets, and data; (2) Protect – Activities that develop and implement appropriate safeguards to provide secure delivery of critical infrastructure services; (3) Detect – Activities that identify the occurrence of a potential security risk, enabling timely discovery and reducing potential consequences; and (4) Respond – Activities that enable effective evaluation of a potential security risk-based event, and impact containment reducing potential consequences. Although there is a fifth NIST CSF category, (5) Recover – Activities that support timely recovery to normal operations following a cybersecurity incident—PG&E did not map projects to this domain.

Cyber Attack is discussed in more detail in Attachment A, Section B.

3. Emergency Preparedness and Response

The EP&R cross-cutting factor examines the drivers and consequences of inadequate planning or response to catastrophic emergencies. Inadequate emergency planning or response could have significant safety, reliability, and regulatory impacts. EP&R advances PG&E's response to emergencies by improving governance, strengthening coordination among the lines of business (LOB), and improving collaboration with external partners such as the Federal Emergency Management Agency and the California Governor's Office of Emergency Services.

EP&R is proposing 12 controls and eight mitigations in the 2020 RAMP. Controls include emergency operations plans and standards, emergency

1 response technology, projects related to PG&E's EOC, and control
2 programs related to the operating LOBs. EP&R mitigations include EOC
3 Enhancements and Mutual Aid Enhancements.

4 EP&R is discussed in more detail in Attachment A, Section C.

5 **4. IT Asset Failure**

6 IT Asset Failure risk is a failure of IT systems or infrastructure, resulting
7 in outages, or system unavailability for mission critical assets impacting
8 operations or the ability to support public safety events. Technology
9 enables and supports virtually all of PG&E's day-to-day activities, including
10 work execution, grid control, customer support, emergency response, asset
11 management, and more. Because of PG&E's growing reliance on
12 technology, the need to maintain the reliability of IT assets and systems
13 becomes increasingly important for PG&E to function effectively.

14 PG&E is proposing four mitigations to address IT Asset Failure.
15 Together these mitigations will enhance IT Asset Failure risk identification,
16 failure detection and response capabilities; add IT asset capacity to support
17 increased demand; remove single points of failure for improved continuity
18 and resiliency; and replace end-of-life, at-risk and high failure rate IT assets.

19 IT Asset Failure is discussed in more detail in Attachment A, Section D.

20 **5. Physical Attack**

21 Physical Attack is defined as incidents related to break-ins, vandalism,
22 theft, fraud, assault, and threats against PG&E's workforce and assets.

23 PG&E is continuing to develop a detailed work plan for the 2020 RAMP
24 period. One of the mitigations PG&E is considering is a program to mitigate
25 identified risks via an internally developed process called the Security
26 Defined Protection Levels (SDPL). Using the SDPL risk framework,
27 Corporate Security has assigned a risk level to approximately 2,600 PG&E
28 facilities. Each risk level corresponds to a standard security package to
29 counter the risk level at each location. Starting with the risk level "elevated"
30 sites, the Corporate Security team will work towards closing any gaps in the
31 security package at that facility.

32 Physical Attack is discussed in more detail in Attachment A, Section E.

6. Records and Information Management

PG&E identified RIM as a cross-cutting factor because the risk of not having an effective RIM program may result in the failure to construct, operate and maintain a safe system and may lead to property damage and/or loss of life. Managing records and information inconsistently can lead to an operational incident or adverse business result if records that are needed cannot be located in a timely fashion.

In the 2020 RAMP period the Enterprise Records and Information Management team will continue to implement existing mitigations and begin new mitigations in the areas of records and information compliance, retention, availability, governance, disposition, and integrity.

RIM is discussed in more detail in Attachment A, Section F.

7. Seismic

Seismic events can be a significant driver of failure in all LOB assets. PG&E's service territory is in an active seismic zone and as such PG&E assets from all LOBs are subject to the potential for damaging ground shaking and related ground failure that ranges from minor to catastrophic from a single event. Damaging effects may occur without warning over a large geographic area and impact PG&E's ability to serve its customers and respond to the event. Seismic events contribute to the likelihood of asset failure events and to the associated safety, reliability, and financial consequences of those events.

During the 2020 RAMP period PG&E's Geosciences team collaborated with LOB asset owners and risk managers to develop the means to consistently quantify seismic risk and to propose risk mitigations tailored to those LOB assets.

Seismic Scenario is discussed in more detail in Attachment A, Section G.

8. Skilled and Qualified Workforce

PG&E's Human Resources Department develops and delivers technical, leadership and other training that helps to maintain a skilled, safe and qualified workforce. Failing to maintain a SQWF is one of PG&E's top cross-cutting factors than can impact safety.

1 The SQWF mitigations and controls planned for the 2020 RAMP period
2 are focused on Gas Operations and Electric Operations employees. One of
3 the key mitigations for the 2020 RAMP period is the Enterprise Safety
4 Management System (ESMS). The ESMS is a series of capabilities
5 (people, process and technology systems) required to define, plan,
6 implement and continuously improve workforce safety and includes an
7 Enterprise Management of Change process to identify, understand, and
8 evaluate the risks and hazards when changes are made to facilities,
9 operations, or personnel to assure they are properly controlled.

10 SQWF is discussed in more detail in Attachment A, Section H.

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 20
ATTACHMENT A
CROSS-CUTTING FACTORS

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 20
ATTACHMENT A
CROSS-CUTTING FACTORS

TABLE OF CONTENTS

A. Climate Change.....	20-1
1. Overview	20-1
2. Modeling.....	20-2
3. Impacts to the 2020 RAMP Risks	20-7
4. Changes Since the 2017 RAMP	20-8
a. Planned Work.....	20-8
b. Mitigations With RSE Scores	20-11
B. Cyber Attack	20-11
1. Overview	20-11
2. Modeling.....	20-12
3. Impacts to the 2020 RAMP Risks	20-12
4. Changes Since the 2017 RAMP	20-13
5. Mitigations and Controls 2020-2026.....	20-19
a. Planned Work.....	20-19
b. Mitigations With RSE Scores	20-21
C. Emergency Preparedness and Response	20-23
1. Overview	20-23
2. Modeling.....	20-26
3. Impacts to the 2020 RAMP Risks	20-26
4. Changes Since the 2017 RAMP	20-27
5. Mitigations and Controls 2020-2026.....	20-27
a. Planned Work.....	20-27
b. Mitigations With RSE Scores	20-32

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 20
ATTACHMENT A
CROSS-CUTTING FACTORS

TABLE OF CONTENTS
(CONTINUED)

D. IT Asset Failure	20-36
1. Overview	20-36
2. Modeling.....	20-38
3. Impacts to the 2020 RAMP Risks	20-39
4. Changes Since the 2017 RAMP	20-41
5. Mitigations and Controls 2020-2026.....	20-41
a. Planned Work.....	20-41
b. Mitigations With RSE Scores	20-44
E. Physical Attack	20-44
1. Overview	20-44
2. Modeling.....	20-44
3. Impacts to the 2020 RAMP Risks	20-45
4. Changes Since the 2017 RAMP	20-46
5. Mitigations and Controls 2020-2026.....	20-46
a. Planned Work.....	20-46
b. Mitigations With RSE Scores	20-47
F. Records and Information Management.....	20-49
1. Overview	20-49
2. Modeling.....	20-50
3. Impacts to the 2020 RAMP Risks	20-50
4. Changes Since the 2017 RAMP	20-51
5. Mitigations and Controls 2020-2026.....	20-52
a. Planned Work.....	20-52

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 20
ATTACHMENT A
CROSS-CUTTING FACTORS

TABLE OF CONTENTS
(CONTINUED)

b. Mitigations With RSE Scores	20-54
G. Seismic	20-57
1. Overview	20-57
2. Modeling.....	20-59
3. Impacts to the 2020 RAMP Risks	20-60
4. Changes Since the 2017 RAMP	20-62
5. Mitigations and Controls 2020-2026.....	20-63
a. Planned Work.....	20-63
b. Mitigations with RSE Scores	20-64
H. Skilled and Qualified Workforce	20-64
1. Overview	20-64
2. Modeling.....	20-65
3. Impacts to the 2020 RAMP Risks	20-66
4. Changes Since the 2017 RAMP	20-66
5. Mitigations and Controls 2020-2026.....	20-67
a. Planned Work.....	20-67
b. Mitigations With RSE Scores	20-70

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 20
ATTACHMENT A
CROSS-CUTTING FACTORS

A. Climate Change

1. Overview

Climate change presents ongoing and future risks to Pacific Gas and Electric Company's (PG&E or the Company) assets, operations, employees, customers, and the communities in which it serves. In the face of these risks, the California Public Utilities Commission (CPUC) has defined climate adaptation for energy utilities in the ongoing Order Instituting Rulemaking (OIR) as adjustments in utility systems using strategic and data-driven consideration of actual or expected climatic impacts and stimuli or their effects on utility planning, facilities maintenance and construction (M&C), and communications, to maintain safe, reliable, affordable, and resilient operations.¹

In line with the ongoing OIR, PG&E is taking action to mitigate against and adapt to the potential consequences of a changing climate and associated weather patterns. This includes ongoing "foundational work" that seeks to improve PG&E's internal capabilities to understand, analyze, and use forward looking climate data in decision-making.

PG&E has identified six primary climate-driven contributors to risk: increased severity and frequency of storm events; sea level rise; land subsidence; change in temperature extremes; changes in precipitation patterns and drought; and wildfire. Consequences of these climate-driven events may vary widely and could include increased stress on the energy supply network due to new patterns of demand, reduced hydroelectric output, physical damage to PG&E's infrastructure, higher operational costs, and an increase in the number and duration of customer outages and safety consequences for both employees and customers.

¹ CPUC's *Climate Adaptation OIR*, Rulemaking (R.)18-04-019 (May 7, 2018).

2. Modeling

Climate Change projections are uncertain. Given the range of potential future conditions and because historical data is often inadequate for understanding how future conditions may impact communities and infrastructure it is difficult to determine how climate change may impact the RAMP risks. To integrate climate data into the risk model, each risk was considered separately, and available climate projections matched to appropriate drivers or consequences. For certain risks a lack of data precluded integration of climate projections, even though PG&E expects these risks to be impacted by climate change.

Table 1 shows the status of climate data integration into the risk models.

TABLE 1
CROSS-CUTTING FACTOR SUMMARY: CLIMATE CHANGE

Line No.	Risk	Status of Climate Data Integration	Explanation of Climate Change Quantification Status
1	Wildfire	Integrated into Model	See Modeling Workpapers Climate
2	Failure of Electric Distribution Overhead Assets	Integrated into Model	See Modeling Workpapers Climate through Climate
3	Failure of Electric Distribution Network Assets	Applicable but not integrated, pending further research	Available data shows limited historical natural hazard impact Developing statistical relationship between climate-driven natural hazards and equipment failure
4	Loss of Containment on Gas Transmission Pipeline	Applicable but not integrated, pending further research	Available data shows limited historical natural hazard impact Developing statistical relationship between climate-driven natural hazards and equipment failure
5	Loss of Containment on Gas Distribution Main or Service	Applicable but not integrated, pending further research	Available data shows limited historical natural hazard impact Developing statistical relationship between climate-driven natural hazards and equipment failure
6	Large Overpressure Event Downstream of a Gas Measurement and Control Facility	Not applicable	Asset failure insensitive to natural hazards based on available data
7	Employee Safety Incident	Applicable but not integrated, pending further research	Available data shows limited historical natural hazard impact Developing statistical relationship between climate-driven natural hazards and employee safety
8	Contractor Safety Incident	Not Applicable	Difficult to build relationships between long-reaching climate change issues and risk events
9	Third Party Safety Incident	Not Applicable	Difficult to build relationships between long-reaching climate change issues and risk events

TABLE 1
CROSS-CUTTING FACTOR SUMMARY: CLIMATE CHANGE
(CONTINUED)

Line No.	Risk	Status of Climate Data Integration	Explanation of Climate Change Quantification Status
10	Motor Vehicle Safety Incident	Applicable but not integrated, pending further research	Difficult to build relationships between long-reaching climate change issues and risk events
11	Real Estate and Facilities Failure	Applicable but not integrated, pending further research	Available data shows limited historical natural hazard impact Need for site-specific flood analysis
12	Large Uncontrolled Water Release	Applicable; De facto integrated via existing FERC risk methodology	Required Federal Energy Regulatory Commission (FERC) dam risk assessment is conservative by design and incorporates consideration of past observed and likely future events when considering the magnitude of extreme floods.

1 PG&E's Climate Resilience Team evaluated all RAMP risks in
2 partnership with Risk Owners and asset family subject matter experts. This
3 involved consideration of each risk's sensitivity to climate-driven natural
4 hazards, and determination of whether existing climate data could be
5 integrated into risk bowties in a statistically meaningful manner.

6 In many cases, the Climate Resilience Team and LOB representatives
7 agreed that climate-driven natural hazards would likely impact or continue to
8 impact the risk in the future, but given the data available, it was not possible
9 to meaningfully quantify that impact without substantial further study. For
10 example, future climate change-driven increases in extreme heat and
11 vector-borne illnesses may pose safety risks to employees and contractors.
12 However, a lack of historical data correlating heat to safety incidents
13 precluded the ability to project how this risk will change over time. Similarly,
14 climate change is likely to affect the condition of transportation
15 infrastructure, which, combined with extreme weather events, could lead to
16 an increase in Motor Vehicle Safety Incidents. In this case, it was difficult to
17 build relationships between long-reaching climate change issues and risk
18 events.

19 PG&E intends to continue to advance the inclusion of forward-looking
20 climate data into PG&E's RAMP risk models in future filings. Additionally,
21 PG&E's Climate Vulnerability Assessment will supplement the Company's
22 understanding of how climate-driven natural hazards may impact PG&E in
23 the future.

24 One way climate change can impact a risk is to increase the likelihood
25 of a risk event and act as a frequency multiplier. The model considers how
26 the climate variable will change (often, increase) over time and therefore
27 impact PG&E employees and operations. For example, for the Failure of
28 Electric Distribution Overhead Assets risk, PG&E conducted a heat wave
29 analysis that projects how temperature will increase over time. The results
30 of this analysis are used to estimate how rising temperatures will impact
31 PG&E's electric assets by comparing the rising temperature data to the
32 electric assets failure rates based on the temperature threshold at which
33 equipment is likely to fail. PG&E also considered other natural hazards for
34 this risk, including major rain events, major snow/ice events, extreme wind,

lightening, flooding due to extreme precipitation, subsidence, and others. To reflect the impact of these changing climate conditions on this risk, PG&E used climate projections to determine how the frequency of these natural hazard sub-drivers could change over time and impact the frequency of risk occurrence.

In contrast, climate change is accounted for in PG&E's Wildfire risk model on the consequence side of the model by correlating the projected change in PG&E territory burned relative to the year 2020 with change in the frequency of ignitions that occur during Red Flag Warnings (RFW). This increases the proportion of ignitions due to PG&E equipment that occur under RFW conditions and therefore, lead to higher consequence wildfires. This correlation is valid because projections of future area burned and RFW events are both driven by underlying factors, like higher temperatures and drier fuels, that are expected to result in more frequent and extreme fires due to climate change.

In addition to quantifiably impacting the Failure of Distribution Overhead Assets and Wildfire risks, PG&E considers climate change to be an applicable sub-driver to all other Risk Assessment and Mitigation Phase (RAMP) risks except Large Overpressure Event Downstream of a Gas Measurement and Control Facility, Motor Vehicle Safety (MVS) Incident, and Third-Party Safety Incident.² PG&E was not able to quantify the impact of climate change on these risks at this time due to limited internal, industry, and/or academic research regarding how specific climate variables impact specific asset types. In many cases, the contribution of climate-impacted natural hazard sub-drivers to risk event frequency was negligibly low relative to other drivers based on historical data. Given that climate change is projected to increase the frequency and intensity of some natural hazard sub-drivers—thereby, making these sub-drivers greater potential contributors to risk in the future—PG&E plans to conduct further research to

² Climate Change does not apply to Motor Vehicle Safety Incident and Third-Party Safety Incident because in each case the bowties focus on the actions of the actor in question, rather than environmental conditions leading to failure. In the case of Large Overpressure Event Downstream of a Gas Measurement and Control Facility risk, PG&E found no evidence that climate variables impact the type of equipment failures that are the dominant driver of this risk.

better quantify the impact of climate-driven hazards on these risks for the 2024 RAMP filing, and in the meantime is conducting a Climate Vulnerability Assessment (CVA) consistent with CPUC proceeding R.18-04-019 to supplement the Company's understanding of climate-driven risk.

3. Impacts to the 2020 RAMP Risks

Climate Change impacts nine RAMP risks as shown in Table 2 below. PG&E is proposing alternative mitigations to address Climate Change for five RAMP risks: (1) Real Estate and Facilities Failure; (2) Failure of Electric Distribution Overhead Assets; (3) Failure of Electric Distribution Network Assets; (4) Loss of Containment on Gas Distribution Main or Service; and, (5) Loss of Containment on Gas Transmission Pipeline.

TABLE 2
CROSS-CUTTING FACTOR SUMMARY: CLIMATE CHANGE

Line No.	RAMP Risk	Taxonomy	Risk Frequency, Percentage (Events/Year)	Percent of Risk
1	Employee Safety Incident	Applicable, but unquantified	(a)	--
2	Failure of Electric Distribution Overhead Assets	Escalating Frequency	(a)	(a)
3	Failure of Electric Distribution Network Assets	Applicable but unquantified	(a)	--
4	Large Uncontrolled Water Release (Dam Failure)	Embedded	(a)	--
5	Loss of Containment Gas Distribution Main or Service	Applicable, but unquantified	(a)	--
6	Loss of Containment on Gas Transmission Pipeline	Applicable, but unquantified	(a)	--
7	Real Estate and Facilities Failure	Applicable, but unquantified	(a)	--
8	Wildfire	Consequence Multiplier	(a)	(a)
<p>(a) This cross-cutting factor is considered by PG&E to impact the RAMP risk, but data limitations precluded a statistically meaningful quantification of its impact. See Attachment A, Section A for more information.</p> <p>Note: The values in the Cross-Cutting Factor Summary tables come from the bow tie graphics in the RAMP risk chapters (Chapters 7 and 18). In certain instances the impact of the cross-cutting factor is such that it is not displayed on the bow tie graphic.</p>				

4. Changes Since the 2017 RAMP

a. Planned Work

PG&E designated Climate Resilience as an enterprise risk in 2017. In the 2017 RAMP, PG&E identified 12 mitigations that together comprised the foundational activities PG&E planned to undertake in order to better understand the risks posed to the Company by climate change and to increase the Company's climate resilience.³

In 2017 Climate Resilience was a stand-alone risk whereas in 2020 this risk has been redefined as a cross-cutting factor to acknowledge that climate-driven natural hazards are contributing drivers to many RAMP risks.

PG&E completed six of the mitigations proposed in 2017: (M1A – Develop and Pilot Climate Resilience Screening Tool; M2 – Establish Standardized Process to Respond to Community Request for Climate Impact Information; M4 – Administer the Better Together Resilience Community Grant Program; M7A1 – Sea Level Rise Deep Dive; M7A2 – Wildfire Deep Dive; and, M7A3 – Increasing Temperatures/Heatwaves Deep Dive).

PG&E is continuing to work on the other seven mitigations proposed in 2017.

M5C – Develop and Report Climate Resilience Metrics: PG&E is making progress on increasing its internal capabilities to understand, plan for, and adapt to climate change. To track and measure this progress a second assessment (the baseline assessment was conducted in 2018) will be conducted in early 2021.

M8 – Research Climate Science and Impacts: While most work in the coming years will be directed at the CVA and Adaptation Plans, future updates will be needed as new climate models are developed and additional research on climate risk is published.

M10 – Governance, Integration, and Continuous Improvement: Key projects within this mitigation including the ongoing development of

³ PG&E's 2017 RAMP Report, Investigation (I.) 17-11-003 (Nov. 30, 2017) (PG&E's 2017 Ramp Report), p. 22-12, Table 22-4.

Climate Line of Business (LOB) Action Plans; ongoing work to integrate future climate risk into LOB project lifecycle plans; updating design standards to account for future climate risk; and ongoing training of staff to use climate risk tools.

M11 – Climate Vulnerability Assessment: PG&E is undertaking a CVA to assess how its assets, operations, and employees are vulnerable to the projected impacts of climate change. The final scope of the CVA will be determined by the forthcoming decision in R.18-04-019. Due to the size of PG&E's service territory, PG&E plans to conduct the CVA in phases, with each phase focused on one of PG&E's regions. Each phase will evaluate climate risk exposure, assess the sensitivity of assets in the region to this climate risk; examine the adaptive capacity of the assets, and use this information to determine vulnerability. PG&E will work with various stakeholders throughout the CVA process to keep customers and infrastructure-adjacent communities apprised of developments and findings from the assessment. The CVA is expected to take at least three years to complete.

M12 – Climate Adaptation Plans: Following the completion of each phase of the CVA, PG&E will begin developing Climate Adaptation Plans, by region to increase the resilience of its assets, operations, and employees. PG&E intends to work closely with local communities to coordinate with local stakeholders as these plans are developed.

M13 – Internal Consulting: The Climate Resilience team receives requests from the LOBs to undertake ad hoc projects related to integrating forward looking climate data into project planning and asset replacement.

The forecast costs for the planned mitigations are shown in Table 3 below.⁴

⁴ Costs for all cross-cutting factor mitigations are included on WP 20-1.

TABLE 3
FORECAST COSTS,
2020-2026 EXPENSE
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	Major Work Category (MWC)	2020	2021	2022	2023	2024	2025	2026	Total
1	M5C	Develop and Report Climate Resilience Metrics	LJA	–	\$155	–	–	\$87	–	–	\$242
2	M8	Research Climate Science and Impacts	LJA	\$52	–	–	\$85	174	\$225	\$185	721
3	M10	Governance, Integration, and Continuous Improvement	LJA	156	160	123	169	174	225	185	1,192
4	M11	CVA	LJA	432	579	588	127	–	–	139	1,865
5	M12	Climate Adaptation Plans	LJA		270	397	446	412	330	139	1,993
6	M13	Internal Consulting	LJA	130	210	214	219	224	319	328	1,645
7		Total		\$770	\$1,373	\$1,322	\$1,047	\$1,072	\$1,098	\$975	\$7,657

b. Mitigations With RSE Scores

PG&E did not calculate an RSE for Climate Change because the Climate Change mitigations are foundational. Foundational mitigations do not directly reduce risk themselves, but they support other mitigations that do.

B. Cyber Attack

1. Overview

The Cyber Attack risk is defined as a coordinated malicious attack purposefully targeting PG&E's core business functions, resulting in a loss of control of company information or systems used for gas, electric or business operations. The consequences of a cyber attack are potentially catastrophic and could impact the safety and reliability of PG&E's operational systems. The Cyber Attack factor includes attacks on Information Technology (IT) in order to obtain unauthorized access to PG&E's data, and attacks on operational technology to impact PG&E's ability to control the delivery of natural gas and/or electricity. In 2018, the energy sector was among the top three most attacked critical infrastructure sectors in the United States (U.S.).⁵

Cybersecurity continues to be increasingly important to the overall safety of PG&E's operating environment as technology becomes more complex and PG&E becomes more dependent on technology-enabled assets to meet business objectives. Security risks must be mitigated to prevent an attack and secure technology in order to guard against safety, reliability, financial and customer trust impacts.

PG&E manages cybersecurity threats through its Cybersecurity organization that is solely focused on managing security risk to PG&E's workforce, critical infrastructure, information assets, customers, and business operations. Efforts to manage risk include: new security mitigation investments; monitoring and reporting cyber attacks; securing operational technology environments; mitigating critical asset risks; Identity and Access

⁵ Scott Foster, Power Engineering International, "Cybersecurity: How Utilities Can Prepare the Next Generation of Smart Grid" (Feb. 12, 2018). Scott Foster is the Chief Executive of Delta Energy and Communications.

1 Management (IAM); educating PG&E's employees on common and
2 emerging security threats; remediating vulnerabilities across the enterprise;
3 managing enterprise security technology; and, investigating and mitigating
4 insider threats.

5 **2. Modeling**

6 Cyber Attack can impact both the likelihood and consequence of a risk
7 event. PG&E does not have internal data wherein a cyber attack resulted in
8 a catastrophic risk event, therefore, PG&E relied on publicly-available data
9 to model this cross-cutting factor. Collecting external data to analyze cyber
10 attack is difficult because it is rare for a cyber attack to cause a catastrophic
11 event and because data about a cyber attack is generally not released to the
12 public. Even publicly-available data is not widely available for evaluating the
13 likelihood of a cyber attack against an industrial control system (like a utility)
14 that could result in a catastrophic outcome.

15 To model the impact this cross-cutting factor had on the frequency of a
16 risk event, PG&E evaluated how frequently there were near cyber attack
17 misses. The near-misses were correlated with the chance for a cyber attack
18 to result in a catastrophic outcome—a PG&E control system is compromised
19 such that it leads to a risk event.

20 On the consequence side of the bow-tie, PG&E determined how much
21 worse the outcome of a risk event would be if a risk event and cyber attack
22 occurred at the same time. The model expresses this relationship by
23 applying a consequence multiplier to represent the impact a cyber attack
24 has on a risk event.

25 **3. Impacts to the 2020 RAMP Risks**

26 Cyber Attack impacts three RAMP risks. PG&E is continuing to
27 evaluate the impact that Cyber Attack has on RAMP risks and expects to
28 present Cyber Attack as a cross-cutting factor relative to additional RAMP
29 risks in the 2023 General Rate Case (GRC).

30 Tables 4 and 5, below, maps the Cyber Attack cross-cutting factor to the
31 applicable RAMP risks.⁶

⁶ Information about how Cyber Attack impacts the RAMP risks is included on WP 20-3.

TABLE 4
CROSS-CUTTING FACTOR DRIVER SUMMARY: CYBER ATTACK

Line No.	RAMP Risk	Taxonomy	Risk Frequency, Percentage (Events/Year)	Percent of Risk
1	Large Uncontrolled Water Release (Dam Failure)	Escalating Frequency	0.6 percent (0.0001)	0.3 percent

TABLE 5
CROSS-CUTTING FACTOR CONSEQUENCE SUMMARY: CYBER ATTACK

Line No.	RAMP Risk	Consequence	Percent Frequency	Percent of Risk
1	Large Overpressure Event Downstream of Gas Measurement and Control Facility	LOC and Cyber Attack	0.02 percent	0.3 percent
2	Loss of Containment on Gas Transmission Pipeline	Leak and Cyber Attack	0.2 percent	<0.01 percent
3	Loss of Containment on Gas Transmission Pipeline	Rupture and Cyber Attack	0.1 percent	0.3 percent

1 Cyber Attack can impact the likelihood of a Large Uncontrolled Water
2 Release (Dam Failure) risk event. A Cyber Attack coincident with conditions
3 that cause a dam failure (flood, seismic, internal erosion, or physical attack)
4 will increase the likelihood that a catastrophic outcome will occur.

5 Cyber Attack can impact the consequences of a Large Overpressure
6 Event Downstream of Gas M&C Facility or a Loss of Containment on Gas
7 Transmission Pipeline. If a Cyber Attack that impacts gas Supervisory
8 Control and Data Acquisition (SCADA) occurred during a risk event, it could
9 amplify that event by reducing PG&E's visibility into the system, decreasing
10 PG&E's ability to respond to the risk event.

11 **4. Changes Since the 2017 RAMP**

12 In the 2017 RAMP PG&E presented two security-related risks, Cyber
13 Attack (Chapter 18) and Insider Threat⁷ (Chapter 19). In the 2020 RAMP,
14 Insider Threat is now positioned as a sub-driver of Cyber Attack.

⁷ Insider threat is the likelihood that employee or non-employee workers (i.e., contractors, consultants, temporary employees, etc.) with current or previously authorized access to PG&E's assets would intentionally or inadvertently use their access and knowledge in a manner that adversely affects safety, reliability or privacy or that results in additional expense to PG&E.

1 In the 2017 RAMP PG&E proposed a series of controls and mitigations
2 designed to manage one or more of the Cyber Attack drivers. The controls
3 and mitigations were aligned to the four pillars of the National Institute of
4 Standards and Technology (NIST) Cybersecurity Framework (CSF) (Identify,
5 Protect, Detect, and Respond). The NIST CSF establishes the basic
6 guidelines of an effective cyber security program.

7 Following the 2017 RAMP filing, PG&E's Cybersecurity organization
8 reevaluated its mitigations to better align them with the Company's overall
9 cybersecurity strategy. Additionally, PG&E identified opportunities for
10 efficiency and identified new work streams that resulted in changes to the
11 mitigation forecasts. These changes were presented in PG&E's 2020
12 GRC.⁸

13 Table 6 below provides a summary status for each of the mitigations
14 presented in the 2017 RAMP.

⁸ Application (A.)18-12-009, Exhibit (PG&E-7), Chapter 9, p. 9-17 to p. 9-40.

TABLE 6
STATUS OF CYBER ATTACK MITIGATIONS PRESENTED IN THE 2017 RAMP

Line No.	2017 RAMP Mitigation Name and Number	Mitigation Objective	Current Status
1	M1 – Identify		
2	Third-Party Risk Management	Implement an integrated vendor risk management system that will provide a central repository for all vendor risk assessments.	Initial objectives not complete. Instead of implementing a new tool the decision was made to enhance the existing system. Improvements will continue through 2020.
3	Critical Application Security Monitoring	Build a prioritized list of application logs and develop a road map to onboard the priority logs into PG&E's log review and correlation platform for monitoring and analysis.	Complete.
4	IAM Product Enhancements	Enhance the IAM solutions to support cloud identity management, developer security operations, database integrations, cloud access security, Department of Energy Part 810 export controls, unstructured high-risk data access management, and segregation of duties. The project also includes extending on-premise IAM solutions to cloud and enterprise mobility.	Partially complete. From the scope of anticipated IAM product enhancements work identified in the 2017 RAMP, a few areas were deprioritized, or ownership transitioned.
5	Next Generation Endpoint Security	Create an end-point security strategy, architecture, configuration, and profiles to support the key operating systems in use at PG&E. The capability augments or replaces signature-based antivirus protection, which is no longer fully effective against malware and other types of attacks.	Not complete. PG&E is currently executing on the implementation of the Endpoint Detection and Response (EDR) tool, targeted for June 2020.
6	Priority Application Integration	Evaluate systems for risk of inappropriate logical access, particularly systems critical for Sarbanes-Oxley compliance and systems critical for compliance with regulatory requirements for the custody of Customer Energy Usage Data.	Complete.

TABLE 6
STATUS OF CYBER ATTACK MITIGATIONS PRESENTED IN THE 2017 RAMP
(CONTINUED)

Line No.	2017 RAMP Mitigation Name and Number	Mitigation Objective	Current Status
7	Vulnerability Management	Develop and implement a comprehensive solution for vulnerability and patch management process across all of PG&E.	Complete.
8	M2 – Protect		
9	Application Integration	Expand role-based LOB access controls and third-party account integration with access provisions for users in order to mitigate the risk of users with inappropriate access to high risk applications.	Initial objectives complete. Program will extend beyond 2020.
10	Auto Cloud Security	Design and implement processes and tools for applications, computers, and storage and network deployment on the cloud to mitigate the risk of data stored in the cloud.	Initial objectives complete. Program will extend beyond 2020.
11	Operational Data Network (ODN) Security Improvements	Establish core security technologies and test their compatibility with Operations Technology devices. This will enable the development of technology architecture and designs to deploy at Distribution Control Centers, transmission substations, distribution substations, and customer service centers.	Project planned as a multi-year initiative that will extend into the 2020-2022 period. Initial objectives complete.
12	Cloud Security Training	Obtain training courses for employees related to cloud security in order to mitigate the risks of deploying and managing vendor-provided cloud systems. Additional training and job aids will be developed internally related to security best practices in secure system development, operations, configuration management, vulnerability management, and data loss prevention.	Complete.

TABLE 6
STATUS OF CYBER ATTACK MITIGATIONS PRESENTED IN THE 2017 RAMP
(CONTINUED)

Line No.	2017 RAMP Mitigation Name and Number	Mitigation Objective	Current Status
13	Customer Information Protection	Develop and implement a data security governance program to address and manage compliance and legal requirements so that sensitive data is protected as per the PG&E requirements. PG&E will use technology to locate sensitive information and assess the controls in place. Where controls are lacking, remediation measures will be identified and implemented in phases based on risk.	Initial objectives complete. Program will extend beyond 2020.
14	Enterprise Password Vault	Provide complex passwords for users.	Complete.
15	Gas SCADA Network	Multi-phase mitigation addressing asset management, network protection (segregation, reduce single point of failure), security monitoring, and technology evaluation and planning for operating system upgrades.	Complete.
16	Catalog Privileged Accounts and Access to Critical Systems	Secures the enterprise network by identifying and cataloging individual users who have custody of critical PG&E logical and/or physical assets. The project will also identify users with privileged access or access to both physical and logical critical systems.	Partially complete. From the scope of anticipated work in the Catalog of Privileged Accounts and Access to Critical Systems initiative identified in the 2017 RAMP, one set of activities was deprioritized and is being evaluated for inclusion in 2020 and beyond.

TABLE 6
STATUS OF CYBER ATTACK MITIGATIONS PRESENTED IN THE 2017 RAMP
(CONTINUED)

Line No.	2017 RAMP Mitigation Name and Number	Mitigation Objective	Current Status
17	M3 – Detect		
18	Mobile Threat Detection	Implement comprehensive threat protection for Bring Your Own Device and Corporate-Owned Personally Enabled device against mobile network, device, and application related cyber-attacks. Implement a solution that monitors mobile devices in real time to detect threats, analyze deviations from baseline behavior, and respond immediately.	Not complete. In 2017-2018 PG&E evaluated having a Mobile Threat Protection solution to be used in conjunction with the Company's Mobile Device Management (MDM) capabilities and determined the investments that would be made would not justify the risk reduction that would be obtained. Instead, PG&E relies on a set of MDM policies, Mobile Application Management policies enforced by the Mobile Iron solution currently used, and multiple layers of preventive controls to evaluate device state, to reduce the risk posed by a malicious actor getting hold of specific devices and applications.
19	Security Analytics and Advanced Monitoring Phase III	Enhance cybersecurity monitoring technology, algorithms, tools, processes, and techniques.	Complete.
20	Security Monitoring Capability Extension	Accommodate organic growth in security monitoring of systems, of system attributes, and log retention that requires the addition of storage, network capacity, software licensing, and hardware.	Complete.
21	M4 – Respond		
22	Advanced Persistent Threats (APT) Detection and Analysis Enhancement	Improve event analysis and accelerate the detection of attacks coming from APT by extending the amount of time that security event logs are retained to improve the ability to detect malicious activity from a range of possible sources allowing for a faster response and mitigating the overall impact of the attack.	Complete.
23	eDiscovery Capability and Resilience Improvement	Increase the capacity of the eDiscovery tool currently and create space for data backups from the tool.	Complete.

In the 2017 RAMP, PG&E proposed five Insider Threat risk mitigations.⁹ Insider Threat mitigations and subsequent controls for this RAMP period are incorporated into the four proposed mitigations described below.

5. Mitigations and Controls 2020-2026

a. Planned Work

In the 2020 RAMP, PG&E is again proposing a series of mitigation programs aligned to the four pillars of the NIST CSF. The work PG&E is proposing for 2020 is described below. PG&E has not yet developed its specific project list for the 2021-2026 time period but will pursue projects closely aligned to each of the NIST CSF domains.

Domain 1 – Identify (Mitigation (M) 1): Activities that develop organizational understanding in managing security risks to systems, assets, and data. Resources supporting critical functions must have a clear understanding of the business context and related risks to prioritize risk mitigation efforts.

PG&E has developed its 2020 project list and is proposing mitigation projects primarily aligned to this domain. One of the Identify projects PG&E is proposing is a new tool that will run in parallel with the existing firewalls to ensure that any firewall misses are identified.¹⁰

Domain 2 – Protect (M2): Activities that develop and implement appropriate safeguards to provide secure delivery of critical infrastructure services. These activities limit the impact of security risk-based events, reducing both frequency and consequence.

PG&E has developed its 2020 project list and is proposing several mitigation projects primarily aligned to this domain. One of the Protect projects PG&E is proposing will prevent cybersecurity events in one operational facility from impacting other remote facilities by segregating critical assets.

⁹ PG&E's 2017 RAMP Report, p. 19-12, Table 19-1.

¹⁰ Many of the cyber attack projects PG&E is proposing impact multiple NIST CSF domains. The new tool to ensure that firewall misses are identified primarily aligns to the Identify domain but applies to the Detect and Respond domains as well. The number of projects planned for 2020 counts each project only once based on the primary domain to which it applies.

1 **Domain 3 – Detect (M3):** Activities that identify the occurrence of a
2 potential security risk, enabling timely discovery and reducing potential
3 consequences.

4 PG&E has developed its 2020 project list and is proposing mitigation
5 projects primarily aligned to this domain. One of the Detect projects
6 PG&E is proposing will improve access certification through technology
7 and business process updates and establish methods to identify and
8 address potentially unauthorized system accounts in an automated
9 manner.

10 **Domain 4 – Respond (M4):** Activities that enable effective evaluation
11 of a potential security risk-based event, and impact containment
12 reducing potential consequences.

13 PG&E has developed its 2020 project list and is proposing
14 a mitigation project primarily aligned to this domain. The Respond
15 project PG&E is proposing will integrate key security tools to improve
16 effectiveness and efficiency of cyber incident response programs.

17 In addition to the mitigations planned for 2020-2026, PG&E will also
18 continue to implement a series of controls to manage cybersecurity risk.
19 These controls provide the operations and maintenance (O&M)
20 framework for cybersecurity and include:

21 **Control 1 – Security Intelligence and Operations Center:** Monitors
22 and reports cyber threats, provides real time event monitoring and
23 incident response, deploys and supports security tools, and performs
24 digital forensic analysis;

25 **Control 2 – Cybersecurity Risk and Strategy:** Provides enterprise
26 cybersecurity strategy, mitigates critical asset risks, secures Operational
27 Technology assets, and collaborates with industry stakeholders;

28 **Control 3 – Cybersecurity Services:** Manages enterprise security
29 technology, IAM, and the remediation of vulnerabilities across the
30 enterprise;

31 **Control 4 – Communications:** Educates PG&E workforce on security
32 threats, and promotes a culture of best security practices; and

33 **Control 5 – Investigation and Insider Threats:** Conducts internal and
34 external investigations of criminal activities and employee misconduct.

1 **b. Mitigations With RSE Scores**

2 The forecast costs, RSEs and risk reduction scores for the planned
3 mitigation work is shown in Tables 7, 8, and 9 below.

TABLE 7
FORECAST COSTS
2020-2026 EXPENSE
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	2023	2024	2025	2026	Total
1	M1	Identify	JV	\$380	\$391	\$403	\$415	\$428	\$440	\$454	\$2,911
2	M2	Protect	JV	1,553	1,599	1,647	1,697	1,748	1,800	1,854	11,898
3	M3	Defect	JV	538	554	571	588	605	624	642	4,122
4	M4	Respond	JV	326	336	346	357	367	378	390	2,502
5		Total		\$2,797	\$2,881	\$2,967	\$3,056	\$3,148	\$3,243	\$3,340	\$21,432

TABLE 8
FORECAST COSTS
2020-2026 CAPITAL
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	2023	2024	2025	2026	Total
1	M1	Identify	2F	\$500	\$515	\$530	\$546	\$563	\$580	\$597	\$3,831
2	M2	Protect	2F	18,013	18,553	19,110	19,683	20,273	20,881	21,508	138,020
3	M3	Defect	2F	3,708	3,819	3,934	4,052	4,173	4,299	4,428	28,412
4	M4	Respond	2F	175	180	185	191	197	202	209	1,338
5		Total		\$22,395	\$23,067	\$23,759	\$24,472	\$25,206	\$25,962	\$26,741	\$171,602

TABLE 9
RSE AND RISK REDUCTION: CYBER ATTACK- ALL MITIGATIONS

Line No.	Applicable RAMP Risk	Aggregated		Applied to RAMP Risk
		RSE ^(a)	Risk Reduction (NPV) ^(b)	Risk Reduction (Net Present Value (NPV)) ^(b)
1	<u>Mitigation: All Cyber Attack Mitigations</u>	0.0002	0.02	–
2	Large Overpressure Event Downstream of M&C Facility	–	–	< 0.01
3	Large Uncontrolled Water Release (Dam Failure)	–	–	0.02
4	Loss of Containment on Gas Transmission Pipeline	–	–	< 0.01
5	Total	0.0002	0.02	0.02

(a) See MWs included in the source document modeling package for information used to calculate the RSE.

(b) Information presented in terms of NPV to account for the discounting of benefits.

1 C. Emergency Preparedness and Response

2 1. Overview

3 The Emergency Preparedness and Response (EP&R) cross-cutting
4 factor examines the drivers and consequences of inadequate planning or
5 response to catastrophic emergencies. Inadequate emergency planning or
6 response could have significant safety, reliability and regulatory impacts.

7 EP&R advances PG&E's response to emergencies by improving
8 governance, strengthening coordination among the LOBs and improving
9 collaboration with external partners such as the Federal Emergency
10 Management Agency (FEMA) and California Governor's Office of
11 Emergency Services. EP&R requires integrated plans and the appropriate
12 facilities, logistics, technology, and processes to respond to a catastrophic
13 incident.

14 The EP&R organization works with PG&E's LOBs to develop
15 capabilities for responding to all emergencies such as: a clearly defined
16 organizational structure for emergency response; scalable restoration plans
17 and systems that assist responders with situational awareness;
18 implementing technologies, such as resilient servers and enhanced
19 basecamp communication systems; developing and disseminating
20 emergency incident communications and situational awareness; training
21 employees to respond to emergencies; testing capabilities through a number

1 of exercises and developing and implementing enterprise-wide business
 2 continuity efforts; community outreach and customer support for coordinated
 3 interaction with Federal, State, County, City and Tribal Agencies. The EP&R
 4 organization also maintains PG&E's Emergency Operations Center (EOC)
 5 and alternate EOCs.

6 In the 2020 GRC, PG&E described several key initiatives that it would
 7 implement during the GRC period¹¹ such as expanding PG&E's weather
 8 forecasting, monitoring and modeling capabilities and engaging in activities
 9 to maintain and enhance PG&E's emergency preparedness. In the third
 10 quarter of 2019, PG&E moved EP&R out of the Community Wildfire Safety
 11 Program (CWSP) and created a new organization (EP&R) because EP&R
 12 addresses all hazard events. The expanded EP&R organization now
 13 consists of five teams each responsible for a unique EP&R scope of work.

14 **EP&R Strategy and Execution:** The Strategy and Execution team is
 15 responsible for a wide range of activities including: developing scalable
 16 plans and systems for responding to hazards; developing roles and
 17 responsibilities for emergency response efforts; working with internal and
 18 external stakeholders; leading business continuity efforts and external
 19 emergency preparedness events; maintaining the EOC and alternate
 20 emergency centers; and measuring and evaluating PG&E emergency
 21 response efforts. This team: publishes the annual Company Emergency
 22 Response Plan, (CERP) that provides guidance on managing emergencies
 23 of all kinds and works with the LOBs to develop CERP annexes; leads
 24 continuous improvement projects that improve emergency response
 25 functions; and tracks metrics on emergency readiness.

26 **Meteorology:** PG&E's meteorology department integrates weather data
 27 from numerous internal and external sources and uses these data streams
 28 to forecast wind and weather patterns to calculate fire risk levels across the
 29 service territory. The team also: provides daily weather forecasts and
 30 Storm Outage Prediction Project models; helps identify locations for new
 31 weather stations; and uses state of the art fire modeling to better understand
 32 fire patterns, movement, and behaviors. The Meteorology department plays

¹¹ A.18-12-009, Exhibit (PG&E-4), Chapter 3.

a key role in the data presented for the decision process during a Public Safety Power Shutoff (PSPS)

EP&R Field Operations: Field Personnel and Public Safety Specialists (PSS) who support external and internal first responders and emergency managers. PSS personnel plan and train with external first responders to prepare for emergencies, wildfires and PSPS events. PSS teams also support CWSP open houses and workshops and provide first responder workshops about responding to gas and electric emergencies.

Public Safety Power Shutoff (PSPS): PG&E's PSPS Program proactively de-energizes select transmission and distribution circuit segments within Tier 2 and Tier 3 HFTD areas when elevated fire danger conditions occur. De energization is determined necessary to protect public safety when PG&E reasonably believes there is an imminent and significant risk of strong winds impacting PG&E assets, and a significant risk of a catastrophic wildfire should an ignition occur.

Wildfire Safety Operations Center (WSOC): The WSOC is a coordination and communications hub for wildfire activities. The WSOC monitors the service territory for wildfires and provides updates on any fires in PG&E's service area. The WSOC will also deploy PSS to fires to interface with the Incident Command organization. PG&E's Safety and Infrastructure Protection Teams are part of the WSOC and deployed via the WSOC to protect infrastructure during fires and other emergencies.

In this RAMP filing, the EP&R initiatives are divided into two categories:

- 1) Those initiatives supporting only Wildfire risk mitigation and aligned to the Wildfire RAMP risk;¹² and
- 2) Those initiatives supporting multiple risk mitigation efforts and therefore assigned in this RAMP filing as a cross-cutting factor.

Those risk mitigations and controls that are aligned to the Wildfire RAMP risk are described in Chapter 10 of this filing. The risk mitigations and controls applicable to multiple risks are described in Section C.5 below.

¹² More information about the EP&R Wildfire initiatives is included in PG&E's 2020 Wildfire Mitigation Plan Report, R.18-10-007, February 7, 2020.

2. Modeling

The EP&R cross-cutting factor impacts the consequence side of the bow-tie and is considered a consequence modifier. EP&R is relevant after a risk event occurs by defining how PG&E responds to a risk event. In modeling the effect EP&R has on a risk event, PG&E applied EP&R to risk events following which the EOC would be activated – catastrophic and severe events.

Because EP&R is an integral part of PG&E's operations, it is difficult to model the consequences of a risk event. Therefore, the model assumes that the safety, reliability and financial consequences of an event are reduced by a certain percentage when the EOC is activated.

3. Impacts to the 2020 RAMP Risks

Table 10 below maps the EP&R cross-cutting factor to the applicable RAMP risks.

TABLE 10
CROSS-CUTTING FACTOR SUMMARY: EP&R

Line No.	RAMP Risk	Taxonomy	Risk Frequency, Percentage (Events/Year)	Percent of Risk
1	Failure of Electric Distribution Overhead Assets	Embedded	--	(a)
2	Failure of Electric Distribution Network Assets	Embedded	--	(a)
3	Large Overpressure Event Downstream of Gas Measurement and Control Facility	Embedded	--	(a)
4	Large Uncontrolled Water Release (Dam Failure)	Embedded	--	(a)
5	Loss of Containment on Gas Distribution Main or Service	Embedded	--	(a)
6	Loss of Containment on Gas Transmission Pipeline	Embedded	--	(a)
7	Real Estate and Facilities Failure	Embedded	--	(a)
8	Wildfire	Embedded	--	(a)
(a) While this cross-cutting factor impacts the RAMP risk, it was not extracted from the data and considered or modeled separately.				

EP&R controls and mitigations help to reduce the impact of a catastrophic or severe risk event. If a catastrophic or severe risk event occurs, PG&E activates its EOC and/or alternate emergency centers. PG&E would then initiate the EP&R controls to help mitigate the impact of these events such as: coordinated responses between the LOBs to re-energize electric lines and re-pressurize gas pipelines; deploying and staffing base camps to enhance restorations efforts for customers; coordinated customer outreach activities; and communications with third-party responder agencies.

4. Changes Since the 2017 RAMP

EP&R was not a 2017 RAMP risk.

5. Mitigations and Controls 2020-2026

EP&R is proposing 12 controls and nine mitigations.

a. Planned Work

Controls

C1 – Company Emergency Operations Plans and Standards for

Response: Align PG&E emergency operations plans and standards with accepted emergency management industry practices and utility industry best practices. Standards that will be updated include: EMER-2001S: Company Emergency Operations Plan (CERP); EMER-1012M: Earthquake Playbook; EMER-3101M: Earthquake Annex, ERMER-3012M; Cybersecurity Annex, EMER-3102M: Fire Prevention Plan.

C2 – Emergency Response Technology: (1) LiveSafe application is a mobile two-way safety communications platform and risk mitigation tool to help employees stay safe in every day and high-risk scenarios.

PG&E will enhance this tool based on employee and user feedback that will increase safety for PG&E staff; (2) Send Word Now (SWN) is a critical communications and alerting messaging tool to notify employees and external agencies of impacting events and incidents. PG&E is evaluating SWN to increase communications capabilities; (3) MutualLink provides seamless operational communications sharing radio, voice, text, video, data files and telephone systems in a secure environment by

1 use of the Interoperable Response and Preparedness Platform network
 2 that connects radios and satellite telephones. PG&E uses this
 3 technology to communicate internally and externally with first
 4 responders in local law enforcement, fire departments and with base
 5 camps and staging sites; and (4) Dynamic Automated Seismic Hazard
 6 (DASH) is an earthquake damage model that sends messages and
 7 graphics to subscribed users.¹³

8 **C3 – EOC/Incident Command System (ICS) Training Program:**

9 Implement an annual credential program to train and enhance ICS
 10 skills and standards to coordinate an emergency response. Training
 11 programs will be built around emergency management industry best
 12 practices for accreditation and in collaboration with Cal-OES. The
 13 emergency training program is aligned with National Incident
 14 Management System, California Standardized Emergency Systems,
 15 and foundational ICS guidance provided by the FEMA's Emergency
 16 Management Institute and the California Specialized Training
 17 Institute (CSTI).

18 **C4 – EOC Response:** PG&E will train personnel to use the ICS as
 19 described in Control C3 above.

20 **C5 – EOC Exercises:** EOC exercises enhance emergency response
 21 coordination capabilities among EOC staff. They provide an opportunity
 22 to test the effectiveness of current EOC procedures and resources.
 23 Exercises include: Grid Restoration Table Top Exercise (TTX), Grid
 24 Restoration Functional, FEMA inspired exercises, Cyber Security TTX,
 25 Cyber Security/Electrical Grid Exercise IV Full-Scale, Earthquake
 26 Full-Scale, and Alternate Company Headquarters exercise.

27 **C6 – Weekly Situational Awareness Calls (WSAC) and**

28 **Enhancements:** WSACs with Enterprise-Wide Coordination Group to
 29 identify operational issues that have enterprise-wide impacts. PG&E will
 30 enhance this control by changing the WSAC criteria to build metrics
 31 around the readiness of all the WSAC participants to respond to a
 32 catastrophic event.

¹³ DASH is described in the Seismic cross-cutting factor section below (Section G).

1 **C7 – Early Earthquake Warning:** PG&E is piloting a Shake
2 Alert-based public-address system for earthquake notifications that
3 includes: pre-event notification linked to ground movement sensors to
4 warn of an impending quake; and links to mechanical systems (e.g., in a
5 high-rise building elevators would be routed to the ground floor prior to
6 shaking without any human intervention).

7 **C8 – Debris Flow Modeling:** Debris-flow modeling focuses on
8 landslide-triggered debris flows in PG&E's service territory. PG&E uses
9 pre and post wildfire geospatial data to model debris flow threat and
10 probabilities. Burn areas are reviewed for proximity to PG&E
11 infrastructure and for potential downstream impacts to communities. If
12 modeling shows potential impacts to infrastructure or communities,
13 plans are developed to eliminate or minimize potential damage.

14 **C9 – Gas Systems Operations Temperature Forecasting:** Provide
15 temperature forecasts used to model forecasted gas demand and loads
16 over a seven day forecast horizon. Gas demand forecasting is used to
17 provide situational awareness and operational triggers for executing
18 procedures such as gas curtailments.

19 **C10 – Power Generation Hydro Management Forecasting:** Provide
20 temperature, precipitation, snow level forecasts and weekly briefings for
21 multiple PG&E watersheds. This forecast data is used to help manage
22 PG&E reservoirs and model inflow expected over the next week.

23 **C11 – Short-Term Electric Supply Forecasting:** Provide temperature
24 and roof-top solar forecasting to help forecast electric demand and
25 support procurement of energy in day-ahead markets.

26 **C12 – Diablo Canyon Power Plant (DCPP) Emergency Response**
27 **Organization Support:** Provide emergency support for any emerging
28 conditions at DCPP that may pose a risk to the public. Meteorological
29 support is provided in the event of an emergency at DCPP including
30 forecasting wind speed and direction and reporting of current
31 conditions that support Protective Action Recommendations to
32 San Luis Obispo County.

Mitigations

PG&E is proposing eight individual mitigations that are divided into three groups. The outputs from the risk model include only the two mitigation groups—EOC Enhancements and Mutual Aid (MA) Enhancements—and not the individual mitigation names.

TABLE 11
EP&R MITIGATIONS GROUPED BY MITIGATION TYPE

Line No.	Mitigation Group 1 – EOC Enhancements	Mitigation Group 2 – MA Enhancements	Foundational Mitigations
1	M1–Base Camp Project	M4–MA Tools and Equipment	M6–New Incident Specific Annexes
2	M2–Check In/Check-Out with Salesforce	M5–Mutual Assistance Improvement	M8–Early Earthquake Warning Enhancements
3	M3–Secondary Emergency Roles, Enterprise-Wide		
4	M7–EOC/ICS Training Program Enhancements		

M1 – Base Camp Project: Improve personnel accountability and operations surrounding base camp activations, including check-in and check-out of employees. Implement IT controls and processes to account for personnel entering and exiting the base camp. Using technology for check-in and check-out will help PG&E account for all personnel entering and exiting the camp and will improve safety if a base camp needs to be evacuated by confirming that all personnel can be accounted for. Required equipment includes ruggedized devices that can be used at multiple entry/exit points.

M2 – EOC Check-In/Check-Out With Salesforce: Develop and implement processes and tools for the check-in and check-out function at the EOC.

M3 – Secondary Emergency Roles, Enterprise-Wide: Implement secondary emergency role in the event of an activated incident. PG&E will train personnel for multiple emergency response roles so that if one area gets hit by an emergency, staff from other areas are ready to

assist. Using an all-hazards approach to training gives the staff the most versatility in managing incidents.

M4 – Mutual Aid Tools and Equipment: Develop a process for identifying, acquiring and dispersing of mutual assistance tools essential to emergency restoration for mutual assistance and internal crews.

M5 – Mutual Assistance Improvement: Develop guidance for acquiring and training mutual assistance resources. Improve mutual assistance program to onboard, process, track, demobilize and pay mutual assistance resources. Develop and implement mutual assistance and DCCP collaboration training program for DCCP employees and new MA Assistance employees.

M6 – New Incident-Specific Annexes: Develop new incident specific annexes (plans) to provide guidance to the LOBs to plan and document their responses to specific disruptions. Current annexes being developed are the Earthquake Emergency Restoration plan and the infectious disease annex. Other annexes will be developed based on current risk data. PG&E considers this to be a foundational mitigation.¹⁴

M7 – EOC/ICS Training Program Enhancements: As part of its foundational mitigation effort, PG&E established a 5-year training plan for personnel in leadership roles in the EOC. The training plan consists of four phases: (1) ICS Baseline Courses; (2) CSTI EOC Baseline Courses; (3) Advanced ICS for Select Personnel; and (4) Position-specific Training Workshops. Phase 3, ICS-300, is for all EOC supervisory personnel and advanced training (ICS-400) for all EOC Command and General staff.

M8 – Early Earthquake Warning Enhancements: The program will improve earthquake preparedness, resiliency, and response capability through the use of early warning technology. PG&E will plan, coordinate and execute: Public Address System upgrades in General Office (245 Market/77 Beale) (C7 above); Debris Flow Analysis (C8 above);

¹⁴ PG&E considers certain mitigations to be foundational mitigations because they support other controls and mitigations rather than directly mitigate risk and, as a result, PG&E is not assigning a risk score or calculating an RSE for these foundational mitigations.

1 and DASH Server Upgrade (C2 above). PG&E considers this to be a
2 foundational mitigation.

3 **b. Mitigations With RSE Scores**

4 The forecast costs for the planned mitigations are shown in
5 Tables 11 and 12, and the RSEs and risk reduction scores in Tables 13
6 and 14 below. PG&E did not calculate RSEs for Mitigation 6 or
7 Mitigation 8 because they are considered foundational work.

TABLE 12
FORECAST COSTS
2020-2026 EXPENSE
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	2023	2024	2025	2026	Total
1	M1	Base Camp Project	AB6	\$1,000	\$2,050	\$1,051	\$1,077	–	–	–	\$5,178
2	M2	EOC Check-In, Check-Out with Salesforce	AB6	30	31	32	32	\$33	\$14	–	172
3	M3	Secondary Emergency Roles Enterprise-Wide	AB6	500	513	525	538	552	566	–	3,194
4	M7	EOC/ICS Training Enhancements ^(a)	AB6	980	980	980	980	980	980	\$980	6,862
5		Subtotal EOC Enhancements		\$2,510	\$2,588	\$2,688	\$2,628	\$1,565	\$1,560	\$980	\$15,405
6	M4	MA Tools and Equipment	AB6	\$40	–	–	–	–	–	–	\$40
7	M5	Mutual Assistance Improvement	AB6	50	\$51	\$53	\$54	–	–	–	208
8		Subtotal MA Enhancements		\$90	\$51	\$53	\$54	–	–	–	\$248
9	M6	New Incident Specific Annexes	AB6	\$250	\$256	\$263	\$269	–	–	–	\$1,038
10		Total		\$2,850	\$3,881	\$2,903	\$2,951	\$1,565	\$1,560	\$980	\$16,691

(a) The forecast costs for this mitigation exclude escalation. PG&E will escalate these costs in the 2023 GRC forecast using the 2023 GRC escalation rate.

TABLE 13
FORECAST COSTS
2020-2026 CAPITAL
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	2023	2024	2025	2026	Total
1	M8	Early Earthquake Warning Enhancements ^(a)	21	\$255	\$255	\$255	\$255	\$255	\$255	\$255	\$1,787
2		Total		\$255	\$255	\$255	\$255	\$255	\$255	\$255	\$1,787

(a) The forecast costs for this mitigation exclude escalation. PG&E will escalate these costs in the 2023 GRC forecast using the 2023 GRC escalation rate.

TABLE 14
RSE AND RISK REDUCTION: EP&R – EOC ENHANCEMENTS

Line No.	Mit No.	Applicable RAMP Risk	Aggregated		Applied to RAMP Risk
			RSE ^(a)	Risk Reduction (NPV) ^(b)	Risk Reduction (NPV) ^(b)
1	M1, M2, M3, M7	<u>Mitigation: EOC Enhancements</u>	440	2,667	–
2		Failure of Electric Distribution Network Assets	–	–	0
3		Failure of Electric Distribution Overhead Assets	–	–	37
4		Large Overpressure Event Downstream of Gas M&C Facility	–	–	2
5		Large Uncontrolled Water Release (Dam Failure)	–	–	7
6		Loss of Containment on Gas Distribution Main or Service	–	–	8
7		Loss of Containment on Gas Transmission Pipeline	–	–	16
8		Real Estate and Facilities Failure	–	–	20
9		Wildfire	–	–	2,576
10		Total	440	2,667	2,667

(a) See MWCs included in the source document modeling package for information used to calculate the RSE.

(b) Information presented in terms of NPV to account for the discounting of benefits.

TABLE 15
RSE AND RISK REDUCTION: EP&R – MA ENHANCEMENTS

Line No.	Mit No.	Applicable RAMP Risk	Aggregated		Applied to RAMP Risk
			RSE ^(a)	Risk Reduction (NPV) ^(b)	Risk Reduction (NPV) ^(b)
1	M4, M5	<u>Mitigation: MA</u>	14,918	654	–
2		Failure of Electric Distribution Network Assets	–	–	–
3		Failure of Electric Distribution Overhead Assets	–	–	10
4		Large Overpressure Event Downstream of Gas M&C Facility	–	–	1
5		Large Uncontrolled Water Release (Dam Failure)	–	–	2
6		Loss of Containment on Gas Distribution Main or Service	–	–	2
7		Loss of Containment on Gas Transmission Pipeline	–	–	4
8		Real Estate and Facilities Failure	–	–	5
9		Wildfire	–	–	630
10		Total	14,918	654	654

(a) See MWCs included in the source document modeling package for information used to calculate the RSE.

(b) Information presented in terms of NPV to account for the discounting of benefits.

D. IT Asset Failure

1. Overview

The IT Asset Failure risk is defined as failure of IT systems or infrastructure, resulting in outages, or system unavailability for mission critical assets impacting operations, or the ability to support public safety events.

IT has become increasingly engrained in PG&E operations. Across all LOBs, technology helps to improve safety and reliability, enhances the customer experience, and supports compliance. Technology enables and supports virtually all of PG&E's day-to-day activities, including work execution, grid control, customer support, emergency response, and asset management. The growing reliance on technology demonstrates PG&E's shift to what's known as a "digital business"—or more specifically, a "Digital Utility." As this shift continues, the reliability of IT assets and integrated systems becomes increasingly important for PG&E to function effectively.

To define the IT assets that could impact a RAMP risk, the 12 RAMP risk teams identified those IT software applications, infrastructure (hardware) and systems that, were they to fail, would significantly impact their RAMP risk event. The IT risk team started its analysis with the software applications and hardware components identified by the RAMP risk teams and used them to develop a more complete list of IT assets that could impact a RAMP risk.

To fully develop the potential impact to the RAMP risks, the IT risk team evaluated all of the software applications, systems, and hardware components that PG&E relies on to operate its business including asset management systems, collaboration tools, infrastructure technologies, operational management systems, work management systems, and others in order to more clearly understand and define the potential risks that could result from an IT asset failure. After completing this holistic analysis of potential IT asset failure risks, the IT risk team then applied the results of the analysis to the 12 RAMP risk events and determine if and how these potential IT asst risks applied to the software applications and hardware components relied on by the RAMP risk teams to mitigate risk. This IT analysis involved a review of foundational infrastructure systems (e.g., data

centers, fiber optic backbone), hardware (e.g., servers, desktop and laptop computers), hosting environments (including compute, storage, and network technologies), communications systems (e.g., network routers, interconnect sites and switches, data collection units, radio base stations), and software applications (e.g., business applications, data management software, operating systems).

Because PG&E's IT systems are so complex and include so many individual elements, PG&E focused its risk analysis on Mission Critical (Tier 1) and Business Critical (Tier 2) systems for this 2020 RAMP. PG&E identified the IT assets that are included in the IT Asset Failure risk by reviewing approximately hundreds of IT assets, grouped by Level 1 Asset Category¹⁵ and Level 2-3 Asset Category,¹⁶ to determine the potential impact each asset would have on a RAMP risk event if that asset failed. This analysis assessed the interdependencies among the different IT assets and evaluated how a failure of one system, software application, or hardware component could impact other, inter-connected assets. PG&E did not identify each specific point where technology failure could impact the application or hardware component identified by the RAMP risk owner but focused instead on generic interdependencies. As the IT Asset Failure risk analysis matures, PG&E will move towards a more granular analysis of interdependencies.

The Level 1 and Level 2-3 Asset Categories that the IT risk team determined could potentially impact a RAMP risk were further analyzed to determine their potential impact on a risk event, a risk driver, or on the consequences of a risk event.

Direct Impact: Failure of an IT asset could directly cause a risk event or risk event driver to occur, could directly inhibit PG&E's ability to detect an

¹⁵ The Level 1 Asset Category was the starting point for the detailed risk analysis, and it is segregated into foundational type technologies and systems such as: collaboration; infrastructure technologies; and management systems (i.e., asset management, customer management, IT management, operations management, etc.).

¹⁶ Level 2-3 Asset Category includes a more granular division of technology assets including: IT facilities; telephony; personal computing; document and filing sharing; application hosting; geographic information systems; outage management tools; and real-time monitoring tools.

occurrence of the risk event, or could directly inhibit PG&E's response to/recovery from a risk event; or

Indirect Impact: Failure of an IT asset/system could cause failure of an asset used directly to prevent, an event, or could, combined with other drivers, increase the likelihood of a risk event.

Consequence Multiplier: Failure of an IT asset could increase the impact of the risk event creating delays in the detection and response to an event.

For example, the Loss of Containment – Gas Transmission Pipeline risk owner determined that IT asset failures that led to the unavailability of the Gas SCADA and the Oasys applications could result in loss of visibility of the system and delayed response capability. Starting with this critical application, the IT risk team evaluated all the different IT assets that, should they fail, could impact the two critical applications. Through this analysis, the IT risk team identified nine different Level 1 Asset Category elements and 89 individual Level 2-3 Asset Category elements whose failure could impact the Gas Transmission risk event.

IT Asset Failure itself does not cause a risk event to occur. However, if a risk event and an IT Asset Failure occur at the same time, it is possible that the likelihood of the risk event occurring could increase or the outcome of the risk event could be more significant.

2. Modeling

IT Asset failure is included in the risk event bow ties as both impacting the likelihood of an event occurring and as a consequence multiplier.

As described above, modeling the risk of IT Asset Failure across the 12 RAMP risks involved a detailed analysis of hundreds of IT assets that can impact the RAMP risks in different ways and can result in minor to catastrophic impacts. Due to the complexities of the IT systems, the number of individual assets, and the compound relationships among the IT assets and the RAMP risks, it was difficult for the RAMP risk owners and IT risk team to determine exactly which IT assets would significantly impact a risk event if they failed. In addition to the individual IT assets, PG&E also struggled with how to account for the "foundational" IT assets (e.g., networks, communication systems, etc.) in frequency/impact quantification and mitigation effectiveness calculations.

Along with the difficulty identifying the critical IT assets (defined here as those that would impact a risk even if they failed), PG&E determined that it does not have sufficient internal data to support IT asset failure frequency, outage frequency, outage durations, the impacts those durations could have on the LOBs if a critical IT asset failed or sufficient internal data to evaluate the potential for IT asset to fail in the future. Finally, PG&E could not determine a defensible method for valuing the effectiveness of the planned mitigations.

PG&E is exploring ways to quantify and model IT Asset Failure and expects to calculate RSEs for IT Asset Failure in the 2023 GRC.

3. Impacts to the 2020 RAMP Risks

Table 16 and 17 below maps the IT Asset Failure cross-cutting factor to the applicable RAMP risks. IT Asset Failure is an added frequency for one RAMP risk and a consequence multiplier for three RAMP risks. PG&E is continuing to evaluate the impact that IT Asset Failure has on RAMP risks and expects to present IT Asset Failures as a cross-cutting factor, relative to additional RAMP risks in the 2023 GRC. ¹⁷

TABLE 16
CROSS-CUTTING FACTOR DRIVER SUMMARY: IT ASSET FAILURE

Line No.	RAMP Risk	Taxonomy	Risk Frequency, Percentage (Events/Year)	Percent of Risk
1	Large Uncontrolled Water Release (Dam Failure)	Added Frequency	6 percent (0.00001)	6 percent

¹⁷ Information about how IT Asset Failure impacts the RAMP risks is included on WP 20-3.

TABLE 17
CROSS-CUTTING FACTOR CONSEQUENCE SUMMARY: IT ASSET FAILURE

Line No.	RAMP Risk	Outcome	Percent Frequency	Percent of Risk
1	Failure of Electric Distribution Overhead Asset	Asset Failure/Not Assoc. w/ Ignition/Coincident with IT Asset Failure	< 0.1 percent	0.3 percent
2	Large Overpressure Event Downstream of Gas Measurement and Control Facility	LOC and IT Asset Failure	0.1 percent	1.6 percent
3	Loss of Containment on Gas Transmission Pipeline	Rupture and IT Asset Failure	0.5 percent	1 percent
4	Loss of Containment on Gas Transmission Pipeline	Leak and IT Asset Failure	0.6 percent	<0.01 percent

1 IT Asset Failure impacts four RAMP risks:

2 Failure of Electric Distribution Overhead Assets

3 PG&E identified four IT assets or IT components that could multiply the
4 consequences of a risk event if they failed at the same time a Failure of
5 Electric Distribution Overhead Asset risk even occurred: (1) SCADA radio
6 systems; (2) backhaul landline/microwave communication components;
7 (3) ODN; and (4) the electric distribution management system.

8 Large Overpressure Event Downstream of Gas M&C Facility

9 IT Asset Failure could amplify the consequences of a risk event because
10 IT asset failures could lead to the unavailability of Gas SCADA resulting on
11 loss of visibility of the system and delayed response capability. IT Asset
12 Failure is not likely to cause this risk event. The IT systems considered
13 when analyzing IT Asset Failure risk are critical network components and
14 mission critical communications systems supporting regulating, gas, meter
15 and compression stations, electric plants, and valve lots.

16 Large Uncontrolled Water Release

17 IT Asset Failure coincident with a Large Uncontrolled Water Release
18 failure (e.g., flood, seismic event, internal erosion or physical attack) will
19 increase the likelihood of a risk event (dam failure). The IT systems
20 considered when analyzing IT Asset Failure risk are critical network
21 components and mission critical communications systems supporting
22 hydroelectric plants.

Loss of Containment on Transmission Pipeline

IT Asset Failure is not likely to cause this risk event but could increase the consequence of an event if Gas SCADA is unavailable, causing loss of visibility into the gas transmission system and delayed response time. The IT systems considered when analyzing IT Asset Failure risk are critical network components and mission critical communications systems supporting regulating, gas, meter and compression stations, electric plants and valve lots.

4. Changes Since the 2017 RAMP

IT Asset Failure was not a 2017 RAMP risk.

5. Mitigations and Controls 2020-2026

a. Planned Work

PG&E has identified five IT Asset Failure risk mitigation programs:

M1 - Asset Management/Monitoring: Implement IT asset failure risk identification and/or failure detection and response capabilities;

M2 - Capacity/Coverage/Scalability: Add IT asset capacity, coverage and/or scalability to support increased demand;

M3 - Resiliency: Remove single points of failure, design IT asset(s) for continuity and resiliency;

M4 – Lifecycle: Replace end-of-life, at-risk, and/or high failure rate IT assets.

M5 - Multiple Risks Impact Mitigation: Risk mitigation projects or programs that combine one or more of the four IT Asset Failure mitigation programs (M1 through M4). For example, a single Multiple Risks Impact Mitigation may address both asset management and monitoring concerns as well as resiliency issues.

To develop the list of mitigation programs and assign them to the appropriate RAMP risks, PG&E evaluated more than 200 individual IT projects and mapped each one to: (1) one of the five RAMP mitigation programs; (2) a RAMP asset category; and (3) a RAMP risk.

For example, PG&E is planning nine third-party fiber replacement and repair projects. Because these projects are designed to replace end-of-life or at-risk assets, they were categorized as a part of the

1 Lifecycle Mitigation Program and IT Asset Failure Mitigation Program.
2 Next, the IT risk team determined that the eight projects contribute to the
3 asset category “Network – Transmission.” Finally, based on the initial
4 mapping of IT assets to risks, the risk team knew that the
5 Network-Transmission asset category applies to RAMP risks in Electric
6 Operations, Gas Operations, and Power Generation.

7 The five IT Asset Failure mitigation programs often include multiple
8 projects and/or programs. Because PG&E is continuing to build out its
9 2021-2026 project plan, it relied on its 2020 work plan as the basis for
10 assigning the mitigation programs to the RAMP risks. A copy of the
11 2020 work plan aligned to mitigation programs is included in
12 workpapers.¹⁸

13 The forecast costs for the planned mitigation programs are shown in
14 Tables 18 and 19 below.

¹⁸ See WP 20-4.

TABLE 18
FORECAST COSTS
2020-2026 EXPENSE
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	2023	2024	2025	2026	Total
1	M1	Asset Management/Monitoring	JV	\$230	\$237	\$244	\$251	\$259	\$266	\$274	\$1,760
2	M2	Capacity/Coverage/ Scalability	JV	86	88	91	94	96	99	102	656
3	M3	Resiliency	JV	77	79	82	84	87	89	92	589
4	M4	Lifecycle	JV	20,722	21,344	21,984	22,644	23,323	24,023	24,744	158,785
5	M5	Multiple Risks Impact Mitigation	JV	972	1,001	1,031	1,062	1,094	1,127	1,161	7,448
6		Total		\$22,087	\$22,749	\$23,432	\$24,135	\$24,859	\$25,605	\$26,373	\$169,239

TABLE 19
FORECAST COSTS, RSE, AND RISK REDUCTION
2020-2026 CAPITAL
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	2023	2024	2025	2026	Total
1	M1	Asset Management/Monitoring	2F	\$3,023	\$3,113	\$3,207	\$3,303	\$3,402	\$3,504	\$3,609	\$23,162
2	M2	Capacity/Coverage/ Scalability	2F	10,818	11,142	11,477	11,821	12,175	12,541	12,917	82,891
3	M3	Resiliency	2F	3,501	3,606	3,714	3,825	3,940	4,058	4,180	26,825
4	M4	Lifecycle	2F	103,662	106,772	109,975	113,274	116,673	120,173	123,778	794,308
5	M5	Multiple Risks Impact Mitigation	2F	11,724	12,075	12,438	12,811	13,195	13,591	13,999	89,833
6		Total		\$132,727	\$136,709	\$140,810	\$145,035	\$149,386	\$153,867	\$158,483	\$1,017,018

b. Mitigations With RSE Scores

Given the complexities of evaluating the relationship between IT assets and RAMP risk events, the lack of internal data and difficulty determining mitigation effectiveness, PG&E was not able to calculate an RSE for IT Asset Failure.

PG&E is working through these issues and expects to present RSEs for IT Asset Failure mitigation programs in the 2023 GRC.

E. Physical Attack

1. Overview

Physical Attack is defined as an attack on PG&E physical assets or personnel, that could result in damage to property, business impacts, or injury/fatality. Physical attacks are increasing as evidenced by the increase in active shooter incidents in the U.S.

PG&E manages the Physical Attack risk in its Corporate Security organization. Activities include assessing and mitigating physical security risks related to employees, contractors, physical assets, facilities and infrastructure. The Corporate Security organization is responsible for emergency response, incident management and collaborating with local management on physical security vulnerability and mitigations.

2. Modeling

Physical Attack impacts the likelihood of a risk event and includes both attacks against a person and attacks on a PG&E facility or asset (vandalism).

To model this cross-cutting factor PG&E used a bottom-up approach, relying on both internal and proxy data. PG&E relied on internal data identifying each physical attack on a PG&E asset related to electric distribution overhead assets and gas distribution and transmission assets. To model physical attacks related to PG&E owned and managed facilities (real estate), electric distribution underground network assets, and hydroelectric facilities PG&E relied on proxy data and Subject Matter Expert (SME) insight.

3. Impacts to the 2020 RAMP Risks

Physical Attack impacts seven risks. PG&E is continuing to evaluate the impact that Physical Attack has on RAMP risks and expects to present Physical Attack as a cross-cutting factor relative to additional RAMP risks in the 2023 GRC.

Table 20 below maps the Physical Attack cross-cutting factor to the applicable RAMP risks.¹⁹

TABLE 20
CROSS-CUTTING FACTOR SUMMARY: PHYSICAL ATTACK

Line No.	RAMP Risk	Taxonomy	Risk Frequency, Percentage (Events/Year)	Percent of Risk
1	Employee Safety Incident	Extracted from Existing	0.23 percent (1.4)	0.26 percent
2	Failure of Electric Distribution Overhead Assets	Extracted from Existing	0.1 percent (27)	0.1 percent
3	Failure of Electric Distribution Network Assets	Added Frequency	0.1 percent (0.01)	0.1 percent
4	Large Uncontrolled Water Release (Dam Failure)	Added Frequency	0.1 percent (0.00001)	0.2 percent
5	Loss of Containment on Gas Distribution Main or Service	Extracted from Existing	0.02 percent (7)	0.01 percent
6	Loss of Containment on Gas Transmission Pipeline	Extracted from Existing	0.4 percent (0.01)	0.5 percent
7	Real Estate and Facilities Failure	Added Frequency	27 percent (2.2)	0.2 percent

Employee Safety Incident

A physical attack is one of the drivers that can lead to the “Violence and other injuries by persons or animals” outcome of the risk event.

Failure of Electric Distribution Overhead Assets

Physical Attack can increase the likelihood of this risk event. It occurs when third parties tamper with Distribution Overhead assets resulting in outages.

Failure of Electric Distribution Network Assets

PG&E has not experienced a physical attack leading to asset failure in this part of the grid. There are controls that exist to make it very difficult for

¹⁹ Information about how Physical Attack impacts the RAMP risks is included on WP 20-3.

1 unauthorized access to the vaults in which these assets are situated. In
2 addition, the redundant nature of the system means that a single failure is
3 unlikely to lead to any impact to the customer.

4 Large Uncontrolled Water Release

5 While a physical attack on a hydroelectric dam could potentially cause a
6 risk event, there are no instances of this occurring in the U.S. Physical
7 Attack is not a significant driver to the risk event.

8 Loss of Containment on Gas Distribution Main or Service

9 A physical attack could cause a loss of containment on Gas Distribution
10 Main or Service event. Fewer than one percent of about 30,000 loss of
11 containment events on gas distribution main or service that are expected to
12 occur annually are attributed as physical attack or intentional damage.

13 Loss of Containment on Gas Transmission Pipeline

14 Physical Attack could cause the Loss of Containment on Gas
15 Transmission Pipeline. Fewer than one percent of the loss of containment
16 events on gas transmission pipeline that are expected to occur annually are
17 attributed as physical attack or intentional damage.

18 Real Estate and Facilities Failure

19 Physical attacks could result in minor damage to a PG&E facility. The
20 minor damage outcome is identified to have only financial consequences.
21 Safety consequences related to a physical attack on a PG&E facility are
22 accounted for in the Employee Safety Incident risk.

23 **4. Changes Since the 2017 RAMP**

24 Physical Attack was not a 2017 RAMP risk.

25 **5. Mitigations and Controls 2020-2026**

26 **a. Planned Work**

27 PG&E has developed its detailed Corporate Security project plan for
28 2020. These Corporate Security projects are designed to mitigate the
29 Physical Attack risk. The projects are aligned to Prevent and Detect
30 categories.

Prevent

Activities designed to reduce the likelihood of a physical attack. These activities limit the impact of security risk-based events, reducing both frequency and consequence.

In 2020, PG&E is planning 15 mitigation projects primarily aligned to this domain. One of the Protect projects PG&E is proposing is a Visitor Management System that will manage risks against an untrusted external visitor.

Detect

Activities designed to timely identify and respond to physical attack incidents.

In 2020, PG&E is planning 13 mitigation projects primarily aligned to this domain. One of the Detect projects PG&E is planning is the Strategic Gap Closure for Elevated Sites under which PG&E will close security gaps at elevated sites to match Security Defined Protection Level (SDPL) standards.

Between 2021 and 2026, PG&E will implement two mitigations: Prevent (Mitigation 1) and Detect (Mitigation 2). The individual projects aligned to these two domains will be developed.

In addition to the mitigations planned for 2020-2026, PG&E will also implement a series of controls to manage Physical Attack risk. These controls include:

Control 1 – Physical Security: Responsible for emergency response, incident management, and collaborating with local management on physical security vulnerabilities and incident management;

Control 2 – Security Asset and Technology: Design and implement technology solutions to mitigate physical security risks; and

Control 3 – Corporate Security Control Center: Monitor and respond to physical security alarms, and provide security office deployment, and physical access control management.

b. Mitigations With RSE Scores

The forecast costs, RSE and risk reduction scores for the planned mitigation work are shown in Tables 21, 22, and 23 below.

TABLE 21
FORECAST COSTS
2020-2026 EXPENSE
(THOUSAND OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	2023	2024	2025	2026	Total
1	M1	Prevent	KZ	\$710	\$731	\$753	\$776	\$799	\$823	\$847	\$5,438
2	M2	Detect	KZ	474	488	502	518	533	549	565	3,629
3		Total		\$1,183	\$1,219	\$1,255	\$1,293	\$1,332	\$1,372	\$1,413	\$9,067

TABLE 22
FORECAST COSTS
2020-2026 CAPITAL
(THOUSAND OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	2023	2024	2025	2026	Total
1	M1	Prevent	3N	\$9,500	\$9,785	\$10,079	\$10,381	\$10,692	\$11,013	\$11,343	\$72,793
2	M2	Detect	3N	6,770	6,973	7,182	7,398	7,620	7,848	8,084	51,874
3		Total		\$16,270	\$16,758	\$17,261	\$17,779	\$18,312	\$18,861	\$19,427	\$124,667

TABLE 23
RSE AND RISK REDUCTION: PHYSICAL ATTACK – ALL MITIGATIONS

Line No.	Applicable RAMP Risk	Aggregated		Applied to RAMP Risk
		RSE ^(a)	Risk Reduction (NPV) ^(b)	Risk Reduction (NPV) ^(b)
1	<u>Mitigation: All Physical Attack Mitigations</u>	< 0.01	0.07	
2	Employee Safety Incident			0.02
3	Failure of Electric Distribution Network Assets			< 0.01
4	Failure of Electric Distribution Overhead Assets			0.03
5	Large Uncontrolled Water Release (Dam Failure)			< 0.01
6	Loss of Containment on Gas Distribution Main or Service			< 0.00
7	Loss of Containment on Gas Transmission Pipeline			0.01
8	Real Estate and Facilities Failure			0.01
9	Total	< 0.01	0.07	0.07

(a) See MWs included in the source document modeling package for information used to calculate the RSE.

(b) Information presented in terms of NPV to account for the discounting of benefits.

1 F. Records and Information Management

2 1. Overview

3 PG&E identified RIM as an enterprise risk because the risk of not having
4 an effective RIM program may result in the failure to construct, operate and
5 maintain a safe system and may lead to property damage and/or loss of life.
6 Managing records and information inconsistently can lead to an operational
7 incident or adverse business result if records that are needed cannot be
8 located in a timely fashion.

9 PG&E manages this risk in its Enterprise Records and Information
10 Management (ERIM) organization with significant input and support from the
11 IT Organization. The ERIM program has become an integral part of PG&E's
12 efforts to further strengthen its safety culture and to provide safe and reliable
13 gas and electric service to its customers. PG&E endeavors to further
14 reduce RIM risk by promoting more consistent records management across
15 the LOBs, promoting consistent, LOB RIM compliance and improving
16 operational efficiency.

PG&E organizes its mitigations and controls according to the ARMA International²⁰ principles for measuring program maturity. PG&E's ERIM Department structure is aligned with key functions needed to support PG&E's goal of reaching Information Governance Maturity Model (IGMM) Level 3 by 2022 and executing its supporting program roadmap. IGMM Level 3 is characterized by defined policies and procedures for meeting the Company's legal and regulatory requirements and is consistent with PG&E's renewed focus on compliance maturity.

2. Modeling

RIM impacts both the likelihood and consequence of a risk event.

RIM issues can impact the likelihood of a risk event if a record does not exist, is missing, is incorrect, or is not readily available. The risk model considers that there is a non-zero probability that records and information issues such as missing inspections records, incorrect construction documents, or asset information that is difficult to find, has the potential to increase the likelihood of a risk event occurring.

RIM issues can also impact the financial consequence of a risk event. To model the financial consequences, PG&E analyzed the potential financial consequences related to identifying and producing records after an event. To account for this financial consequence PG&E added a RIM multiplier that is adjusted according to the records maturity level of the LOB and that varies according to the financial consequences of the event itself (the model assumes that it would cost more to identify and produce records after a larger event). Penalties and fines are excluded from the financial consequences in the risk model.

3. Impacts to the 2020 RAMP Risks

RIM impacts 10 RAMP risks. Table 24 below maps the RIM cross-cutting factor to the applicable RAMP risks.

²⁰ ARMA International was previously known as the "Association of Records Managers and Administrators (ARMA)." ARMA International is a membership association for information management and information governance professionals.

TABLE 24
CROSS-CUTTING FACTOR SUMMARY: RIM

Line No.	RAMP Risk	Taxonomy	Risk Frequency, Percentage (Events/Year)	Percent of Risk
1	Employee Safety Incident	Consequence Impact/ Extracted from Existing	0.7 percent (4.2)	(a)
2	Failure of Electric Distribution Overhead Assets	Consequence Impact/ Extracted from Existing	0.02 percent (6)	(a)
3	Failure of Electric Distribution Network Assets	Consequence Impact/ Extracted from Existing	0.8 percent (0.01)	(a)
4	Large Overpressure Event Downstream of Gas Measurement and Control Facility	Consequence Impact/ Extracted from Existing	3 percent (0.2)	(a)
5	Large Uncontrolled Water Release (Dam Failure)	Consequence Impact	--	(a)
6	Loss of Containment on Gas Distribution Main or Service	Consequence Impact/ Extracted from Existing	0.1 percent (35)	(a)
7	Loss of Containment on Gas Transmission Pipeline	Consequence Impact/ Extracted from Existing	0.1 percent (0.001)	(a)
8	Motor Vehicle Safety Incident	Consequence Impact	--	(a)
9	Real Estate and Facilities Failure	Consequence Impact	--	(a)
10	Wildfire	Consequence Impact	--	(a)
(a) Percent of Risk was not calculated when the cross-cutting factor impacts consequences of risk events.				

4. Changes Since the 2017 RAMP

In the 2017 RAMP PG&E presented 13 mitigations and 4 controls it planned to implement during the 2017-2019 period. PG&E reported on the progress of the mitigations and controls in its 2020 GRC.²¹

Of the 13 mitigations PG&E proposed in its 2017 RAMP for the 2017-2019 period,²² 3 mitigations were implemented during that period and have become ongoing controls. The mitigation numbers referred to herein are the numbers assigned in the 2017 RAMP.

- Accountability Related Mitigations (M1B);

²¹ A.18-12-009, Exhibit (PG&E-7), p. 7-10 to p. 7-17.

²² PG&E's 2017 RAMP Report, p. 20-20, Table 20-3.

- Protection Related Mitigations (M5B); and
 - Enterprise Data Management System Migration (M8B)
- Seven mitigations will continue to be implemented during the 2020-2022 period.

- M3B – Compliance Related Mitigations;
- M4B – Retention Related Mitigations;
- M6B – Availability Related Mitigations;
- M7B – Implement RIM Governance for Content in Unstructured Data Repositories;
- M10 – Disposition Related Mitigations;
- M11 – Integrity Related Mitigations; and
- M13A – Implement RIM Governance for Content in Structured Data Repositories.

The scope of work for the three remaining has been modified due to scope overlap with other projects and the mitigations as described in the 2017 RAMP are no longer being pursued.

- M9B – Electronic Records Cleanup;
- M12A – Preservation Strategy and Implementation; and
- M14A – Map Work Processes that Generate Records.

PG&E implemented the four controls as described in the 2017 RAMP to manage records and information risk.²³ The four controls, which are aligned to the framework of the IGMM, are: Accountability Related Controls; Transparency Related Controls; Compliance Related Controls; and Retention Related Controls.

5. Mitigations and Controls 2020-2026

PG&E is proposing seven individual RIM mitigations. These seven mitigations are combined in the risk model into a single RIM mitigation.

a. Planned Work

The RIM mitigations that PG&E will implement during the 2020 RAMP period are:

²³ PG&E's 2017 RAMP Report, p. 20-14, Table 20-2.

M3C – Records Compliance Related Mitigations: These mitigations involve verification of compliance with applicable laws and other regulations issued by binding authorities, as well as with the ERIM program’s policy and standards.

M4C – Records Retention Related Mitigations: These mitigations involve maintaining records and non-records for an appropriate time, accounting for legal, regulatory, fiscal, and operational requirements.

M6C – Records Availability Related Mitigations: These mitigations involve maintaining records and information in a manner that allows for timely, efficient, and accurate retrieval of records.

M7C (2020-2022) and M7D (2023-2026) – Implement RIM

Governance for Content in Unstructured Data Repositories:

Implementing metadata, retention controls and retention trigger events in applications such as e-mail, SharePoint, and file shares to support efficient and accurate retrieval of needed information and the application of automated retention and disposition of non-records.

M10C – Records Disposition Related Mitigations: This mitigation involves providing secure and appropriate disposition for records and non-records that have met retention and are not otherwise subject to an applicable legal hold.

M11C – Records Integrity Related Mitigations: These mitigations improve the integrity of records and information to support authenticity and reliability.

M13C (2020-2022) and M13D (2023-2026) – Implement RIM

Governance for Content in Structured Data Repositories: This mitigation implements retention controls and identifies retention trigger events in database applications such as SAP, Customer Care and Billing, and other systems to dispose of records and information that are no longer needed.

PG&E will continue to use the four controls originally proposed in the 2017 RAMP to manage records and information risk during this RAMP period: C1 – Accountability Related Controls; C2 – Transparency Related Controls; C3 – Compliance Related Controls; and C4 – Retention Related Controls.

1 In addition, Records Protection Related Mitigations (formerly M5)
2 will become a control (Control 5) in 2020.

3 **b. Mitigations With RSE Scores**

4 The forecast costs, RSE and risk reduction scores for the planned
5 mitigation work are shown in Tables 25, 26, and 27 below.

TABLE 25
FORECAST COSTS
2020-2026 EXPENSE
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	2023	2024	2025	2026	Total
1	M3C	Records Compliance Related Mitigations	AB	\$2	–	–	–	–	–	–	\$2
2	M4C	Records Retention Related Mitigations	AB/JV	23	\$889	\$1,149	\$383	\$374	\$384	\$408	3,611
3	M6C	Records Availability Related Mitigations	AB/JV	1,321	646	660					2,627
4	M7C/ M7D	Implement RIM Governance for Content in Unstructured Data Repositories	AB/JV	3,350	5,657	5,633	5,557	2,296	2,474	1,376	26,343
5	M10C	Records Disposition Related Mitigations	AB/JV	421	860	610	650	500	250	–	3,291
6	M11C	Records Integrity Related Mitigations	AB/JV	1,190	863	897	1,072	802			4,823
7	M13C/ M13D	Implement RIM Governance for Content in Structured Data Repositories	AB/JV								
8		Total		220	1,767	2,507	2,572	2,227	1,979	2,097	13,370
				\$6,527	\$10,682	\$11,456	\$10,235	\$6,199	\$5,087	\$3,881	\$54,067

TABLE 26
FORECAST COSTS
2020-2026 CAPITAL
(THOUSANDS OF DOLLARS)

Line No.	Mit. No.	Mitigation Name	MWC	2020	2021	2022	2023	2024	2025	2026	Total
1	M6C	Records Availability Related Mitigations	2F	\$279	-	-	-	-	-	-	\$279
2	M7C/ M7D	Implement RIM Governance for Content in Unstructured Data Repositories	2F	1,446	-	-	-	-	-	-	1,446
3	M13C/ M13D	Implement RIM Governance for Content in Structured Data Repositories	2F	-	\$100	\$1,000	\$1,000	\$1,000	\$1,000	\$1,000	5,100
4		Total		\$1,725	\$100	\$1,000	\$1,000	\$1,000	\$1,000	\$1,000	\$6,825

TABLE 27
RSE AND RISK REDUCTION: RIM- ALL MITIGATIONS

Line No.	Applicable RAMP Risk	Aggregated		Applied to RAMP Risk
		RSE ^(a)	Risk Reduction (NPV) ^(b)	Risk Reduction (NPV) ^(b)
1	<u>Mitigation: All RIM Mitigations</u>	6.3	139.3	–
2	Employee Safety Incident	–	–	0.1
3	Failure of Electric Distribution Network Assets	–	–	< 0.1
4	Failure of Electric Distribution Overhead Assets	–	–	1.0
5	Large Overpressure Event Downstream of Gas M&C Facility	–	–	< 0.1
6	Large Uncontrolled Water Release (Dam Failure)	–	–	< 0.1
7	Loss of Containment on Gas Distribution Main or Service	–	–	0.3
8	Loss of Containment on Gas Transmission Pipeline	–	–	0.2
9	Motor Vehicle Safety Incident	–	–	< 0.1
10	Real Estate and Facilities Failure	–	–	0.6
11	Wildfire	–	–	137.1
12	Total	6.3	139.3	139.3

(a) See MWs included in the source document modeling package for information used to calculate the RSE.

(b) Information presented in terms of NPV to account for the discounting of benefits.

1 G. Seismic

2 1. Overview

3 Seismic events can be a significant driver of failure in LOB assets.

4 Seismic events contribute to the likelihood of asset failure events and to the

5 associated safety, reliability, and financial consequences of those events.

6 PG&E's service territory is in an active seismic zone and as such PG&E

7 assets from all LOBs are subjected to potentially damaging ground shaking

8 and related ground failure that ranges from minor to catastrophic from a

9 single event. Damaging effects may occur without warning over a large

10 geographic area and impact PG&E's ability to serve its customers and

11 respond to the event. The greater San Francisco (SF) Bay Area is

12 considered to have the highest seismic risk in PG&E's service territory due

13 to the existence of many active faults located in highly-populated urban

14 areas with dense PG&E infrastructure. Extensive damage to non-PG&E

15 infrastructure and supporting business and suppliers will impact restoration

16 efforts.

1 PG&E studies seismic hazard developments in its Geosciences
2 Department (Geosciences). Geosciences is part of the Generation
3 organization and provides services across PG&E's LOBs. Geosciences was
4 developed as a department in the 1980s as part of the Long-Term Seismic
5 Program (LTSP) focusing on geohazard issues at the DCP. Currently
6 Geosciences is involved in and supports geohazard risk assessments efforts
7 across the enterprise and all the LOBs including:

- 8 • The DCP LTSP;
- 9 • The Hydro Facility Safety Program;
- 10 • Evaluating seismic risk at all sites;
- 11 • The Gas Transmission Pipeline Geohazards Program;
- 12 • Electric transmission tower evaluations and support projects;
- 13 • Evaluating seismic risk in PG&E's facilities;
- 14 • The EP&R earthquake exercise, post-event reconnaissance and
15 Dynamic Automated Seismic Hazard (DASH) program that functions as
16 the company earthquake alert and initial response tool; and
- 17 • Earthquake science and learning from earthquakes ground motion
18 model development and support including collaborations with the
19 United States Geological Survey (USGS), national laboratories, industry
20 working groups and many leading academic institutions advancing the
21 seismic knowledge and implementation for risk reduction.

22 Focused seismic risk assessment and reduction activities are managed
23 through the Geosciences Integrated Seismic Risk Management Program
24 (ISRMP) that includes application of various tools to quantify seismic risk.
25 The ISRMP enables progressive quantification of seismic hazard.
26 Geosciences uses a tool called System Earthquake Risk Assessment
27 (SERA) to analyze seismic risk. SERA is a commercial platform that has
28 been modified for PG&E's applications to evaluate the geographically
29 distributed electric and gas linear assets. SERA is used by utilities across
30 the western U.S. and Canada, helping to standardize seismic hazard
31 analyses.

32 The SERA platform includes fragility models for system components that
33 have been developed from both California-specific and worldwide data from
34 past earthquakes. The platform evaluates system performance from both

1 ground shaking and ground failure (e.g., surface fault rupture, liquefaction,
2 landslides) based on geohazard maps and earthquake scenarios. To test
3 system performance PG&E models a number of plausible earthquake
4 scenarios. Examples of earthquake scenarios include large earthquakes on
5 numerous active faults which in the SF Bay Area region include the
6 San Andreas, Hayward, and Rogers Creek faults.

7 Until 2019, SERA was used to analyze seismic performance of the
8 electric system. At the end of 2019 Geosciences, with help and support
9 from the Gas Organization, engaged the SERA vendor to incorporate
10 PG&E's entire gas underground piping network (transmission and
11 distribution) into the SERA platform. After this work is complete,
12 Geosciences will incorporate the balance of the key above ground gas
13 infrastructure into the model. The resulting integrated electric and gas
14 system model covers the entire PG&E service territory and will permit
15 evaluation of cross-cutting impacts to these LOBs.

16 The current focus of the ISRMP is to prioritize seismic risk assessment
17 to assets in the greater SF Bay Area and then extend evaluations through
18 the rest of PG&E's service territory. This strategy is informed by the USGS'
19 findings that the seismic hazard and the consequential impact in the
20 SF Bay Area is highest in this region and therefore represents the greatest
21 seismic risk.

22 **2. Modeling**

23 The Seismic cross-cutting factor impacts both the likelihood of a risk
24 event occurring and the consequences of a risk event. Seismic is a risk
25 driver for the Large Uncontrolled Water Release (Dam Failure), Real Estate
26 and Facilities Failure risks, Electric Operations risks, and Loss of
27 Containment on Gas Transmission Pipeline and Distribution Main or
28 Service risks.

29 As described above, PG&E modeled this cross-cutting factor
30 using two tools: SERA and DASH. SERA is used to evaluate the
31 geographically-distributed electric and gas linear assets. DASH is an
32 earthquake response tool that evaluates and notifies the LOB about
33 potential system impacts.

PG&E evaluated the likelihood of a seismic event occurring by modeling three plausible earthquake scenarios in the SF Bay Area. The consequence of a seismic event is evaluated in terms of how a seismic event would impact gas and electric assets.

Outputs from the modeling included frequency of an earthquake and the costs of asset failures due to the seismic event. PG&E also considered how much worse asset failure could be following an earthquake compared to a routine asset failure. The risk model applies a consequence multiplier to risk events to describe this more severe outcome.

3. Impacts to the 2020 RAMP Risks

Seismic hazard impacts seven RAMP risks. A seismic event can result in safety, reliability and financial consequences. Table 28 and 29 below maps the Seismic cross-cutting factor to the applicable RAMP risks.

TABLE 28
CROSS-CUTTING FACTOR DRIVERS SUMMARY: SEISMIC

Line No.	RAMP Risk	Taxonomy	Risk Frequency Percentage (Events/Year)	Percent of Risk
1	Failure of Electric Distribution Overhead Assets	Added Frequency	0.2 percent (41)	12 percent
2	Failure of Electric Distribution Network Assets	Added Frequency	0.8 percent (0.08)	1 percent
3	Large Uncontrolled Water Release (Dam Failure)	Added Frequency	10 percent (0.0014)	6 percent
4	Loss of Containment on Gas Distribution Main or Service	Added Frequency	0.3 percent (86)	39 percent
5	Loss of Containment on Gas Transmission Pipeline	Added Frequency	11 percent (0.2)	27 percent ¹
6	Real Estate and Facilities Failure	Added Frequency	62 percent (5)	99.8 percent
7	Wildfire	Added Frequency	<0.01 percent (0.01)	1 percent

TABLE 29
CROSS-CUTTING FACTOR OUTCOME SUMMARY: SEISMIC

Line No.	RAMP Risk	Outcome	Percent Frequency	Percent Risk
1	Failure of Electric Distribution Overhead Assets	Asset Failure/Seismic Scenario	0.2 percent	12 percent
2	Failure of Electric Distribution Network Assets	Asset Failure/Seismic Scenario	1 percent	1 percent
3	Loss of Containment on Gas Distribution Main or Service	Major – Seismic	<0.01 percent	38 percent
4	Loss of Containment on Gas Distribution Main or Service	Minor – Seismic	0.3 percent	0.3 percent
5	Loss of Containment on Gas Transmission Pipeline	Seismic-Rupture	9 percent	27 percent
6	Loss of Containment on Gas Transmission Pipeline	Seismic-Leak	1.6 percent	0.01 percent
7	Real Estate and Facilities Failure	Seismic-Minor	50 percent	22 percent
8	Real Estate and Facilities Failure	Seismic-Moderate	8 percent	28 percent
9	Real Estate and Facilities Failure	Seismic-Strong	2 percent	24 percent
10	Real Estate and Facilities Failure	Seismic-Severe	1 percent	25 percent
11	Wildfire	Seismic-RFW-Catastrophic Fire	<0.01 percent	0.7 percent
12	Wildfire	Seismic-Non-RFW-Catastrophic Fire	<0.01 percent	0.3 percent

Real Estate and Facilities Failure

Seismic risk accounts for 99.8 percent of the Real Estate and Facilities Failure risk and it is the key driver of this risk event. To model this risk PG&E conducted an initial sample study of 50 higher risk facilities primarily in the SF Bay Area, considering key facility parameters (e.g., age, type, occupancy, location, business functional criticality, etc.). Going forward, PG&E plans to conduct a more detailed assessment of the building portfolio in the SF Bay Area. PG&E will prioritize the facilities in the SF Bay Area due to high concentration of assets in this highly populated and seismically active zone.

Large Uncontrolled Water Release (Dam Failure)

Seismic is a risk driver of the Large Uncontrolled Water Release risk event and accounts for 6 percent of the total risk.

Loss of Containment on Gas Distribution Main or Service and Loss of Containment on Gas Transmission Pipeline

The seismic cross-cutting factor is considered a driver for these risk events. Seismic risk accounts for 27 percent of the Gas Transmission risk and 39 percent of the Gas Distribution risk.

Failure of Electric Distribution Overhead Assets, Failure of Electric Distribution Network Assets and Wildfire

Seismic is a cross-cutting factor for the failure of Electric Distribution Overhead and Network Assets risks and Wildfire risk. The seismic risk accounts for 12 percent of the Electric Distribution Overhead Assets risk, 1 percent of the Electric Distribution Network Assets risk, and 1 percent of the Wildfire risk.

In addition to the RAMP risks, seismic risk is associated with other PG&E safety risks.²⁴ Seismic risk associated with the nuclear operation at DCPD was fully developed in a Seismic Probabilistic Risk Assessment (SPRA) under the rules mandated by the Nuclear Regulatory Commission (NRC). The SPRA was updated and submitted to the NRC in 2018, and incorporated hazard input from the LTSP which was vetted by a formal Senior Seismic Hazard Advisory Committee process. NRC has reviewed and accepted the SPRA as meeting their requirements as of January 2019. This SPRA is being maintained and managed under the LTSP Program. The seismic risk was determined to be approximately 32 percent of the total risk (Core Damage Frequency)

PG&E will continue conducting seismic risk evaluations for all RAMP assets and, as appropriate, will also conduct seismic risk evaluations for non-RAMP assets as well.

4. Changes Since the 2017 RAMP

Seismic was not a 2017 RAMP risk element.

²⁴ Only PG&E's Top 12 safety risks are designated as RAMP risks in the 2020 RAMP filing. PG&E describes the additional safety risks in Chapter 19, "Other Safety Risks."

5. Mitigations and Controls 2020-2026

a. Planned Work

The ISRMP started in 2019 to more consistently assess the seismic hazard and seismic risk for all LOBs. As its first priority during this RAMP period, PG&E will focus its seismic risk mitigation efforts in the SF Bay Area for electric, gas, and real estate (facilities) assets. Going forward, the ISRMP will develop and maintain seismic risk quantifications by focusing on key elements such as:

- Seismic source characterization, regional geology;
- Site specific and distributed system ground motion models;
- Ground failures such as landslide, liquefaction and fault crossings;
- Asset health as an input to more accurately quantify seismic risk; and
- Logic modeling developments/enhancements.

This program is modeled after the LTSP that has been successfully used at the DCPD for more than 30 years. Seismic risk analysis for gas and electric assets includes three viable and severe scenarios: the Hayward Fault at the foot of the East Bay hills; the San Andreas Fault that extends through the SF Peninsula; and the Rogers Creek Fault that extends from the Bay through Santa Rosa. Future updates will expand to consider total hazard from other faults.

During the 2020 RAMP period Geosciences will work with LOB asset owners and risk managers to develop the means to consistently quantify seismic risk and to propose risk mitigations tailored to those LOB assets. To develop the seismic mitigations for the different asset types, Geosciences and the LOB teams will work together to analyze asset failure modes and asset-specific risks.

PG&E will also continue to update and refine information in SERA to address uncertainties in modeling results based on earthquake experience learnings, research, and collaborations with leading earthquake academia and government agencies, including the California Energy Commission. This continual improvement process will lead to more granular system performance modeling to better estimate damages from future earthquakes.

1 In addition to system damage assessment tools such as SERA,
2 PG&E has also developed a proprietary earthquake response tool called
3 DASH. The DASH tool collects seismic instrument records and ground
4 shaking maps from the USGS to evaluate and notify of potential system
5 impacts within a 15-30 minute timeframe after an earthquake. The
6 DASH tool compares ground shaking maps against simplified damage
7 models specific to each LOB and produces reports of potential damage
8 that the business uses to inform and prioritize inspections and
9 responses. The DASH tool also includes a continuous improvement
10 element that includes annual updates of infrastructure inventories and
11 tool maintenance/reliability improvements.

12 In the 2023 GRC PG&E will propose that the ISRMP and LTSP will
13 be combined into a single program for the enterprise.

14 **b. Mitigations with RSE Scores**

15 Seismic risk assessment is a collaborative process between ISRMP
16 and the LOBs. It is a foundational program that quantifies the potential
17 seismic risk for operations assets. The LOBs develop the mitigations to
18 address this risk.

19 While the ISRMP is not proposing seismic mitigations in the 2020
20 RAMP, PG&E will maintain its LTSP and ISRMP Program for assessing
21 seismic risk.

22 **H. Skilled and Qualified Workforce**

23 **1. Overview**

24 PG&E's Human Resources (HR) Department develops and delivers
25 technical, leadership and other training that helps to maintain a skilled, safe
26 and qualified workforce. Failing to maintain a Skilled and Qualified
27 Workforce (SQWF) is one of PG&E's top cross-cutting factor factors than
28 can impact safety.

29 PG&E Academy develops and updates courses based on priorities
30 established by the LOBs and to reflect new or changing regulations and
31 business procedures. In 2019 PG&E Academy delivered more than
32 5,300 instructor-led training sessions. That translates to 69,570 student
33 days of training (one student day equals one student in one day of training).

As a part of PG&E's Apprenticeship training programs, employees also are required to complete on-the-job training in areas such as electric operations, gas operations, safety and compliance, and leadership. PG&E Academy also offers web-based technical training courses to employees and contractors. These courses cover a wide range of disciplines, from beginner to advanced levels, across many technical specialties, including compliance, emergency response, systems O&M, and hazardous energy control. PG&E also offers 31 state-certified apprentice programs.

PG&E's goal is to ensure that training and qualifications for high consequence work is current and applied to the workforce in a systematic and repeatable way. High-risk work includes activities such as: excavation and trenching beyond 4 feet; heavy equipment operation; utility tree trimming, clearance work and vegetation management; general construction activities; welding and/or hot tapping of gas lines; and fault protection/grounding.²⁵

PG&E uses the "human performance"²⁶ driver from the RAMP asset-based risks to establish the baseline for the SQWF risk because this driver captures incidents or events due to a person incorrectly performing a task. Recognizing that not all mistakes are due to a lack of skills or qualifications, PG&E used skills assessment data along with SME judgement to establish the proportion of incorrect operations likely attributable to an employee not having the necessary skills and qualifications.

2. Modeling

The SQWF cross-cutting factor impacts the frequency of a risk event such that a portion (expressed as a percentage in the model) can be attributed to a workforce that does not have the appropriate training for the work they are performing. SQWF is a sub-driver to the Human Performance and Incorrect Operations drivers in Electric Operations and Gas Operations respectively.

²⁵ See PG&E's Contractor Safety Program Risk Matrix that is aligned to the PG&E Utility Standard SAFE-3001S.

²⁶ This driver is also referred to as Incorrect Operations.

To estimate the impact that a lack of training can have on a risk event, PG&E reviewed the results of the skills tests maintained by the HR organization for the Gas and Electric Organizations. Each failed skilled assessment is assumed to be an indicator of a risk event. For example, if there is a one percent failure rate on a Gas Organization skills assessment, the risk model applies that one percent to the increased likelihood that a Gas Operations risk event could occur due to Incorrect Operations.

3. Impacts to the 2020 RAMP Risks

SQWF impacts six RAMP risks. Table 30 below maps the SQWF cross-cutting factor to the applicable RAMP risks.

**TABLE 30
CROSS-CUTTING FACTOR SUMMARY: SQWF**

Line No.	RAMP Risk	Risk Modeling Taxonomy	Risk Frequency Percentage (Events/Year)	Percent of Risk
1	Employee Safety Incident	Extracted from Existing	3 percent (19)	3 percent
2	Failure of Electric Distribution Network Assets	Extracted from Existing	2 percent (0.2)	4 percent
3	Failure of Electric Distribution Overhead Assets	Extracted from Existing	0.1 percent (15)	0.1 percent
4	Large Overpressure Event Downstream of Gas Measurement and Control Facility	Extracted from Existing	0.5 percent (0.03)	1 percent
5	Loss of Containment on Gas Distribution Main or Service	Extracted from Existing	<0.01 percent (2)	<0.01 percent
6	Loss of Containment on Gas Transmission Pipeline	Extracted from Existing	<0.01 percent (0.0001)	<0.01 percent

4. Changes Since the 2017 RAMP

In the 2017 RAMP PG&E proposed eight controls focused on rigorous training programs for new and existing employees, and ongoing assessments of specific skills and qualifications. Together, these controls help to reduce the chance that a worker will perform tasks for which they are not qualified. PG&E continues to implement these controls to mitigate the SQWF risk.

In the 2017 RAMP PG&E proposed 13 mitigations focused on qualifications and training needed to safely perform high consequence work. The mitigations were designed to identify which workers are expected to perform high consequence work through qualifications catalogs and training profiles in order to match the right workers with the right training. The proposed mitigations fell into three categories:

- 1) Foundational: Work that will improve PG&E's data and information in order to identify all high consequence work and refine risk model inputs related to consequences and frequencies. PG&E completed nine of the eleven foundational mitigations. One mitigation (M10 – Qualification and Tasks Loaded into HR Systems) was incorporated into Control 1 (Gas Operator Qualifications Program). One mitigation (M11 – IT Solution for Curriculum Management) was cancelled because PG&E has a process in place and did not need to pursue this additional work.
- 2) Technical Competence: Improving access to technical procedures, standards and job aids. PG&E proposed and completed one mitigation (M13 – Training Substation in Livermore) in 2018.
- 3) Qualification Verification: Increase the visibility into and use of qualifications when scheduling and assigning work. PG&E proposed and completed one mitigation (M12 – Applicant Installer On-Boarding Process) in 2019.

5. Mitigations and Controls 2020-2026

a. Planned Work

The SQWF mitigations and controls planned for the 2020 RAMP period are focused on Gas Operations and Electric Operations employees since the SQWF cross-cutting factor is a driver of gas and electric risks. The mitigations planned for this period were initially proposed in PG&E's 2017 RAMP.²⁷ PG&E completed two mitigations (M14A and M21)²⁸ proposed in the 2017 RAMP.

²⁷ PG&E's 2017 RAMP Report, p. 15-10, Table 15-2 (M1A – Safety Management System) and p. 21-24, Table 21-4 (all other mitigations).

²⁸ PG&E's 2017 RAMP Report, p. 21-24, Table 21-4. Note, In the 2017 RAMP (I.17-11-003) this mitigation was referred to, in error, as both M20 (p. 21-23) and M21 (p. 21-24, Table 21-4).

PG&E is planning five mitigations:

M1B (Employee Safety Incident) – Enterprise Safety Management

System (ESMS): PG&E will identify and implement a new enterprise tool in lieu of the “Expand Business Process Index” mitigation (M1B) proposed in the 2017 RAMP for the 2020-2022 period. The project will be led by the Enterprise Health and Safety organization. The ESMS is a series of capabilities (people, process, and technology systems) required to define, plan, implement, and continuously improve workforce safety. It includes an Enterprise Management of Change (EMOC) process to identify, understand, and evaluate the risks and hazards when changes are made to facilities, operations, or personnel to assure they are properly controlled. When a standard or procedure changes, or there is new equipment introduced in the field, the EMOC process will indicate that the associated training needs to be updated accordingly. The EMOC system database will provide support for tracking changes to other controls and mitigations.

M15 – Enhance Technical Information Library (TIL) and Guidance Document Library (GDL) (Technical Competence): The TIL and GDL

are online repositories for PG&E’s policies, standards, procedures, and guidance documents. PG&E’s employees refer to these documents whenever they are completing a new or unfamiliar task or procedures. The planned enhancements include: improve ease of use through developing a standard, mobile friendly, format for new documents and reformatting of existing documents; improve search engine/function with key words and task names; and create the data and capability to link a specific task from the work scheduling system to the appropriate procedure or job aid.

M17 – Work Scheduling Integration with Qualifications

(Qualification Verification): Automate the verification of qualifications by integrating PG&E's SAP HR system, where qualifications are tracked, with the work scheduling system. This will allow for matching work to specific employee qualifications. The Gas Operations organization is in the process of implementing a solution to integrate work scheduling and qualification verification. Electric Operations is evaluating the best way to move forward to improve their processes to management certifications and the scheduling of work.

M18 – Qualification Cards for Electric Employees: Qualification cards contain information about the qualification status for each employee and are scanned at the yard or job site, before work begins. Scanning the card before work begins reduces the risk that an employee will be assigned a task for which they are not qualified. PG&E has issued a request for proposal for a vendor to implement a new qualification card system that will include employees in the operating LOBs.

M19 –Electric Review and Update Expected Job Functions: This foundational mitigation enhances the details about the specific qualifications and skills required for Electric tasks, similar to the details tracked for Gas Operations and Nuclear Operations. This mitigation will improve the qualifications documentation for jobs classifications, specific positions and tasks performed.

PG&E will continue to perform Controls 1 through 8 as described in the 2017 RAMP.²⁹ They are:

- C1/C2 – Gas Operator Qualifications Program and Employee Knowledge and Skills Program;
- C3 – Job Profile, Job Description/Profiling Process;
- C4 – Technical Training Profiling/Governance;
- C5 – Standards and Procedures Review Process;
- C6 – Apprentice Training;
- C7 – Training Effectiveness Monitoring; and

²⁹ PG&E's 2017 RAMP Report, p. 21-9 to p. 21-12, and Table 21-2.

- C8 – Display Training in the Learning Management System.

PG&E completed work on two mitigations proposed in the 2017 RAMP and is transitioning those activities from mitigations to controls:

C9 (M20 in the 2017 RAMP³⁰) – Improve, Collect, and Analyze Data

Related to Skill Degradation: This control was proposed as a mitigation in the 2017 RAMP (M20) for the 2020-2022 period. This mitigation is complete for the Electric Organization. PG&E's Electric Operations organization used a third party to analyze skill degradation timeframes for various skills and tasks. This data was averaged to result in a 3-year re-assessment and re-training cycle for Electric Field employees. The majority of Gas Operations work is strictly regulated by the Department of Transportation and employees must re-qualify for specific tasks on regulatory intervals. Most tasks are requalified every three years though certain tasks are requalified more often (e.g., welders must be requalified every six months). If an employee fails a re-qualification, they are remediated, but if they fail a second time they are not allowed to do that type of work.

C10 (M14A in the 2020 RAMP) – On the Job Support – Mobile

Technology for Foreman and Crew Leads: This control was proposed as a mitigation in the 2017 RAMP (M14A) for the 2020-2022 period. PG&E completed the work described in the 2017 RAMP. Going forward, this activity will consist of making improvements and enhancements to the mobile technology and available documentation.

b. Mitigations With RSE Scores

The ESMS mitigation is discussed in greater detail in the Employee Safety Incident risk chapter. The RSE and risk reduction scores are shown in Table 31 below.

³⁰ In PG&E's 2017 RAMP Report this mitigation was referred to, in error, as both M20 (p. 21-23) and M21 (p. 21-24, Table 21-4).

TABLE 31
RSE AND RISK REDUCTION: SQWF

Line No.	Mit. No.	Applicable RAMP Risk	Aggregated		Applied to RAMP Risk
			RSE ^(a)	Risk Reduction (NPV) ^(b)	Risk Reduction (NPV) ^(b)
1	M1B	<u>Mitigation: ESMS</u>	12.9	29.6	–
2		Employee Safety Incident	–	–	29.6
3		Total	12.97	29.6	29.6

(a) See MWs included in the source document modeling package for information used to calculate the RSE.

(b) Information presented in terms of NPV to account for the discounting of benefits.

- 1 PG&E is not estimating costs for the other four mitigations described
- 2 above in this RAMP due to uncertainties around the scope work.
- 3 Therefore, PG&E cannot provide RSEs for these programs. PG&E will
- 4 continue to refine the scopes of the proposed mitigations and will
- 5 provide cost forecasts in the 2023 GRC.

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 21
RISK ASSESSMENT AND MITIGATION PHASE
STEADY STATE OPERATIONS

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 21
RISK ASSESSMENT AND MITIGATION PHASE
STEADY STATE OPERATIONS

TABLE OF CONTENTS

A. Introduction.....	21-1
1. 2020 General Rate Case Settlement Agreement: Principles for Asset Replacement.....	21-1
2. Definition	21-1
B. Gas Operations	21-2
1. Gas Operations Asset Management Strategy Overview	21-2
2. Gas Operations Asset Management Programs.....	21-2
a. Gas Storage	21-3
1) Storage Well Refurbishments.....	21-4
b. Compression and Processing.....	21-5
1) Compressor Replacements.....	21-6
2) Compressor Unit and Station Control Replacements.....	21-6
c. Transmission Pipe	21-7
1) Vintage Pipe Replacement Program	21-8
2) Other Pipeline Safety and Reliability Pipe Replacements	21-8
d. Measurement and Control	21-8
1) Regulator Station Rebuilds.....	21-9
2) Regulator Station Component Replacements	21-10
e. Distribution Mains and Services	21-10
1) Distribution Pipeline Replacement Programs	21-11
3. How Gas Operations Uses Risk Prioritization to Identify Equipment for Replacement.....	21-11
C. Electric Operations	21-12
1. Electric Operations Asset Management Strategy Overview.....	21-12

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 21
RISK ASSESSMENT AND MITIGATION PHASE
STEADY STATE OPERATIONS

TABLE OF CONTENTS
(CONTINUED)

2. Electric Operations Asset Management Programs	21-13
a. Distribution Line Overhead	21-14
1) Pole Replacements	21-14
2) Overhead Conductor Replacement.....	21-15
b. Substation.....	21-16
c. Distribution Line Underground	21-18
1) Primary Cable Replacements.....	21-19
2) Load Break Oil Rotary Switch Replacements.....	21-20
d. Distribution Network	21-21
1) Targeted Replacements of Network Transformer and Network Protectors.....	21-21
2) Network Cable Replacement and Switch Installations	21-22
3. How Electric Operations Uses Risk Prioritization to Identify Equipment for Replacement.....	21-22
D. Generation.....	21-24
1. Generation Asset Management Strategy Overview	21-24
2. Generation Asset Management Programs	21-24
a. Hydroelectric.....	21-24
b. Fossil and Solar	21-24
c. Nuclear	21-25
3. How Power Generation Uses Risk Prioritization to Identify Equipment for Replacement.....	21-25
a. Hydroelectric Asset Management Practices and Programs.....	21-26
1) Hydroelectric Asset Management Practices.....	21-26

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 21
RISK ASSESSMENT AND MITIGATION PHASE
STEADY STATE OPERATIONS

TABLE OF CONTENTS
(CONTINUED)

2) Hydroelectric Asset Management Programs	21-28
b. Fossil Asset Management Practices and Programs	21-31
1) O&M Standard	21-31
2) Fossil Generation HESSP Standard	21-32
c. Nuclear Asset Management Practices and Programs	21-32
1) Equipment Reliability Process	21-33
2) Equipment Reliability Classification.....	21-34

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 21
RISK ASSESSMENT AND MITIGATION PHASE
STEADY STATE OPERATIONS

A. Introduction

1. 2020 General Rate Case Settlement Agreement: Principles for Asset Replacement

The 2020 General Rate Case (GRC) Settlement Agreement (Settlement Agreement)¹ includes the following provision (Settlement Agreement, Section 5.1):

PG&E should strive for reasonable rates of steady state replacement, consistent with risk-informed decision making, for crucial operating equipment necessary to provide safe and reliable service. Such steady state replacement includes pro-active replacement of an asset prior to in-service failure when warranted based on risk and engineering analysis that considers vintage, material properties, environmental conditions, life-extension maintenance practices, and any other relevant parameters. PG&E should strive to reduce post-failure replacement for assets where failure can result in unreasonable safety or cost impacts. PG&E will evaluate and explain in its next Risk Assessment and Mitigation Phase (RAMP) Report how its existing capital asset maintenance and replacement activities, including both pro-active and post-failure replacement, and costs thereof, promote cost-effective and risk informed steady state replacement. In those instances where PG&E's proposals in its next RAMP Report do not follow the principle of steady state replacement, PG&E should explain the basis for PG&E's proposals.

In this chapter, Pacific Gas and Electric Company (PG&E or the Company) discusses its risk-informed approach to pro-active asset replacement for each of its operating lines of business: Gas Operations, Electric Operations, and Power Generation.

2. Definition

PG&E defines "steady state replacement," as described in the Settlement Agreement, to include ongoing replacements and pro-active

¹ The Settlement Agreement was filed by PG&E and Settling Parties on December 21, 2019 with the California Public Utilities Commission (CPUC or Commission) in Docket No. Application (A.) 18-12-009.

1 replacement of an asset prior to in-service failure when warranted based on
 2 risk and engineering analysis that considers vintage, material properties,
 3 environmental conditions, life-extension maintenance practices, and any
 4 other relevant parameters.

5 **B. Gas Operations**

6 **1. Gas Operations Asset Management Strategy Overview**

7 Gas Operations (GO) includes the asset families listed below as part of
 8 PG&E's Asset Management (AM) framework under the Publicly Available
 9 Specification 55/International Organization for Standardization 55001
 10 standards. Each asset family has an AM plan that provides an assessment
 11 of the condition of the asset, risk mitigations, strategic objectives and asset
 12 maintenance for the lifecycle of the assets. The asset family structure
 13 allows PG&E to drive risk management strategies consistently within and
 14 among the GO asset families. The GO asset families are as follows:

- 15 a) Gas Storage
- 16 b) Compression and Processing (C&P)
- 17 c) Transmission Pipe
- 18 d) Measurement and Control (M&C)
- 19 e) Distribution Mains and Services (DMS)
- 20 f) Customer Connected Equipment
- 21 g) Liquefied Natural Gas/Compressed Natural Gas
- 22 h) Asset Data

23 The discussion below focuses on those GO asset families with ongoing,
 24 proactive replacement programs for aging and/or deteriorating assets in the
 25 field. These include Gas Storage; C&P; Transmission Pipe; Measurement
 26 and Control; and Distribution Mains and Services.

27 **2. Gas Operations Asset Management Programs**

28 GO plans, designs, installs, maintains, and replaces the physical assets
 29 of the gas transmission and distribution system so that each component
 30 operates in a safe and reliable manner. GO has proactive replacement
 31 programs for the following key assets:

- 32 • Gas Storage
- 33 – Storage Wells

- 1 • Compression and Processing
- 2 – Compressor Units
- 3 • Transmission Pipe
- 4 – Transmission Pipeline
- 5 • Measurement and Control
- 6 – Distribution Regulator Stations
- 7 – High Pressure Regulator (HPR) Stations
- 8 • Distribution Mains and Services
- 9 – Distribution Mains

10 PG&E also replaces other gas assets, such as valves, distribution services,
 11 Supervisory Control and Data Acquisition equipment, and regulator station
 12 components, as identified through maintenance programs.

13 Asset replacement is the most effective mitigation for certain risk drivers.
 14 For example, the Vintage Pipe Replacement Program for transmission pipe
 15 that replaces pipe with vintage fabrication and construction defects
 16 interacting with land movement, is a key mitigation for threats leading to
 17 Loss of Containment (LOC) and Loss of Service events. However, asset
 18 replacement is not the most effective mitigation for other risk drivers such as
 19 third party/mechanical damage since the asset is in the ground and a third
 20 party may dig into it. In such a case, other layers of controls are built around
 21 it such as the Public Awareness program to reduce dig-ins, and In-Line
 22 Inspection (ILI) to detect any latent damage.

23 This section includes a description of the key steady state replacement
 24 programs by asset family and further explains how the replacement
 25 programs are associated with the top Company risks.

26 **a. Gas Storage**

27 For the storage asset family, AM is focused on risk integrity
 28 management via assessment, rework, and refurbishments of wells
 29 within the storage fields. As part of the lifecycle management of the
 30 storage assets, wells are evaluated for their need and usefulness. If a
 31 well is determined to be no longer needed and useful, the well is
 32 plugged and abandoned (permanent removal of the asset from service),
 33 which includes closure of the wellbore, reclamation of the surface area

1 and possible modifications to the remaining facilities and
2 equipment removal.

3 **1) Storage Well Refurbishments**

4 The Storage Well Inspection Program is a key mitigation for the
5 LOC at Natural Gas Storage Well or Reservoir risk and addresses
6 several drivers including corrosion, erosion, incorrect operations,
7 third party/ mechanical damage, and weather related/outside forces
8 thereby reducing the likelihood of the risk event occurring due to
9 these drivers.

10 The mitigation pace is generally determined by using the
11 prioritized risk based ranking of wells for consideration for
12 assessments and rework projects. The factors that are taken into
13 consideration for the risk-based prioritization include condition,
14 years in service, and component and well performance. Work
15 execution schedule for remedial work also considers ability to
16 effectively and efficiently conduct work, opportunity to minimize
17 mobilization efforts as well as station outages.

18 Well entry work includes: integrity logging (inspections);
19 pressure testing; and replacement and repair of wellheads,
20 downhole safety valves, up-hole safety valves, compromised
21 tubulars, and other associated well auxiliary equipment. The near
22 and long term focus for Storage is as follows:

23 Near-term: PG&E is continuing with its plan to complete well
24 integrity baseline assessments, repair or replace gravel pack and
25 liner, and retrofit wells to tubing and packer to meet California
26 Geologic Energy Management Division requirements to eliminate a
27 single point of failure and well construction standard. This program
28 will be completed by October 1, 2025. The sale or decommissioning
29 of Pleasant Creek and Los Medanos potentially will eliminate the
30 need to perform baseline assessment and eliminate a single point of
31 failure as the facilities would no longer be classified as storage
32 facilities and would only be used to recover any remaining working
33 or base gas from the assets if decommissioned.

1 Long-term: The adopted Natural Gas Storage Strategy includes
2 continued operations of McDonald Island and selling or
3 decommissioning Los Medanos and Pleasant Creek storage fields.
4 Although the outlook for natural gas in California predicts we will
5 have a reduced demand for storage, the installation of tubing and
6 packer will have an impact on the field deliverability at McDonald
7 Island likely necessitating the construction and connection of new
8 wells to continue to meet the storage needs.

9 **b. Compression and Processing**

10 C&P assets include compressor units and associated equipment
11 installed at PG&E's nine gas transmission compressor stations and
12 three underground storage facilities (McDonald Island, Los Medanos,
13 and Pleasant Creek). The C&P Asset Family also includes the gas
14 odorizers installed systemwide.

15 Approximately 65 percent of the units in PG&E's compressor fleet
16 are at or over 40 years old. The AM strategy for compressor units
17 focuses on life extension, with the overall objective of ensuring safe and
18 reliable operation of the units. Elements of this strategy include:
19 Routine maintenance programs including inspections, periodic
20 overhauls of compressor units, targeted component replacements and
21 compressor replacements. Compressor asset health is determined
22 based on age, parts availability for critical asset components, vendor
23 support, upgrades or replacements completed or in progress, and
24 performance of critical asset components. Aging and obsolete
25 equipment represents a key threat area for the C&P asset family.
26 Equipment-related risks are managed by replacing aging and obsolete
27 equipment or upgrading or retrofitting equipment to meet current
28 industry and environmental regulations, or changing business needs.
29 There are several programs for mitigating equipment-related risks in
30 C&P family such as Compressor Replacements, Compressor Unit and
31 Station Control Replacements, Emergency Shutdown System
32 Upgrades, Electrical Upgrades at Hinkley and Topock Compressor
33 Stations, and Routine Capital and Expense. There are also C&P
34 programs aimed to address threats like incorrect operations,

manufacturing-related and welding/fabrication defects, corrosion, and weather and outside force/third-party damage. These are common to both C&P and M&C assets and include programs such as: (1) Critical Documents, (2) Engineering Critical Assessments, (3) Station Strength Testing, (4) Facilities Integrity Management Program (FIMP) Risk Management and, (5) Physical Security Upgrades.

The key steady state replacement programs in the C&P Asset Family are: (1) the Compressor Replacements program and (2) the Compressor Units and Station Control Replacements program. These address the LOC at Gas M&C or C&P Facility risk and are described in more detail below.

1) Compressor Replacements

The Compressor Replacements program is a key mitigation for the risk of LOC at the transmission C&P facility. This program mitigates equipment-related threats and risks that can adversely impact gas system operations through the loss of service, loss of operating flexibility and reliability, and inability to meet evolving industry and environmental regulations. As part of its AM process, PG&E prioritizes compressor units and equipment for replacement. The Long-Term Compression Investment Plan is part of the C&P AM Plan², which enables long-term planning and forecasting investments associated with lifecycle management of compression assets, and provides an initial schedule for replacing the appropriate assets of PG&E's compressor units over a 30-year period (2016-2045). Together with the AM strategy, compression utilization or changes in markets are evaluated to ensure that investments are not placed in assets which do not align with long term projections.

2) Compressor Unit and Station Control Replacements

The Compressor Units and Station Control Replacements program mitigates the LOC risk at the transmission C&P facility. This program was established to systematically replace compressor unit and station controls that are becoming obsolete. Most

² 2018 C&P Asset Management Plan presented in 2019 Gas Safety Plan Appendix C.

compressor units and stations are installed with a Programmable Logic Circuit (PLC) that monitors and controls the operation of the compressor unit, ensuring safe and reliable operation. The lifespan of compressor unit and station PLCs is 15-20 years on average. PG&E considers several factors like age, obsolescence, lack of ongoing vendor support and spare parts availability to determine the pace of station control and unit control replacements. This program addresses the threats of equipment-related issues that reduce station reliability, and equipment-related lack of service and spare parts availability along with technology obsolescence.

c. **Transmission Pipe**

For the Transmission Pipe asset family there are several programs that proactively either repair or replace pipe prior to in-service failure when warranted based on risk and engineering analysis, including ILI, Direct Assessment, Hydrostatic Testing, Shallow/Exposed Pipe, Earthquake Fault Crossings, Geo-Hazard Threat Identification and Mitigation, Valve Automation, Valve Safety and Reliability, Class Location Change, Vintage Pipe Replacement, and Other Pipeline Safety and Reliability Replacements. Transmission pipe replacements are driven by inspection/assessment findings and analysis of risk factors. The key steady state replacement program is the Transmission Pipe Replacement Program.³ This program addresses pipe replacements specific to: (1) the Vintage Pipe Replacement Program; and (2) the Other Pipeline Safety and Reliability Pipe Replacement program. These programs address the LOC on Gas Transmission Pipeline RAMP risk.

³ Refer to A.17-11-009, PG&E's 2019 Gas Transmission and Storage rate case application for further details on these programs.

1) Vintage Pipe Replacement Program

The Vintage Pipe Replacement Program addresses various drivers including fabrication and construction defects,⁴ weather related and outside forces, external corrosion, internal corrosion, and stress corrosion cracking and thereby reduces the likelihood of the risk event occurring due to these risk drivers.

PG&E's plan for its Vintage Pipeline Replacement Program is to mitigate risk, by the end of 2027, for vintage pipe segments containing vintage fabrication and construction threats that are subject to a high risk of land movement and are in close proximity to population. PG&E continues to monitor for land movement risk changes for the remaining vintage fabrication and construction threats and may add those to this mitigation program should the land movement risk rise at these pipeline locations.

2) Other Pipeline Safety and Reliability Pipe Replacements

Safety and Reliability driven pipe replacements (other than vintage pipe replacements) are included in this program. The pipe replacement program addresses several risk drivers including external corrosion, internal corrosion, stress corrosion cracking, third-party/mechanical damage, manufacturing related defects and weather related outside forces. PG&E expects to continue to replace pipe due to leaks, dig-ins, corrosion integrity issues, overbuilds and encroachments, and other pipeline safety and reliability issues that arise.

d. Measurement and Control

The M&C asset family includes gas regulation equipment associated with transmission and distribution regulating stations, and gas

⁴ While age alone does not pose a threat to pipeline integrity, age does play a role because of the type of vintage manufacturing and construction practices that were acceptable at that time. PG&E considers "vintage pipe" to include pipe manufactured or constructed and fabricated using certain historic practices that are no longer being used today.

transmission terminals. In addition, this asset family includes, farm tap⁵ regulator sets, large volume customer regulating and meter stations, selected large customer meter sets, and equipment for monitoring gas quality. The M&C AM strategy is determined based on the condition of the overall station and its individual components through an assessment based on age, obsolescence, physical condition, functional performance, and maintenance history. The population of M&C stations varies in terms of age and condition. The aging and obsolete equipment is a key threat for the M&C assets. There are several programs to address this threat in the M&C family, such as: (1) Regulator Station Rebuilds, (2) Regulator Station Component Replacements, (3) HPR Replacements, (4) Terminal Upgrades, and (5) Station Overpressure Protection Enhancements. There are also M&C programs aimed to address threats like incorrect operations, manufacturing-related and welding/fabrication defects, corrosion, and weather and outside force/third-party damage. These threats are common to C&P and M&C assets and include programs, such as: (1) Critical Documents, (2) Engineering Critical Assessments, (3) Station Strength Testing, (4) FIMP Risk Management, and (5) Physical Security Upgrades.

The key steady state replacement programs for the M&C Asset family are: (1) Regulator Station Rebuilds, and (2) Regulator Station Component Replacements.

1) Regulator Station Rebuilds

The gas transmission and distribution Regulator Station Rebuild program is a key mitigation for: (1) the risk of an Overpressure (OP) event leading to a LOC on downstream assets; and (2) the risk of LOC at the M&C facility. This program includes projects to completely rebuild the station (above and below ground) to replace old and obsolete equipment, valves and piping, upgrade configuration to meet current system needs, and address any

⁵ PG&E defines a farm tap as a facility connected to the high-pressure gas transmission pipeline system that includes regulation equipment to regulator pressure below 60 pounds per square inch gauge and that provides gas service to one or two services. Farm taps are typically installed with HPR-type regulators.

1 outstanding issues with station maintenance and operations. The
2 criteria for determining the frequency and priority of station rebuilds
3 include, station condition based on age, equipment obsolescence
4 (product and parts no longer supported and available), operational
5 issues identified for equipment and station configuration,
6 maintenance status (high level of corrective maintenance); and
7 modifications required to address changing operational
8 requirements for the station.

9 **2) Regulator Station Component Replacements**

10 The gas transmission and distribution Regulator Station
11 Component Replacements program is a key mitigation for: (1) the
12 risk of an OP event leading to a LOC on downstream assets, and
13 (2) the risk of LOC at the M&C facility. Regulator Station
14 Component Replacement program includes mitigation activities for
15 equipment-related threats related to age and obsolescence,
16 maintenance difficulties, and impaired functional operation. This
17 program includes routine expense and capital projects for gas
18 transmission and distribution regulator stations that arise during
19 normal operation of M&C facilities that must be performed to
20 maintain current levels of service and reliability. Typical projects
21 include repair or replacement of failed or malfunctioning equipment
22 and instrumentation, inspection and testing of asset components,
23 and needed modifications to address equipment safety or
24 performance issues.

25 **e. Distribution Mains and Services**

26 For the DMS asset family, the key steady state replacement
27 programs for the LOC on Gas Distribution Main or Service RAMP risk
28 event are the Distribution Pipeline Replacement Programs. These
29 programs include: (1) the Gas Pipeline Replacement Program; (2) the
30 Plastic Pipe Replacement Program; and (3) the Reliability Main
31 Replacement Program.

1) Distribution Pipeline Replacement Programs

These programs address risk drivers Corrosion, Material or Weld – Metallic and Plastic, and Natural Forces and thereby reduce the likelihood of the risk event occurring. Factors for prioritization include age, material type, leak history, cathodic protection, seismic impact, and proximity to the public. PG&E's annual pipeline replacement rate across all three programs has increased from 27 miles in 2010 to 126 miles in 2019. The long-term plan is reaching a deactivation rate for the approximately 26,000 miles of pre-1985 pipe that would limit asset age to 100 years⁶ by:

- Continuing to replace high priority steel pipe;
- Increasing replacement rate of pre-1985 Aldyl-A and similar plastic year over year; and
- Completing all identified reliability main replacement for each given year.

3. How Gas Operations Uses Risk Prioritization to Identify Equipment for Replacement

GO mitigates and/or controls identified risks through the following methods:

- Operational changes and restrictions. For example, PG&E might temporarily lower the pressure within the pipeline after performing safety work such as ILI.
- Increased or modified maintenance, monitoring and surveillance. For example, PG&E performs additional leak surveys in areas where clusters of historical leaks have occurred on the gas system.
- Repair, refurbishment or replacement projects. For example, PG&E might replace equipment prior to obsolescence or replace various components within a regulator station.

The integrity management teams for each asset family assess the condition of assets using information from a variety of sources including SAP, preventive and corrective maintenance records, Corrective Action Program,

⁶ Gas Distribution Mains and Service Asset Management Plan (GP-1102).

and process hazards analysis.⁷ For assets in GO, age is one of many likelihood of failure factors related to asset condition that is considered in asset replacement decisions. Other asset condition factors considered may include corrosion, land movement, and third party damage, for example. Factors such as population density, system reliability, and cost effectiveness are also considered. GO takes a risk based approach to AM and as such the AM/risk framework includes understanding of the data associated with the asset around:

- Material property/physical characteristics of the asset (impacts the likelihood of risk event);
- Geospatial location of the asset (impacts the consequence of risk event); and
- Condition of the asset (impacts the likelihood of risk event).

All of PG&E's GO expense and capital projects/programs are evaluated using the Risk-Informed Budget Allocation (RIBA) prioritization methodology.⁸ Each project/program is classified as Mandatory, Compliance, Commitment, Customer Generated (Work Requested by Others), Support, Interdependent, and None. Projects/programs are then assessed for impacts to safety, the environment, and reliability that could be mitigated by the project. The portfolio prioritization process incorporates the RIBA assessment as well as constraints information such as resources and system availability. The asset family owners use this information to make prioritization decisions.⁹

C. Electric Operations

1. Electric Operations Asset Management Strategy Overview

PG&E's Electric Operations (EO) AM vision is to attain the optimum balance of asset risk, performance, and cost. This vision is achieved

⁷ A process hazard analysis is a structured approach to identify hazards, understand their consequences, and develop safeguards to prevent or mitigate their effects.

⁸ As discussed more fully in Chapter 2 (PG&E's Enterprise Risk Management Framework, Section C.4.h), the RIBA scoring methodology is being revised to use the outputs of the quantitative operational risk modeling developed in RAMP to enable consistent data driven, risk informed decision making.

⁹ See A.18-12-009, Exhibit (PG&E-3), for further information on this process.

through activities associated with the asset objectives created for each asset family. Asset families are groups of similar assets for the purposes of managing PG&E's electric system's physical assets and developing planned approaches to work management and prioritization through a risk-informed strategy. PG&E's EO has nine asset families:

- 1) Transmission Line Overhead;
- 2) Transmission Line Underground;
- 3) Substation;
- 4) Operational Assets and Systems;
- 5) Distribution Line Overhead;
- 6) Distribution Line Underground;
- 7) Distribution Network;
- 8) Asset Information; and
- 9) Streetlights.

AM develops 5-year plans for each asset family, containing plans to achieve asset objectives and include a risk-based approach for managing assets to reduce risk. The asset objectives are drafted based on current conditions and future uncertainties, and ongoing reviews are performed as part of continuous improvement. Where improvement activities impact the AM strategy, changes will be incorporated into strategic plans.

2. Electric Operations Asset Management Programs

PG&E has proactive replacement programs focused on aging or deteriorating distribution assets in the field with reliability impacts in the following asset families:

- a) Distribution Line Overhead;
- b) Substation;
- c) Distribution Line Underground; and
- d) Distribution Network.

The long-term vision for these asset families is to improve the overall safety and reliability of the assets through a combination of asset condition understanding, infrastructure improvements, and promotion of a culture that focuses on the long-term safety and reliability of the assets.

While EO strives to establish steady-state replacement strategies and programs, EO's overall AM strategy assesses EO's entire portfolio of risks to

1 achieve risk reductions. As such, EO's AM approach considers several
2 factors (maintenance requirements, replacement requirements, resources,
3 competing priorities) when identifying work plans to manage its risks. For
4 example, achieving risk reduction on EO's top risk, the wildfire risk, may
5 impact ongoing replacement programs if both activities rely on the same
6 resources. The following sections describe current considerations and
7 strategies for key asset replacement programs.

8 **a. Distribution Line Overhead**

9 The Distribution Line Overhead asset family includes key
10 components needed to operate a distribution overhead system,
11 including pole/support structure, primary conductor, voltage regulating
12 equipment, protection equipment, switching equipment, transformers,
13 and secondary conductor.

14 Long term goals related to ongoing replacements for this asset
15 family include leveraging prioritization models to support identifying
16 priority asset replacements/programs, developing a smooth ramping of
17 asset replacements to minimize spikes in replacements for asset age
18 bubbles, and implementing asset resilience strategies (e.g., wildfire
19 system hardening). Key proactive replacement programs in this asset
20 family include pole replacements and conductor replacement.

21 **1) Pole Replacements**

22 PG&E has approximately 2.3 million poles providing distribution
23 service, including approximately 25,000 non-wood poles. With fire
24 resiliency improvement efforts, non-wood or wood poles wrapped in
25 fire resistant coatings may increase in the future.

26 PG&E has an extensive condition monitoring program for wood
27 poles in accordance with requirements of General Order 165.
28 Annual patrols in urban areas and bi-annual patrols in rural areas
29 are conducted, visually looking for damaged poles and other defects
30 on the distribution overhead system. Detailed inspections, looking
31 for external damage or deterioration, are performed on assets at
32 varying intervals depending on their High Fire-Threat District (HFTD)
33 designation: every five years for Tier 1/non-HFTD assets, every

three years for Tier 2 HFTD facilities, and every year for Tier 3 HFTD facilities. Future inspection cycles may be adjusted to align with new information. Intrusive inspections are also performed approximately every 10 years to identify internal or below ground decay that may be present in the pole.

Historically, PG&E replaces an average of 21,000 wood poles per year for a variety of reasons, including damage or deterioration. Poles are also replaced for projects requiring larger conductor (capacity), installation of covered conductor as part of system hardening, and work at the request of others. During 2019, the number of pole replacements identified through inspections increased as a result of the Wildfire Safety Inspection Program-enhanced inspections. Additionally, poles in good condition, except for decay around the ground line, are identified for reinforcement. Installing a steel truss and banding it to these poles PG&E can restore the strength of the pole to 100 percent (commonly known as pole stubbing).

Ultimately, PG&E strives to minimize wood pole failures and associated outages and remediate degraded wood poles in a timely manner.

2) Overhead Conductor Replacement

PG&E has approximately 81,000 circuit miles of overhead conductor on its distribution system that operate between four kilovolt (kV) to 21 kV, including bare and covered conductors made from aluminum and copper. PG&E monitors the condition of overhead primary conductor through patrols and inspections consistent with General Order 165, and targeted infrared scans. Replacement plans are developed using failure rates obtained through wire down analysis and splice data from the infrared scans.

In 2018, a study was performed to better understand the condition and performance of distribution overhead conductors. The study helped establish a distribution of service life, near-term replacement rate, and long-term steady-state replacement rates. The modeling from the study indicated that a significant

year-over-year increase of total replacement length is needed to maintain 2016 outage levels. The results of the study informed PG&E's decision to forecast replacing additional miles of overhead conductor. In the 2020 GRC, PG&E forecast replacing an average of 97.3 miles annually from 2020-2022, compared to approximately 47 miles of overhead conductor replaced in 2017. Future replacement rates will also leverage the study results.

PG&E's strategy for replacing overhead conductor targets primary conductor that poses a high risk of failure in non-HFTD areas. Planned replacements to maintain or improve reliability, however, may not be fully executed due to higher priority work, such as safety/emergency or compliance-related work. Additional proactive replacements will occur as part of PG&E's System Hardening program, where bare overhead primary conductor will be replaced with covered conductor to reduce wildfire risk in HFTDs areas.¹⁰ System Hardening related replacements will currently focus on Tier 2 and Tier 3 HFTD areas. PG&E plans to replace approximately 1,000 circuit miles of overhead conductor, as part of System Hardening from 2020-2022. Some of the conductor replaced in Tier 2 and Tier 3 HFTD areas would have otherwise been identified for replacement as a result of annealing or deterioration. Ultimately, PG&E strives to replace deteriorated conductor, reduce conductor failures, and reduce the possibility of wildfire as a result of energized conductor falling to the ground.

b. Substation

The substation asset family consists of equipment forming the electric network that interconnects electric generation, transmission, and distribution systems throughout PG&E's territory. Equipment in this asset family includes substation facilities, transformers and voltage regulators, circuit breakers and switchgear, switches, batteries, reactive equipment, grounding systems, bus structures, and energy storage.

¹⁰ More information about conductor replacement as it relates to the Wildfire risk can be found in Chapter 10.

1 Long term goals related to ongoing replacements for this asset
2 family include initiatives to better understand asset failures and asset
3 life expectancy.

4 Substation equipment may be replaced for a variety of reasons,
5 including equipment failure, equipment reaching the end of its useful life,
6 operational performance issues, not meeting current operational or
7 cybersecurity standards, replacement parts becoming obsolete or
8 unavailable, or excessive cost of maintenance. The majority of
9 substation equipment replacement projects involve more than just the
10 in-kind replacement of a single piece of equipment with a like-for-like
11 piece of equipment. For instance, the newer equipment may be
12 manufactured with different dimensions or operating specifications,
13 requiring relocation of other existing equipment and installation or
14 replacement of ancillary equipment. Additionally, when PG&E replaces
15 equipment, it may make engineering and economic sense to upgrade or
16 add other equipment to improve reliability, enhance public safety, or
17 bring up to current standards. For example, PG&E may upgrade
18 associated connectors, switches, and communication equipment, when
19 replacing a substation circuit breaker or transformer. This approach of
20 work bundling results in efficient execution of work, lowering the
21 replacement cost of the associated assets.

22 PG&E's substation asset replacement program includes replacing
23 various types of major and minor equipment within this asset family,
24 including transformers, circuit breakers and switchgear.

25 PG&E has 760 distribution substations in its electric system.
26 Substations are facilities containing assets and infrastructure used to
27 transform voltage from one level to another. Other electric facilities exist
28 that are used for switching purposes only, for power generation and/or
29 third-party service. Transformers, circuit breakers switchgear, and other
30 assets reside within substations.

31 Transformers convert higher voltages of electricity to
32 distribution/utilization voltages for delivery to customers. PG&E
33 maintains an inventory of approximately 2,200 distribution substation
34 transformers throughout its service territory. PG&E identifies, prioritizes

1 and replaces transformers that are near the end of their useful lives and
2 are at high risk of failure. A condition-based assessment of substation
3 equipment through monitoring, testing and inspection is used to
4 prioritize replacements. In addition to proactive planned replacement
5 based on asset health indices, PG&E replaces transformers to provide
6 increased capacity, and performs emergency replacements based on
7 actual or imminent in-service failures.

8 Circuit breakers automatically interrupt the flow of electricity in the
9 event of a problem, such as a short circuit or circuit overload. Including
10 substation switchgear breakers, PG&E has approximately 5,200 circuit
11 breaking units. Circuit breaker replacements include a combination of
12 proactive planned replacements and emergency replacements.
13 Planned replacements are based on asset health indices, capacity
14 additions or replacements included during bus upgrades. Circuit
15 breakers can also be replaced as part of larger substation projects or on
16 an emergency basis for in-service or imminent in-service failures.
17 Substation circuit breakers are identified and prioritized by developing a
18 health index for the distribution circuit breakers throughout the PG&E
19 service area. Key factors included in the health index are: asset age,
20 overstress (if any), failure, obsolete parts, oil analysis and maintenance
21 and operating history.

22 **c. Distribution Line Underground**

23 The distribution line underground asset family consists of
24 underground cables, line equipment, and transformers.

25 Long term goals related to ongoing replacements for this asset
26 family include replacing all remaining primary Paper Insulated Lead
27 Covered (PILC) cables, replacing all oil-filled switches with solid
28 dielectric switches, and leveraging technological advances to develop
29 condition-based replacement programs with appropriate replacement
30 rates. Key proactive replacement programs in this asset family include:
31 primary cable replacements and oil switch replacements.

1) Primary Cable Replacements

Excluding network cables, the distribution underground primary cable asset class is comprised of over 26,000 circuit miles of cable. Cables are categorized by the following insulation types, along with their typical deployment periods:

- PILC – Primarily installed for use in both San Francisco and Oakland network systems as early as the 1920s, up to the present, in certain circumstances where underground conduit constraints exist.
- High Molecular Weight Polyethylene (HMWPE) – Deployed from the early 1960s through the 1980s.
- Cross-Linked Polyethylene (XLP) – Installed from the early 1960s through the late 1990s.
- Ethylene Polypropylene Rubber (EPR) – Deployed from the late 1990s to the present.

The majority of these underground cables are installed in urban and suburban areas throughout the service territory. Most PILC cables in PG&E's system are located in PG&E's San Francisco and East Bay Divisions, while EPR cable is used for most new installations systemwide.

Cables are replaced by re-pulling new cable within the existing infrastructure, or by trenching or boring to install new underground facilities where replacement in-place is not feasible or cost effective. Cable replacement projects may also include upgrading switches, transformers, enclosures, and other associated equipment. In some cases, cable targeted for replacement is evaluated using cable testing or rejuvenation to determine whether a more cost-effective alternative would be effective for all or part of the project.

Cable replacements are prioritized based on age and type of cable, or a combination of these factors and other influences. When possible, PG&E's Reliability Related Cable Replacement Program leverages the results of diagnostic testing to further prioritize the replacement of poor performing primary cable sections. Cables tested with neutral deterioration are prioritized higher for

1 replacement. PG&E's replacement strategy focuses on cable
2 sections that are failing at higher rates (e.g., HMWPE). In the 2020
3 GRC, from 2020-2022, PG&E forecast replacing 24 miles of
4 HMWPE cable, 21 miles of XLP and other cable, and 15 miles
5 of PILC.

6 PG&E's strategy also includes reactive replacement for all failed
7 cable. Mainline cables are primarily replaced under the Emergency
8 Program, while local loop cables are typically replaced under the
9 Critical Operating Equipment Cable Replacement Program.
10 Underground cable is also replaced as part of Capacity program if
11 there is an overload, or current exceeds the current rating, and in
12 PG&E's Emergency and Maintenance programs. Ultimately, PG&E
13 strives to proactively replace primary cables to maintain the current
14 failure rate and overall system reliability.

15 **2) Load Break Oil Rotary Switch Replacements**

16 Line switches are used to interconnect, sectionalize, and
17 transfer load between circuits. Load Break Oil Rotary (LBOR)
18 switches are a type of switch that are manually operated and
19 oil-filled that use solid blade mechanisms immersed in oil to break or
20 make loads. There is no easy or efficient way to properly inspect
21 the oil level and test the quality of the insulating oil for LBOR
22 switches. As these switches age, the strength and quality of the
23 insulating oil becomes suspect and can potentially be a safety
24 hazard for PG&E personnel. PG&E has approximately
25 13,300 LBOR switches in its service territory.

26 In 2014, PG&E began replacing LBOR switches. PG&E's
27 LBOR replacement program primarily focuses on switches
28 manufactured prior to 1975 without oil inspection sight glasses.
29 However, switches manufactured after 1975 may also be replaced
30 when inspection and condition assessments indicate such work is
31 necessary. In the 2020 GRC period, PG&E plans to replace
32 90 pre-1975 LBOR switches annually. Ultimately, PG&E strives to
33 eliminate oil-filled switchgear from the distribution system.

d. Distribution Network

The distribution network asset family is composed of network transformers and network protectors serving customers in the San Francisco Financial District and downtown Oakland.

Long-term goals associated with ongoing replacement programs include maintaining or decreasing in-service failure rates and developing a smooth ramping up of asset replacements that minimizes spikes in replacements for asset age bubbles. Key proactive replacement programs in this asset family include: targeted replacements of network transformer and network protectors, and network cable replacement and switch installations.

1) Targeted Replacements of Network Transformer and Network Protectors

Network transformers are used to step primary voltages down to service voltages. Network protectors are designed to automatically isolate faults in order to prevent service interruptions on the network. PG&E has a total of 1,392 network transformers, including 94 transformers located in high-rise buildings, and a total of 1,385 network protectors.

Some transformers in high-rise buildings are oil-filled, posing a fire risk. In 2010, PG&E began replacing oil-filled transformers with dry-type transformers to minimize fire risks and increase safety. PG&E plans to replace all oil-filled network transformers in its service territory by the end of 2022. Network oil-filled transformer replacements are included in a mitigation to the Failure of Electric Distribution Network Assets risk.¹¹

PG&E also makes condition-based replacements for equipment in this asset family. PG&E routinely monitors the condition of its network transformers and network protectors through inspections and oil sampling. Equipment found with deteriorated conditions are flagged for replacements. Condition-based replacement is a

¹¹ See Chapter 12 for more information on the Failure of Electric Distribution Network Assets risk.

continuous effort to ensure safe and reliable operation of the equipment. Condition-based replacements are also included as a control to the Failure of Electric Distribution Network Assets risk.¹²

Ultimately, PG&E strives to minimize in-service failure, work towards fully deployed condition-based maintenance, and identify a reasonable life cycle plan for these assets.

2) Network Cable Replacement and Switch Installations

PG&E's networked distribution systems consist of 188 circuit miles of cable in 12 network groups, ten in San Francisco and two in Oakland. PG&E performs systematic replacement of network cable assets and installation of switches in downtown San Francisco and Oakland networks. Many of the existing network primary and secondary cables date from the 1920s to the 1960s and are nearing the end of their useful life. The network systems replacement program is an on-going program that started in 2011. The program work includes replacing primary and secondary cables, modifying network transformers to accept the new primary cables, and installing switches. PG&E is installing switches at the same time cables are replaced to meet operational requirements by providing a switching location outside the substation to establish feeder clearance points. PG&E plans to proactively replace additional network cable as part of a new mitigation.¹³

3. How Electric Operations Uses Risk Prioritization to Identify Equipment for Replacement

PG&E's EO Risk Management Program is consistent with PG&E's Integrated Planning process. PG&E develops an active list of risk profiles, quantifies risks, maps each risk driver, control, and consequence affecting the risk, develops mitigations to promote risk reductions, and establishes key performance indicators or metrics to monitor risk performance. In order

¹² See Chapter 12 for more information on the Failure of Electric Distribution Network Assets risk.

¹³ See Chapter 12 for more information on the Failure of Electric Distribution Network Assets risk.

1 to inform work prioritization, EO performs a RIBA analysis to characterize
 2 risks based on a number of factors and utilizes additional prioritization
 3 frameworks and tools to help prioritize its work.¹⁴

4 The RIBA process evaluates projects and programs from a safety,
 5 environmental, and reliability risk perspective to assess the degree of
 6 relative risk exposure and impact being addressed. Other factors are also
 7 incorporated into the evaluation to inform capital investment decisions,
 8 including, but not limited to, compliance requirements and project
 9 inter-dependencies. RIBA scores are assigned to approved projects or
 10 programs. The RIBA scores for the EO portfolio of work are used to support
 11 creation of or adjustments to the capital investment plan that meets the most
 12 critical demands of the electric distribution system, consistent with available
 13 resources and operational performance requirements.

14 Following the 2017 and 2018 wildfires, EO instituted an additional risk
 15 prioritization framework to prioritize fire ignition prevention work within the
 16 EO portfolio. The framework evaluates whether programs and projects
 17 prevent fire ignitions (highest priority), have strong links to safety (medium to
 18 high priority), or have a low safety risk (lowest priority). These inputs were
 19 used in conjunction with EO's newly-designed circuit-based approach, which
 20 was developed to prioritize work starting in 2020. The circuit-based
 21 approach applies to distribution line, transmission line and substation work
 22 and optimizes the work within EO portfolio by value, risk ranking, and
 23 resource availability to develop a work plan targeting the highest priority
 24 activities on the circuits with most risk.

25 PG&E continues to improve risk models for both distribution and
 26 transmission. This continuous improvement aims to model probability and
 27 consequence at the asset level, forecast risk and inform planned mitigations.
 28 This also enables the prioritization of work based on these forecasted risk
 29 reductions. As new data becomes available and the environment in which

¹⁴ As discussed more fully in Chapter 2 (PG&E's Enterprise Risk Management Framework, Section C.4.h), the RIBA scoring methodology is being revised to use the outputs of the quantitative operational risk modeling developed in RAMP to enable consistent data driven, risk informed decision making.

PG&E operates continues to change, EO will continue to evolve its risk management and prioritization.

D. Generation

1. Generation Asset Management Strategy Overview

Generation's AM Program provides a systemwide look into the condition of the generation equipment and proposes projects and/or changes to operations and/or maintenance practices to ensure that Generation's long-term investment plan maintains or reduces risk and maintains or improves the safety and reliability of the generation portfolio.

2. Generation Asset Management Programs

a. Hydroelectric

PG&E has 105 hydroelectric generating units at 66 powerhouses with a generating capacity of 3,890.6 megawatts (MW). PG&E has a hydroelectric AM Program that includes most of the equipment used for hydroelectric generation.

Equipment and systems associated with water storage and conveyance and with the power train are considered key operating equipment in the hydroelectric AM program.

b. Fossil and Solar

PG&E has three fossil-fuel generating stations that are between ten and 11 years old. These three generating facilities have a combined maximum normal operating capacity of 1,400 MW. These units have an expected life of 30 years and the major components are currently covered by long-term service agreements with the original equipment manufacturer for the major components of the power train. PG&E is guided by the Commission's operations and maintenance (O&M) standards (General Order 167) and uses a high energy piping (HEP) standard to help assure the stations are safely maintained.

PG&E also has ten solar photovoltaic generating facilities. The majority of these sites are less than nine years old. PG&E has a program in place to repair or replace the inverters and to replace panels as they fail.

Major components necessary to provide safe and reliable service are proactively replaced, repaired or refurbished.

c. Nuclear

PG&E has one nuclear generating facility, the Diablo Canyon Power Plant (DCPP), located nine miles northwest of Avila Beach in San Luis Obispo County. DCPP consists of twin pressurized water reactors, Units 1 and 2, rated at a nominal 1,122 MW and 1,118 MW, respectively. DCPP Units 1 and 2 began commercial operation in May 1985 and March 1986, respectively, and are licensed by the Nuclear Regulatory Commission (NRC) to operate until November 2, 2024 and August 26, 2025. PG&E has a robust NRC-required maintenance (AM) program where major components necessary to provide safe and reliable service are monitored, tested, and proactively replaced or refurbished in accordance with NRC regulations. PG&E does not plan to operate DCPP past its current NRC license expiration dates.¹⁵

3. How Power Generation Uses Risk Prioritization to Identify Equipment for Replacement

PG&E takes a risk informed approach to AM for Generation. PG&E quantifies risks using the Enterprise Risk Management process, which includes enterprise risks such as a large uncontrolled water release or a nuclear core damaging event. Following that process, PG&E performs a RIBA analysis to characterize risks based on several factors. The RIBA process is used to evaluate projects and programs from a safety, environmental, and reliability perspective to assess the degree of relative risk exposure and impact being addressed.¹⁶ The purpose of a RIBA score is to capture on a relative basis the safety, environmental and reliability risks that each project or program in Generation aims to prevent, based on the worst direct reasonable impact or event that the work activity mitigates. In

¹⁵ The Commission has approved a retirement plan for DCPP (Decision 18-01-022).

¹⁶ As discussed more fully in Chapter 2 (PG&E's Enterprise Risk Management Framework, Section C.4.h), the RIBA scoring methodology is being revised to use the outputs of the quantitative operational risk modeling developed in RAMP to enable consistent data driven, risk informed decision making.

1 addition to safety, environmental and reliability risks, other factors including,
2 but not limited to, the RIBA classification, justification and project
3 inter-dependencies are incorporated into the evaluation to inform investment
4 decisions.

5 All approved projects or programs have RIBA scores. The RIBA
6 process is used to aggregate the individual project and program risk
7 assessments to support creation of or adjustments to the investment plan.
8 The following sections describe considerations and strategies for key asset
9 replacement programs.

10 **a. Hydroelectric Asset Management Practices and Programs**

11 **1) Hydroelectric Asset Management Practices**

12 PG&E employs the following process to identify and ultimately
13 mitigate the risks associated with PG&E's hydroelectric assets:

14 **a) Asset Registry**

15 PG&E uses equipment records in SAP Work Management
16 to track the key characteristics and nameplate data for each
17 hydro asset. These records provide the foundation for
18 maintenance planning, AM and engineering.

19 **b) Design and Performance Criteria**

20 For each hydro asset type, PG&E develops technical
21 documents which contain design and performance criteria.
22 While design criteria are used primarily for new equipment,
23 performance criteria are used to assess existing equipment,
24 providing a technical threshold against which to measure
25 assessment results.

26 **c) Assessment Standards**

27 For each hydro asset type, PG&E develops technical
28 documents which contain assessment standards and
29 procedures. Such standards and procedures (based on
30 industry best-practices and regulations) explain how and when
31 each asset type should be assessed.

d) Assessments

In line with its assessment standards and procedures, PG&E conducts tests and inspections across its fleet of hydro assets. For each asset type, there are often numerous types of tests and inspections, each with its own required frequency, as outlined by the assessment standard/procedure. Assessment results are analyzed and interpreted, and corresponding condition indicators are logged in SAP that is linked directly to each equipment record.¹⁷

e) Quantification of Asset Risk

Based on its assessment results and condition indicators, PG&E's AM team calculates risk scores for each key piece of hydro equipment. Risk scores consist of health scores (which are a proxy for the probability of failure) and consequence scores (which are a proxy for the consequence of failure). Taken together, PG&E can quantify the risk of its respective hydro assets. Risk scores are logged in Excel Workbooks on a secure SharePoint site.

f) Asset Risk Mitigation/Control

PG&E mitigates and/or controls identified risks through the following methods:

- Operational changes and restrictions. For example, where appropriate PG&E will temporarily lower the flow in a leaking canal or institute a no-run-zone on a hydro unit with vibration problems.
- Increased or modified maintenance, monitoring and surveillance. For example, where appropriate PG&E will install instrumentation near a penstock to monitor ground movement.
- Repair, refurbishment or replacement projects. For example, where appropriate PG&E will replace a

¹⁷ SAP is used for the penstock program and powertrain programs. The dams and water conveyance program assessment results are tracked separately.

highly-deteriorated (due to cavitation or corrosion) turbine runner, or it might re-line a degraded section of canal.

2) Hydroelectric Asset Management Programs

a) Storage and Conveyance

The assets in this category have long service lives and are not routinely replaced. PG&E's focus regarding storage and conveyance assets is centered around on-going maintenance and mitigations to assure the assets are safe and reliable for employees and the public and meet all regulatory requirements.

PG&E's water storage and conveyance systems consist of dams, reservoirs, tunnels, canals, flumes, siphons, and penstocks, which enable PG&E to transport and store runoff and aquifer flows to the hydro powerhouses to allow for flexible generation. Additionally, the conveyance and storage systems meet critical water storage and delivery requirements, for purposes of water conservation, fish and wildlife habitat protection and enhancement, domestic water usage, recreational water requirements, irrigation district and agricultural water needs, and natural resource protection. The system collectively includes the following approximate number of, or miles of, support infrastructure: 98 reservoirs, 73 diversions, 170 dams (68 large dams¹⁸ and 103 small dams), 173 miles of canals, 43 miles of flumes, 132 miles of tunnels, 65 miles of pipe (penstocks, siphons, and low head pipes), four miles of natural waterways, and approximately 140,000 acres of fee-owned land.

i) Dams

Dams are routinely maintained with mitigations to address any issues that develop, and not typically replaced.

¹⁸ The Federal Energy Regulatory Commission (FERC) classifies large dams as those dams with a height of greater than 33 feet. Dams less than 33 feet high, but that are classified by FERC as high or significant hazard are treated as large dams and must comply with the Part 12 regulations. (18 Code of Federal Regulations (CFR) Part 12D).

PG&E's dams are associated with the Enterprise Risk, Large Uncontrolled Water Release. The dam safety program is regulated by the State of California Department of Water Resources, Division of Safety of Dams (DSOD) and the FERC. The following includes the AM approach to dams:

- Routine observations by trained Hydro O&M personnel;
- Regular inspections by qualified engineers in PG&E's Dam Safety Program;
- Regular regulatory inspections by the FERC and DSOD based on dam hazard classification;
- Five-year Independent Consultant Safety Inspections in accordance with 18 CFR Part 12D;
- Engineering evaluations of dam stability, seismicity, spillway design capacity, and other design and operational issues as conditions and engineering guidelines evolve; and
- Major repairs are infrequent, but can require high cost (~\$20-\$100 million) projects.

ii) Penstocks

Penstocks are typically repaired or refurbished, not replaced, based on condition and consequence of failure. PG&E utilizes a condition, risk and economic-based approach to AM. The following includes the AM approach to penstocks:

- Routine O&M patrols may yield emergent maintenance/repair performed as-needed;
- Detailed inspection by subject matter experts and non-destructive examination inspections;
- Inspection frequency is based on penstock risk; and
- Replacement is usually not cost effective.

iii) Water Conveyance

Water Conveyance assets are typically repaired or refurbished, not replaced, based on condition and consequence of failure. PG&E utilizes a condition, risk and economic-based approach to AM. The following includes the AM approach to water conveyance:

- Major repair project prioritization based on locational health and consequence of failure scores, determined through five-year AM condition assessments;
- Conveyance relining costs are decreasing as several high consequence sites have been addressed in recent years; and
- Routine maintenance is performed by O&M based on findings from monthly patrols.

b) Power Train

The assets in this category are replaced or refurbished based on condition, reliability requirements, and economics.

i) Turbines

PG&E utilizes a condition, reliability and economic-based approach to AM. The following includes the AM approach to turbines:

- Turbine replacement or refurbishment decisions are based on current condition of the equipment, safety and powerhouse economics;
- Typical inspections and tests are performed every five to eight years depending on previous condition assessments; and
- Weld repairs are performed periodically during annual outages for life extension.

ii) Generators and Rotors

PG&E utilizes a condition, reliability and economic-based approach to AM. The following includes the AM approach to generators and rotors:

- Generator performance testing and modeling every five years per Western Electricity Coordinating Council requirements;
- Physical inspection occurs during outages and stator insulation testing is performed annually; and
- Life extension through stator rewinds and rotor cleaning or refurbishment based on asset condition.

PG&E has plans to rewind several generator stators and the associated generator rotors will be cleaned or refurbished over the next few years.

iii) Transformers

PG&E utilizes a condition and risk-based approach to AM. The following includes the AM approach to transformers:

- Visual inspections and oil testing are conducted annually. Offline electrical testing is done every five years. More extensive assessments are conducted if warranted by the condition of the transformer.
- Replacement or refurbishment typically address deteriorating oil quality, paper insulation, or leaks in the transformer bank.
- PG&E has plans to replace or refurbish several transformers over the next few years.

b. Fossil Asset Management Practices and Programs

PG&E's fossil AM practices and programs are guided primarily by the Commission's O&M standards (General Order 167) and the PG&E fossil generation High Energy System Safety Program (HESSP) standard.

1) O&M Standard

General Order 167 sets forth standards that govern the O&M of power plants. The purpose of General Order 167 is:

...to implement and enforce standards for the maintenance and operation of electric generating facilities and power plants so as to maintain and protect the public health and safety of California

residents and businesses, to ensure that electric generating facilities are effectively and appropriately maintained and efficiently operated, and to ensure electrical service reliability and adequacy.¹⁹

The standards set forth in General Order 167 include operation standards, maintenance standards, and logbook standards. PG&E accomplishes compliance with General Order 167 through the use of various internal controls, and through audits by the CPUC. General Order 167 was set in place post energy crisis by the CPUC to enforce prudent practices in the availability of the fossil fleet for California.

2) Fossil Generation HESSP Standard

This standard provides the requirements for inspecting, conducting analysis, managing associated mitigation, and corrective actions for PG&E's fossil generation HESSP, which includes HEP and high energy fixed equipment. This program monitors HEP systems for integrity and safety while meeting the requirements of the American National Standards Institute/American Society of Mechanical Engineers B31.1, Power Piping, Appendix V Section V-6.0 and other codes for high energy fixed equipment.

HEP systems are normally considered to include the main steam, reheat (both hot and cold), bypasses, feedwater (high pressure and low pressure), blowdown lines, drain lines, vent lines, and extraction steam piping.

High energy fixed equipment includes heat recovery steam generators, boiler drums, blowdown tanks, economizers, evaporators, attemperator, condenser, deaerator, and other balance of plant pressurized equipment, such as air receivers, ammonia tanks, and gas filters.

c. Nuclear Asset Management Practices and Programs

Nuclear generation has classified the operating equipment at its nuclear generating station and applied testing, maintenance, and

¹⁹ CPUC, General Order 167, Section 1.0 Purpose.

1 replacement strategies reflective of a zero-tolerance for critical
2 equipment failures.

3 **1) Equipment Reliability Process**

4 The nuclear generation equipment reliability process integrates
5 a broad range of activities into one process. Using this process,
6 personnel evaluate important plant equipment, develop and
7 implement long-term equipment health plans, monitor equipment
8 performance and condition, and adjust preventive maintenance
9 tasks and frequencies based on equipment operating experience.

10 This process includes activities such as:

- 11 • Reliability-centered maintenance—optimized maintenance plans
12 that are established based on systematic evaluation of the
13 safety and operational consequences of each failure and
14 degradation mechanism that causes the failures;
- 15 • Preventive maintenance (PM), periodic, predictive (PdM), and
16 planned—maintenance performed either periodically, or based
17 on observed conditions, that ensures the equipment will
18 continue to meet its design requirements without failure;
- 19 • Surveillance and post-maintenance testing—assures equipment
20 that will be relied upon is capable of performing its
21 design function;
- 22 • Lifecycle management planning—integrates aging management
23 and economic planning for optimized operation, maintenance
24 and service life of equipment to maintain acceptable
25 performance and safety;
- 26 • Equipment performance and condition monitoring—performance
27 monitoring over time that detects performance degradation and
28 need for maintenance before a failure occurs;
- 29 • Internal and external operating experience assessment—
30 formalized process of reviewing industry and station equipment
31 experience to identify equipment reliability vulnerabilities and
32 address them before a failure occurs; and
- 33 • Maintenance Rule evaluation—regulated process to ensure that
34 reliability of equipment important to safety is maintained and

causes of unacceptable performance are investigated
and corrected.

2) Equipment Reliability Classification

The equipment reliability classification (ERC) is established, using industry-standard criteria, to identify the equipment in one of the four following categories:

- Critical – failure can cause such results as a reactor trip, power transient greater than 20 percent, complete loss of nuclear heat removal, or complete loss of vital AC power;
- Important Non-Critical – failure can cause results such as an unplanned power reduction greater than 2 percent, a power transient of 2 percent to 20 percent, or loss of a redundant safety feature;
- Economic Non-Critical – failure can cause unplanned power reduction less than 2 percent, or is required to meet North American Electric Reliability Corporation, FERC or insurance requirements, emergency response equipment, or has been found to be more cost-effective to maintain than to allow failure;
- Run-to-Maintenance – equipment that does not fall into the above categories that can be run until corrective maintenance is required; and
- Exempt – equipment includes those that are operationally insignificant, highly reliable, or largely passive.

The equipment reliability for each objective guides the development of the reliability strategies for that component as shown in Table 21-1 below:

**TABLE 21-1
NUCLEAR EQUIPMENT RELIABILITY CLASSIFICATION**

Line No.	ERCs	Objectives	Strategies
1	Critical	Early detection of incipient failures. Failures are rare.	Level of PM/PdM ensures incipient failures are detected and all failures are prevented wherever practical. Inventory management (spare parts strategy). AM (develop long term strategy). Implement cost effective design changes to avoid single point functional failures. Maintenance strategies maximize reliability and availability, and minimize possible failures caused by infant mortality and human error. Plant resources are applied first to protecting these components from failure.
2	Important Non-Critical	Few failures are expected.	Level of PM/PdM ensures few failures and that all performance criteria are met. AM (develop long term strategy). The condition of these components is not allowed to degrade simply because there may be redundancy in design. Maintenance strategies and the level of resources applied ensure components meet required levels of performance.
3	Economic Non-Critical	Most component failures are prevented. PM strategies ensure that industry requirements are met. Prescribed strategies are more cost effective than an RTF strategy.	Simple and effective PM tasks performed to extend useful life.
4	Run-to-Maintenance	Failures can be tolerated.	PM or PdM not performed. Repair or replacement of these components on a corrective or elective basis is the most cost-effective maintenance strategy. Plant resources will not be expended to prevent failures.
5	Exempt	Failures are not expected. Exempt from analysis of consideration of preventive or predictive maintenance.	Exempting highly reliable or operationally insignificant components permits a more focused effort on components which merit most attention. Components may fall under plant programs other than PM.

PACIFIC GAS AND ELECTRIC COMPANY
APPENDIX A
RAMP ACRONYM LIST

RAMP ACRONYM LIST
GLOSSARY OF ACRONYMS AND ABBREVIATIONS

A

ACSR	Aluminum Conductor Steel-Reinforced
AM	Asset Management
API	American Petroleum Institute
ARB	Air Resources Board (see CARB)
ARMA	Association of Records Managers and Administrators
ASME	American Society of Mechanical Engineers
ATWACC	After Tax Weighted Average Cost of Capital

B

BC Hydro	BC Hydro and Power Authority is a Canadian electric utility in the province of British Columbia, simply known as BC Hydro
BDB	Beyond Design Basis

C

49 CFR	Title 49 of the Code of Federal Regulations – Transportation
C&P	Compression & Processing or Compression and Processing
C/Mins	customer minutes
CalGEM	California Geological Energy Management
CAP	Corrective Action Program
CARB	California Air Resources Board
CDL	commercial driver's license
CDLA	Class A Commercial Driver's License
CDSE	Chief Dam Safety Engineer
CE	Cause Evaluation
CEC	California Energy Commission
CEMA	Catastrophic Event Memorandum Account
CEO	Chief Executive Officer
CERP	Company Emergency Response Plan
CFR	Code of Federal Regulations
CMI	Customer Minutes of Interruption
CNG	Compressed Natural Gas (can be used as lowercase)
COE	Critical Operating Equipment
CoRe	Consequence of Risk Event
COVID-19	Coronavirus
CPUC or Commission	California Public Utilities Commission
CRESS	Corporate Real Estate Strategy and Services
CRO	Chief Risk Officer
CRR	Corporate Risk Register
CSF	Cybersecurity Framework
CSO	Customer Service Office

RAMP ACRONYM LIST
GLOSSARY OF ACRONYMS AND ABBREVIATIONS

CSTI	California Specialized Training Institute
CUE	Coalition of Utility Employees
CVA	Climate Vulnerability Assessment
CWSP	Community Wildfire Safety Program

D

D.	Decision
D-Line	Distribution Line
DA	Direct Assessment
DART	Days Away, Restricted and Transferred
DASH	Daminfo Automated Seismic Hazard
DCD	Downed Wire Detection
DCPP or DCNPP	Diablo Canyon Power Plant or Diablo Canyon Nuclear Power Plant
DFA	Distribution Fault Anticipation
DIMP	Distribution Integrity Management Program
DMS	Distribution Mains and Services
DMV	Department of Motor Vehicle
DOCP	Distribution Overhead Conductor – Primary
DOH	Distribution Overhead
DOT	Department of Transportation or U.S. Department of Transportation
DSOD	Division of Safety of Dams
DSP	Dam Safety Program
DTS-FAST	Distribution Transmission Substation—Fire Action Scheme and Technology

E

E&R	Engineering and Risk
EAP	Emergency Action Plan
EAP	Employee Assistance Program
ECA	Engineering Critical Assessment
ECISSP	Electrically-Connected Isolated Steel Service Program
EF	Equivalent Fatalities
EHS	Environmental and Health and Safety
EIR	Electric Incident Report
EO	Electric Operations
EOC	Emergency Operations Center
EORM	Enterprise and Operational Risk Management
EP&R	Emergency Preparedness and Response
EPH	Enterprise Performance Huddle
EPR	Ethylene Polypropylene Rubber (can be used as lowercase)
ERC	equipment reliability classification
ERIM	Enterprise Records and Information Management

RAMP ACRONYM LIST
GLOSSARY OF ACRONYMS AND ABBREVIATIONS

ERR	Enterprise Risk Register
ESMS	Enterprise Safety Management System
EVM	Enhanced Vegetation Management
EWT	Early Warning Technologies

F

FAA	Federal Aviation Administration
Fd	Force of water
FEMA	Federal Emergency Management Agency
FERC	Federal Energy Regulatory Commission
FFD	Fitness for Duty (can be used as lowercase)
FIA	Fire Index Area
FIMP	Facility Integrity Management Program
FMEA	Failure Modes and Effects Analysis
FPI	Fire Potential Index

G

GCC	Gas Control Center
GD-GIS	Gas Distribution Geographic Information System
GDL	Guidance Document Library
GMC	ground motion characterization
GO	Gas Operations
GO	General Office or General Order
GOES	Governance Oversight Execute Support
GPRP	Gas Pipeline Replacement Program
GPS	Global Positioning System or Geographic Positioning System
GRC	General Rate Case
GT	Gas Transmission (can be used as lowercase)
GT&S	Gas Transmission and Storage

H

HCA	High Consequence Area
HEP	High Energy Piping
HFTD	High Fire Threat District
HMWPE	High Molecular Weight Polyethylene or High Molecule Weight Polyethylene
HPR	High-Pressure Regulator (can be used as lowercase)
HR	Human Resources
HSSP	High Energy System Safety Program

I

IAM	Identity and Access Management
-----	--------------------------------

RAMP ACRONYM LIST
GLOSSARY OF ACRONYMS AND ABBREVIATIONS

ICS	Incident Command System or Incident Command Structure
IGMM	Information Governance Maturity Model
ILI	In-Line Inspection
IMT	Incident Management Team
IOU	Investor-Owned Utility (can be used as lowercase)
ISN	ISNetworld
ISO	International Standards Organization
ISRMP	Integrated Seismic Risk Management Program

J

K

L

LFHC	low-frequency/high consequence
LiDAR or LIDAR	Light Detection and Ranging
LNG	Liquefied Natural Gas (can be used as lowercase)
LNT	linear no dose threshold
LOB	Line of Business (can be used as lowercase)
LOBs	Lines of Business (do not define Lines of Business—use LOB above)
LOC	loss of containment
LoRe	Likelihood of a Risk Event
LTIP	Long-Term Incentive Plan
LTSP	Long-Term Seismic Program or Long Term Seismic Program
LVCR	Large Volume Customer Regulator

M

M&C	Maintenance and Construction
M&C	Measurement & Control or Measurement and Control
MAOP	Maximum Allowable Operating Pressure
MARS	Multi-Attribute Risk Score (can be used as lowercase)
MAVF	Multi-Attribute Value Function (can be used as lowercase)
MOC	Management of Change
MPP	Meter Protection Program
MSD	Musculoskeletal Disorder (can be used as lowercase)
MVS	Motor Vehicle Safety
MVSI	Motor Vehicle Safety Incident
MW	megawatt
MW	Mitigation Effectiveness workpapers

N

NCL	Nurse Care Line
-----	-----------------

RAMP ACRONYM LIST
GLOSSARY OF ACRONYMS AND ABBREVIATIONS

NERC	North American Electric Reliability Corporation
NESE 100	Near 100 year storm event
NIST	National Institute of Standards and Technology
NOAA	National Oceanic and Atmospheric Administration
NPV	Net Present Value
NRC	Nuclear Regulatory Commission
NTSB	National Transportation Safety Board
NWS	National Weather Service

O

O&M	operations and maintenance (should be lowercase unless it is a Dept.)
ODN	Operational Data Network (can be used lowercase)
OIR	Order Instituting Rulemaking
OP	Over Pressure
OPP	Over Pressure Protection
OSA	Office of Safety Advocate
OSHA	Occupational Safety and Health Administration

P

PAR	Population at Risk
PdM	Predictive maintenance
PRA	Probabilistic Risk Assessment
PRC	Public Resource Code
PSPS	Public Safety Power Shutoff
PSPs	Public Safety Plans
PSS	Public Safety Specialists
PVMI	preventable motor vehicle incident

Q

R

R.	Rulemaking
RAMP	Risk Assessment and Mitigation Proceeding
RCC	Risk and Compliance Committee
REFCL	Rapid Earth Fault Current Limiter
REM	Roentgen Equivalent Man
RFW	Red Flag Warnings
RIBA	Risk Informed Budget Allocation or Risk-Informed Budget Allocation
RIM	Records and Information Management
RMC	Risk Management Community
RO	Regulated Output

RAMP ACRONYM LIST
GLOSSARY OF ACRONYMS AND ABBREVIATIONS

ROW	Right-of-Way (can be used as lowercase)
RP	Recommended Practice
RSE	Risk Spend Efficiency
RTU	Remote Terminal Unit

S

SAMA	Severe Accident Mitigation Alternative
SAP	Systems Applications and Products (should <u>not be spelled out</u> unless we get an approval from the case manager)
SCADA	System Control and Data Acquisition
SCC	Stress Corrosion Cracking
scfh	standard cubic feet per hour
SED	Safety and Enforcement Division
SERA	System Earthquake Risk Assessment
SGF	Sensitive Ground Fault
SHED	Safety, Health, ECAP, DOT
SIF	Serious Injury or Fatality or Serious Injuries or Fatalities or Serious Injury and Fatality
SIPT	Safety and Infrastructure Protection Teams
SLD	Safety Leadership Development
SLR	Sea level rise
S-MAP or SMAP	Safety Model Assessment Proceeding
SME	Subject Matter Expert (can be used as lowercase)
SMYS	Specified Minimum Yield Strength
SNO	Safety and Nuclear Operations or Safety and Nuclear Oversight
SOPP	Storm Outage Prediction Program or Storm Outage Prediction Project
SPRA	Seismic Probabilistic Risk Assessment (can be used as lowercase)
SQWF	Skilled and Qualified Workforce
SSC	seismic source characterization
STIP	Short-Term Incentive Plan
SWN	Send Word Now

T

TIL	Technical Information Library
TIMP	Transmission Integrity Management Program
TS	Transportation Services
TURN	The Utility Reform Network
TVMR	Transmission Vegetation Management Reliability

U

UAM	Underground Asset Management
UG	Underground
USGS	U.S. Geological Survey or United States Geological Survey

RAMP ACRONYM LIST
GLOSSARY OF ACRONYMS AND ABBREVIATIONS

V

VP	Vice President
VST	Vehicle Safety Technology

W

WBT	web-based training
WELL	Well Integrity Management Plan
WHO	World Health Organization
WRO	Work Required by Others
WROF	Weather-Related Outside Force
WSAC	Weekly Situational Awareness Calls
WSD	Wildfire Safety Division
WSIP	Wildfire Safety Inspection Program
WSOC	Wildfire Safety Operations Center
Wt	warning time

X

XLP	cross-linked polyethylene
-----	---------------------------

Y**Z**