EXHIBIT: PacifiCorp PAC_201
CPUC PROCEEDING: H.25-07-005
SPONSOR/WITNESS: PacifiCorp/Carrie Laird
DESCRIPTION: Public - Response to CPUC SED Data Request 2.1 (SED-02-PacifiCorp 2020 WMP)
DATE IDENT. 6/9/2026 RECD. _____
ALJ: GERALD F. KELLY

PAC_201
(Public)

CPUC SED Data Request 2.1

PacifiCorp identified, in response to SED-01 Q2(c), a November 7, 2000, fire near facility point 06240004.0357000. This facility was part of the 2020 WMP covered conductor Initiative 5.3.3.3 target, but PacifiCorp did not install such upgrades in this area.

(a) Provide any fire authority report regarding such fire.

(b) State the time and date that the fire was reported to the Commission. Provide all Documents Related to Your answer and state the page number(s) of the relevant section(s) of such Documents.

Response to CPUC SED Data Request 2.1

PacifiCorp assumes that the reference to "a November 7, 2000", fire" is intended to be a reference to a fire incident that occurred on November 7, 2020. Based on the foregoing assumption, the Company responds as follows:

(a) PacifiCorp has no record of any fire authority report regarding the fire incident that occurred on November 7, 2020.

(b) PacifiCorp estimates it reported the fire that occurred on November 7, 2020 to the California Public Utilities Commission (CPUC) on or about March 30, 2021 at 08:20. Please refer to Attachment CPUC SED 2.1 which provides a copy of the PacifiCorp's 2020 Fire Incident Data Collection Annual Report.

Despite PacifiCorp's diligent efforts, certain information protected from disclosure by the attorney-client privilege or other applicable privileges or law may have been included in its responses to these data requests. PacifiCorp did not intend to waive any applicable privileges or rights by the inadvertent disclosure of protected information, and PacifiCorp reserves its right to request the return or destruction of any privileged or protected materials that may have been inadvertently disclosed. Please inform PacifiCorp immediately if you become aware of any inadvertently disclosed information.

PAC_201.02
(Public)

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	**Pursuant to California Public Utilities Commission (Commission or CPUC) Decision 14-12-015, this is a draft of Pacific Power's Fire Incident Data Collection Plan annual report. The attached information is preliminary and subject to change. The information is provided to facilitate review and comment by the recipient parties.** **Fire incidents from 2020 where the cause of the ignition is under investigation have been excluded from this report.**														
2	**Utility Name**	**Fire Start**		**Location**				**Fire**			**Utility Facility**				
3		**Date**	**Time**	**Latitude**	**Longitude**	**Material at Origin**	**Land Use at Origin**	**Size (small assumed to be no more than .25 acres)**	**Suppressed by**	**Suppressing Agency**	**Facility Identification**	**Other Companies**	**Voltage**	**Equipment Involved With Ignition**	**Type**
4	PacifiCorp	4/24/2020	19:11	[redacted]		Vegetation	Rural	<0.25	Fire Agency	Cal-Fire, Hammond Ranch Fire, Weed Fire and Lake	06241005.0108700	none	12,470	Lightning arrestor	Overhead
5	PacifiCorp	5/6/2020	0:12			Vegetation	Highly Rural	<0.25	Fire Agency	Klamath National Forest and Seiad Fire Dept.	D 06246011.0180660 T 2/23	none	12,740 / 69,000	Conductor - Primary	Overhead
6	PacifiCorp	5/28/2020	22:53			Vegetation	Highly Rural	<3 meters of linear travel	Fire Agency	Cal Fire	06242009.0110400	none	12,470	Conductor - Primary	Overhead
7	PacifiCorp	7/16/2020	17:20			grass and shed	Rural	0.26-9.99	Fire Agency	Alturas Fire	06142012.0111203	none	12,470	Conductor - Secondary	Overhead
8	PacifiCorp	7/23/2020	17:50			Vegetation	Highly Rural	<0.25	Fire Agency	Dunsmuir Fire Dept	11/60	na	69,000	Insulator	Overhead
9	PacifiCorp	8/4/2020	5:18			Structure	Highly Rural	Structure Only	Fire Agency	CAL fire, Etna and FT. Jones emergancy personel	06242009.0112400	none	12,470	Crossarm	Overhead
10	PacifiCorp	8/10/2020	17:31			Vegetation	Highly Rural	<0.25	Fire Agency	Local Fire Department	06244010.0352201	none	12,470	Connector device	Overhead
11	PacifiCorp	8/15/2020	13:55			Vegetation	Rural	<3 meters of linear travel	Unknown	Unknown	06243009.0131300	none	12,470	Fuse	Overhead
12	PacifiCorp	9/3/2020	13:17			Vegetation	Rural	<3 meters of linear travel	Unknown	Unknown	06242006.0037601	AT&T CALIFORNIA Telco	12,470	Connector device	Overhead
13	PacifiCorp	9/6/2020	0:16			Vegetation	Rural	<0.25	Fire Agency	Cal Fire	06243008.0056900	none	12,470	Lightning arrestor	Overhead
14	PacifiCorp	9/17/2020	15:25			Vegetation	Highly Rural	<0.25	Fire Agency	Local Fire Department	06242009.0102101	none	12,470	Conductor - Primary	Overhead
15	PacifiCorp	9/18/2020	12:21			Vegetation	Highly Rural	0.26-9.99	Fire Agency	Cal Fire	06243009.0192400	none	12,470	Sectionalizer	Overhead
16	PacifiCorp	10/21/2020	16:30			Vegetation	Rural	<0.25	Fire Agency	Cal Fire	06245006.0035001	HUNTER COMMUNICATIONS (CA)(Fiber)	12,470	Support structure (pole or tower)	Overhead
17	PacifiCorp	11/1/2020	13:33			Structure	Rural	< 1 meter	Fire Agency	Local emergancy personnel	06241005.0013641	none	12,470	Insulator and bushing	Overhead
18	PacifiCorp	11/7/2020	17:25			vegetation and structure	Rural	0.26-9.99	Fire Agency	Cal Fire	06240004.0357000	none	12,470	Lightning arrestor	Overhead

	A	B	C	P	Q	R	S	T	U	V	W	X
1												
2	Utility Name	Fire Start		Outage			Field Observations					Notes (Optional):
3		Date	Time	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
4	PacifiCorp	4/24/2020	19:11	Yes	4/24/2020	19:11	Contamination				Contamination	
5	PacifiCorp	5/6/2020	0:12	Yes	5/6/2020	00:12	Object contact		Vegetation Contact	Electric facility	Weather	
6	PacifiCorp	5/28/2020	22:53	Yes	5/28/2020	22:53	Object contact		Vegetation Contact	Electric facility	Weather	
7	PacifiCorp	7/16/2020	17:20	No			Object contact		Vegetation Contact	Electric facility	External Force	
8	PacifiCorp	7/23/2020	17:50	Yes	7/23/2020	14:40	Contamination			Electric facility	Contamination	
9	PacifiCorp	8/4/2020	5:18	Yes	8/4/2020	05:18	Object contact		Animal contact	Electric facility	Bird nest	
10	PacifiCorp	8/10/2020	17:31	Yes	8/10/2020	17:31	Equipment failure	Connector device		Electric facility	Unknown	
11	PacifiCorp	8/15/2020	13:55	Yes	8/15/2020	13:54	Equipment failure	Fuse		Electric facility	old equipment	
12	PacifiCorp	9/3/2020	13:17	Yes	9/3/2020	13:17	Equipment failure	Connector device			Unknown	
13	PacifiCorp	9/6/2020	0:16	no			Equipment failure	Lightning arrestor			Unknown	
14	PacifiCorp	9/17/2020	15:25	Yes	9/17/2020	15:25	Object contact		Vegetation Contact	Electric facility	External Force	
15	PacifiCorp	9/18/2020	12:21	Yes	9/18/2020	12:21	Object contact		Vegetation Contact	Electric facility	External Force	
16	PacifiCorp	10/21/2020	16:30	Yes	10/21/2020	16:30	Object contact		Vehicle contact - car pole	Pole	External Force	
17	PacifiCorp	11/1/2020	13:33	Yes	11/1/2020	13:33	Equipment failure	Insulator and bushing		Electric facility	Unknown	
18	PacifiCorp	11/7/2020	17:25	Yes	11/7/2020	5:30	Equipment failure	Lightning arrestor			Unknown	