EXHIBIT: PacifiCorp PAC_232
CPUC PROCEEDING: H.25-07-005
SPONSOR/WITNESS: PacifiCorp/Carrie Laird
DESCRIPTION: Public - Response to CPUC SED Data Request 3.7 (SED-03-PacifiCorp 2020 WMP)
DATE IDENT. 6/9/2026 RECD. _____
ALJ: GERALD F. KELLY

PAC_232
(Public)

CPUC SED Data Request 3.7

SED understands that vegetation contacted PacifiCorp facilities on February 25, 2021, igniting a fire at Mount Shasta ([redacted]).

(a) Provide any fire authority report regarding such fire.

(b) State the time and date that the fire was reported to the Commission. Provide all Documents Related to Your answer and state the page number(s) of the relevant section(s) of such Documents.

(c) State the circuit name and voltage.

(d) State the size and location of the area burned.

(e) State the fire suppression costs (PacifiCorp and fire authority).

Response to CPUC SED Data Request 3.7

(a) PacifiCorp has no fire authority report regarding the fire incident on February 25, 2021, at Mount Shasta.

(b) PacifiCorp estimates it reported this fire to the California Public Utilities Commission (CPUC) on or about March 29, 2022, at 17:42. Please refer to Attachment CPUC SED 3.7 which provides a copy of PacifiCorp's 2021 Fire Incident Data Collection Annual Report.

(c) Transmission: COPCO-2D, 69 kilovolt (kV), Distribution: 5G79, 12.47 kV.

(d) Less than 0.25 acres in the vicinity of Interstate 5 at approximately [redacted]

(e) PacifiCorp has no record of fire suppression costs for the fire incident on February 25, 2021, at Mount Shasta.

Despite PacifiCorp's diligent efforts, certain information protected from disclosure by the attorney-client privilege or other applicable privileges or law may have been included in its responses to these data requests. PacifiCorp did not intend to waive any applicable privileges or rights by the inadvertent disclosure of protected information, and PacifiCorp reserves its right to request the return or destruction of any privileged or protected materials that may have been inadvertently disclosed. Please inform PacifiCorp immediately if you become aware of any inadvertently disclosed information.

PAC_232.02
(Public)

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	**Pursuant to California Public Utilities Commission (Commission or CPUC) Decision 14-12-015, this is a draft of Pacific Power's Fire Incident Data Collection Plan annual report. The attached information is preliminary and subject to change. The information is provided to facilitate review and comment by the recipient parties.** **Fire incidents where the cause of the ignition is under investigation have been excluded from this report.** **Any events with a fire start date prior to the last calendar year reflect events where the fire cause was determined during this reporting period.**														
2		**Fire Start**		**Location**				**Fire**			**Utility Facility**				
3	**Utility Name**	**Date**	**Time**	**Latitude**	**Longitude**	**Material at Origin**	**Land Use at Origin**	**Size (small assumed to be no more than .25 acres)**	**Suppressed by**	**Suppressing Agency**	**Facility Identification**	**Other Companies**	**Voltage**	**Equipment Involved With Ignition**	**Type**
4	PacifiCorp	7/22/2020	11:50	[redacted]		Vegetation	Rural	10 - 100 Acres	Fire agency	Klamath National Forest	06245010.0162200	[redacted]	12,470	Conductor - Primary	Overhead
5	PacifiCorp	2/25/2021	14:00			Vegetation	Rural	<0.25	Fire agency	Cal Fire	(T) 10/049, (D) 06240004.0216262		(T) 69,000, (D) 12.47	Conductor - Transmission	Overhead
6	PacifiCorp	3/4/2021	10:21			Vegetation	Rural	<3 meters of linear travel	Fire agency	Cal Fire & Weed City	06242005.0361401		12,470	Conductor - Primary	Overhead
7	PacifiCorp	3/5/2021	2:47			Vegetation	Rural	<0.25	Fire agency	Del Norte Fire Department	07217001.0234570		69,000	Conductor - Transmission	Overhead
8	PacifiCorp	6/7/2021	15:24			Vegetation	Rural	<0.25	Fire agency	Cal Fire and Mt Shasta Fire	06240004.0273800		12,470	Conductor - Primary	Overhead
9	PacifiCorp	6/27/2021	19:58			Vegetation	Rural	<0.25	Fire agency	Yreka Fire Department	06245007.0235361		12,470	Fuse	Overhead
10	PacifiCorp	6/30/2021	11:55			Vegetation	Urban	<0.25	Fire agency	CAL Fire	06245005.0344900		7,200	Cut-out	Overhead
11	PacifiCorp	7/4/2021	20:22			Vegetation	Rural	<0.25	Fire agency	Forest Service and Cal-Fire	2/61		69,000	Conductor - Transmission	Overhead
12	PacifiCorp	7/30/2021	15:14			Vegetation	Rural	0.26-9.99	Fire agency	Cal-Fire	06245010.0178902		12,470	Conductor - Secondary	Overhead

	A	B	C	P	Q	R	S	T	U	V	W	X
1	**Pursuant to California Public Utilities Commission (Commission or CPUC) Decision 14-12-015, this is a draft of Pacific Power's Fire Incident Data Collection Plan annual report. The attached information is preliminary and subject to change. The information is provided to facilitate review and comment by the recipient parties.** **Fire incidents where the cause of the ignition is under investigation have been excluded from this report.** **Any events with a fire start date prior to the last calendar year reflect events where the fire cause was determined during this reporting period.**											
2	**Utility Name**	**Fire Start**		**Outage**			**Field Observations**					**Notes (Optional):**
3		**Date**	**Time**	**Was There an Outage**	**Date**	**Time**	**Suspected Initiating Event**	**Equipment /Facility Failure**	**Contact From Object**	**Facility Contacted**	**Contributing Factor**	**Notes (Optional):**
4	PacifiCorp	7/22/2020	11:50	Yes	7/22/2020	11:50	Object contact		Vegetation Contact	Electric facility	Human Error	Tree crew fell tree
5	PacifiCorp	2/25/2021	14:00	Yes	2/25/2021	12:07	Object contact		Vegetation	Electric facility	Weather	Green cedar tree on outside edge of right of way, tree fell in the wind and was rotten at the butt, pulled down line and our pole which was both transmittion and distribution. CAL fire responded, with a hand crew 2 engines. CAL fire report #21CAsku001411.
6	PacifiCorp	3/4/2021	10:21	Yes	5/4/2021	10:12	Object contact		Other – Truck Snagged Line	Electric facility	External Force	Truck Snagged line
7	PacifiCorp	3/5/2021	2:47	Yes	3/5/2021	02:47	Object contact		Vegetation	Electric facility	Weather	Transmission line down to Lake Earl sub
8	PacifiCorp	6/7/2021	15:24	Yes	6/7/2021	15:24:18	Equipment failure	Conductor			Unknown	Wire down, fire in area, one phase found open, opened remaining. Isolated wire down due to fire. Will re-energize when fire crew allows.
9	PacifiCorp	6/27/2021	19:58	Yes	6/27/2021	19:44	Equipment failure	Fuse			Unknown	
10	PacifiCorp	6/30/2021	11:55	Yes	6/30/2021	11:55	Equipment failure	Fuse			Unknown	blown cut out
11	PacifiCorp	7/4/2021	20:22	Yes	7/4/2021	20:24	Object contact		Vegetation	Electric facility	External Force	
12	PacifiCorp	7/30/2021	15:14	Yes	7/30/2021	15:41	Object contact		Vegetation	Electric facility	Weather	Top blew out of dead tree onto lines. Fire approximately ½ to 1 acre in size, CalFire present. Area Thunderstorm